DAIKIN

ED 34 - 845A

R-410A

Engineering Data

VRV III®

THE INTELLIGENT AIR CONDITIONING SYSTEM







HEAT PUMP

Heat Pump
50 Hz / 60 Hz

Introduction ii

Part 1 General Information 1 1

Part 2 Indoor Units 45

Ceiling Mounted Cassette Type (Round Flow) ..... 2 FXFQ-P 47

Ceiling Mounted Cassette Type (Double Flow) ..... 3 FXCQ-M 123

Ceiling Mounted Cassette Corner Type ..... 4 FXKQ-MA 147

Slim Ceiling Mounted Duct Type ..... 5 FXDQ-PB, NB 169

Ceiling Mounted Built-In Type ..... 6 FXSQ-M 207

Ceiling Mounted Duct Type (Middle and High Static Pressure) ..... 7 FXMQ-P 251

Ceiling Mounted Duct Type ..... 8 FXMQ-MA 305

Ceiling Suspended Type ..... 9 FXHQ-MA 325

Wall Mounted Type ..... 10 FXAQ-MA 343

Floor Standing Type / Concealed Floor Standing Type ..... 11 FXLQ/FXNQ-MA 373

Ceiling Suspended Cassette Type (Connection Unit Series) ..... 12 FXUQ-MA 397

Part 3 Outdoor Air Processing Unit 433

Outdoor Air Processing Unit ..... 13 FXMQ-MF 435

Part 4 Outdoor Units; Normal Series (Space Saving Series) 469

Heat Pump (50/60Hz) ..... 14 RXYQ-P(A) 471

Part 5 Outdoor Units; High COP Series (Energy Saving Series) 613

Heat Pump (50/60Hz) ..... 15 RXYQ-P(A)H 615

Part 6 Installation of Outdoor Units 16 699

Part 7 Control 17 805

Part 8 Guide Specification 18 1005

1. Introduction

Preface

Along higher quality building environment and more sophisticated building function, there is now a greater demand for system expansion for a flexible air-conditioning system capable of finer air-conditioning, thus increasing importance of individual air-conditioning systems. On the other hand, due to social significance of environmental and energy problems, elements such as energy-efficiency and low maintenance are still strongly desired.

Daikin is the sole air conditioning company in the world that manufactures every component from refrigerant to complete air conditioning systems itself. Our commitment to offering the best for people as well as the environment inspires us to develop new systems that make the most effective use of energy resources.
Daikin, the first in the industry to develop the VRV system, has now enhanced the R-410A, R-22 with the Inverter that features an upgraded capacity of up to 54 horsepower to further refine all the features of the current VRV system.

This publication contains a variety of information related to the design and installation of this new VRV System. We hope this information will serve to deepen your understanding of the system, and will help you to efficiently develop its highly evolved characteristics.

Global Operations Division
DAIKIN INDUSTRIES, LTD


2. Publication History of VRV Engineering Data

Refrigerant	Type		Pub. : No.	Outdoor Units		Notes	Published In
R-410A	Air Cooled	■ INVERTER **M**	**ED39-436**	**50/60Hz H/P**	RXYMQ4, 5, 6M	**VRV II-S** Heat Pump ■ New line up of 4, 5, 6HP outdoor units ■ New line up of FXDQ Indoor units	Jul. 2004
			ED39-526	**50Hz H/R**	REYQ8M~48M	**VRV II** Heat Recovery Separation of Heat Recovery Series from ED39-226B	Feb. 2006
			ED35-511B	**50/60Hz H/P**	RXYQ8~30MY1K(E) RXYQ8~30MYLK(E)	**VRV II** Heat Pump for High outdoor temperature. ■ Minor change of Indoor Units from M to MA ■ Model change of Remote Controller as follows BRC1A61, 62 BRC8A61 →**BRC1C62**	Jul. 2006
		■ INVERTER **MA**	**ED39-428B**	**50/60Hz H/P** **50Hz C/O**	RXYQ5MA~48MA RXQ5MA~48MA	**VRV II** Heat Pump, Cooling Only ■ New line up of 60Hz Heat Pump outdoor units to ED39-428A	Oct. 2005
		■ INVERTER **P**	**ED34-645B**	**50/60Hz H/P**	Normal Series RXYQ5P~54P High COP Series RXYQ16PH~50PH	**VRV III** Heat Pump ■ Addition of 60Hz Heat Pump to ED34-645A	Nov. 2006
			ED34-845A	**50/60Hz H/P**	Normal Series RXYQ5P(A)~54P(A) High COP Series RXYQ16P(A)H~50P(A)H	**VRV III** Heat Pump ■ Change of refrigerant amount Refrigerant amount reduced to less than 12 kg.	Oct. 2008
	Water Cooled	■ INVERTER **M**	**ED30-442B**	**50Hz H/P** **50Hz H/R**	RWEYQ10, 20, 30M Y1	**VRV-W II** Heat Pump, Heat Recovery Following change has been newly added to ED30-442A ■ Minor change of Indoor Units from M to MA ■ Model change of Remote Controller as follows BRC1A61, 62 BRC8A61 →**BRC1C62**	May. 2006
			ED30-653	**60Hz H/P** **60Hz H/R**	RWEYQ10, 20, 30M YL, TL	**VRV-W II** Heat Pump, Heat Recovery 60Hz	Apr. 2006
		■ INVERTER **P**	**ED30-842**	**50/60Hz H/P, H/R**	RWEYQ-P Y1, YL, TL	**VRV-W III** Heat Pump, Heat Recovery Preliminary	Oct. 2008
R-22	Air Cooled	■ INVERTER **K-K**	**ED35-211**	**50/60Hz** **50/60Hz**	RXY 16K-K~30K-K RX 16K-K~30K-K	**VRV** Heat Pump, Cooling Only ■ For High Outdoor Temperature up to 50°CDB ■ For Saudi Arabia and Middle East	Nov. 2002
		■ INVERTER **M**	**ED38-225C**	**50/60Hz H/P** **50Hz C/O**	RXY5M~48M RX5M~48M	**VRV II** Heat Pump, Cooling Only Following change has been newly added to ED38-225B ■ FXD20~32P (Additional) ■ Model change of Remote Controller as follows BRC1A61, 62 BRC8A61 →**BRC1C62** ■ VAM150~2000FA→VAM150~2000GJ (Model change)	Jun. 2006
			ED38-329	**50/60Hz H/P** **50Hz C/O**	RXYM4, 5, 6M RXM4, 5, 6M	**VRV II-S** Heat Pump, Cooling Only ■ New line up of 4, 5, 6HP outdoor units ■ New line up of FXD Indoor units	Jan. 2004
For All Types			**OH 08-1**	For Indoor and Outdoor Units.		**Option Handbook**	Apr. 2008
HRV(VAM)		GJ	**ED71-613**	**50/60Hz**	VAM150~2000GJ	**HRV** ■ New line-up from FA to GJ Series	Feb. 2006
HRV(VKM)		G(M)	**ED71-440**	**50Hz**	VKM50~100G(M) (R-410A)	**HRV** • With DX Coil (VKM-G) • With DX Coil and Humidities (VKM-GM)	Mar. 2005

This time we publish **ED34-845A** as shown by ▭ .

H/P : Heat Pump
H/R : Heat Recovery
C/O : Cooling Only

3. Step by Step VRV System Selection Process (Reference)



Caution

1. Air conditioners should not be installed in areas where corrosive gases, such as acid gas or alkaline gas, are produced.
2. If the outdoor units is to be installed close to the sea shore, direct exposure to the sea breeze should be avoided.
3. Refer to the latest drawing numbers.

Part 1
General Information

1. Model Names of Indoor/Outdoor Units....2
2. External Appearance....4
   2.1 Indoor Units....4
   2.2 Outdoor Units....5
3. Combination of Outdoor Units....7
4. Nomenclature....9
5. Capacity Range....11
6. Features....13
   6.1 Technologies....13
   6.2 Flexible Design....15
   6.3 A sense of responsibility....18
   6.4 Enhanced Comfort....19
   6.5 Control Systems....20
   6.6 Advanced Control Systems....22
   6.7 HRV (Heat Reclaim Ventilation)....26
   6.8 HRV-With DX Coil-(Heat Reclaim Ventilation) VKM-GA(M) Series....34

1. Model Names of Indoor/Outdoor Units

Indoor Units

Type		Model Name											Power Supply
Ceiling Mounted Cassette Type (Round Flow)	FXFQ	—	25P	32P	40P	50P	63P	—	80P	100P	125P	—	—	VE
Ceiling Mounted Cassette Type (Double Flow)	FXCQ	20M	25M	32M	40M	50M	63M	—	80M	—	125M	—	—	
Ceiling Mounted Cassette Corner Type	FXKQ	—	25MA	32MA	40MA	—	63MA	—	—	—	—	—	—	
Slim Ceiling Mounted Duct Type	FXDQ-PBVE	20PB	25PB	32PB	—	—	—	—	—	—	—	—	—	
	FXDQ-PBVET	20PB	25PB	32PB	—	—	—	—	—	—	—	—	—	
	FXDQ-NBVE	—	—	—	40NB	50NB	63NB	—	—	—	—	—	—	
	FXDQ-NBVET	—	—	—	40NB	50NB	63NB	—	—	—	—	—	—	
Ceiling Mounted Built-In Type	FXSQ	20M	25M	32M	40M	50M	63M	—	80M	100M	125M	—	—	
Ceiling Mounted Duct Type (Middle and high static pressure)	FXMQ	20P	25P	32P	40P	50P	63P	—	80P	100P	125P	—	—	
Ceiling Mounted Duct Type	FXMQ	—	—	—	—	—	—	—	—	—	—	200MA	250MA	
Ceiling Suspended Type	FXHQ	—	—	32MA	—	—	63MA	—	—	100MA	—	—	—	
Wall Mounted Type	FXAQ	20MA	25MA	32MA	40MA	50MA	63MA	—	—	—	—	—	—	
Floor Standing Type	FXLQ	20MA	25MA	32MA	40MA	50MA	63MA	—	—	—	—	—	—	
Concealed Floor Standing Type	FXNQ	20MA	25MA	32MA	40MA	50MA	63MA	—	—	—	—	—	—	
Ceiling Suspended Cassette Type	FXUQ	—	—	—	—	—	—	71MA	—	100MA	125MA	—	—	V1
Connection Unit for FXUQ	BEVQ	—	—	—	—	—	—	71MA	—	100MA	125MA	—	—	VE

Note: FXDQ has following 2 series, as shown below.

FXDQ-PBVET, NBVET: without Drain Pump (For General, Asia: except for EU, China and Australia)

FXDQ-PBVE, NBVE: with Drain Pump

BEV unit is required for FXUQ only.

MA: RoHS Directive models; Specifications, dimensions and other functions are not changed compared with M type.

Outdoor Units

Normal Series (Space Saving Series)

Series	Model Name									Power Supply
Heat Pump	RXYQ	5PA	8PA	10PA	12PA	14PA	16PA	18PA	20PA	22PA	Y1(E) YL(E)
		24PA	26PA	28PA	30PA	32PA	34PA	36PA	38PA	40PA	
		42PA	44PA	46PA	48PA	50PA	52PA	54PA	—	—	
		5P	8P	10P	12P	14P	16P	18P	20P	22P	TL(E)
		24P	26P	28P	30P	32P	34P	36P	38P	40P	
		42P	44P	46P	48P	50P	52P	54P	—	—	

High COP Series (Energy Saving Series)

Series	Model Name									Power Supply
Heat Pump	RXYQ	16PAH	18PAH	24PAH	26PAH	28PAH	30PAH	32PAH	34PAH	36PAH	Y1(E) YL(E)
		38PAH	40PAH	42PAH	44PAH	46PAH	48PAH	50PAH	—	—	
		16PH	18PH	24PH	26PH	28PH	30PH	32PH	34PH	36PH	TL(E)
		38PH	40PH	42PH	44PH	46PH	48PH	50PH	—	—	

E: The unit with anti corrosion treatment

Combination of Outdoor Units (Normal Series (Space Saving Series))

HP	5HP	8HP	10HP	12HP	14HP	16HP	18HP
Model name	**RXYQ5P(A)**	**RXYQ8P(A)**	**RXYQ10P(A)**	**RXYQ12P(A)**	**RXYQ14P(A)**	**RXYQ16P(A)**	**RXYQ18P(A)**

HP	20HP	22HP	24HP	26HP	28HP	30HP	32HP
Model name	**RXYQ20P(A)**	**RXYQ22P(A)**	**RXYQ24P(A)**	**RXYQ26P(A)**	**RXYQ28P(A)**	**RXYQ30P(A)**	**RXYQ32P(A)**
Outdoor unit 1	RXYQ8P(A)	RXYQ10P(A)	RXYQ8P(A)	RXYQ8P(A)	RXYQ10P(A)	RXYQ12P(A)	RXYQ16P(A)
Outdoor unit 2	RXYQ12P(A)	RXYQ12P(A)	RXYQ16P(A)	RXYQ18P(A)	RXYQ18P(A)	RXYQ18P(A)	RXYQ16P(A)
Outdoor unit 3	–	–	–	–	–	–	–

HP	34HP	36HP	38HP	40HP	42HP	44HP	46HP
Model name	**RXYQ34P(A)**	**RXYQ36P(A)**	**RXYQ38P(A)**	**RXYQ40P(A)**	**RXYQ42P(A)**	**RXYQ44P(A)**	**RXYQ46P(A)**
Outdoor unit 1	RXYQ16P(A)	RXYQ18P(A)	RXYQ8P(A)	RXYQ8P(A)	RXYQ8P(A)	RXYQ8P(A)	RXYQ10P(A)
Outdoor unit 2	RXYQ18P(A)	RXYQ18P(A)	RXYQ12P(A)	RXYQ16P(A)	RXYQ16P(A)	RXYQ18P(A)	RXYQ18P(A)
Outdoor unit 3	–	–	RXYQ18P(A)	RXYQ16P(A)	RXYQ18P(A)	RXYQ18P(A)	RXYQ18P(A)

HP	48HP	50HP	52HP	54HP
Model name	**RXYQ48P(A)**	**RXYQ50P(A)**	**RXYQ52P(A)**	**RXYQ54P(A)**
Outdoor unit 1	RXYQ12P(A)	RXYQ14P(A)	RXYQ16P(A)	RXYQ18P(A)
Outdoor unit 2	RXYQ18P(A)	RXYQ18P(A)	RXYQ18P(A)	RXYQ18P(A)
Outdoor unit 3	RXYQ18P(A)	RXYQ18P(A)	RXYQ18P(A)	RXYQ18P(A)

Combination of Outdoor Units (High COP Series (Energy Saving Series))

HP	16HP	18HP	24HP	26HP	28HP	30HP	32HP
Model name	**RXYQ16P(A)H**	**RXYQ18P(A)H**	**RXYQ24P(A)H**	**RXYQ26P(A)H**	**RXYQ28P(A)H**	**RXYQ30P(A)H**	**RXYQ32P(A)H**
Outdoor unit 1	RXYQ8P(A)	RXYQ8P(A)	RXYQ8P(A)	RXYQ8P(A)	RXYQ8P(A)	RXYQ8P(A)	RXYQ8P(A)
Outdoor unit 2	RXYQ8P(A)	RXYQ10P(A)	RXYQ8P(A)	RXYQ8P(A)	RXYQ8P(A)	RXYQ10P(A)	RXYQ12P(A)
Outdoor unit 3	–	–	RXYQ8P(A)	RXYQ10P(A)	RXYQ12P(A)	RXYQ12P(A)	RXYQ12P(A)

HP	34HP	36HP	38HP	40HP	42HP	44HP	46HP
Model name	**RXYQ34P(A)H**	**RXYQ36P(A)H**	**RXYQ38P(A)H**	**RXYQ40P(A)H**	**RXYQ42P(A)H**	**RXYQ44P(A)H**	**RXYQ46P(A)H**
Outdoor unit 1	RXYQ10P(A)	RXYQ12P(A)	RXYQ12P(A)	RXYQ12P(A)	RXYQ12P(A)	RXYQ12P(A)	RXYQ12P(A)
Outdoor unit 2	RXYQ12P(A)	RXYQ12P(A)	RXYQ12P(A)	RXYQ12P(A)	RXYQ12P(A)	RXYQ16P(A)	RXYQ16P(A)
Outdoor unit 3	RXYQ12P(A)	RXYQ12P(A)	RXYQ14P(A)	RXYQ16P(A)	RXYQ18P(A)	RXYQ16P(A)	RXYQ18P(A)

HP	48HP	50HP
Model name	**RXYQ48P(A)H**	**RXYQ50P(A)H**
Outdoor unit 1	RXYQ16P(A)	RXYQ16P(A)
Outdoor unit 2	RXYQ16P(A)	RXYQ16P(A)
Outdoor unit 3	RXYQ16P(A)	RXYQ18P(A)

VE: 1ϕ, 220~240V, 50Hz, 1ϕ, 220V, 60Hz
V1: 1ϕ, 220~240V, 50Hz
Y1: 3ϕ, 380~415V, 50Hz
YL: 3ϕ, 380V, 60Hz
TL: 3ϕ, 220V, 60Hz

2. External Appearance

2.1 Indoor Units

Ceiling Mounted Cassette Type (Round Flow)

FXFQ25P
FXFQ32P
FXFQ40P
FXFQ50P
FXFQ63P
FXFQ80P
FXFQ100P
FXFQ125P



Ceiling Mounted Duct Type

FXMQ200MA
FXMQ250MA



Ceiling Mounted Cassette Type (Double Flow)

FXCQ20M
FXCQ25M
FXCQ32M
FXCQ40M
FXCQ50M
FXCQ63M
FXCQ80M
FXCQ125M



Ceiling Suspended Type

FXHQ32MA
FXHQ63MA
FXHQ100MA



Ceiling Mounted Cassette Corner Type

FXKQ25MA
FXKQ32MA
FXKQ40MA
FXKQ63MA



Wall Mounted Type

FXAQ20MA
FXAQ25MA
FXAQ32MA
FXAQ40MA
FXAQ50MA
FXAQ63MA



Slim Ceiling Mounted Duct Type


FXDQ20PB FXDQ40NB
FXDQ25PB FXDQ50NB
FXDQ32PB FXDQ63NB

with Drain Pump (VE)
without Drain Pump (VET)



Floor Standing Type

FXLQ20MA
FXLQ25MA
FXLQ32MA
FXLQ40MA
FXLQ50MA
FXLQ63MA



Ceiling Mounted Built-In Type

FXSQ20M
FXSQ25M
FXSQ32M
FXSQ40M
FXSQ50M
FXSQ63M
FXSQ80M
FXSQ100M
FXSQ125M



Concealed Floor Standing Type

FXNQ20MA
FXNQ25MA
FXNQ32MA
FXNQ40MA
FXNQ50MA
FXNQ63MA



Ceiling Mounted Duct Type (Middle and high static pressure)

FXMQ20P
FXMQ25P
FXMQ32P
FXMQ40P
FXMQ50P
FXMQ63P
FXMQ80P
FXMQ100P
FXMQ125P



Ceiling Suspended Cassette Type

FXUQ71MA + BEVQ71MA
FXUQ100MA + BEVQ100MA
FXUQ125MA + BEVQ125MA

Connection Unit



2.2 Outdoor Units

Normal Series (Space Saving Series)

RXYQ5P(A)	RXYQ8P(A), 10P(A)	RXYQ12P(A), 14P(A), 16P(A), 18P(A)
		
5HP	8, 10HP	12, 14, 16, 18HP

RXYQ20P(A), 22P(A), 24P(A), 26P(A), 28P(A)	RXYQ30P(A), 32P(A), 34P(A), 36P(A)
	
20, 22, 24, 26, 28HP	30, 32, 34, 36HP

RXYQ38P(A), 40P(A), 42P(A), 44P(A), 46P(A)	RXYQ48P(A), 50P(A), 52P(A), 54P(A)
	
38, 40, 42, 44, 46HP	48, 50, 52, 54HP

High COP Series (Energy Saving Series)

RXYQ16P(A)H, 18P(A)H	RXYQ24P(A)H, 26P(A)H
 16, 18HP	 24, 26HP
RXYQ28P(A)H, 30P(A)H	**RXYQ32P(A)H, 34P(A)H**
 28, 30HP	 32, 34HP

RXYQ36P(A)H, 38P(A)H, 40P(A)H, 42P(A)H, 44P(A)H, 46P(A)H, 48P(A)H, 50P(A)H



36, 38, 40, 42, 44, 46, 48, 50HP

3. Combination of Outdoor Units

Normal Series (Space Saving Series)

System Capacity	Number of units	Module							Outdoor Unit Multi Connection Piping Kit (Option)
		5	8	10	12	14	16	18	
5HP	1	●							—
8HP	1		●						
10HP	1			●					
12HP	1				●				
14HP	1					●			
16HP	1						●		
18HP	1							●	
20HP	2		●		●				Heat Pump: BHFP22P100
22HP	2			●	●				
24HP	2		●				●		
26HP	2		●					●	
28HP	2			●				●	
30HP	2				●			●	
32HP	2						●●		
34HP	2						●	●	
36HP	2							●●	
38HP	3		●		●			●	Heat Pump: BHFP22P151
40HP	3		●				●●		
42HP	3		●				●	●	
44HP	3		●					●●	
46HP	3			●				●●	
48HP	3				●			●●	
50HP	3					●		●●	
52HP	3						●	●●	
54HP	3							●●●	

★Note: For multiple connection of 20HP system or more, an optional Daikin Outdoor Unit Multi Connection Piping Kit is required.


High COP Series (Energy Saving Series)

System Capacity	Number of units	Module						Outdoor Unit Multi Connection Piping Kit (Option)
		8	10	12	14	16	18	
16HP	2	●●						Heat Pump: BHFP22P100
18HP	2	●	●					
24HP	3	●●●						Heat Pump: BHFP22P151
26HP	3	●●	●					
28HP	3	●●		●				
30HP	3	●	●	●				
32HP	3	●		●●				
34HP	3		●	●●				
36HP	3			●●●				
38HP	3			●●	●			
40HP	3			●●		●		
42HP	3			●●			●	
44HP	3			●		●●		
46HP	3			●		●	●	
48HP	3					●●●		
50HP	3					●●	●	

★Note: For multiple connection of 16HP system or more, an optional Daikin Outdoor Unit Multi Connection Piping Kit is required.

4. Nomenclature

Indoor Unit



Power Supply Symbol
VE : Single Phase 220 to 240V, 50Hz : 220V, 60Hz
V1 : Single Phase 220 to 240V, 50Hz

Indicates Major Design Category
M : Standard
MA : Standard (RoHS Applied Models)
NB, PB : Standard

Capacity Indication
Conversion to Horsepower:


20 : 0.8 HP	50 : 2.0 HP	100 : 4 HP
25 : 1 HP	63 : 2.5 HP	125 : 5 HP
32 : 1.25 HP	71 : 3 HP	200 : 8 HP
40 : 1.6 HP	80 : 3.2 HP	250 : 10 HP

Refrigerant : R-410A


Type of Unit
F : Ceiling Mounted Cassette Type (Round Flow)
C : Ceiling Mounted Cassette Type (Double Flow)
K : Ceiling Mounted Cassette Corner Type
D : Slim Ceiling Mounted Duct Type
S : Ceiling Mounted Built-In Type
M : Ceiling Mounted Duct Type
H : Ceiling Suspended Type
A : Wall Mounted Type
L : Floor Standing Type
N : Concealed Floor Standing Type
U : Ceiling Suspended Cassette Type

Indicates that this is VRV system indoor unit.

Connection Unit



Outdoor Unit



5. Capacity Range

Outdoor Units

Normal Type (Space Saving Type)

HP	Model name	Combination	Outdoor unit multi connection piping kit	Total capacity index of connectable indoor units*	Maximum number of connectable indoor units*
5 HP	RXYQ5P(A)	RXYQ5P(A)	–	62.5 to 162.5 (250)	8 (12)
8 HP	RXYQ8P(A)	RXYQ8P(A)	–	100 to 260 (400)	13 (20)
10 HP	RXYQ10P(A)	RXYQ10P(A)	–	125 to 325 (500)	16 (25)
12 HP	RXYQ12P(A)	RXYQ12P(A)	–	150 to 390 (600)	19 (30)
14 HP	RXYQ14P(A)	RXYQ14P(A)	–	175 to 455 (700)	23 (35)
16 HP	RXYQ16P(A)	RXYQ16P(A)	–	200 to 520 (800)	26 (40)
18 HP	RXYQ18P(A)	RXYQ18P(A)	–	225 to 585 (900)	29 (45)
20 HP	RXYQ20P(A)	RXYQ8P(A) + RXYQ12P(A)	BHFP22P100	250 to 650 (800)	32 (40)
22 HP	RXYQ22P(A)	RXYQ10P(A) + RXYQ12P(A)		275 to 715 (880)	35 (44)
24 HP	RXYQ24P(A)	RXYQ8P(A) + RXYQ16P(A)		300 to 780 (960)	39 (48)
26 HP	RXYQ26P(A)	RXYQ8P(A) + RXYQ18P(A)		325 to 845 (1,040)	42 (52)
28 HP	RXYQ28P(A)	RXYQ10P(A) + RXYQ18P(A)		350 to 910 (1,120)	45 (56)
30 HP	RXYQ30P(A)	RXYQ12P(A) + RXYQ18P(A)		375 to 975 (1,200)	48 (60)
32 HP	RXYQ32P(A)	RXYQ16P(A) x 2		400 to 1,040 (1,280)	52 (64)
34 HP	RXYQ34P(A)	RXYQ16P(A) + RXYQ18P(A)		425 to 1,105 (1,360)	55 (64)
36 HP	RXYQ36P(A)	RXYQ18P(A) x 2		450 to 1,170 (1,440)	58 (64)
38 HP	RXYQ38P(A)	RXYQ8P(A) + RXYQ12P(A) + RXYQ18P(A)	BHFP22P151	475 to 1,235 (1,235)	61 (61)
40 HP	RXYQ40P(A)	RXYQ8P(A) + RXYQ16P(A) x 2		500 to 1,300 (1,300)	64 (64)
42 HP	RXYQ42P(A)	RXYQ8P(A) + RXYQ16P(A) + RXYQ18P(A)		525 to 1,365 (1,365)	
44 HP	RXYQ44P(A)	RXYQ8P(A) + RXYQ18P(A) x 2		550 to 1,430 (1,430)	
46 HP	RXYQ46P(A)	RXYQ10P(A) + RXYQ18P(A) x 2		575 to 1,495 (1,495)	
48 HP	RXYQ48P(A)	RXYQ12P(A) + RXYQ18P(A) x 2		600 to 1,560 (1,560)	
50 HP	RXYQ50P(A)	RXYQ14P(A) + RXYQ18P(A) x 2		625 to 1,625 (1,625)	
52 HP	RXYQ52P(A)	RXYQ16P(A) + RXYQ18P(A) x 2		650 to 1,690 (1,690)	
54 HP	RXYQ54P(A)	RXYQ18P(A) x 3		675 to 1,755 (1,755)	

Note: •For multiple connection of 20 HP systems and above, the above Daikin optional kit (separately sold) is required.
*Values inside brackets are based on connection of indoor units rated at maximum capacity, 200% for single outdoor units, 160% for double outdoor units, and 130% for triple outdoor units.

High-COP Type (Energy Saving Type)

HP	Model name	Combination	Outdoor unit multi connection piping kit	Total capacity index of connectable indoor units*	Maximum number of connectable indoor units*
16 HP	RXYQ16P(A)H	RXYQ8P(A) x 2	BHFP22P100	200 to 520 (640)	26 (32)
18 HP	RXYQ18P(A)H	RXYQ8P(A) + RXYQ10P(A)		225 to 585 (720)	29 (36)
24 HP	RXYQ24P(A)H	RXYQ8P(A) x 3	BHFP22P151	300 to 780 (780)	39 (39)
26 HP	RXYQ26P(A)H	RXYQ8P(A) x 2 + RXYQ10P(A)		325 to 845 (845)	42 (42)
28 HP	RXYQ28P(A)H	RXYQ8P(A) x 2 + RXYQ12P(A)		350 to 910 (910)	45 (45)
30 HP	RXYQ30P(A)H	RXYQ8P(A) + RXYQ10P(A) + RXYQ12P(A)		375 to 975 (975)	48 (48)
32 HP	RXYQ32P(A)H	RXYQ8P(A) + RXYQ12P(A) x 2		400 to 1,040 (1,040)	52 (52)
34 HP	RXYQ34P(A)H	RXYQ10P(A) + RXYQ12P(A) x 2		425 to 1,105 (1,105)	55 (55)
36 HP	RXYQ36P(A)H	RXYQ12P(A) x 3		450 to 1,170 (1,170)	58 (58)
38 HP	RXYQ38P(A)H	RXYQ12P(A) x 2 + RXYQ14P(A)		475 to 1,235 (1,235)	61 (61)
40 HP	RXYQ40P(A)H	RXYQ12P(A) x 2 + RXYQ16P(A)		500 to 1,300 (1,300)	64 (64)
42 HP	RXYQ42P(A)H	RXYQ12P(A) x 2 + RXYQ18P(A)		525 to 1,365 (1,365)	
44 HP	RXYQ44P(A)H	RXYQ12P(A) + RXYQ16P(A) x 2		550 to 1,430 (1,430)	
46 HP	RXYQ46P(A)H	RXYQ12P(A) + RXYQ16P(A) + RXYQ18P(A)		575 to 1,495 (1,495)	
48 HP	RXYQ48P(A)H	RXYQ16P(A) x 3		600 to 1,560 (1,560)	
50 HP	RXYQ50P(A)H	RXYQ16P(A) x 2 + RXYQ18P(A)		625 to 1,625 (1,625)	

Note: •For multiple connection of 16 HP systems and above, the above Daikin optional kit (separately sold) is required.
*Values inside brackets are based on connection of indoor units rated at maximum capacity, 200% for single outdoor units, 160% for double outdoor units, and 130% for triple outdoor units.

Indoor Units

Capacity Range		0.8HP	1HP	1.25HP	1.6HP	2HP	2.5HP	3HP	3.2HP	4HP	5HP	8HP	10HP
Capacity Index		20	25	31.25	40	50	62.5	71	80	100	125	200	250
Ceiling Mounted Cassette Type (Round Flow)	FXFQ	—	25P	32P	40P	50P	63P	—	80P	100P	125P	—	—
Ceiling Mounted Cassette Type (Double Flow)	FXCQ	20M	25M	32M	40M	50M	63M	—	80M	—	125M	—	—
Ceiling Mounted Cassette Corner Type	FXKQ	—	25MA	32MA	40MA	—	63MA	—	—	—	—	—	—
Slim Ceiling Mounted Duct Type	FXDQ-PBVE	20PB	25PB	32PB	—	—	—	—	—	—	—	—	—
	FXDQ-PBVET	20PB	25PB	32PB	—	—	—	—	—	—	—	—	—
	FXDQ-NBVE	—	—	—	40NB	50NB	63NB	—	—	—	—	—	—
	FXDQ-NBVET	—	—	—	40NB	50NB	63NB	—	—	—	—	—	—
Ceiling Mounted Built-In Type	FXSQ	20M	25M	32M	40M	50M	63M	—	80M	100M	125M	—	—
Ceiling Mounted Duct Type (Middle and high static pressure)	FXMQ	20P	25P	32P	40P	50P	63P	—	80P	100P	125P	—	—
Ceiling Mounted Duct Type	FXMQ	—	—	—	—	—	—	—	—	—	—	200MA	250MA
Ceiling Suspended Type	FXHQ	—	—	32MA	—	—	63MA	—	—	100MA	—	—	—
Wall Mounted Type	FXAQ	20MA	25MA	32MA	40MA	50MA	63MA	—	—	—	—	—	—
Floor Standing Type	FXLQ	20MA	25MA	32MA	40MA	50MA	63MA	—	—	—	—	—	—
Concealed Floor Standing Type	FXNQ	20MA	25MA	32MA	40MA	50MA	63MA	—	—	—	—	—	—
Ceiling Suspended Cassette Type	FXUQ	—	—	—	—	—	—	71MA	—	100MA	125MA	—	—

Note: FXDQ has following 2 series, as shown below.
FXDQ-PBVET, NBVET: without Drain Pump (For General, Asia: except for EU, China and Australia)
FXDQ-PBVE, NBVE: with Drain Pump

6. Features

6.1 Technologies

VRV III—Created to respond to the needs of large-sized buildings

Daikin's constant efforts have been devoted towards using the latest and most revolutionary technologies in the development of the VRVIII system for large-sized buildings. The system offers larger outdoor capacities, greater energy savings, easier installation, longer actual and total piping, and more.

1 Newly improved fans and grilles


A higher external static pressure has been achieved–from 58. 8 Pa to 78.4 Pa–thanks to reduced internal pressure loss, use of the new fans and the new grilles.

New aero spiral fan and aero asymmetrical fan

The area of these new fan blades has been increased and optimised for each casing. This greatly reduces pressure loss, resulting in a higher external static pressure.

New aero asymmetrical fan

The three-bladed fan on the 10 HP unit, with a diameter of 700 mm, has been redesigned to include four blades and now has a diameter of 680 mm. Blade area has been increased by 25%.



Diameter of **700 mm** Diameter of **680 mm**

New aero spiral fan (Powerful Dual DC fan)

In the 14 and 16 HP unit, a single fan with a diameter of 700 mm has been split into two fans with diameters of 540 mm each. Blade area has been increased by 20% to increase airflow.





Diameter of **700 mm** Diameter of **540 mm x 2**

Aero smooth grille

The three-dimensional, integrated, soft woven steel grilles are covered with a plastic coating that protects them from rotating elements and the possibility of fire damage.

Perspective view





2 Heat exchanger

The new heat exchanger contributes to a high COP because of an increase from 7% to 10% of the effective length as well as an optimised e-Pass heat exchanger.

3 Improving the high efficiency compressor to achieve a high COP and larger capacity

Reluctance DC scroll compressor

Daikin's unique scroll compressor minimises heat loss, and is driven by a high efficiency motor to achieve significant energy savings.


High torque and efficiency is attained with the adoption of neodymium magnets. Achieves 70% reduction in volume.

Secret to raising energy-efficiency!
Powerful magnets



Neodymium magnets are much more powerful than the widely used ferrite magnets.

Reluctance DC motor



High-performance, low-noise new scroll compressor operates at a faster rate. The speed increase has been achieved through advanced stress analysis for increased strength and utilisation of the advantages (oil film control) of the high thrust mechanism*.

***High thrust mechanism**
By introducing high pressure oil, the reactive force from the fixed scroll is added to the internal force, thereby reducing thrust losses. This results in improved efficiency and suppressed sound levels.

4 Heat transfer circuit


By performing super cooling before the expansion process, the volume of refrigerant that needs to be circulated to the indoor units can be reduced without lowering the evaporation temperature. This permits the use of narrower piping.

5 Compact aero box

Realises a compact casing by stacking the Inverter and control PCBs plus optimising the internal design to suit airflow speed. This achieves lower noise and reduces the power required by the large-diameter fanned outdoor unit.

6 Smooth sine wave DC Inverter

By adoption of the Sine Wave, which smoothes the rotation of the motor, operation efficiency is improved sharply.




7 DC fan motor

- Across entire range of models (from 5 to 54 HP).
- Efficiency improvement by approximately 40% especially at low speed.

DC fan motor structure



DC motor efficiency
(comparison with a conventional AC motor)



1


6.2 Flexible Design

Large capacities for large-sized buildings

An increased number of connectable indoor units

The number of connectable indoor units has been drastically increased from 40 to 64!

Increased indoor unit connections




Combination ratio

Connection capacity at maximum is 200%.

Connection capacity
50%—200%

Conditions of indoor unit connection capacity

Applicable indoor units	 FXDQ, FXSQ, FXAQ models	Other indoor unit models*
Single outdoor units	200%	**200%**
Double outdoor units		**160%**
Triple outdoor units		**130%**

* For the FXFQ25 models, maximum connection ratio is 130% for the entire range of outdoor units.

Notes: • If the operational capacity of indoor units is more than 130%, low airflow operation is enforced in all the indoor units.

Large capacities for large-sized buildings

Extended long piping length

Piping length is drastically extended! The long piping length provides more design flexibility, which can match even large-sized buildings.

Max. actual piping length

VRVII MA series 150 m → VRV III 165 m

Max. equivalent piping length

VRVII MA series 175 m → VRV III 190 m

Max. total piping length

VRVII MA series 510 m → VRV III 1000 m

Max. level difference between the outdoor units and the indoor units

VRV III

RXYQ8P(A)-54P(A)

Outdoor unit above indoor unit:

VRVII MA series: 90 m *2

*2. Level differences above 50 m are available on request.


Outdoor unit below indoor unit:

VRVII MA series: 90 m

RXYQ5P(A)

Outdoor unit above indoor unit: 50 m

Outdoor unit below indoor unit: 40 m



			Actual piping length	Example	Equivalent piping length
Maximum allowable piping length	Refrigerant piping length		**165** m or less	a+f+g+h+i	**190** m or less
	Total extension length		**1000** m or less	a+b+c+d+e+f+g+h+i	—
	Between the first indoor branch and the farthest indoor unit		**90** m or less*1	f+g+h+i	—
	Between the outdoor branch and the last outdoor unit		**10** m or less	k+p	**13** m or less
			Level Difference	Example	Outdoor Units
Maximum allowable level difference	Between the outdoor units (Multiple use)		**5** m or less	q	RXYQ8P(A)-54P(A)
	Between the indoor units		**15** m or less	s	—
	Between the outdoor units and the indoor units	If the outdoor unit is above.	*2 Available on request **90** m or less	r	RXYQ8P(A)-54P(A)
		If the outdoor unit is below.	**90** m or less	r	
		If the outdoor unit is above.	**50** m or less	r	RXYQ5P(A)
		If the outdoor unit is below.	**40** m or less	r	


*1. No special requirements up to 40 m. The maximum actual piping length can be 90 m, or less depending on conditions. Various conditions and requirements have to be met to allow utilisation of 90 m piping length.


*2. Level differences above 50 m are not supported by default but are available on request for RXYQ8P(A)-54P(A).

Large capacities for large-sized buildings

High external static pressure 78.4 Pa (8 mm H_2O)

Higher external static pressure has been achieved thanks to the fan grilles and the dual DC fans that reduce internal pressure loss. Exceeding the previous 58.8 Pa (6 mm H_2O) level, Daikin now offers 78.4 Pa (8 mm H_2O) external static pressure by field setting to meet the requirements for installation on each floor, often requested for large-sized buildings.





Easier installation and maintenance

Automatic test operation

Simply press the test operation button and the unit performs an automatic system check, including wiring, shutoff valves, sensors, and refrigerant volume. The results are returned automatically after the check finishes.

Memory function for operational data

Operating data for the preceding 3 minutes is automatically stored in memory. Should a malfunction occur, this speeds up the process of identifying and fixing the cause of the problem. It also helps in developing measures to eliminate malfunctions.


6.3 A sense of responsibility

High COPs

It has become essential for air conditioning manufacturers to develop systems that provide high energy savings. We at Daikin have made great efforts in this field, and the newly-developed VRVIII delivers highly efficient performance, contributing to high energy savings.


Achieving a high COP

We have reached a new level of efficiency, thanks to the new advanced features such as the heat exchanger, the grille and the dual DC fans.



•Cooling operating conditions: Indoor temp. of 27 ˚CDB, 19.0 ˚CWB, and outdoor temp. of 35 ˚CDB.
•Heating operating conditions: Indoor temp. of 20 ˚CDB, and outdoor temp. of 7 ˚CDB, 6 ˚CWB.

Comparison of VRVII and VRVIII



* Compared to VRV II MA series

Compliant with the RoHS Directive*

We have been making efforts to facilitate the transition to using RoHS Directive*-compliant materials for system parts.

* RoHS Directive
The RoHS (Restriction of Hazardous Substances (in electrical and electronic equipment)) Directive is an environmental directive enacted to regulate the use of designated chemical substances (lead, cadmium, hexavalent chromium, mercury, polybrominated biphenyls and polybrominated diphenylether) in electrical equipment. All household products subject to this Directive and sold in Europe from July 1, 2006 are legally bound to comply with the RoHS Directive.

Double backup operation in compressors and units

- If one of the multiple compressors in a single outdoor unit system malfunctions, the other compressors take over emergency operation.*1
- If one of the unit in a multiple outdoor system malfunctions, the other outdoor units provide emergency operation*2 until repairs can be made.

If one compressor malfunctions...



Emergency operation occurs.*1

If one outdoor unit malfunctions...



Emergency operation occurs.*2



Emergency operation can be easily started by remote control of the indoor unit.*2

*1. Possible only with single outdoor unit systems that are equipped with two or more compressors. Local setting of the outdoor unit is necessary.
*2. For systems composed of two or more outdoor units

Less chances of refrigerant leakage

Conventionally, shutoff valve connections are flanged or flared. In the VRVIII system, the connections for all outdoor units are brazed, meaning less chance of refrigerant leakage.

6.4 Enhanced Comfort

Enhanced comfort

Outdoor units designed for low-sound operation

Outdoor units created with cutting-edge technologies provide quiet operation to increase users' comfort.

Efficient compressor

New high-performance, low-sound scroll compressor operates at a faster rate, reducing start-up time. This helps the unit to bring the room temperature up to the set level quickly.



Nighttime quiet operation function

Operation sound level selectable from 3 steps for the night mode

Mode 1. Automatic mode

Set on the outdoor PCB. Time of maximum temperature is memorised. The low operating mode will initiate 8 hours*1 after the peak temperature in the daytime, and normal operation will resume 10 hours*2 after that. The operation sound level for the night mode can be selected from 55 dB(A) (Step 1), 50 dB(A) (Step 2) and 45 dB(A) (Step 3). (For a single outdoor unit.)

Mode 2. Manual mode


Starting time and ending time can be input. (An external control adaptor for outdoor unit, DTA104A53/61/62 or DTA114A61, and a subsequently obtained timer are necessary.)

Mode 3. Combined mode

Combinations of modes 1 and 2 can be used depending on your needs.

*1. Initial setting. Can be selected from 6, 8 and 10 hours.
*2. Initial setting. Can be selected from 8, 9 and 10 hours.

Mode 1. Automatic mode



Notes: • This function is available in setting at site.
• The relationship of outdoor temperature (load) and time shown in the graph is just an example.

* The capacity reduction rate differs depending on the operation sound level step selected.

6.5 Control Systems

Individual Control Systems

Wired remote controller (Option)



BRC1C62

- Easier to read because LCD screen is larger.
- Digital display lets you set temperature in 1°C units.
- Lets you individually programme by timer the respective times for operation start and stop within a maximum of 72 hours.
- Equipped with a thermostat sensor in the remote controller that makes possible more comfortable room temperature control.
- Enables you to select cool/heat/fan operation mode with the indoor remote controller of your choice without using the cool/heat selector.
- Constantly monitors malfunctions in the system for a min. of 40 items, and is equipped with a "self-diagnosis function" that lets you know by message immediately when a malfunction occurs.
- Lets you carry out various field settings by remote controller.
- Enables you to select the ventilation mode and the volume of the HRV.
- The rubber switch and the oil-resisting resin casing have been adopted for durability.

* When the auto-swing function is not available, the message, THIS FUNCTION IS NOT AVAILABLE is displayed when the wind direction adjustment button

Wired remote controller with weekly schedule timer (Option)




BRC1D61

Adds advanced functions to those of the above wired remote controller.

- Includes ventilation mode and airflow rate switching, the main functions of HRV series.
- 24-hour clock function (1-hour backup for power failures)
- Programming function for each day of week.
- Scheduling possible of start/stop and temperature limit (5 settings/day)
- Programming can be enabled or disabled.
- Copy function for programmed schedules.

Notes: 1. Standard remote controllers (BRC1C62) not required.
2. If the BRC1D61 is connected to the centralised remote controllers (DCS303A51, DCS302CA61, DCS301BA61, DST301BA61), the schedule function is not available.

The wired remote controller supports a wide range of control functions



1 Control by two remote controller

The indoor unit can be connected by the two remote controller, for example one in the room and the other one in the control room, which can control the operation of indoor unit freely. (The last command has a priority.) Of course, the group control by two remote controller is also possible.

2 Remote control

The wiring of remote controller can be extended to max. 500 m and it is possible to install the remote controllers for the different indoor units in one place.

3 Control for the combined operation

The operation of HRV can be controlled by the remote controller of the indoor unit. Of course, the remote controller can display the time to clean the filter.

4 Expansion of system control

The system can be expanded to add several controllers, such as BMS, Forced OFF input and etc.

Wireless remote controller (Option)




Wireless remote controller


Signal receiver unit
(Separate type)

- The same operation modes and settings as with wired remote controllers are possible.
- A compact light receiver unit to be mounted into a wall or ceiling is included.
  - A light receiver unit for a Ceiling Mounted Cassette (Round Flow, Double Flow) type, Ceiling Suspended type and Wall Mounted type is mounted into the indoor unit.



Signal receiver unit can be installed on the panel
ex. Ceiling Mounted Cassette (Round Flow) type



Simple remote controller (Option)


Exposed type
(BRC2C51)


Concealed type
(For hotel use)
(BRC3A61)

- The remote controller has centralised its frequently used operation selectors and switches (on/off, operation mode, temperature setting and airflow volume), making itself suitable for use in hotel rooms or conference rooms.
- The exposed type remote controller is fitted with a thermostat sensor.


The concealed-type remote controller smartly fits into a night table or console panel in a hotel room.


Wide variation of remote controllers for indoor units

	FXFQ	FXCQ	FXKQ	FXDQ	FXSQ	FXMQ	FXHQ	FXAQ	FXL(N)Q	FXUQ
Wired remote controller (BRC1C62)	●	●	●	●	●	●	●	●	●	●
Wired remote controller with weekly schedule timer (BRC1D61)	●	●	●	●	●	●	●	●	●	●
Wireless remote controller (Installed signal receiver unit)	●	●					●	●		●
Wireless remote controller (Separate type signal receiver unit)			●	●	●	●			●	
Simple remote controller (Exposed type) (BRC2C51)				●	●	●			●	
Simple remote controller (Concealed type: for Hotel use) (BRC3A61)				●	●	●			●	

6.6 Advanced Control Systems

intelligent touch Controller

Communication functions in the user-friendly icon-based multilingual controller simplify centralised control of the VRV system.



Function 1 **Support for centralised control from elsewhere using a PC with a Web browser** (Option)

Function 2 **Sending of e-mail alerts to a specified address when malfunctions occur** (Option)

Function 3 **Built-in modem for connecting to Air Conditioning Network Service System** (Option)

Function 4 **Doubling of number of connectable indoor units by adding a DIII-NET Plus Adaptor** (Option)


Function 5 **Management of facilities/equipment other than A/C units** (By adding Dio unit or Di unit)

Function 6 **Simple Interlock Function**

- Colour LCD touch panel icon display
- Small manageable size
- Simplified engineering
- Multi language (English, French, Italian, German, Spanish and Chinese)
- Yearly schedule
- PPD (Power Proportinal Distribution function) (Option)
- Auto heat/cool change-over
- Temperature limitation
- Enhanced history function
- Air Conditioning Network Service System (Optional Maintenance Service)
- Simple Interlock Function

Interface for BACnet® and LONWORKS®

Integrated control systems that recognise the trend of open control systems



- Compatibility with BMS enhanced by utilising the international communication standards, BACnet® or LONWORKS®.

DMS502B51 Interface for use in BACnet®


- BTL Certification
- PPD data (Optional Di board is required.)
- ISO 16484-5 (Does not support IEEE 802.3 protocol for BACnet®)
- Conformance class 3 (ASHRAE 135–1995)
- Standard BACnet® Device B-ASC (ASHRAE 135–2001)
- Up to 40 outdoor units and 256 indoor unit groups on one gateway. (optional adaptor)

DMS504B51 Interface for use in LONWORKS®

- XIF file for confirming of specifications of the units.
- Connectable up to 10 outdoor units and 64 indoor unit groups.

Air Conditioning Network Service System

Maintenance services that boost profits and customer satisfaction



- 24 hour on-line diagnostic system
- Energy saving and extention of aircon operating life
- Maintenance management via A/C network service system reports
- Reliable service at shortest lead time


*1. Model name varies upon the system size.
*2. BACnet® is a registered trademark of American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE).
*3. LONWORKS® is a registered trade mark of Echelon Corporation.
*4. For an I/F unit, one of the following can be selected: ***Local Controller***, intelligent touch Controller, or intelligent Manager III.
*5. Ethernet is a registered trademark of Xerox Corporation.
*6. Refer to the Options page for the name of each model.

intelligent Manager III

Centralised control system for easy provision of effective control and monitoring of VRV system functions

New Features


- Monitor and control from the remote site by Web browser (Option)
- PPD data can be managed from the remote site by Web browser (Option)
- Send malfunction report through the Internet by E-mail (Option)
- Compliant with the RoHS Directive (DAM602B51/52)



Special Functions

- Features control and monitoring functions for central A/C products and an Air Conditioning Network Service function.
- Using an external contact via DIII-NET, monitors and controls equipment such as lighting, fans, or building security systems.

- Floor visual navigation
- Graphical report
- Multi-PC access
- Analogue interlock
- Automatic heat/cool change-over
- Temperature limitation
- Sliding temperature <Optional (DAM101A51) unit required>
- Energy saving function (ECONO mode) (Option)
- Air Conditioning Network Service System (Optional Maintenance Service)



*1. There are restrictions in applicable areas and release times, therefore please consult us separately for details.
★Interfacing requirements vary depending on model, and some systems may not be suitable. Please contact your distributor for details.
• Information on these systems is preliminary only. Please contact Daikin for formal information on the products.

6.7 HRV (Heat Reclaim Ventilation)

6.7.1 Product Introduction

Background

To maintain the comfortable environment in a building, the fresh air intake is essential the same as an appropriate room temperature control.

The heating / cooling efficiency of conventional standard ventilating systems drops during cooling / heating operation and it is waste of energy.

The Heat Reclaim Ventilation was developed to solve those problems.

What is HRV (Heat Reclaim Ventilation) ?

HRV is a system which recovers the thermal energy of exhaust air and reuses it for heating or cooling of supply air. It exchanges heat between the exhaust and the supply air.


Daikin's HRV

Daikin's HRV greatly reduces the total power consumption by operation interlocked with air conditioner such as VRV or SkyAir.

The total heat exchange mode and the ventilation mode can be automatically selected by setting to the automatic ventilation mode.


Main Features

1. The operation is available when the outdoor air temperature is down to –15°C.
2. Interlocked operation with VRV (SkyAir)
3. Automatic ventilation mode changeover
4. Energy Saving
5. FRESH-UP operation
6. Quiet operation
7. Easy installation
8. Easy maintenance
9. Wide variety of optional accessories




6.7.2 Structure

VAM150GJVE, VAM250GJVE, VAM350GJVE, VAM500GJVE, VAM650GJVE, VAM800GJVE, VAM1000GJVE



3P034927-5J

VAM1500GJVE, VAM2000GJVE



3P034927-5J



6.7.3 Features



Interlocked Operation with VRV (SkyAir)

1. Simultaneous ON / OFF with the indoor unit by the indoor unit remote controller.
2. HRV independent operation during air conditioning off season by the indoor unit remote controller.
3. Automatic ventilation mode changeover: Auto / Heat Recovery / Bypass
4. Fan speed changeover by the indoor unit remote controller : High / Low (Ultra-High / High, Ultra-High / Low)
5. Precooling / heating control function setting to delay the start of ventilation during air conditioner start-up to realize the high energy saving efficiency.
6. FRESH-UP operation setting
7. Filter sign display notifies the time for cleaning the filter.
8. No need to purchase or install the HRV exclusive remote controller
9. Advantage to IAQ (Internal Air Quality)



Note:

5,6 can be set at the initial setting only.

Type	Interlocked operation with air conditioner	HRV independent operation
Structure		
Features	■ Simultaneous operation by air conditioner's remote controller is available.	■ Operation / Stop ■ Ventilation mode changeover ■ Fresh-up changeover ■ Timer mode start / stop ■ Malfunction digital display
Connectable Indoor unit	VRV (all indoor unit), SkyAir	

Daikin's HRV	Other types
	
Dust does not fall off from the air filter because the air supply fan of the interlocked indoor unit remains activated even when the HRV is operated independently.	If conventional HRV, with exclusive remote controller, is directly connected to indoor unit of air conditioner, dust may fall off from air filter when air conditioner is OFF.

Installation Examples

Direct duct connection system	Independent duct system
	


Energy Saving

By heat recovery operation

Approx. **20%** reduction of heating / cooling load

+

HRV unit recovers the thermal energy during cooling / heating operation of air conditioner. HRV reduces the cooling / heating load drastically and enhances the heating / cooling efficiency.



By setting to automatic ventilation mode

Approx. **8%** reduction of heating / cooling load


+

Proper use of Heat recovery ventilation and normal ventilation saves energy.
When the cooling operation is required in winter, use of heat recovery ventilation is not efficient because the outdoor air temperature is normally lower than that of the indoor. Thus, the proper use of ventilation mode enhances the heating / cooling efficiency.

Automatic Ventilation mode changeover

Operation	Sensor of ventilation	Decision of mode (Which is more energy efficient?)
	Difference between indoor / outdoor temp.	
Cooling	Indoor temp. > Outdoor temp. Indoor temp. < Outdoor temp.	Normal ventilation (Bypass) Heat recovery ventilation
Heating	Indoor temp. > Outdoor temp. Indoor temp. < Outdoor temp.	Heat recovery ventilation Normal ventilation (Bypass)

Refer to the CONTROL for the mode changeover.




By Precooling / heating operation


Approx. **2%** reduction of heating / cooling load

=

The load is reduced at startup of the air conditioner by the following control.
Before the working hour, the room air is clean.
Therefore, the startup of HRV can be delayed.





Total 30% reduction of heating / cooling load



Note:
The total heating / cooling load may vary depending on the climate or the other environmental conditions.

FRESH-UP Operation

Both the excessive supply mode and the excessive exhaust mode are selectable.
This function creates a more comfortable air environment.


	Supply Fresh-up (Excessive outdoor air supply)	Exhaust Fresh-up (Excessive exhaust air supply)
Detail	Supply air volume can be set at a higher level than the exhaust air by the remote controller.	Exhaust air volume can be set at a higher level than the supply air by the remote controller.
Major effects	■ Prevents inflow of toilet odor ■ Prevents inflow of outdoor air in winter	■ Prevents outflow of airborne bacteria from rooms in a hospital ■ Prevents outflow of odors from rooms in a nursing home
Application	Offices, etc.	Hospitals, Nursing homes, etc.
Example		

Nighttime free cooling operation
〈AUTOMATIC HEAT PORGE FUNCTION AT NIGHT〉

The nighttime free cooling is an energy-conserving function which works at night when the air conditioners is off, reducing the cooling load in the morning when the air conditioner is turned on by ventilating rooms which contain office equipment which raises the room temperature.

- Nighttime free cooling only works during cooling and when connected to Building Multi or VRV systems.
- Nighttime free cooling is set to “off” in the factory settings; so request your dealer to turn it on if you intend to use it.

Operation image



(a) Outside temperature
(b) Indoor temperature
(c) Set temperature
(d) Operating state of Air conditioner
(e) Operating state of Total heat exchanger

■ **EXPLANATION OF NIGHTTIME FREE COOLING OPERATION IMAGE**

The unit compares the indoor and outdoor temperatures after the air conditioning operation stops for the night. If the following conditions are satisfied, the operation starts, and when the indoor temperature reaches the air conditioning setting, the operation stops.

<Conditions>

1. the indoor temperature is higher than the air conditioning setting and
2. the outdoor temperature is lower than the indoor temperature,

If the above conditions are not satisfied, revaluation is made every 60 minutes.

NOTE


- The nighttime free cooling operation works when the HRV unit is off. Therefore, it is not possible to stop the nighttime free cooling operation, though the forced off is input from the optional controllers for centralized control.

1

Element (HEP element) Material

Material

The partition sheet in the heat exchanger element has been significantly upgraded. It is approximately two-third thinner than the conventional type, resulting in a great improvement in moisture absorption!
The material is flame-retardant for safety.
The fungiproof design also keeps the air clean.



(HC0013)

Structure

The heat exchanger element is designed without moving parts for higher durability and reliability.
The supply air passage and the exhaust air passage are arranged in right angle to prevent the supply and exhaust air from getting mixed.

Features


- High air shielding
  Even in the conventional less humidity conditions, maintaining the features of the material that can get excellent moisture permeability, we have achieved high air shielding, by special processing in the step of milling paper.

New ultra-thin film element

Conventional element

Moisture absorption is less effective due to the thickness of the partition sheets. It also limits the effective area that supply and exhaust air can be exposed to.

Thickness of the partition sheet **60 µm**



New ultra-thin film element


Newly developed!


Due to the thinner film…

- Decreases the moisture resistance of the partition sheets drastically.
- Realizes more space for extra layers in the element, resulting in increased effective area that supply and exhaust air can be exposed to.

Moisture absorption increased by approx. 10%!

Thickness of the partition sheet **40 µm**





Moisture exchange efficiency is greatly improved by using optimized thinner films and moisture-absorption materials in the element. Furthermore, miscellaneous gas barrier properties are maintained by decreasing the porosity in the moisture-absorption materials.


Easy installation and service maintenance

Downsized


Model name	Height (mm)
VAM150GJVE	278
VAM250GJVE	278
VAM350GJVE	306
VAM500GJVE	306
VAM650GJVE	338
VAM800GJVE	387
VAM1000GJVE	387
VAM1500GJVE	785
VAM2000GJVE	785

Parallel air flow system (Daikin)

This system prevents misconnection and simplifies the installation work




Cross air flow system





Service Maintenance

Vertical installation is available.
The unit must be installed with the side of RA, SA down.
It is necessary to make a trap.
Because the trap of wiring can protect against ingress of water.



Upside-down installation is available.
It allows the common use of the inspection hole and reduces the space and installation work.
For 2 units closely installed, only one inspection hole of 450 × 450 mm will do for maintenance or replacement of the heat exchanger element, etc.
Long life filter is equipped.





The operation is available when the outdoor air temperature is down to -15°C

(Operation when the outdoor air temperature becomes lower than -10°C)

When the outdoor air suction temperature becomes lower than -10°C, the unit is changed to intermittent operation to prevent freezing of the heat exchanger element and dew condensation within the unit.

Intermittent operation

The outdoor air thermistor (standard equipment) within the unit detects the temperature. According to the detected temperature, the following operation determines.

<Step 1>

- The air supply fan is changed to intermittent operation, when the temperature is lower than -10°C.
- The intermittent operation of the air supply fan is changed to an operation of each cycle for 45 minutes' operation after stopping operation for 15 minutes.
- The exhaust fan operates continuously according to setup.


<Step 2>

- When the temperature becomes lower than -15°C, the unit stops operation to prevent any defect, such as dew condensation and freezing. The unit does not ventilate.
  But, to detect the elevation of the outdoor air temperature, the unit operates for 5 minutes per hour.
- The control by the external damper (local purchase) is available.
  When the unit is not operating, the unit prevents the cool outdoor air from invading.
  The power is applied from the connector X15A to the external damper. Therefore, the operation of the unit is controlled in conjunction with the external damper.

Note:

Local setting is required.

The high efficiency filter (that has 65% of average dust collecting efficiency) is suitable



Additional optional accessories

Built-in optional high efficiency filter

BRP4A50: Heater control kit

6.8 HRV-With DX Coil-(Heat Reclaim Ventilation) VKM-GA(M) Series

6.8.1 General

- Interlocked operation with VRV
- (Controls of interlocked operation for energy saving : The remote controller for air conditioner can be used, so special remote controller for HRV is unnecessary.)
- Mounted for Direct expansion coil unit for outdoor air treatment
- Changeover function for ventilation mode to Auto/Manual
- FRESH-UP operation (Selectable : Supply air rich mode or exhaust air rich mode ; initial setting)
- Mounted for Water flow type Natural evaporating humidifier
- Possible to attach the High efficiency filter
- Attaching the Power supply terminal for easy connection
- Quiet operation
- Changeover function for air flow rate to High/Low (Ultra-high setting is possible.)
- The power supply of HRV is commonly used with the air-conditioner (Single-phase 220-240V, 50Hz)
- Filter sign display and reset
- Timer setting

■ Features of Direct Expansion Coil

- Draftless ventilation in Heating.
- High humidifying function.


■ How to use this unit

- This unit should be used with air conditioners.
- Air conditioning is impossible only by this unit, because this unit does not have temperature control function. (It's capacity is too small in order to control the room temperature to the whole)
  And should be operated in combination with standard indoor units. (Interlocked operation)
- Independent operation without taking an interlock with indoor units is possible, however, temperature setting by remote controller is impossible.
  In this ON/OFF operation by thermostat depends on factory setting, however, this value is changeable by setting mode on site.
- Model selection should be done not by cooling capacity but by ventilating air flow rate.


6.8.2 Design Flexibility

6.8.2.1 Efficient Fan Performance Produces a High Static Pressure

Improvements to the fan, including the use of multi-arc blades, a thinner scroll and optimized fan scroll angle, help to boost efficiency.



Dramatically higher static pressure is achieved due to improved fan performance. This reduces limitations on unit placement and allows more flexibility in duct design.



6.8.2.2 Operable Outdoor Temperature Down to –15°C

If the outdoor air temperature falls below –10° C, the unit changes to intermittent operation to prevent freezing of the heat exchanger element and dew condensation within the unit.

Intermittent operation

A thermistor (standard equipment) within the unit detects the outdoor air temperature. Unit operation varies according to the detected temperature.

6.8.2.3 Indoor Unit Connectable to up to 130% of the Capacity

6.8.2.4 Slim Design


The slim design of only 387 mm in height enables installation inside ceilings with less than 400 mm of clearance.



6.8.3 Energy Saving


6.8.3.1 Automatic Heat purge Function at Night

Not operation



Automatic heat purge control

The heat which accumulated indoors is discharged at night. Air Conditioning load of the next day is reduced, and efficiency is increased.




In case of interlocking operation with an air conditioner

■ **Mechanism**

<Operation>


1. Interlocking operation is carried out with the air-conditioning machine, and the time of 2 hours passing after an operation stop is judged to be night.
   (The same judgment as the present preparatory operation)
2. After 2-hour progress, when indoor temperature is higher than the preset temperature of an air-conditioning machine and higher than outdoor temperature, operation is started.
3. Operation will be stopped if indoor temperature falls to air-conditioning machine preset temperature.



■ **Effect** (Field Setting by remote controller)


It is reduction of about 5% of air-conditioning load at the time of cooling operation.

Air conditioning operation carries out to April to October, and air-conditioning load is calculated only with sensible heat load.



6.8.3.2 Automatic Changeover to Efficient Operation Patterns

Operation automatically changes to the optimum pattern to suit conditions.




1

6.8.3.3 Efficient Outdoor Air Introduction with Heat Exchanger and Cooling/heating Operation


Indoor unit with outdoor air treatment

Using outdoor air, the temperature can be brought near room temperature with minimal cooling capacity through the use of outdoor air.



6.8.3.4 Operations, Such as Cleaning, Ventilation, Cooling/heating and Humidifying, are Possible with One Remote Controller.


Four air conditioner functions can be managed using a single remote control. This makes it easy to obtain high-quality and energy-efficient outdoor air treatment.



6.8.4 Unique Control System

6.8.4.1 Independent Control Possible

Individual outdoor air treatment operation is possible by connecting an optional remote controller.




6.8.5 Quiet Operation

Reduced pressure loss and quieter operation internally lowers the noise output of the 1,000m^3/h type system to 38dB (50Hz 240V, High mode).

6.8.6 Easy Installation

6.8.6.1 Integrated System Includes Ventilation, Air Conditioning and Humidifying Operations

Rather than using separate ventilation, air conditioning, and humidifying components, the system incorporating HRV (VKM) integrates all functions, reducing the total number of indoor units and facilitating a far simpler system. The installation space becomes smaller and the labor required for installation and maintenance is reduced significantly.




6.8.7 Other Features

6.8.7.1 Interlocked Operation with VRV


1. Simultaneous ON / OFF with the indoor unit by the indoor unit remote controller.
2. HRV independent operation during air conditioning off season by the indoor unit remote controller.
3. Automatic ventilation mode changeover : Auto / Heat Recovery / Bypass
4. Fan speed changeover by the indoor unit remote controller : High / Low, Ultra-High / High
5. FRESH-UP operation setting
6. Filter sign display notifies the time for cleaning the filter.
7. No need to purchase or install the HRV exclusive remote controller
8. Advantage to IAQ (Internal Air Quality)

Note

4-6 can be set at the initial setting only. (When using the remote controller BRC1C62)


Type	Interlocked operation with air conditioner
Structure	
Features	• Simultaneous operation by air conditioner's remote controller is available. • Fan speed can be set at the initial setting.
Connectable Indoor unit	VRV (all indoor unit)

Daikin's HRV



Dust does not fall off from the air filter because the air supply fan of the interlocked indoor unit remains activated even when the HRV is operated independently.

Other types



If conventional HRV, with exclusive remote controller, is directly connected to indoor unit of air conditioner, dust may fall off from air filter when air conditioner is OFF.



Note

1) In case of the direct duct connection system, operate interlocking with indoor units.

2) Do not connect the duct with discharge air side of indoor units.

1

Installation Examples

Direct duct connection system	Independent duct system
 (HC0007)	 (HC0008)


6.8.7.2 Mechanism of Energy Saving

By heat recovery operation

Approx. **20%** reduction of heating / cooling load

+

HRV unit recovers the thermal energy during cooling / heating operation of air conditioner. HRV reduces the cooling / heating load drastically and enhances the heating / cooling efficiency.



By setting to automatic ventilation mode


Approx. **6%** reduction of heating / cooling load

+

Proper use of Heat recovery ventilation and normal ventilation saves energy.
When the cooling operation is required in winter, use of heat recovery ventilation is not efficient because the outdoor air temperature is normally lower than that of the indoor. Thus, the proper use of ventilation mode enhances the heating / cooling efficiency.
Automatic Ventilation mode changeover


Operation	Sensor of ventilation	Decision of mode (Which is more energy efficient?)
	Difference between indoor / outdoor temp.	
Cooling	Indoor temp. > Outdoor temp. Indoor temp. < Outdoor temp.	Normal ventilation (Bypass) Heat recovery ventilation
Heating	Indoor temp. > Outdoor temp. Indoor temp. < Outdoor temp.	Heat recovery ventilation Normal ventilation (Bypass)

Refer to the CONTROL for the mode changeover.



=

Total **26%** reduction of heating / cooling load





Note :

The total heating / cooling load may vary depending on the climate or the other environmental conditions.

6.8.7.3 Fresh-up Operation


Both the excessive supply mode and the excessive exhaust mode are selectable.
This function creates a more comfortable air environment.

	Supply Fresh-up (Excessive outdoor air supply)	Exhaust Fresh-up (Excessive exhaust air supply)
Detail	Supply air volume can be set at a higher level than the exhaust air by the remote controller.	Exhaust air volume can be set at a higher level than the supply air by the remote controller.
Major effects	• Prevents inflow of toilet odor • Prevents inflow of outdoor air in winter	• Prevents outflow of airborne bacteria from rooms in a hospital • Prevents outflow of odors from rooms in a nursing home
Application	Offices, etc.	Hospitals, Nursing homes, etc.
Example		

6.8.7.4 Proprietary Developed HEP Element

The heat exchange element uses a High Efficiency Paper (HEP) that has superior moisture-absorption and humidifying properties and doubles the current efficiency of moisture absorption. The heat exchange unit speedily recovers heat contained as latent heat (vapor). The element is made of a material with superior flame-resistant properties and is treated with an anti-molding agent.

Operation of the heat exchanger element






(HC0013)
HEP anti-molding

Features

- High air shielding
  Even in the conventional less humidity conditions, maintaining the features of the material that can get excellent moisture permeability, we have achieved high air shielding, by special processing in the step of milling paper.



- Polymer material that inhibits air permeability that treated on the surface of the heat exchanger element restrains air permeability.


6.8.7.5 Easy Installation and Service Maintenance

Downsized


Model name	Height (mm)
VKM50GAMV1	387
VKM50GAV1	
VKM80GAMV1	
VKM80GAV1	
VKM100GAMV1	
VKM100GAV1	

Parallel air flow system (Daikin)

This system prevents misconnection and simplifies the installation work



Cross air flow system (Others)



6.8.7.6 The Operation is Available When the Outdoor Air Temperature is Down to -15°C

(Operation when the outdoor air temperature becomes lower than -10°C)

When the outdoor air suction temperature becomes lower than -10°C, the unit is changed to intermittent operation to prevent freezing of the heat exchanger element and dew condensation within the unit.

Intermittent operation

The outdoor air thermistor (standard equipment) within the unit detects the temperature. According to the detected temperature, the following operation determines.


<Step1>

- The air supply fan is changed to intermittent operation, when the temperature is lower than -10°C.
- The intermittent operation of the air supply fan is changed to an operation of each cycle for 45 minutes' operation after stopping operation for 15 minutes.
- The exhaust fan operates continuously according to setup.

<Step2>

- When the temperature becomes lower than -15°C, the unit stops operation to prevent any defect, such as dew condensation and freezing. The unit does not ventilate.
  But, to detect the elevation of the outdoor air temperature, the unit operates for 5 minutes per hour.

6.8.7.7 The High Efficiency Filter (that has 65% of Average Dust Collecting Efficiency) is Suitable



6.8.7.8 Additional Optional Accessories

Built-in optional high efficiency filter

It greatly reduces the installation space.

The installation of access doors and the unit can be reduced.

■ **Selection Procedures (in Japan)**

Various methods are used to calculate the required ventilating air flow rate according to CO_2 generated by inhabitants in a room, waste gas generated by use of fire, and other conditions of a room.
Here are 2 patterns of calculating methods.

Based on inhabitants

$$\text{Required ventilating air flow rate } (m^3/h) = \frac{20 \times A}{B}$$

A : 20 × Living room floor space (m^2)
B : Area occupied per person (m^2)
The above equation conforms to article 20, 2 No.2 of the Building Standards Act in Japan.

Note :

1. 20 (in the above equation) means "20(m^3 / h / person)", which is the required ventilating air flow rate based on the CO_2 exhausted by an adult sitting still in a room. If smoking is allowed, other calculation method should be used.
2. Use 10 (m^2) if the area occupied per person exceeds 10 (m^2).

<Table 1>

Type of building	Area occupied per person (N)	Remarks
Dining houses, restaurants, coffee-shops	3 m^2	Floor space of a part used for business purposes.
Cabarets, beer halls	2 m^2	Floor space of a part used for business purposes.
Japanese-style restaurants, hall for hire	3 m^2	Floor space of a part used for business purposes.
Store market	3 m^2	Floor space of a part used for business purposes.
Pool rooms, Ping-pong rooms, dance halls, bowling alleys	2 m^2	Floor space of a part used for business purposes.
Pin-ball parlors, Go club houses, mahjong parlors	2 m^2	Floor space of a part used for business purposes.
Inns, hotels, and motels	10 m^2	Floor space of a part used for business purposes.
Massage parlors	5 m^2	Floor space of a part used for business purposes.
Meeting places, public halls	0.5 – 1 m^2	Persons accommodated simultaneously with the number of persons calculated per unit.
Offices	5 m^2	Floor space of an office.

* : Values set by the Metropolitan Maintenance Bureau in Japan.

Note :

1. Table indicates the required ventilating air flow rate calculated as 20 m^3 / h.
2. The area occupied per person by type of business is calculated in reference to Application Standards for building administration in compliance with Building Standards Act in Japan.

Based on Room size

$$\text{Required ventilating air flow rate } (m^3/h) = C \times D \times E$$

C : Number of ventilation required per hour (ventilation / h)
D : Area of room (m^2)
E : Height of Ceiling (m)
Calculation is based on the experiences of hygienic laboratory, etc. to find out the number of hourly ventilation of the room air.
(Selection example)

Place : Living room of common household
Required ventilation : 6 times / h (See Table 2)
Area of room : Approx. 30 (m^2)
Height of ceiling : 2.4 m
Required ventilating air flow rate = $6 \times 30 \times 2.4 \fallingdotseq$ 432 (m^3 / h)

Required ventilating air flow rate and the unit size 500 is almost equal.
So select the close size of the unit.
In this case, select VKM500GMV1.

<Table 2>

Groups	Type of room	Ventilation required
Common household	Living room	6
	Bathroom	6
	Drawing room	6
	Toilet	10
	Kitchen	15
Dining places	Restaurant	6
	Sushi restaurant	6
	Banquet hall	10
	Tempura restaurant	20
	Cooking room	20
Inns and hotels	Guest room	5
	Corridor	5
	Dance hall	8
	Large dining hall	8
	Washroom, Toilet	10
	Cooking room	15
	Laundry room	15
	Engine room	20
	Boiler room	20
Hospitals	Consultation office	6
	Sick room	6
	Office room	6
	Corridor	10
	Waiting room	10
	Bathroom	10
	Dining room, Toilet	10
	Respiratory disease room	10
	Laundry room	15
	Cooking room	15
	Surgery room	15
	Sterilizing room	15
	Engine room	20
	Boiler room	20
Schools	Class room, library	6
	Auditorium	6
	Experimental chemistry room	6
	Gymnasium	8
	Toilet	12
	Cooking room	15

Groups	Type of room	Ventilation required
Playhouses and movie theaters	Audience room	6
	Corridor	6
	Smoking room	12
	Toilet	12
	Projector room	20
Plants	Office room	6
	General work room	6
	Telephone room	6
	Spinning plant,	10
	Printing plant	10
	Battery room	10
	Machinery plant	10
	Generator room	15
	Substation room,	15
	Painting shop,	15
	Welding plant	15
	Chemical plant	15
	Food plant	20
	Wood working plant	20
	Casting plant	50
General buildings	Office room	6
	Waiting room	10
	Show room, Toilet	10
	Conference room	12
Comfort stations		20
Dark rooms	Dark rooms for photo	16
Guest rooms of ship		6
Room of potential noxious gas or combustible gas		20 or more

Part 2
Indoor Units

FXFQ-P
Ceiling Mounted Cassette Type
(Round Flow) 47

FXCQ-M
Ceiling Mounted Cassette Type
(Double-Flow) 123

FXKQ-MA
Ceiling Mounted Cassette
Corner Type. 147

FXDQ-PB, FXDQ-NB
Slim Ceiling Mounted Duct Type 169

FXSQ-M
Ceiling Mounted Built-In Type 207

FXMQ-P
Ceiling Mounted Duct Type
(Middle and High Static Pressure) 251

FXMQ-MA
Ceiling Mounted Duct Type. 305

FXHQ-MA
Ceiling Suspended Type 325

FXAQ-MA
Wall Mounted Type 343

FXLQ-MA / FXNQ-MA
Floor Standing Type /
Concealed Floor Standing Type 373

FXUQ-MA
Ceiling Suspended Cassette Type
(Connection Unit Series). 397

FXFQ-P
Ceiling Mounted Cassette Type (Round Flow)

1. Features 48
2. Specifications 49
3. Dimensions 51
4. Piping Diagrams 54
5. Wiring Diagrams 55
6. Electric Characteristics 56
7. Capacity Tables 57
   7.1 Cooling Capacity 57
   7.2 Heating Capacity 58
8. Sound Levels 59
9. Center of Gravity 61
10. Installation Manual 62
11. Accessories 86

1. Features

Ceiling Mounted Cassette (Round Flow) Type


New

FXFQ25P/FXFQ32P/FXFQ40P
FXFQ50P/FXFQ63P/FXFQ80P
FXFQ100P/FXFQ125P




360° airflow improves temperature distribution and offers a comfortable living environment.

- The industry's first* Round Flow Ceiling Mounted Cassette type offers 360° airflow with improved temperature distribution.



* As of April 2004, the release date for Japan.

- All models are lighter than the conventional ones. Ex: Models FXFQ25P-50P are 4.5 kg lighter (reduced from 24 kg to 19.5 kg).
- Drain pump is equipped as standard accessory, and the lift height has been improved from 750 mm to 850 mm.



- A modern sophisticated decoration panel has been applied, with a panel surface that has been treated with a dirt-repellant coating.




- Control of the airflow rate has been improved from 2-step to 3-step control.
- Low operation sound level (dB(A))

FXFQ-P	25	32	40	50	63	80	100	125
Sound level (HH/H/L)	30/28.5/27		31/29/27	32/29.5/27	34/31/28	36/33.5/31	43/37.5/32	44/39/34



- A new antibacterial treatment that uses silver ions has been applied to the drain pan, preventing the growth of slime, mould and bacteria that cause blockages and odours.
- The horizontal louvres prevent dew condensation. Their non-flocking surfaces, which repel dirt, are easy to clean.
- The air filter has an anti-mould and antibacterial treatment that prevents the growth of mould generated from dust or moisture that may adhere to the filter.

- Example of airflow patterns:
  360° airflow is available, as well as 2- to 4-way flows, so you can choose the most suitable airflow pattern depending on location or room layout.



Note: Whatever the discharge direction, the same type of panel is used. If installing for other than all-round flow, an air discharge outlet sealing member (option) must be used to close each unused outlet.

2. Specifications

Ceiling Mounted Cassette (Round Flow) Type

Model			FXFQ25PVE	FXFQ32PVE	FXFQ40PVE	FXFQ50PVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	2,500	3,200	4,000	5,000
		Btu/h	9,900	12,600	16,000	19,800
		kW	2.9	3.7	4.7	5.8
∗2 Cooling Capacity (19.0°CWB)		kW	2.8	3.6	4.5	5.6
∗3 Heating Capacity		kcal/h	2,800	3,400	4,300	5,400
		Btu/h	10,900	13,600	17,100	21,500
		kW	3.2	4.0	5.0	6.3
Casing			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	246×840×840	246×840×840	246×840×840	246×840×840
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	2×6×1.2	2×6×1.2	2×6×1.2	2×6×1.2
	Face Area	m²	0.267	0.267	0.267	0.267
Fan	Model		QTS48C15M	QTS48C15M	QTS48C15M	QTS48C15M
	Type		Turbo Fan	Turbo Fan	Turbo Fan	Turbo Fan
	Motor Output × Number of Units	W	56×1	56×1	56×1	56×1
	Air Flow Rate (HH/H/L)	m³/min	13/11.5/10	13/11.5/10	15/13/11	16/13.5/11
		cfm	459/406/353	459/406/353	530/459/388	565/477/388
	Drive		Direct Drive	Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Polyurethane Form	Polyurethane Form	Polyurethane Form	Polyurethane Form
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)
	Drain Pipe	mm	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)
Mass (Weight)		kg	19.5	19.5	19.5	19.5
∗5 Sound Level (HH/H/L) (220-240V)		dBA	30/28.5/27	30/28.5/27	31/29/27	32/29.5/27
Safety Devices			Fuse	Fuse	Fuse	Fuse
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A VRV P(A) Series	R-410A VRV P(A) Series	R-410A VRV P(A) Series	R-410A VRV P(A) Series
Decoration Panels (Option)	Model		BYCP125K-W1	BYCP125K-W1	BYCP125K-W1	BYCP125K-W1
	Panel Color		Fresh White	Fresh White	Fresh White	Fresh White
	Dimensions: (H×W×D)	mm	50×950×950	50×950×950	50×950×950	50×950×950
	Air Filter		Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
	Weight	kg	5.5	5.5	5.5	5.5
Standard Accessories			Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Washer Fixing Plate. Sealing Pads. Clamps. Screws. Washer for Hanging Bracket. Insulation for Fitting. Installation Guide.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Washer Fixing Plate. Sealing Pads. Clamps. Screws. Washer for Hanging Bracket. Insulation for Fitting. Installation Guide.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Washer Fixing Plate. Sealing Pads. Clamps. Screws. Washer for Hanging Bracket. Insulation for Fitting. Installation Guide.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Washer Fixing Plate. Sealing Pads. Clamps. Screws. Washer for Hanging Bracket. Insulation for Fitting. Installation Guide.
Drawing No.			C : 3D060255			

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit centre. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 56 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Ceiling Mounted Cassette (Round Flow) Type

Model			FXFQ63PVE	FXFQ80PVE	FXFQ100PVE	FXFQ125PVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	6,300	8,000	10,000	12,500
		Btu/h	24,900	31,700	39,600	49,500
		kW	7.3	9.3	11.6	14.5
∗2 Cooling Capacity (19.0°CWB)		kW	7.1	9.0	11.2	14.0
∗3 Heating Capacity		kcal/h	6,900	8,600	10,800	13,800
		Btu/h	27,300	34,100	42,700	54,600
		kW	8.0	10.0	12.5	16.0
Casing			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	246×840×840	246×840×840	288×840×840	288×840×840
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	2×10×1.2	2×10×1.2	2×12×1.2	2×12×1.2
	Face Area	m²	0.446	0.446	0.535	0.535
Fan	Model		QTS48C15M	QTS48C15M	QTS48C15M	QTS48C15M
	Type		Turbo Fan	Turbo Fan	Turbo Fan	Turbo Fan
	Motor Output × Number of Units	W	56×1	56×1	120×1	120×1
	Air Flow Rate (HH/H/L)	m³/min	19/16.5/13.5	21/18/15	32/26/20	33/28/22.5
		cfm	671/583/477	742/636/530	1,130/918/706	1,165/989/794
	Drive		Direct Drive	Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Polyurethane Form	Polyurethane Form	Polyurethane Form	Polyurethane Form
Piping Connections	Liquid Pipes	mm	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes	mm	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe	mm	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)
Mass (Weight)		kg	22	22	25	25
∗5 Sound Level (HH/H/L) (220-240V)		dBA	34/31/28	36/33.5/31	43/37.5/32	44/39/34
Safety Devices			Fuse	Fuse	Fuse	Fuse
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A VRV P(A) Series	R-410A VRV P(A) Series	R-410A VRV P(A) Series	R-410A VRV P(A) Series
Decoration Panels (Option)	Model		BYCP125K-W1	BYCP125K-W1	BYCP125K-W1	BYCP125K-W1
	Panel Color		Fresh White	Fresh White	Fresh White	Fresh White
	Dimensions: (H×W×D)	mm	50×950×950	50×950×950	50×950×950	50×950×950
	Air Filter		Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
	Weight	kg	5.5	5.5	5.5	5.5
Standard Accessories			Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Washer Fixing Plate. Sealing Pads. Clamps. Screws. Washer for Hanging Bracket. Insulation for Fitting. Installation Guide.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Washer Fixing Plate. Sealing Pads. Clamps. Screws. Washer for Hanging Bracket. Insulation for Fitting. Installation Guide.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Washer Fixing Plate. Sealing Pads. Clamps. Screws. Washer for Hanging Bracket. Insulation for Fitting. Installation Guide.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Washer Fixing Plate. Sealing Pads. Clamps. Screws. Washer for Hanging Bracket. Insulation for Fitting. Installation Guide.
Drawing No.			C : 3D060255			

Note:


∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit centre. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 56 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

3. Dimensions

FXFQ25P / 32P / 40P / 50PVE


Unit (mm)



NOTE) 1. STICKING LOCATION FOR MANUFACTURE'S LABEL
MANUFACTURE'S LABEL FOR INDOOR UNIT:
SUCTION GRILL INNER SIDE'S ELECTRIC COMPONENTS BOX'S LID SURFACE
MANUFACTURE'S LABEL FOR DECORATION PANEL:
DECORATION PANEL'S CORNER DECORATION COVER INNER SURFACE
2. IN CASE OF USING WIRELESS REMOTE CONTROLLER, THIS POSITION WILL BE A SIGNAL RECEIVER. REFER TO THE DRAWING OF WIRELESS REMOTE CONTROLLER IN DETAIL.
3. WHEN THE TEMPERATURE AND HUMIDITY IN THE CEILING EXCEED 30°C AND RH 80% OR THE FRESH AIR IS INDUCTED INTO THE CEILING OR THE UNIT CONTINUES 24 HOUR OPERATION, AN ADDITIONAL INSULATION (THICKNESS 10mm OR MORE OF GLASSWOOL OR POLYETHYLENE FORM) IS REQUIRED.
4. THOUGH THE INSTALLATION IS ACCEPTABLE UP TO MAXIMUM OF 910mm SQUARE CEILING OPENING, KEEP THE CLEARANCE OF 35mm OR LESS BETWEEN THE INDOOR UNIT AND THE CEILING OPENING SO THAT THE PANEL OVERLAP ALLOWANCE CAN BE ENSURED.
5. PLEASE DO NOT PLACE THE THING BEEN DAMP AND TROUBLED UNDER AN INDOOR UNIT.
WHEN THE CASE WHERE HUMIDITY IS 80% OR MORE, AND THE DRAIN OUTLET ARE CHOKED UP AND THE AIR FILTER ARE DIRTY, DEW MAY FALL.

FXFQ63P / 80PVE

Unit (mm)



ITEM	PART NAME	REMARK
9	DRAIN HOSE (ACCESSORY)	LOCAL CONNECTION OD ϕ 32 (OUTLET) (UNIT CONNECTION OD ϕ 26)
8	CORNER DECORATION COVER	
7	SUCTION GRILLE	
6	AIR-OUTLET	
5	CONNECTION WIRING/ REMOTE CONTROL WIRING CONNECTION	
4	POWER-SOURCE WIRING AND A UNIT WIRING CONNECTION	
3	DRAIN PIPE CONNECTION	VP25 (OD ϕ 32)
2	GAS PIPE CONNECTION	ϕ 15.9 (FLARE CONNECTION)
1	LIQUID PIPE CONNECTION	ϕ 9.5 (FLARE CONNECTION)

3D058460A


NOTE) 1. STICKING LOCATION FOR MANUFACTURE'S LABEL
MANUFACTURE'S LABEL FOR INDOOR UNIT:
SUCTION GRILL INNER SIDE'S ELECTRIC COMPONENTS BOX'S LID SURFACE
MANUFACTURE'S LABEL FOR DECORATION PANEL:
DECORATION PANEL'S CORNER DECORATION COVER INNER SURFACE
2. IN CASE OF USING WIRELESS REMOTE CONTROLLER, THIS POSITION WILL BE A SIGNAL RECEIVER. REFER TO THE DRAWING OF WIRELESS REMOTE CONTROLLER IN DETAIL.
3. WHEN THE TEMPERATURE AND HUMIDITY IN THE CEILING EXCEED 30˚C AND RH 80% OR THE FRESH AIR IS INDUCTED INTO THE CEILING OR THE UNIT CONTINUES 24 HOUR OPERATION, AN ADDITIONAL INSULATION (THICKNESS 10mm OR MORE OF GLASSWOOL OR POLYETHYLENE FORM) IS REQUIRED.
4. THOUGH THE INSTALLATION IS ACCEPTABLE UP TO MAXIMUM OF 910mm SQUARE CEILING OPENING, KEEP THE CLEARANCE OF 35mm OR LESS BETWEEN THE INDOOR UNIT AND THE CEILING OPENING SO THAT THE PANEL OVERLAP ALLOWANCE CAN BE ENSURED.
5. PLEASE DO NOT PLACE THE THING BEEN DAMP AND TROUBLED UNDER AN INDOOR UNIT.
WHEN THE CASE WHERE HUMIDITY IS 80% OR MORE, AND THE DRAIN OUTLET ARE CHOKED UP AND THE AIR FILTER ARE DIRTY, DEW MAY FALL.

* WHEN THE BLOW-OFF GRILL IS CLOSING. THE REQUIRED SPACE IS 500mm OR MORE.
WHEN UNITING AND CLOSING A CORNER PART (BOTH RIGHT AND LEFT OF THE BLOW-OFF GRILL TO CLOSE), IT IS 200mm OR MORE.

FXFQ100P / 125PVE

Unit (mm)

2



• DECORATION PANEL

BYCP125K-W1 FRESH WHITE 6.5Y 9.5/0.5

ITEM	PART NAME	REMARK
9	DRAIN HOSE (ACCESSORY)	LOCAL CONNECTION OD ϕ 32 (OUTLET) (UNIT CONNECTION OD ϕ 26)
8	CORNER DECORATION COVER	
7	SUCTION GRILLE	
6	AIR-OUTLET	
5	CONNECTION WIRING/ REMOTE CONTROL WIRING CONNECTION	
4	POWER-SOURCE WIRING AND A UNIT WIRING CONNECTION	
3	DRAIN PIPE CONNECTION	VP25 (OD ϕ 32)
2	GAS PIPE CONNECTION	ϕ 15.9 (FLARE CONNECTION)
1	LIQUID PIPE CONNECTION	ϕ 9.5 (FLARE CONNECTION)


• REQUIRED SPACE

* WHEN THE BLOW-OFF GRILL IS CLOSING. THE REQUIRED SPACE IS 500mm OR MORE.
WHEN UNITING AND CLOSING A CORNER PART (BOTH RIGHT AND LEFT OF THE BLOW-OFF GRILL TO CLOSE), IT IS 200mm OR MORE.

NOTE) 1. STICKING LOCATION FOR MANUFACTURE'S LABEL
MANUFACTURE'S LABEL FOR INDOOR UNIT:
SUCTION GRILL INNER SIDE'S ELECTRIC COMPONENTS BOX'S LID SURFACE
MANUFACTURE'S LABEL FOR DECORATION PANEL:
DECORATION PANEL'S CORNER DECORATION COVER INNER SURFACE
2. IN CASE OF USING WIRELESS REMOTE CONTROLLER, THIS POSITION WILL BE A SIGNAL RECEIVER. REFER TO THE DRAWING OF WIRELESS REMOTE CONTROLLER IN DETAIL.
3. WHEN THE TEMPERATURE AND HUMIDITY IN THE CEILING EXCEED 30˚C AND RH 80% OR THE FRESH AIR IS INDUCTED INTO THE CEILING OR THE UNIT CONTINUES 24 HOUR OPERATION, AN ADDITIONAL INSULATION (THICKNESS 10mm OR MORE OF GLASSWOOL OR POLYETHYLENE FORM) IS REQUIRED.
4. THOUGH THE INSTALLATION IS ACCEPTABLE UP TO MAXIMUM OF 910mm SQUARE CEILING OPENING, KEEP THE CLEARANCE OF 35mm OR LESS BETWEEN THE INDOOR UNIT AND THE CEILING OPENING SO THAT THE PANEL OVERLAP ALLOWANCE CAN BE ENSURED.
5. PLEASE DO NOT PLACE THE THING BEEN DAMP AND TROUBLED UNDER AN INDOOR UNIT.
WHEN THE CASE WHERE HUMIDITY IS 80% OR MORE, AND THE DRAIN OUTLET ARE CHOKED UP AND THE AIR FILTER ARE DIRTY, DEW MAY FALL.

3D058469A

4. Piping Diagrams



4D024460B


■ **Refrigerant pipe connection port diameters**

(mm)

Model	Gas	Liquid
FXFQ25P / 32P / 40P / 50PVE	ϕ12.7	ϕ6.4
FXFQ63P / 80P / 100P / 125PVE	ϕ15.9	ϕ9.5

5. Wiring Diagrams

FXFQ25P / 32P / 40P / 50P / 63P / 80P / 100P / 125PVE



INDOOR UNIT	H1P	LIGHT EMITTING DIODE	(ON-RED)
A1P PRINTED CIRCUIT BOARD	H2P	LIGHT EMITTING DIODE	(TIMER-GREEN)
A2P PRINTED CIRCUIT BOARD	H3P	LIGHT EMITTING DIODE	(FILTER SIGN-RED)
C1 CAPACITOR	H4P	LIGHT EMITTING DIODE	(DEFROST-ORANGE)
F1U FUSE (F, 5A, 250V)	SS1	SELECTOR SWITCH	(MAIN/SUB)
HAP LIGHT EMITTING DIODE (SERVICE MONITOR GREEN)	SS2	SELECTOR SWITCH	(WIRELESS ADDRESS SET)
K1R MAGNETIC RELAY	X24A	CONNECTOR (WIRELESS	REMOTE CONTROLLER)
KPR MAGNETIC RELAY (M1P)	X33A	CONNECTOR	(ADAPTOR FOR WIRING)
M1F MOTOR (INDOOR FAN)	X35A	CONNECTOR (GROUP	CONTROL ADAPTOR)
M1P MOTOR (DRAIN PUMP)		WIRED REMOTE CONTROLLER	
M1S MOTOR (SWING FLAP)	R1T	THERMISTOR (AIR)	
R1T THERMISTOR (AIR)	SS1	SELECTOR SWITCH (MAIN/SUB)	
R2T THERMISTOR (COIL LIQUID)		CONNECTOR FOR OPTIONAL PARTS	
R3T THERMISTOR (COIL GAS)			
R4T THERMISTOR PTC			
S1L FLOAT SWITCH			
V1R DIODE BRIDGE			
X1M TERMINAL STRIP			
X2M TERMINAL STRIP			
Y1E ELECTRONIC EXPANSION VALVE			
Z1C FERRITE CORE			
Z1F NOISE FILTER			
(PS) POWER SUPPLY CIRCUIT			
RECEIVER/DISPLAY UNIT (ATTACHED TO WIRELESS REMOTE CONTROLLER)			
A3P PRINTED CIRCUIT BOARD			
A4P PRINTED CIRCUIT BOARD			
BS1 PUSH BUTTON (ON/OFF)			

NOTES)
1. □□□□ : TERMINAL ⊡, ⊃ : CONNECTOR
   ⏚ : FIELD WIRING
2. IN CASE USING CENTRAL REMOTE CONTROLLER, CONNECT IT TO THE UNIT IN ACCORDANCE WITH THE ATTACHED INSTALLATION MANUAL.
3. X24A, X33A AND X35A ARE CONNECTED WHEN THE OPTIONAL ACCESSORIES ARE BEING USED.
4. WHEN CONNECTING THE INPUT WIRES FROM OUTSIDE, FORCED OFF OR ON/OFF CONTROL OPERATION CAN BE SELECTED BY THE REMOTE CONTROLLER. SEE INSTALLATION MANUAL FOR MORE DETAILS.
5. CONFIRM THE METHOD OF SETTING THE SELECTOR SWITCH (SS1, SS2) BY INSTALLATION MANUAL AND ENGINEERING DATA, ETC.
6. SYMBOLS SHOWS AS FOLLOWS:
   RED : RED BLK : BLACK WHT : WHITE YLW : YELLOW GRN : GREEN
   ORG : ORANGE BRN : BROWN PNK : PINK GRY : GRAY BLU : BLUE

6. Electric Characteristics

Units				Power supply		IFM		Input(W)	
Model	Hz	Volts	Voltage range	MCA	MFA	kW	FLA	Cooling	Heating
FXFQ25PVE	50	220-240	MAX. 264 Min. 198	0.3	15	0.056	0.2	33	27
FXFQ32PVE				0.3	15	0.056	0.2	33	27
FXFQ40PVE				0.3	15	0.056	0.2	47	34
FXFQ50PVE				0.3	15	0.056	0.2	52	38
FXFQ63PVE				0.4	15	0.056	0.3	66	53
FXFQ80PVE				0.5	15	0.056	0.4	93	75
FXFQ100PVE				1.3	15	0.120	1.0	187	174
FXFQ125PVE				1.5	15	0.120	1.2	209	200
FXFQ25PVE	60	220	MAX. 242 Min. 198	0.3	15	0.056	0.2	32	27
FXFQ32PVE				0.3	15	0.056	0.2	32	27
FXFQ40PVE				0.3	15	0.056	0.2	42	34
FXFQ50PVE				0.3	15	0.056	0.2	50	38
FXFQ63PVE				0.4	15	0.056	0.3	63	53
FXFQ80PVE				0.5	15	0.056	0.4	92	75
FXFQ100PVE				1.3	15	0.120	1.0	186	174
FXFQ125PVE				1.5	15	0.120	1.2	208	200

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
kW : Fan Motor Rated Output(kW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

Note:

1. Voltage range

   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.

2. Maximum allowable voltage unbalance between phases is 2%.

3. MCA/MFA

   MCA = 1.25 X FLA

   MFA ≦ 4 X FLA

   (Next lower standard fuse rating. Min. 15A)

4. Select wire size based on the MCA.

5. Instead of fuse, use Circuit Breaker.

4D060238A

7. Capacity Tables

7.1 Cooling Capacity

FXFQ-P **[50/60Hz]**

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	14.0°CWB 20°CDB SHC	16.0°CWB 23°CDB TC	16.0°CWB 23°CDB SHC	18.0°CWB 26°CDB TC	18.0°CWB 26°CDB SHC	19.0°CWB 27°CDB TC	19.0°CWB 27°CDB SHC	20.0°CWB 28°CDB TC	20.0°CWB 28°CDB SHC	22.0°CWB 30°CDB TC	22.0°CWB 30°CDB SHC	24.0°CWB 32°CDB TC	24.0°CWB 32°CDB SHC
63	10.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.6	5.7	8.5	5.8	9.0	5.7
	12.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.6	5.7	8.5	5.8	8.9	5.7
	14.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.6	5.7	8.5	5.8	8.7	5.7
	16.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.6	5.7	8.5	5.8	8.6	5.6
	18.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.6	5.7	8.3	5.8	8.5	5.6
	20.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.6	5.7	8.2	5.7	8.4	5.5
	21.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.6	5.7	8.2	5.7	8.3	5.5
	23.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.6	5.7	8.1	5.6	8.2	5.5
	25.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.6	5.7	7.9	5.6	8.1	5.4
	27.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.6	5.7	7.8	5.6	8.0	5.4
	29.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.5	5.7	7.7	5.5	7.9	5.4
	31.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.4	5.7	7.6	5.5	7.8	5.3
	33.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.3	5.6	7.5	5.4	7.6	5.3
	35.0	4.8	4.3	5.7	5.0	6.6	5.6	7.1	5.6	7.2	5.5	7.4	5.4	7.5	5.3
	37.0	4.8	4.3	5.7	5.0	6.6	5.6	7.0	5.6	7.1	5.5	7.2	5.4	7.4	5.2
	39.0	4.8	4.3	5.7	5.0	6.6	5.6	6.9	5.6	7.0	5.4	7.1	5.3	7.3	5.2
80	10.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.6	6.8	10.8	6.9	11.4	6.8
	12.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.6	6.8	10.8	6.9	11.2	6.8
	14.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.6	6.8	10.8	6.9	11.1	6.7
	16.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.6	6.8	10.7	6.9	10.9	6.7
	18.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.6	6.8	10.6	6.9	10.8	6.6
	20.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.6	6.8	10.4	6.8	10.6	6.6
	21.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.6	6.8	10.4	6.8	10.6	6.5
	23.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.6	6.8	10.2	6.7	10.4	6.5
	25.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.6	6.8	10.1	6.6	10.3	6.4
	27.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.6	6.8	9.9	6.6	10.1	6.4
	29.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.5	6.8	9.8	6.5	10.0	6.3
	31.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.4	6.7	9.6	6.5	9.8	6.3
	33.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.3	6.6	9.5	6.4	9.7	6.2
	35.0	6.1	5.1	7.2	5.9	8.4	6.6	9.0	6.7	9.1	6.6	9.3	6.4	9.5	6.2
	37.0	6.1	5.1	7.2	5.9	8.4	6.6	8.9	6.5	9.0	6.5	9.2	6.3	9.4	6.1
	39.0	6.1	5.1	7.2	5.9	8.4	6.6	8.7	6.5	8.8	6.4	9.0	6.3	9.3	6.1
100	10.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	13.4	9.3	14.2	9.2
	12.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	13.4	9.3	14.0	9.1
	14.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	13.4	9.3	13.8	9.0
	16.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	13.3	9.3	13.6	9.0
	18.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	13.2	9.2	13.4	8.9
	20.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	13.0	9.1	13.2	8.8
	21.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	12.9	9.1	13.2	8.8
	23.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	12.7	9.0	13.0	8.7
	25.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	12.5	8.9	12.8	8.7
	27.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	12.3	8.8	12.6	8.6
	29.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.9	9.0	12.2	8.7	12.4	8.5
	31.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.7	8.9	12.0	8.7	12.2	8.5
	33.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.5	8.9	11.8	8.6	12.1	8.4
	35.0	7.6	6.8	9.0	7.8	10.5	8.7	11.2	8.9	11.3	8.8	11.6	8.5	11.9	8.3
	37.0	7.6	6.8	9.0	7.8	10.5	8.7	11.0	8.9	11.2	8.7	11.4	8.5	11.7	8.2
	39.0	7.6	6.8	9.0	7.8	10.5	8.7	10.8	8.7	11.0	8.6	11.2	8.4	11.5	8.2
125	10.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	16.7	10.9	17.7	10.7
	12.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	16.7	10.9	17.5	10.6
	14.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	16.7	10.9	17.2	10.6
	16.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	16.7	10.8	17.0	10.5
	18.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	16.4	10.7	16.8	10.4
	20.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	16.2	10.6	16.6	10.3
	21.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	16.1	10.6	16.4	10.2
	23.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	15.9	10.5	16.2	10.1
	25.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	15.6	10.4	16.0	10.0
	27.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	15.4	10.3	15.8	9.9
	29.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.9	10.5	15.2	10.2	15.5	9.9
	31.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.6	10.4	15.0	10.1	15.3	9.8
	33.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.4	10.3	14.7	10.0	15.1	9.7
	35.0	9.4	7.9	11.3	9.0	13.1	10.1	14.0	10.3	14.2	10.2	14.5	9.9	14.9	9.6
	37.0	9.4	7.9	11.3	9.0	13.1	10.1	13.8	10.3	13.9	10.1	14.3	9.8	14.6	9.5
	39.0	9.4	7.9	11.3	9.0	13.1	10.1	13.5	10.1	13.7	10.0	14.1	9.7	14.4	9.4

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	14.0°CWB 20°CDB SHC	16.0°CWB 23°CDB TC	16.0°CWB 23°CDB SHC	18.0°CWB 26°CDB TC	18.0°CWB 26°CDB SHC	19.0°CWB 27°CDB TC	19.0°CWB 27°CDB SHC	20.0°CWB 28°CDB TC	20.0°CWB 28°CDB SHC	22.0°CWB 30°CDB TC	22.0°CWB 30°CDB SHC	24.0°CWB 32°CDB TC	24.0°CWB 32°CDB SHC
25	10.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.3	2.9	3.5	2.9
	12.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.3	2.9	3.5	2.9
	14.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.3	2.9	3.4	2.9
	16.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.3	2.9	3.4	2.8
	18.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.3	2.9	3.4	2.8
	20.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.2	2.9	3.3	2.8
	21.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.2	2.9	3.3	2.8
	23.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.2	2.9	3.2	2.8
	25.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.1	2.8	3.2	2.7
	27.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.1	2.8	3.2	2.7
	29.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	3.0	2.8	3.0	2.8	3.1	2.7
	31.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	2.9	2.8	3.0	2.8	3.1	2.7
	33.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	2.9	2.8	2.9	2.7	3.0	2.6
	35.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	2.8	2.8	2.9	2.7	2.9	2.6
	37.0	1.9	1.9	2.3	2.3	2.6	2.6	2.8	2.8	2.8	2.8	2.9	2.7	2.9	2.6
	39.0	1.9	1.9	2.3	2.3	2.6	2.6	2.7	2.7	2.7	2.7	2.8	2.7	2.9	2.6
32	10.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.2	4.3	3.2	4.6	3.1
	12.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.2	4.3	3.2	4.5	3.1
	14.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.2	4.3	3.2	4.4	3.1
	16.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.2	4.3	3.2	4.4	3.1
	18.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.2	4.2	3.1	4.3	3.1
	20.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.2	4.1	3.1	4.2	3.1
	21.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.2	4.1	3.1	4.2	3.0
	23.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.2	4.0	3.1	4.1	3.0
	25.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.2	4.0	3.1	4.1	3.0
	27.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.2	3.9	3.1	4.0	3.0
	29.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.8	3.1	3.8	3.1	3.9	3.0
	31.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.7	3.1	3.8	3.1	3.9	3.0
	33.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.6	3.1	3.7	3.1	3.8	3.0
	35.0	2.4	2.4	2.9	2.8	3.4	3.1	3.6	3.1	3.6	3.1	3.7	3.0	3.8	2.9
	37.0	2.4	2.4	2.9	2.8	3.4	3.1	3.5	3.1	3.5	3.1	3.6	3.0	3.7	2.9
	39.0	2.4	2.4	2.9	2.8	3.4	3.1	3.5	3.1	3.5	3.1	3.6	3.0	3.7	2.9
40	10.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	5.4	3.9	5.7	3.9
	12.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	5.4	3.9	5.6	3.8
	14.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	5.4	3.9	5.5	3.8
	16.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	5.4	3.9	5.4	3.8
	18.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	5.3	3.9	5.3	3.7
	20.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	5.2	3.8	5.3	3.7
	21.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	5.2	3.8	5.3	3.7
	23.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	5.1	3.8	5.2	3.7
	25.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	5.0	3.8	5.1	3.7
	27.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	4.9	3.7	5.0	3.6
	29.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.8	3.8	4.8	3.7	4.9	3.6
	31.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.7	3.8	4.8	3.7	4.8	3.6
	33.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.6	3.7	4.7	3.7	4.8	3.5
	35.0	3.0	2.9	3.6	3.4	4.2	3.7	4.5	3.8	4.6	3.7	4.7	3.6	4.7	3.5
	37.0	3.0	2.9	3.6	3.4	4.2	3.7	4.4	3.8	4.5	3.7	4.6	3.6	4.7	3.5
	39.0	3.0	2.9	3.6	3.4	4.2	3.7	4.4	3.7	4.4	3.7	4.5	3.6	4.6	3.5
50	10.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	6.0	4.5	6.7	4.6	7.1	4.5
	12.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	6.0	4.5	6.7	4.6	7.0	4.5
	14.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	6.0	4.5	6.7	4.6	6.9	4.5
	16.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	6.0	4.5	6.7	4.5	6.8	4.4
	18.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	6.0	4.5	6.6	4.5	6.7	4.4
	20.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	6.0	4.5	6.5	4.5	6.6	4.3
	21.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	6.0	4.5	6.4	4.5	6.6	4.3
	23.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	6.0	4.5	6.4	4.4	6.5	4.3
	25.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	6.0	4.5	6.3	4.4	6.4	4.3
	27.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	6.0	4.5	6.2	4.4	6.3	4.2
	29.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	5.9	4.5	6.1	4.3	6.2	4.2
	31.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	5.9	4.4	6.0	4.2	6.1	4.2
	33.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	5.8	4.4	5.9	4.2	6.0	4.2
	35.0	3.8	3.4	4.5	3.9	5.2	4.3	5.6	4.4	5.7	4.4	5.8	4.2	5.9	4.1
	37.0	3.8	3.4	4.5	3.9	5.2	4.3	5.5	4.4	5.6	4.4	5.7	4.2	5.8	4.1
	39.0	3.8	3.4	4.5	3.9	5.2	4.3	5.4	4.3	5.5	4.3	5.6	4.2	5.8	4.0

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

7.2 Heating Capacity

FXFQ-P [50/60Hz]

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
25	-19.8	-20.0	1.9	1.9	1.9	1.9	1.9	1.9
	-18.8	-19.0	1.9	1.9	1.9	1.9	1.9	1.9
	-16.7	-17.0	2.1	2.1	2.0	2.0	2.0	2.0
	-14.7	-15.0	2.2	2.2	2.2	2.2	2.2	2.1
	-12.6	-13.0	2.3	2.3	2.3	2.3	2.3	2.3
	-10.5	-11.0	2.4	2.4	2.4	2.4	2.4	2.4
	-9.5	-10.0	2.5	2.4	2.4	2.4	2.4	2.4
	-8.5	-9.1	2.5	2.5	2.5	2.5	2.5	2.5
	-7.0	-7.6	2.6	2.6	2.6	2.6	2.6	2.6
	-5.0	-5.6	2.7	2.7	2.7	2.7	2.7	2.7
	-3.0	-3.7	2.8	2.8	2.8	2.8	2.8	2.8
	0.0	-0.7	3.0	3.0	3.0	3.0	3.0	2.8
	3.0	2.2	3.1	3.1	3.1	3.1	3.0	2.8
	5.0	4.1	3.3	3.2	3.2	3.1	3.0	2.8
	7.0	6.0	3.4	3.4	3.2	3.1	3.0	2.8
	9.0	7.9	3.5	3.4	3.2	3.1	3.0	2.8
	11.0	9.8	3.6	3.4	3.2	3.1	3.0	2.8
	13.0	11.8	3.6	3.4	3.2	3.1	3.0	2.8
	15.0	13.7	3.6	3.4	3.2	3.1	3.0	2.8
32	-19.8	-20.0	2.4	2.4	2.3	2.3	2.3	2.3
	-18.8	-19.0	2.4	2.4	2.4	2.4	2.4	2.4
	-16.7	-17.0	2.6	2.6	2.6	2.6	2.7	2.5
	-14.7	-15.0	2.7	2.7	2.7	2.7	2.7	2.7
	-12.6	-13.0	2.9	2.8	2.8	2.8	2.8	2.8
	-10.5	-11.0	3.0	3.0	3.0	3.0	3.0	3.0
	-9.5	-10.0	3.1	3.1	3.1	3.1	3.0	3.0
	-8.5	-9.1	3.1	3.1	3.1	3.1	3.1	3.1
	-7.0	-7.6	3.2	3.2	3.2	3.2	3.2	3.2
	-5.0	-5.6	3.4	3.4	3.4	3.4	3.4	3.4
	-3.0	-3.7	3.5	3.5	3.5	3.5	3.5	3.5
	0.0	-0.7	3.7	3.7	3.7	3.7	3.7	3.5
	3.0	2.2	3.9	3.9	3.9	3.9	3.7	3.5
	5.0	4.1	4.1	4.1	4.0	3.9	3.7	3.5
	7.0	6.0	4.2	4.3	4.0	3.9	3.7	3.5
	9.0	7.9	4.3	4.3	4.0	3.9	3.7	3.5
	11.0	9.8	4.5	4.3	4.0	3.9	3.7	3.5
	13.0	11.8	4.5	4.3	4.0	3.9	3.7	3.5
	15.0	13.7	4.5	4.3	4.0	3.9	3.7	3.5
40	-19.8	-20.0	3.0	2.9	2.9	2.9	2.9	2.9
	-18.8	-19.0	3.0	3.0	3.0	3.0	3.0	3.0
	-16.7	-17.0	3.2	3.2	3.2	3.2	3.2	3.2
	-14.7	-15.0	3.4	3.4	3.4	3.4	3.4	3.4
	-12.6	-13.0	3.6	3.6	3.6	3.5	3.5	3.5
	-10.5	-11.0	3.7	3.7	3.7	3.7	3.7	3.7
	-9.5	-10.0	3.8	3.8	3.8	3.8	3.8	3.8
	-8.5	-9.1	3.9	3.9	3.9	3.9	3.9	3.9
	-7.0	-7.6	4.0	4.0	4.0	4.0	4.0	4.0
	-5.0	-5.6	4.2	4.2	4.2	4.2	4.2	4.2
	-3.0	-3.7	4.4	4.4	4.4	4.4	4.4	4.4
	0.0	-0.7	4.7	4.6	4.6	4.6	4.6	4.4
	3.0	2.2	4.9	4.9	5.0	4.8	4.7	4.4
	5.0	4.1	5.1	5.2	5.0	4.8	4.7	4.4
	7.0	6.0	5.2	5.2	5.0	4.8	4.7	4.4
	9.0	7.9	5.4	5.3	5.0	4.8	4.7	4.4
	11.0	9.8	5.6	5.3	5.0	4.8	4.7	4.4
	13.0	11.8	5.6	5.3	5.0	4.8	4.7	4.4
	15.0	13.7	5.6	5.3	5.0	4.8	4.7	4.4
50	-19.8	-20.0	3.7	3.7	3.7	3.7	3.7	3.7
	-18.8	-19.0	3.8	3.8	3.8	3.8	3.8	3.8
	-16.7	-17.0	4.1	4.0	4.0	4.0	4.0	4.0
	-14.7	-15.0	4.3	4.3	4.2	4.2	4.2	4.2
	-12.6	-13.0	4.5	4.5	4.5	4.5	4.5	4.5
	-10.5	-11.0	4.7	4.7	4.7	4.7	4.7	4.7
	-9.5	-10.0	4.8	4.8	4.8	4.8	4.8	4.8
	-8.5	-9.1	4.9	4.9	4.9	4.9	4.9	4.9
	-7.0	-7.6	5.1	5.1	5.1	5.1	5.1	5.1
	-5.0	-5.6	5.3	5.3	5.3	5.3	5.3	5.3
	-3.0	-3.7	5.5	5.5	5.5	5.5	5.5	5.5
	0.0	-0.7	5.9	5.9	5.8	5.8	5.8	5.5
	3.0	2.2	6.2	6.4	6.2	6.1	5.9	5.5
	5.0	4.1	6.4	6.6	6.3	6.1	5.9	5.5
	7.0	6.0	6.6	6.7	6.3	6.1	5.9	5.5
	9.0	7.9	6.8	6.7	6.3	6.1	5.9	5.5
	11.0	9.8	7.0	6.7	6.3	6.1	5.9	5.5
	13.0	11.8	7.1	6.7	6.3	6.1	5.9	5.5
	15.0	13.7	7.1	6.7	6.3	6.1	5.9	5.5

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
63	-19.8	-20.0	4.7	4.7	4.7	4.7	4.7	4.7
	-18.8	-19.0	4.9	4.9	4.8	4.8	4.8	4.8
	-16.7	-17.0	5.1	5.1	5.1	5.1	5.1	5.1
	-14.7	-15.0	5.4	5.4	5.4	5.4	5.4	5.4
	-12.6	-13.0	5.7	5.7	5.7	5.7	5.7	5.7
	-10.5	-11.0	6.0	6.0	6.0	6.0	6.0	5.9
	-9.5	-10.0	6.1	6.1	6.1	6.1	6.1	6.1
	-8.5	-9.1	6.3	6.3	6.2	6.2	6.2	6.2
	-7.0	-7.6	6.5	6.5	6.4	6.4	6.4	6.4
	-5.0	-5.6	6.8	6.7	6.7	6.7	6.7	6.7
	-3.0	-3.7	7.0	7.0	7.0	7.0	7.0	7.0
	0.0	-0.7	7.5	7.4	7.4	7.4	7.4	7.0
	3.0	2.2	7.9	8.1	7.8	7.7	7.5	7.0
	5.0	4.1	8.1	8.4	8.0	7.7	7.5	7.0
	7.0	6.0	8.4	8.5	8.0	7.7	7.5	7.0
	9.0	7.9	8.7	8.5	8.0	7.7	7.5	7.0
	11.0	9.8	8.9	8.5	8.0	7.7	7.5	7.0
	13.0	11.8	9.0	8.5	8.0	7.7	7.5	7.0
	15.0	13.7	9.0	8.5	8.0	7.7	7.5	7.0
80	-19.8	-20.0	5.9	5.9	5.9	5.9	5.9	5.8
	-18.8	-19.0	6.1	6.1	6.0	6.0	6.0	6.0
	-16.7	-17.0	6.4	6.4	6.4	6.4	6.4	6.4
	-14.7	-15.0	6.8	6.8	6.8	6.7	6.7	6.7
	-12.6	-13.0	7.1	7.1	7.1	7.1	7.1	7.1
	-10.5	-11.0	7.5	7.5	7.5	7.5	7.4	7.4
	-9.5	-10.0	7.7	7.8	7.6	7.6	7.6	7.6
	-8.5	-9.1	7.8	7.8	7.8	7.8	7.8	7.8
	-7.0	-7.6	8.1	8.1	8.1	8.1	8.0	8.0
	-5.0	-5.6	8.4	8.4	8.4	8.4	8.4	8.4
	-3.0	-3.7	8.8	8.8	8.7	8.7	8.7	8.7
	0.0	-0.7	9.3	9.3	9.3	9.3	9.3	8.7
	3.0	2.2	9.8	9.8	9.8	9.7	9.4	8.7
	5.0	4.1	10.2	10.1	10.0	9.7	9.4	8.7
	7.0	6.0	10.5	10.5	10.0	9.7	9.4	8.7
	9.0	7.9	10.8	10.6	10.0	9.7	9.4	8.7
	11.0	9.8	11.2	10.6	10.0	9.7	9.4	8.7
	13.0	11.8	11.3	10.6	10.0	9.7	9.4	8.7
	15.0	13.7	11.3	10.6	10.0	9.7	9.4	8.7
100	-19.8	-20.0	7.4	7.4	7.3	7.3	7.3	7.3
	-18.8	-19.0	7.6	7.6	7.6	7.5	7.5	7.5
	-16.7	-17.0	8.0	8.0	8.0	8.0	8.0	8.0
	-14.7	-15.0	8.5	8.5	8.4	8.4	8.4	8.4
	-12.6	-13.0	8.9	8.9	8.9	8.9	8.9	8.8
	-10.5	-11.0	9.4	9.3	9.3	9.3	9.3	9.3
	-9.5	-10.0	9.6	9.6	9.5	9.5	9.5	9.5
	-8.5	-9.1	9.8	9.8	9.7	9.7	9.7	9.7
	-7.0	-7.6	10.1	10.1	10.1	10.1	10.1	10.0
	-5.0	-5.6	10.6	11.0	10.5	10.9	10.5	10.5
	-3.0	-3.7	11.0	11.6	10.9	11.6	10.9	10.9
	0.0	-0.7	11.6	12.3	11.6	12.2	11.6	10.9
	3.0	2.2	12.3	12.7	12.5	12.5	12.1	10.9
	5.0	4.1	12.7	13.1	12.5	12.1	11.7	10.9
	7.0	6.0	13.1	13.3	12.5	12.1	11.7	10.9
	9.0	7.9	13.5	13.3	12.5	12.1	11.7	10.9
	11.0	9.8	14.0	13.3	12.5	12.1	11.7	10.9
	13.0	11.8	14.1	13.3	12.5	12.1	11.7	10.9
	15.0	13.7	14.1	13.3	12.5	12.1	11.7	10.9
125	-19.8	-20.0	9.4	9.4	9.4	9.4	9.4	9.3
	-18.8	-19.0	9.7	9.7	9.7	9.7	9.6	9.6
	-16.7	-17.0	10.3	10.3	10.2	10.2	10.2	10.2
	-14.7	-15.0	10.9	10.8	10.8	10.8	10.8	10.7
	-12.6	-13.0	11.4	11.4	11.4	11.4	11.4	11.3
	-10.5	-11.0	12.0	12.0	12.2	11.9	11.9	11.9
	-9.5	-10.0	12.3	12.2	12.2	12.2	12.2	12.2
	-8.5	-9.1	12.5	12.5	12.5	12.5	12.4	12.4
	-7.0	-7.6	13.0	12.9	12.9	12.9	12.9	12.8
	-5.0	-5.6	13.5	13.5	13.5	13.5	13.4	13.4
	-3.0	-3.7	14.1	14.0	14.0	14.0	14.0	13.9
	0.0	-0.7	14.9	14.9	14.8	14.8	14.8	13.9
	3.0	2.2	15.7	15.7	15.7	15.5	15.0	13.9
	5.0	4.1	16.3	16.2	16.0	15.5	15.0	13.9
	7.0	6.0	17.3	16.8	16.0	15.5	15.0	13.9
	9.0	7.9	17.9	17.0	16.0	15.5	15.0	13.9
	11.0	9.8	18.1	17.0	16.0	15.5	15.0	13.9
	13.0	11.8	18.1	17.0	16.0	15.5	15.0	13.9
	15.0	13.7	18.1	17.0	16.0	15.5	15.0	13.9


Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

8. Sound Levels

2

Overall

■ **Ceiling Mounted Cassette (Round Flow) Type**



4D060231

Note:

1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.


dBA

Model	220~240V 50Hz / 220V 60Hz		
	HH	H	L
FXFQ25P / 32P	30	28.5	27
FXFQ40P	31	29	27
FXFQ50P	32	29.5	27
FXFQ63P	34	31	28
FXFQ80P	36	33.5	31
FXFQ100P	43	37.5	32
FXFQ125P	44	39	34

Octave Band Level


○——○ 220V~240V 50Hz / 220V 60Hz

FXFQ25/32PVE




4D060231

FXFQ40PVE




4D060232

FXFQ50PVE




4D060233

FXFQ63PVE




4D060234

FXFQ80PVE




4D060235

FXFQ100PVE



4D060236

FXFQ125PVE




4D060237

9. Center of Gravity

FXFQ25P / 32P / 40P / 50P / 63P / 80P / 100P / 125PVE

Unit (mm)



MODEL NAME	A	B
FXFQ25P~80PVE	246	90
FXFQ100・125PVE	288	120

4D052237B

10. Installation Manual

FXFQ25PVE FXFQ32PVE FXFQ40PVE FXFQ50PVE	FXFQ63PVE FXFQ80PVE FXFQ100PVE FXFQ125PVE	VRV SYSTEM Inverter Air Conditioners	Installation manual

CONTENTS

1. SAFETY PRECAUTIONS 1
2. BEFORE INSTALLATION 3
3. SELECTING INSTALLATION SITE 5
4. PREPARATIONS BEFORE INSTALLATION 7
5. INDOOR UNIT INSTALLATION 8
6. REFRIGERANT PIPING WORK 10
7. DRAIN PIPING WORK 12
8. ELECTRIC WIRING WORK 15
9. WIRING EXAMPLE AND HOW TO SET THE REMOTE CONTROLLER 16
10. INSTALLATION OF THE DECORATION PANEL 22
11. FIELD SETTING 22
12. TEST OPERATION 24

1. SAFETY PRECAUTIONS

Please read these “SAFETY PRECAUTIONS” carefully before installing air conditioning unit and be sure to install it correctly. After completing installation, conduct a trial operation to check for faults and explain to the customer how to operate the air conditioner and take care of it with the aid of the operation manual. Ask the customer to store the installation manual along with the operation manual for future reference.
This air conditioner comes under the term “appliances not accessible to the general public”.

This unit is a class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

Meaning of WARNING and CAUTION notices.

⚠ **WARNING** .....Failure to follow these instructions properly may result in personal injury or loss of life.

⚠ **CAUTION** .....Failure to observe these instructions properly may result in property damage or personal injury, which may be serious depending on the circumstances.

⚠ WARNING

- Ask your dealer or qualified personnel to carry out installation work.
  Do not attempt to install the air conditioner yourself. Improper installation may result in water leakage, electric shocks or fire.
- Install the air conditioner in accordance with the instructions in this installation manual.
  Improper installation may result in water leakage, electric shocks or fire.
- Consult your local dealer regarding what to do in case of refrigerant leakage.
  When the air conditioner is to be installed in a small room, it is necessary to take proper measures so that the amount of any leaked refrigerant does not exceed the concentration limit in the event of a leakage. Otherwise, this may lead to an accident due to oxygen depletion.

- Be sure to use only the specified accessories and parts for installation work.
  Failure to use the specified parts may result in the unit falling, water leakage, electric shocks or fire.
- Install the air conditioner on a foundation strong enough to withstand the weight of the unit.
  A foundation of insufficient strength may result in the equipment falling and causing injury.
- Carry out the specified installation work after taking into account strong winds, typhoons or earthquakes.
  Failure to do so during installation work may result in the unit falling and causing accidents.
- Make sure that a separate power supply circuit is provided for this unit and that all electrical work is carried out by qualified personnel according to local laws and regulations and this installation manual.
  An insufficient power supply capacity or improper electrical construction may lead to electric shocks or fire.
- Make sure that all wiring is secured, the specified wires are used, and that there is no strain on the terminal connections or wires.
  Improper connections or securing of wires may result in abnormal heat build-up or fire.
- When wiring the power supply and connecting the remote controller wiring and transmission wiring, position the wires so that the terminal box lid can be securely fastened.
  Improper positioning of the terminal box lid may result in electric shocks, fire or the terminals overheating.
- If refrigerant gas leaks during installation, ventilate the area immediately.
  Toxic gas may be produced if the refrigerant comes into contact with fire.
- After completing installation, check for refrigerant gas leakage.
  Toxic gas may be produced if the refrigerant gas leaks into the room and comes into contact with a source of fire, such as a fan heater, stove or cooker.
- Be sure to switch off the unit before touching any electrical parts.
- Do not directly touch refrigerant that has leaked from refrigerant pipes or other areas, as there is a danger of frostbite.
- Be sure to earth the air conditioner.
  Do not earth the unit to a utility pipe, lightning conductor or telephone earth lead.
  Imperfect earthing may result in electric shocks or fire.
  A high surge current from lightning or other sources may cause damage to the air conditioner.
- Be sure to install an earth leakage breaker.
  Failure to install an earth leakage breaker may result in electric shocks or fire.

⚠ CAUTION

- While following the instructions in this installation manual, install drain piping to ensure proper drainage and insulate piping to prevent condensation.
  Improper drain piping may result in indoor water leakage and property damage.
- Install the indoor and outdoor units, power cord and connecting wires at least 1 meter away from televisions or radios to prevent picture interference and noise.
  (Depending on the incoming signal strength, a distance of 1 meter may not be sufficient to eliminate noise.)
- Remote controller (wireless kit) transmitting distance can be shorter than expected in rooms with electronic fluorescent lamps (inverter or rapid start types).
  Install the indoor unit as far away from fluorescent lamps as possible.
- Do not install the air conditioner in the following locations:
  1. Where there is a high concentration of mineral oil spray or vapour (e.g. a kitchen).
     Plastic parts will deteriorate, parts may fall off and water leakage could result.
  2. Where corrosive gas, such as sulphurous acid gas, is produced.
     Corroding of copper pipes or soldered parts may result in refrigerant leakage.
  3. Near machinery emitting electromagnetic radiation.
     Electromagnetic radiation may disturb the operation of the control system and result in a malfunction of the unit.
  4. Where flammable gas may leak, where there is carbon fibre or ignitable dust suspensions in the air, or where volatile flammables such as paint thinner or gasoline are handled.
     Operating the unit in such conditions may result in fire.

2. BEFORE INSTALLATION

Do not exert pressure on the resin parts when opening the unit or when moving it after opening
Be sure to check the type of R410A refrigerant to be used before doing any work. (Using an incorrect refrigerant will prevent normal operation of the unit.)

- When opening the unit or moving it after opening, be sure to lift it by holding on to the lifting lugs without exerting any pressure on other parts, especially, drain piping, and other resin parts.
- Decide upon a line of transport.
- Leave the unit inside its packaging while moving, until reaching the installation site. Use a sling of soft material, where unpacking is unavoidable or protective plates together with a rope when lifting, to avoid damage or scratches to the unit.
- Refer to the installation manual of the outdoor unit for items not described in this manual.
- Do not dispose of any parts necessary for installation until the installation is complete.


1. PRECAUTIONS

- Be sure to read this manual before installing the indoor unit.
- When selecting installation site, refer to the paper pattern.
- This unit is suitable for installation in a household, commercial and light industrial environment.
- Do not install or operate the unit in rooms mentioned below.
  - Laden with mineral oil, or filled with oil vapor or spray like in kitchens. (Plastic parts may deteriorate.)
  - Where corrosive gas like sulfurous gas exists. (Copper tubing and brazed spots may corrode.)
  - Where volatile flammable gas like thinner or gasoline is used.
  - Where machines can generate electromagnetic waves. (Control system may malfunction.)
  - Where the air contains high levels of salt such as that near the ocean and where voltage fluctuates greatly such as that in factories. Also in vehicles or vessels.

2. ACCESSORIES

Check the following accessories are included with your unit.

Name	(1) Drain hose	(2) Metal clamp	(3) Washer for hanger bracket	(4) Clamp	(5) Paper pattern for installation	(6) Screw (M4)
Quantity	1 pc.	1 pc.	8 pcs.	6 pcs.	1 pc.	4 pcs.
Shape					Also used as packing material 	For paper pattern for installation 

Name	(7) Washer fixing plate	Insulation for fitting	Sealing pad			Installation guide	
Quantity	4 pcs.	1 each	1 each	1 pc.	1 pc.	1 pc.	
Shape		(8) for gas pipe  (9) for liquid pipe 	(10) Large  (11) Medium-1  (12) Medium-2 	(13) Small 	(14) 	(15) 	(Other) • Installation manual • Operation manual

3. OPTIONAL ACCESSORIES

- The optional decoration panel and remote controller are required for this indoor unit. (Refer to Table 1, 2) (However, the remote controller is not required for the slave unit of a simultaneous operation system.)

Table 1

Unit model	Optional decoration panel
FXFQ25 · 32 · 40 · 50 · 63 · 80 · 100 · 125PVE	BYCP125K-W1
	Color : Fresh white

- These are two types of remote controllers: wired and wireless. Select a remote controller from Table 2 according to customer request and install in an appropriate place.

Table 2

Remote controller	
Wired type	BRC1C62
Wireless type (Heat pump type/Cooling only type)	BRC7F634F/BRC7F635F

NOTE

- If you wish to use a remote controller that is not listed in “Table 2” on page 4, select a suitable remote controller after consulting catalogs and technical materials.

FOR THE FOLLOWING ITEMS, TAKE SPECIAL CARE DURING CONSTRUCTION AND CHECK AFTER INSTALLATION IS FINISHED.

1. Items to be checked after completion of work

Items to be checked	If not properly done, what is likely to occur	Check
Are the indoor unit and outdoor unit fixed firmly?	The unit may drop, vibrate or make noise.	
Is the outdoor unit fully installed?	The unit may malfunction or the components burn out.	
Is the gas leak test finished?	It may result in insufficient cooling.	
Is the unit fully insulated?	Condensate water may drip.	
Does drainage flow smoothly?	Condensate water may drip.	
Does the power supply voltage correspond to that shown on the name plate?	The unit may malfunction or the components burn out.	
Are wiring and piping correct?	The unit may malfunction or the components burn out.	
Is the unit safely grounded?	It may result in electric shock.	
Is wiring size according to specifications?	The unit may malfunction or the components burn out.	
Is something blocking the air outlet or inlet of either the indoor or outdoor units?	It may result in insufficient cooling.	
Are refrigerant piping length and additional refrigerant charge noted down?	The refrigerant charge in the system is not clear.	

2. Items to be checked at time of delivery

* Also review the “1. SAFETY PRECAUTIONS”

Items to be checked	Check
Are the terminal box lid, air filter, suction grille attached?	
Did you explain about operations while showing the instruction manual to your customer?	
Did you hand the instruction manual over to your customer?	

3P161684-3B

Points for explanation about operations

The items with ⚠ WARNING and ⚠ CAUTION marks in the instruction manual are the items pertaining to possibilities for bodily injury and material damage in addition to the general usage of the product. Accordingly, it is necessary that you make a full explanation about the described contents and also ask your customers to read the instruction manual.

4. NOTE TO THE INSTALLER

Be sure to instruct customers how to properly operate the unit (especially cleaning filters, operating different functions, and adjusting the temperature) by having them carry out operations themselves while looking at the manual.

3. SELECTING INSTALLATION SITE

〈Hold the unit by the 4 lifting lugs when opening the box and moving it, and do not exert pressure on to any other part piping (refrigerant, drain, etc.) or plastic parts.
If the temperature or humidity inside the ceiling might rise above 30˚C or RH 80%, respectively, use the high-humidity kit (sold separately) or add extra insulation to the main unit body.
Use glass wool or polyethylene foam as insulation and make sure it is at least 10mm thick and fits inside the ceiling opening.〉

The direction this product blows can be selected. However, a separately sold shut-off material kit is needed in order to make the unit blow in two, three, or four (corner shut-off) directions.

(1) Select an installation location with the customer's approval which matches the following conditions.
- A location from which cool (warm) air will reach the whole room.
- A location with no objects blocking the air passage.
- A location where drainage can be done with no problem.
- A location strong enough to support the weight of the indoor unit.
- Locations where the wall is not significantly tilted.
- A location which leaves enough room for installation and service work.
- A location where there is no risk of flammable gas leaking.
- A location where the length of the indoor-outdoor piping is no longer than the tolerated length (see the installation manual that came with the outdoor unit for details).

[Space required for installation]




Fig. 1




Fig. 2

Model	H (mm)
FXFQ25 · 32 · 40 · 50 · 63 · 80PVE	256
FXFQ100 · 125PVE	298

3P161684-3B

2

⚠ CAUTION

- The indoor and outdoor units and the power supply wiring and remote controller cord must be installed at least 1m away from any televisions or radios. This is to prevent interference with picture and sound reception. (Interference may occur even at 1m away depending on the reception quality.)
- If installing the wireless kit, the distance of the signal sent from the remote controller might be shorter if there are fluorescent lights which are electrically started (such as with inverters, rapid starters, etc.) in the room. The indoor unit should be installed as far away from fluorescent lights as possible.

(2) Ceiling height
This product can be installed in ceilings up to 3.5m high (4.2m high for the 100 and 125).
If the ceiling height is 2.7m (3.2m for the 100 and 125) or more, field settings will have to be made with the remote controller. See “11. FIELD SETTING” for details.

(3) Air direction
The air direction shown in Fig. 3 is an example.
Select the appropriate number of directions according to the shape of the room and the location of the unit. (Field settings have to be made using the remote controller and the outlet vents have to be shut off if two, three, or four (corner shut-off) directions are selected. See the shut-off materials (sold separately) installation manual for details.)

(4) Use eyebolts for installation. Check if the location for the installation is strong enough to support the weight of the unit, reinforce it if necessary, and install using eyebolts. (The spacing of the installation is shown on the “paper pattern for installation (5)”.)




Fig. 3

4. PREPARATIONS BEFORE INSTALLATION

(1) Relation of ceiling opening to unit and suspension bolt position.




Fig. 4




Fig. 5

■ **Installation is possible when ceiling opening dimensions is as follows**

• When installing the unit within the frame for fixing false ceiling.




Fig. 6




Fig. 7

NOTE

• Installation is possible with a ceiling dimension of 910mm (marked with *). However, to achieve a ceiling-panel overlapping dimension of 20mm, the spacing between the ceiling and the unit should be 35mm or less. If the spacing between ceiling and the unit is over 35mm, attach ceiling material to ■ part or recover the ceiling.




Fig. 8

(2) Make the ceiling opening needed for installation where applicable. (For existing ceilings)

- Refer to the paper pattern for installation (5) for ceiling opening dimensions.
- Create the ceiling opening required for installation. From the side of the opening to the casing outlet, implement the refrigerant and drain piping and wiring for remote controller (unnecessary for wireless type) and indoor-outdoor unit casing outlet. Refer to “6. REFRIGERANT PIPING WORK”, “7. DRAIN PIPING WORK” and “8. ELECTRIC WIRING WORK”.
- After making an opening in the ceiling, it may be necessary to reinforce ceiling beams to keep the ceiling level and to prevent it from vibrating. Consult the builder for details.

(3) Install the suspension bolts.

(Use either a M8~M10 size bolt)
Use a hole-in anchor for existing ceilings, and a sunken insert, sunken anchor or other field supplied parts for new ceilings to reinforce the ceiling to bear the weight of the unit.
Adjust clearance (50 – 100mm) from the ceiling before proceeding further.

<installation example>




Fig. 9

NOTE

- All the above parts are field supplied.

5. INDOOR UNIT INSTALLATION


Installing optional accessories (except for the decoration panel) before installing the indoor unit is easier. However, for existing ceilings, install fresh air inlet component kit and branch duct before installing the unit.

As for the parts to be used for installation work, be sure to use the provided accessories and specified parts designated by our company.

(1) For new ceilings


(1-1)Install the indoor unit temporarily.

- Attach the hanger bracket to the suspension bolt. Be sure to fix it securely by using a nut and washer (3) from the upper and lower sides of the hanger bracket.
  The washer fixing plate (7) will prevent the washer from falling.



[Securing the hanger bracket]

Fig. 10



[Securing the washer]

Fig. 11

(1-2) Refer to the paper pattern for installation (5) for ceiling opening dimension.
Consult the builder or carpenter for details.

- The center of the ceiling opening is indicated on the paper pattern for installation.
  The center of the unit is indicated on the triangular mark to the unit bottom and on the paper pattern for installation.
- Fix the paper pattern to the unit with screws (6) (×4).
- Ceiling height is shown on the side of the paper pattern for installation (5). Adjust the height of the unit according to this indication.

Please perform one of the following, as the shape of the paper pattern for installation differs according to the model.





Fig. 12

[Installation of paper pattern for installation]

<Ceiling work>


(1-3) Adjust the unit to the right position for installation.
(Refer to **"4. PREPARATIONS BEFORE INSTALLATION-(1)"**.)
- Using the Installation guide (15) allows you to check the positions from the underside of the unit to the lower ceiling surface.



(1-4) Check the unit is horizontally level.
- The indoor unit is equipped with a built-in drain pump and float switch. Verify that it is level by using a level or a water-filled vinyl tube.

⚠ CAUTION

If the unit is tilted against condensate flow, the float switch may malfunction and cause water to drip.



[Maintaining horizontality]

Fig. 13

(1-5) Remove the washer fixing plate (7) used for preventing the washer from falling and tighten the upper nut.

(1-6) Remove the paper pattern for installation (5).

(2) For existing ceilings

(2-1) Install the indoor unit temporarily.
Perform step (1-1) in (1) For new ceilings.

(2-2) Adjust the height and position of the unit.
(Refer to "**4. PREPARATIONS BEFORE INSTALLATION-(1)"** and (1-3) in (1) For new ceilings.)

(2-3) Perform steps (1-4), (1-5) in (1) For new ceilings.

6. REFRIGERANT PIPING WORK

〈**For refrigerant piping of outdoor units, see the installation manual attached to the outdoor unit.**〉
〈Execute heat insulation work completely on both sides of the gas piping and the liquid piping. Otherwise, a water leakage can result sometimes.〉
(When using a heat pump, the temperature of the gas piping can reach up to approximately 120˚C, so use insulation which is sufficiently resistant.)
〈Also, in cases where the temperature and humidity of the refrigerant piping sections might exceed 30˚C or RH80%, reinforce the refrigerant insulation. (20mm or thicker) Condensate may form on the surface of the insulating material.〉
〈Be sure to check the type of R410A refrigerant to be used before doing any work. (Using an incorrect refrigerant will prevent normal operation of the unit.)〉

⚠ CAUTION

- Use a pipe cutter and flare suitable for the type of refrigerant.
- Apply ester oil or ether oil around the flare section before connecting.
- To prevent dust, moisture or other foreign matter from infiltrating the tube, either pinch the end or cover it with tape.
- Do not allow anything other than the designated refrigerant to get mixed into the refrigerant circuit, such as air, etc. If any refrigerant gas leaks while working on the unit, ventilate the room thoroughly right away.

- **Do not mix air or other gas with the specified refrigerant in the refrigeration cycle.**
- **Ventilate the room if refrigerant gas leaks during the work.**
- The outdoor unit is charged with refrigerant.
- Be sure to use both a spanner and torque wrench together, as shown in the drawing, when connecting or disconnecting pipes to/from the unit. **(Refer to Fig. 14)**
- Refer to “Table 3” for the dimensions of flare nut spaces.




Fig. 14

- When connecting the flare nut, apply ether oil or ester oil only to inner side of the flare, and spin 3-4 times before screwing in. **(Refer to Fig. 15)**
- **Keep all the screw mounting resin parts (e.g., piping presser plates) away from oil.**
  If oil adheres, the strength of the screw mounting resin parts may drop.




Fig. 15


⚠ CAUTION

Over-tightening the flare nut may break it and/or cause the refrigerant to leak.

NOTE

- Use the flare nut included with the unit main body.

Table 3

Pipe size	Tightening torque	Flare dimensions A (mm)	Flare
ϕ 6.4 (1/4”)	14.2 – 17.2N·m (144 – 176 kgf·cm)	8.7 – 9.1	
ϕ 9.5 (3/8”)	32.7 – 39.9N·m (333 – 407 kgf·cm)	12.8 – 13.2	
ϕ 12.7 (1/2”)	49.5 – 60.3N·m (504 – 616 kgf·cm)	16.2 – 16.6	
ϕ 15.9 (5/8”)	61.8 – 75.4N·m (630 – 770 kgf·cm)	19.3 – 19.7	

- Refer to “Table 3” to determine the proper tightening torque.

C : 3P161684-3B

Not recommendable but in case of emergency

You must use a torque wrench but if you are obliged to install the unit without a torque wrench, you may follow the installation method mentioned below.

When you keep on tightening the flare nut with a spanner, there is a point where the tightening torque suddenly increases. From that position, further tighten the flare nut the angle shown below:

Pipe size	Further tightening angle	Recommended arm length of tool
ϕ 6.4 (1/4")	60 to 90 degrees	Approx. 150mm
ϕ 9.5 (3/8")	60 to 90 degrees	Approx. 200mm
ϕ 12.7 (1/2")	30 to 60 degrees	Approx. 250mm
ϕ 15.9 (5/8")	30 to 60 degrees	Approx. 300mm

After the work is finished, make sure to check that there is no gas leak.

- Make absolutely sure to execute heat insulation works on the pipe-connecting section after checking gas leakage by thoroughly studying the following figure and using the attached heat insulating materials for fitting (8) and (9). (Fasten both ends with the clamps (4).) **(Refer to Fig. 16)**
- Wrap the sealing pad (11) only around the insulation for the joints on the gas piping side. **(Refer to Fig. 16)**




Fig. 16

CAUTION

For local insulation, be sure to insulate local piping all the way into the pipe connections inside the machine. Exposed piping may cause condensation or burns on contact.

CAUTION

CAUTION TO BE TAKEN WHEN BRAZING REFRIGERANT PIPING

"Do not use flux when brazing refrigerant piping. Therefore, use the phosphor copper brazing filler metal (BCuP-2: JIS Z 3264/B-Cu93P-710/795: ISO 3677) which does not require flux."

(Flux has extremely harmful influence on refrigerant piping systems. For instance, if the chlorine based flux is used, it will cause pipe corrosion or, in particular, if the flux contains fluorine, it will damage the refrigerant oil.)

- Before brazing local refrigerant piping, nitrogen gas shall be blown through the piping to expel air from the piping. If you brazing is done without nitrogen gas blowing, a large amount of oxide film develops inside the piping, and could cause system malfunction.
- When brazing the refrigerant piping, only begin brazing after having carried out nitrogen substitution or while inserting nitrogen into the refrigerant piping. Once this is done, connect the indoor unit with a flared or a flanged connection.
- Nitrogen should be set to 0.02MPa with a pressure-reducing valve if brazing while inserting nitrogen into the piping. **(Refer to Fig. 17)**




Fig. 17

7. DRAIN PIPING WORK

(1) Rig drain piping

- As for drain work, perform piping in such a manner that water can be drained properly.
- Employ a pipe with either the same diameter or with the diameter larger (excluding the raising section) than that of the connecting pipe (PVC pipe, nominal diameter 25mm, outside diameter 32mm).
- Keep the drain pipe short and sloping downwards at a gradient of at least 1/100 to prevent air pockets from forming.
- If the drain pipe cannot be sufficiently set on a slope, execute the drain raising piping.
- To keep the drain pipe from sagging, space hanging wires every 1 to 1.5m.




Fig. 18-1




Fig. 18-2

⚠ CAUTION

Water pooling in the drainage piping can cause the drain to clog.

- Use the attached drain hose (1) and Metal clamp (2).
- Insert the drain hose into the drain socket up to the base, and tighten the Metal clamp securely within the portion of a white tape of the hose-inserted tip. Tighten the Metal clamp until the screw head is less than 4mm from the hose.
- Wrap the attached sealing pad (10) over the Metal clamp and drain hose to insulate.
- Make sure that heat insulation work is executed on the following 2 spots to prevent any possible water leakage due to dew condensation.
  - Indoor drain pipe
  - Drain socket




Fig. 19




Fig. 20

<PRECAUTIONS FOR DRAIN RAISING PIPING>

- Install the drain raising pipes at a height of less than 675mm.
  The drain pump of this unit has a high delivery flow rate. Therefore, the higher the drain raising height is, the lower the sound of draining will be. For this reason, a minimum drain raising height of 300mm is recommended.
- Install the drain raising pipes at a right angle to the indoor unit and no more than 300mm from the unit.





Fig. 21

NOTE

- To ensure no excessive pressure is applied to the included drain hose (1), do not bend or twist when installing. (This may cause leakage.)
- If converging multiple drain pipes, install according to the procedure shown below.



Central drain pipe

The drain pipe should have a downward slope of at least 1/100 to prevent air pockets from forming.

Water accumulating in the drain piping can cause the drain to clog.


Fig. 22

Select converging drain pipes whose gauge is suitable for the operating capacity of the unit.

(2) After piping work is finished, check if drainage flows smoothly.

WHEN ELECTRIC WIRING WORK IS FINISHED

- Add approximately 1000cc of water slowly from the air outlet and check drainage flow.
- Check drainage flow during COOL running, explained under “12. TEST OPERATION”.
- Refer to the figure on the following after checking the draining of water, and mount the thermal insulation material for drainage (14) and thermal insulate the drain socket.



WHEN ELECTRIC WIRING WORK IS NOT FINISHED


⚠ CAUTION

- Electrical wiring work should be done by a certified electrician.
- If someone who does not have the proper qualifications performs the work, perform the following after the test run is complete.

3P161684-3B

2

- Remove the terminal box lid. Connect the single phase power supply (SINGLE PHASE 50Hz 240V) to connections No.1 and No.2 on the terminal block for wiring the units. Do not connect to No.3 of the terminal block for wiring the units. (The drain pump will not operate.) Connect the ground wire firmly. When carrying out wiring work around the terminal box, make sure none of the connectors come undone. Be sure to attach the terminal box lid before turning on the power.
- Put approximately 1000cc of water into the drain pan through the blow-off mouth on the left-hand side of the drain socket. Make sure not to pour water over the drain pump or any electric parts including those of the drain pump.
- When the power is turned on, the drain pump will operate and you can check the draining of water through the transparent part of the drain socket. (The drain pump will stop automatically in 10 minutes.)
  After checking the draining of water, mount the thermal insulation material for drainage (14) and thermal insulate the drain socket.
- After confirming drainage **(Fig.23, Fig.24)**, turn off the power and remove the power supply.
- Attach the terminal box lid as before.



<Adding water through air discharge outlet>
[Method of adding water]

Fig. 23




Fig. 24

⚠ CAUTION

Drain piping connections
Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain pipes and corrode the heat exchanger.

8. ELECTRIC WIRING WORK

8-1 General instructions

- All field supplied parts and materials and electric works must conform to local codes.
- Use copper wire only.
- For electric wiring work, refer to also “WIRING DIAGRAM” attached to the unit body.
- For remote controller wiring details, refer to the installation manual attached to the remote controller.
- All wiring must be performed by an authorized electrician.
- A circuit breaker capable of shutting down power supply to the entire system must be installed.
- Refer to the installation manual attached to the outdoor unit for the size of power supply electric wire connected to the outdoor unit, the capacity of the circuit breaker and switch, and wiring instructions.
- Be sure to ground the air conditioner.
- Do not connect the ground wire to gas pipes, plumbing pipes, lightning rods, or telephone ground wires.
  - Gas pipes: might cause explosions or fire if gas leaks.
  - Plumbing: no grounding effect if hard vinyl piping is used.
  - Telephone ground wires or lightning rods: might cause abnormally high electric potential in the ground during lighting storms.

8-2 Electrical characteristics

Units				Power supply		Fan motor	
Model	Hz	Volts	Voltage range	MCA	MFA	kW	FLA
FXFQ25PVE	50	220-240	Max. 264 Min. 198	0.3	15	0.056	0.2
FXFQ32PVE				0.3	15	0.056	0.2
FXFQ40PVE				0.3	15	0.056	0.2
FXFQ50PVE				0.3	15	0.056	0.2
FXFQ63PVE				0.4	15	0.056	0.3
FXFQ80PVE				0.5	15	0.056	0.4
FXFQ100PVE				1.3	15	0.120	1.0
FXFQ125PVE				1.5	15	0.120	1.2
FXFQ25PVE	60	220	Max. 242 Min. 198	0.3	15	0.056	0.2
FXFQ32PVE				0.3	15	0.056	0.2
FXFQ40PVE				0.3	15	0.056	0.2
FXFQ50PVE				0.3	15	0.056	0.2
FXFQ63PVE				0.4	15	0.056	0.3
FXFQ80PVE				0.5	15	0.056	0.4
FXFQ100PVE				1.3	15	0.120	1.0
FXFQ125PVE				1.5	15	0.120	1.2

MCA: Min. Circuit Amps (A) MFA: Max. Fuse Amps (A)
kW: Fan Motor Rated Output (kW) FLA: Full Load Amps (A)

8-3 Specifications for field supplied fuses and wire

Model	Power supply wiring			Remote controller wiring Transmission wiring	
	Field fuses	Wire	Size	Wire	Size
FXFQ25·32·40·50PVE	15A	H05VV-U3G	Wire size must comply with local codes.	Sheathed wire (2 wire)	0.75 - 1.25 mm^2
FXFQ63PVE					
FXFQ80·100PVE					
FXFQ125PVE					

Allowable length of transmission wirings and remote controller wiring are as follows.
(1) Outdoor unit - Indoor unit:
Max. 1000m (Total wiring length: 2000m)
(2) Indoor unit - Remote controller
Max. 500m

NOTE
1. Shows only in case of protected pipes. Use H07RN-F in case of no protection.
2. Vinyl cord with sheath or cable (Insulated thickness : 1mm or more)

9. WIRING EXAMPLE AND HOW TO SET THE REMOTE CONTROLLER

9-1 How to connect wirings

Connection of wiring between units, ground wire and for the remote controller cord (Refer to Fig. 25)

- Wiring the units and ground wire
  Remove the terminal box lid and connect wires of matching number to the terminal block for wiring the units (3 P) inside. And connect the ground wire to the ground terminal. In doing this, pull the wires inside through the hole and fix the wires securely with the included clamp (4) (2 points).
- Remote controller cords (not neccessary for slave unit of simultaneous operation system)
  Remove the terminal box lid and pull the wires inside through the hole and connect to the terminal block for remote controller (6 P). (no polarity) Securely fix the remote controller cord with the included clamp (4) (2 points).
- After connection, attach sealing pad (13).
- Be sure to attach it to prevent the infiltration of water from the outside.

[PRECAUTIONS]

1. Use round crimp-style terminals for connecting wires to the power supply terminal block.
If unavailable, observe the following points when wiring.
  - Do not connect wires of different gauge to the same power supply terminal.
    (Looseness in the connection may cause overheating.)
  - Use the specified electric wire. Connect the wire securely to the terminal. Lock the wire down without applying excessive force to the terminal. (Tightening torque: 131N·cm ±10 %)




Fig. 25

2. **Tightening torque for the terminal screws.**
   - Use the correct screwdriver for tightening the terminal screws. If the blade of screwdriver is too small, the head of the screw might be damaged, and the screw will not be properly tightened.
   - If the terminal screws are tightened too hard, screws might be damaged.
   - Refer to the table below for the tightening torque of the terminal screws.

Terminal	Size	Tightening torque
Terminal block for remote controller (6P)	M3.5	0.79 – 0.97N·m
Power supply terminal block (3P)	M4	1.18 – 1.44N·m
Ground terminal	M4	1.44 – 1.94N·m

When none are available, follow the instructions below.

3. Do not connect wires of different gauge to the same grounding terminal.




Fig. 26

Looseness in the connection may deteriorate protection.

4. Outside of the unit, keep transmission wiring at least 50mm away from power supply wiring. The equipment may malfunction if subjected to electrical (external) noise.
5. For remote controller wiring, refer to the “INSTALLATION MANUAL OF REMOTE CONTROLLER.” attached to the remote controller.
6. **Never connect power supply wiring to the terminal block for remote controller. A mistake of the sort could damage the entire system.**
7. Use only specified wire and tightly connect wires to terminals. Be careful wires do not place external stress on terminals. Keep wiring in neat order and so as not to obstruct other equipment such as popping open the terminal box lid. Make sure the lid closes tight. Incomplete connections could result in overheating, and in worse case, electric shock or fire.





Fig. 27

Observe the notes mentioned below when wiring to the terminal block for wiring the units.

⚠ CAUTION

- When clamping wiring, use the included clamping material to prevent outside pressure being exerted on the wiring connections and clamp firmly. When doing the wiring, make sure the wiring is neat and does not cause the terminal box lid to stick up, then close the cover firmly.
- When attaching the terminal box lid, make sure you do not pinch any wires.
- After all the wiring connections are done, fill in any gaps in the through holes with putty or insulation (procured locally) to prevent small animals and insects from entering the unit from outside. (If any do get in, they could cause short circuits in the terminal box.)
- Outside the machine, separate the weak wiring (remote controller cord) and strong wiring (interunit, ground, and other power wiring) at least 50 mm so that they do not pass through the same place together. Proximity may cause electrical interference, malfunctions, and breakage.

Processing method of wiring through-holes



9-2 Wiring example

- Fit the power supply wiring of each unit with a switch and fuse as shown in the drawing.

COMPLETE SYSTEM EXAMPLE (3 systems)




Fig. 28

1. When using 1 remote controller for 1 indoor unit. (Normal operation)




Fig. 29

3P161684-3B

2. For group control or use with 2 remote controllers




Fig. 30

3. When including BS unit




Fig. 31

[PRECAUTIONS]

1. A single switch can be used to supply power to units on the same system. However, branch switches and branch circuit breakers must be selected carefully.
2. Do not ground the equipment on gas pipes, water pipes or lightning rods, or crossground with telephones. Improper grounding could result in electric shock.

9-3 Control by 2 remote controllers (controlling 1 indoor unit by 2 remote controllers)

• When using 2 remote controllers, one must be set to “MAIN” and the other to “SUB”.

MAIN/SUB CHANGEOVER

(1) Insert a ⊖ screw driver into the recess between the upper and lower part of remote controller and, working from the 2 positions, pry off the upper part. (The remote controller PC board is attached to the upper part of remote controller.) **(Refer to Fig. 32)**

(2) Turn the **main/sub changeover** switch on one of the two remote controller PC boards to “S”. (Leave the switch of the other remote controller set to “M”.) **(Refer to Fig. 33)**




Fig. 32




Fig. 33

Wiring Method (See “ELECTRIC WIRING WORK”)


(3) Remove the terminal box lid

(4) Add remote control 2 (slave) to the terminal block for remote controller (P1, P2) in the terminal box. (There is no polarity.) (Refer to Fig. 30 and 8-3.)

9-4 Computerised control (forced off and on/off operation)

(1) Wire specifications and how to perform wiring

• Connect the input from outside to terminals T1 and T2 of the terminal block for remote controller.



Wire specification	Sheathed vinyl cord or cable (2 wire)
Gauge	0.75 - 1.25 mm^2
Length	Max. 100 m
External terminal	Contact that can ensure the minimum applicable load of 15 V DC, 10 mA.

(2) Actuation
- The following table explains FORCED OFF and ON/OFF OPERATIONS in response to Input A.

FORCED OFF	ON/OFF OPERATION
Input "ON" stops operation (impossible by remote controllers.)	Input OFF → ON turns ON unit.
Input OFF enables control by remote controller.	Input ON → OFF turns OFF unit.

(3) How to select FORCED OFF and ON/OFF OPERATION
- Turn the power on and then use the remote controller to select operation.

9-5 Centralized control
- For centralized control, it is necessary to designate the group No. For details, refer to the manual of each optional controllers for centralized control.

10. INSTALLATION OF THE DECORATION PANEL

Caution:
With a wireless remote controller, field setting and test operation cannot be performed without attaching the decoration panel.
<If performing a test run without attaching the decoration panel, read "11. FIELD SETTING" and "12. TEST OPERATION" first.>
Refer to the installation manual attached to the decoration panel.
After installing the decoration panel, ensure that there is no space between the unit body and decoration panel.

11. FIELD SETTING

⚠ CAUTION

When performing field setting or test operation without attaching the decoration panel, do not touch the drain pump. This may cause electric shock.

- Check that the outdoor unit has been wired properly.

Make sure the terminal box lids are closed on the indoor and outdoor units.
Field setting must be made from the remote controller and in accordance with installation conditions.
- Setting can be made by changing the "Mode No.", "FIRST CODE NO." and "SECOND CODE NO.".
- For setting procedures and instructions, see "Field settings" provided with the remote controller.

11-1 Setting ceiling height
- Select the SECOND CODE NO. that corresponds to the ceiling height "Table 4". (SECOND CODE NO. is factory set to "01".)

Table 4

		FXFQ - PVE		Mode No. Note) 1	FIRST CODE NO.	SECOND CODE NO.
		25 · 32 · 40 · 50 · 63 · 80 type	100 · 125 type			
Ceiling height (m)	Standard · All round outlet	≤ 2.7	≤ 3.2	13 (23)	0	01
	High ceiling 1	2.7 - 3	3.2 - 3.6			02
	High ceiling 2	3 - 3.5	3.6 - 4.2			03

Note:
1. "Mode No." setting is done in a batch for the group. To make or confirm settings for an individual unit, set the internal mode number in parentheses.
2. The figure of the ceiling height is for the all round outlet. For the settings for four-direction (part of corner closed off), three-direction and two-direction outlets, see the installation manual and technical guide supplied with the separately sold closure material kit.

3P161684-3B

11-2 Setting of air direction

- See the installation manual included with the sealing material of air discharge outlet kit, sold separately and technical guide, for ceiling height settings for two and three-direction air discharge. (The SECOND CODE NO. is factory set to “01” (all round outlet) before shipping.)

11-3 Settings for Mounting Options

- When installing an option sold separately, refer to the installation manual provided to the option.

11-4 Setting air filter sign

- Remote controllers are equipped with liquid crystal display air filter signs to display the time to clean air filters.
- Change the SECOND CODE NO. according to “Table 5” depending on the amount of dirt or dust in the room.
  (SECOND CODE NO. is factory set to “01” for filter contamination-light.)

Table 5


Setting	Spacing time of display air filter sign (long life type)	Mode No.	FIRST CODE NO.	SECOND CODE NO.
Air filter contamination-light	Approx. 2500 hrs	10 (20)	0	01
Air filter contamination-heavy	Approx. 1250 hrs			02
No Display			3	

Note:
1. “Mode No.” setting is done in a batch for the group. To make or confirm settings for an individual unit, set the internal mode number in parentheses.
2. Make settings for “No Display” in cases where no cleaning display is required, e.g., at the time of regular maintenance servicing.

- The air conditioner is provided with a long life filter as a standard accessory. Explain to the customer the necessity of cleaning the filter periodically along with the set time for filter cleaning for the prevention of clogging.

When using wireless remote controllers

- When using wireless remote controllers, wireless remote controller address setting is necessary. Refer to the installation manual attached to the wireless remote controller for setting instructions.



- Set the remote controller to the field set mode. For details, refer to the “HOW TO SET IN THE FIELD”, in the remote controller manual.
- When in the field set mode, select mode No. 12, then set the first code (switch) No. to “1”. Then set second code (position) No. to “01” for FORCED OFF and “02” for ON/OFF OPERATION. (FORCED OFF at factory set)

12. TEST OPERATION

Refer to the installation manual of the outdoor unit.

- The operation lamp of the remote controller will flash when an malfunction occurs. Check the malfunction code on the liquid crystal display to identify the point of trouble. An explanation of malfunction codes and the corresponding trouble is provided in “CAUTION FOR SERVICING” of the indoor unit.
  If any of the items in Table 6 are displayed, there may be a problem with the wiring or power, so check the wiring again.

Table 6

Remote control display	Content
“Concentrated Management” is lit up	• There is a short circuit at the FORCED OFF terminals (T1, T2).
“U4” is lit up “UH” is lit up	• The power on the outdoor unit is off. • The outdoor unit has not been wired for power supply. • Incorrect wiring for the transmission wiring and / or FORCED OFF wiring.
No display	• The power on the indoor unit is off. • The indoor unit has not been wired for power supply. • Incorrect wiring for the remote controller wiring, the transmission wiring, and / or the FORCED OFF wiring.

- If the decoration panel is installed on the indoor unit during the test run, check the operation of the swing flap on the panel.
- In order to protect the indoor unit, instruct the customer not to operate the air conditioner until the interior work is completed if the interior work has not been finished at the end of the test run.
  (If the air conditioner is operated, substances discharged from the paint, adhesive, etc. can contaminate the indoor unit, and they may cause splashing or leakage of water.)

NOTE


- After the test run is finished, check the items listed in “**2. Items to be checked at time of delivery**”.

11. Accessories

Standard Accessories

FXFQ25~125P

Name	(1) Drain hose	(2) Metal clamp	(3) Washer for hanger bracket	(4) Clamp	(5) Paper pattern for installation	(6) Screw (M4)
Quantity	1 pc.	1 pc.	8 pcs.	6 pcs.	1 pc.	4 pcs.
Shape					Also used as packing material 	For paper pattern for installation 

Name	(7) Washer fixing plate	Insulation for fitting	Sealing pad			Installation guide	
Quantity	4 pcs.	1 each	1 each	1 pc.	1 pc.	1 pc.	
Shape		(8) for gas pipe  (9) for liquid pipe 	(10) Large  (11) Medium-1  (12) Medium-2 	(13) Small 	(14) 	(15) 	(Other) • Installation manual • Operation manual

3P161684-3B

Optional Accessories (For Unit)

Item			Model FXFQ25PVE	FXFQ32PVE	FXFQ40PVE	FXFQ50PVE	FXFQ63PVE	FXFQ80PVE	FXFQ100PVE	FXFQ125PVE
Decoration panel			BYCP125K-W1							
Sealing member of air discharge outlet			KDBH55K160F							
Panel spacer			KDBP55H160FA							
Filter related	High efficiency filter unit	65%	KAFP556H80						KAFP556H160	
		90%	KAFP557H80						KAFP557H160	
	Replacement high efficiency filter	65%	KAFP552H80						KAFP552H160	
		90%	KAFP553H80						KAFP553H160	
	Filter chamber		KDDFP55H160							
	Replacement long life filter	Non-woven type	KAFP551K160							
	Ultra long-life filter		KAFP55H160							
	Replacement ultra long life filter		KAFP55H160H							
Fresh air intake kit	Chamber type	Without T-joint pipe and fan	KDDP55K160							
		With T-joint pipe without fan	KDDP55K160K							
	Direct installation type		KDDP55X160							
Branch duct chamber			KDJP55H80						KDJP55H160	
Chamber connection kit			KKSJ55K160							
Insulation kit for high humidity			KDTP55K80						KDTP55K160	

C:3D060297

Optional Accessories (For Controls) : Refer to P.807

BYCP125K-W1 — Decoration Panel

1. BEFORE INSTALLATION

1. PRECAUTIONS
- Refer also to the installation manual attached to the indoor unit.

2. ACCESSORIES
- Installation manual.

3. NOTE TO INSTALLER
- Be sure to instruct the customer how to properly operate the system showing him/her the attached operation manual.

2. PREPARATION OF DECORATION PANEL

<<For this unit, you are able to select air flow directions. To discharge air in 2 or 3 directions, it is necessary to purchase optional blocking pad kit.>>

HANDLING OF DECORATION PANELS
- Never place the panel facing down nor lean it against a wall nor leave it on a projecting object.
- Never touch or put pressure on the swing flap.
  (The swing flap may malfunction)

(1) Remove the suction grille from the decoration panel.

1 Press the lever on the suction grille and lift the lever side. **(Refer to Fig. 1)**

2 Detach the suction grille from the decoration panel by lifting the grille up approximately 45 degrees. **(Refer to Fig. 2)**

3 Remove the transporting cardboard (in 4 locations) from the main unit. **(Refer to Fig. 3)**

4 Remove the transporting tape (in 4 locations) on the back of the suction grille. **(Refer to Fig. 4)**




Fig. 1




Fig. 2

(2) Remove the corner section decoration cover.
- Lift the four corner decoration covers in the direction of the arrow and remove. **(Refer to Fig. 5)**





Fig. 3



Rear side of the suction grille

Fig. 4




Fig. 5

3. INSTALLATION OF THE DECORATION PANEL TO THE INDOOR UNIT BODY

<<Refer to the installation manual attached to the indoor unit for the installation of the indoor unit.>>

(1) Match the “PIPING SIDE” and “DRAIN SIDE” displays on the decoration panel with the position of the piping section and drain section on the indoor unit.

(2) Install the decoration panel

1 Temporarily install the decoration panel to the indoor unit by hanging the temporary latch of the decoration panel to the hook of the indoor unit body. (2 locations)

2 Hook the four mounting brackets on the corner sections of the decoration panels onto the hooks around the main indoor unit body.
(Make sure at this time that the swing motor lead wire does not get caught between the decoration panel and the main unit.)

3 Screw all 4 hexagon head screws located right beneath the latches in approximately 5 mm. (Panel will rise)

4 Adjust the decoration panel by turning it to the arrowed direction in Fig. 6 so that the ceiling opening is completely covered.





Fig. 6

5 Tighten the screws until the thickness of the sealing material between the decoration panel and the indoor unit body reduces to 5-8 mm.



2

[PRECAUTIONS]

- Inproper screwing of the screws may cause the troubles shown in Fig. 7 Screw properly.




Fig. 7

- If gap is still left between the ceiling and the decoration panel after screwing the screws, readjust the indoor unit body height. **(Refer to Fig. 8)**





Fig. 8

Adjustment of the indoor unit body height from the holes in the corner of the decoration panel is possible if the indoor unit is kept leveled and the drain piping, etc. is unaffected.




(3) Wiring of the decoration panel **(Refer to Fig. 9)**

6 Remove the electric components box lid.

7 Connect the connectors for swing flap motor lead wire installed on the decoration panel.

8 Replace the electric components box lid reversing the procedure to remove it.

Make sure that the swing flap motor lead wire is not caught between the electric components box and its lid, and between the indoor unit body and the decoration panel.




<Wiring Diagram>
(The orientation of the indoor unit is changed for purposes of description.)

Loosen the two screws, slide the cover in the direction of the arrows, and disengage from the hooks.

Fig. 9

4. INSTALLATION OF SUCTION GRILLE AND SERVICE COVER

(1) Install the suction grille
Install by reversing the procedure shown in “PREPARATION OF DECORATION PANEL”.
It is possible to install the suction grille in 4 directions by turning the suction grille.
Change the direction when adjusting the direction of the suction grille of multiple units or in meeting customers’ demands.



NOTE :
Be careful not to get swing flap motor lead wire get caught when installing the suction grille.

2

(2) Install the corner section decoration cover.

1 Attach the string of the corner section decoration cover to the pin of the decoration panel. **(Refer to Fig. 10)**

2 Install the corner section decoration cover over the decoration panel. **(Refer to Fig. 11)**





Fig. 10



Attach by inserting the five tabs on the corner section decoration cover into the holes on the decoration panel.

Fig. 11

C : 3PA64319-13Q

KDBH55K160(F) — Sealing Material of Air Discharge Outlet


KDBH55K160



Dimensions

Unit:mm


Sealing materials for long air outlets (Polyethylene foam t10): 2 pieces




Sealing materials for horizontal blades (Polyethylene foam t10): 8 pieces




Sealing materials for air outlets at the corner (Polyethylene foam t10): 1 piece for each



Tape for sealing materials for long air outlets (Non-woven fabric t0.6): 2




Tape for sealing materials for air outlets at the corner (Non-woven fabric t0.6): 3




Tape for sealing materials for air outlets at the corner (Non-woven fabric t0.6): 1



Side insulation plate (NB foam t10) : 2




Antisweat material (Flocking tape): See right



Applicable part number	Q'ty and colour
KDBH55K160F	4, grey
KDBH55K160	4 for each, Dark grey or black

Antisweat material (Flocking tape): See right




Applicable part number	Q'ty and colour
KDBH55K160F	4, grey
KDBH55K160	4 for each, Dark grey or black

1 Blow Direction Selection and Sealing Material Mounting


(1) Blow direction selection

- Depending on the installation location, select a blow direction from the table below. For the setting position number, refer to 4 Field Setting.
  For the selection of installation location, refer to the installation manual attached to the indoor unit's main body.

Precautions Blow direction patterns other than those shown in the figure below cannot be selected. (Condensation may occur.)




(2) Matching with the corner air outlets Ⓐ to Ⓓ that are to be blocked, stick the sealing material to the tape for fixing the sealing material.
(Stick the sealing material so that the sealing material comes to the positions shown in the schematic diagram.)



- With air outlets Ⓑ to Ⓓ, using the same procedure, stick the sealing material to the tape for fixing the sealing material as shown in the figure.

(3) Stick the sealing material that was prepared in (2) to the air outlet of indoor unit main body.




Precautions

- The sealing material has a directional property. Be sure to stick the sealing material to the tape for fixing the sealing material so that the printed number of outlet to be blocked becomes visible.
- When blocking both the air outlet 1 and air outlet Ⓓ, start the sticking of sealing material with the air outlet Ⓓ.

(4) Matching the longitudinal air outlet numbered 1 to 4 that are to be blocked, prepare the sealing material and tape for fixing the sealing material.


- Cut both the sealing material and tape for fixing the sealing material along the perforation (dotted line).
- Stick the sealing material to the tape for fixing the sealing material.
  (Stick so that the sealing material comes to the centre of tape for fixing the sealing material.)

Example) When blocking air outlet 2 or 3



- When blocking the air outlet 1, the sealing material preparation is not necessary.

(5) Stick the sealing material that was prepared in (4) to the air outlet of indoor unit main body.



<Mounting to air outlet>

Precautions The sealing material has a directional property. Be sure to stick the sealing material to the tape for fixing the sealing material so that the printed number of outlet to be blocked becomes visible.

J : 1P177350A

2


❷ Sticking of Absorbent to Air Outlet

● Stick the absorbent indicated in the table below to the air outlet that was not blocked in ❶ according to the procedure shown in the figure below.


	Classes 28 to 56	Classes 63 to 160
Air outlet ①	——	——
Air outlet ②	Absorbent 10 13 14 Total 3 pieces	——
Air outlet ③	Absorbent 10 13 14 15 Total 4 pieces	Absorbent 11 13 14 Total 3 pieces
Air outlet ④	Absorbent 12 15 Total 2 pieces	——

Precautions
- If the sticking of absorbent is omitted, condensation may occur.
- To positions where the absorbent is already stuck, the sticking of absorbent is not necessary.

Classes 28 to 56



Classes 63 to 160



continued on back side


J : 1P177350A

3 Sticking of Insulator to Indoor Unit Main Body


- For safety, be sure to shut off power supply before starting the insulator sticking operation, decoration panel mounting operation, and connecting of connectors for swinging.

Precautions If the sticking of insulator is omitted, condensation may occur.


- Stick the side insulator plate 16 according to the figure below.



For a wiring takeoff point with two sections, make a slit on the side insulator plate 16 as shown in the figure below, then route the wiring.



Wiring takeoff point



Superimpose the surplus section.


4 Sticking of Absorbent to Panel Horizontal Blade


- Perform the operation on soft cloth to prevent damage to the panel.
- Perform sticking for the horizontal blades of all air outlets.
- Do not apply force to the horizontal blade. (Application of force may lead to horizontal blade swing failure.)

- According to the figure below, stick the horizontal blade absorbent 17 and 18 as well as the horizontal blade sealing pad 19 .
(With KDBH55K160, stick the horizontal blade absorbent with matching blade colour.)


Precautions When the sticking of absorbent and sealant is omitted, condensation may occur.

① Stick the horizontal blade absorbent 17 in line with the blade shape to the front face of the horizontal blade.







A-A cross section




② Stick the horizontal blade sealing pad 19 to the backside of the blade. (For both left and right)





Using the base of the rib as a reference, stick without leaving any gap.

③ Stick the horizontal blade absorbent 18 in between the horizontal blade sealing pad 19.



B-B cross section

5 Field Setting

- Depending on the installation status of the indoor unit's main body, the field setting needs to be performed by remote control operation.

- Perform the setting by switching among the following three items: "Mode number", "Setting switch number", and "Setting position number".
- The setting procedure and operation method are described in "How to perform field setting" attached to the remote control.

(1) Setting by number of air outlets used
While referring to "How to perform field setting" attached to the remote control, perform the setting according to the table in the right.
Also, when the corner air outlet is blocked with 4-way blow, set the wind direction slightly downward.
(Note) When the installation height becomes higher than the standard, the setting by ceiling height in (2) becomes necessary.

(2) Setting by ceiling height
For the ceiling height, refer to the guidelines of ceiling height and number of air outlets used, then perform the setting for each air outlet used according to the table below.

(Guidelines of ceiling height and number of air outlets used)

Indoor unit		Number of air outlets used							
		Types 28 to 90				Types 112 to 160			
		All-around blow	4-way blow	3-way blow	2-way blow	All-around blow	4-way blow	3-way blow	2-way blow
Ceiling height	Standard	2.7m or less	3.1m or less	3.0m or less	3.5m or less	3.2m or less	3.4m or less	3.6m or less	4.2m or less
	High ceiling ①	3.0m or less	3.4m or less	3.3m or less	3.8m or less	3.6m or less	3.9m or less	4.0m or less	4.2m or less
	High ceiling ②	3.5m or less	4.0m or less	3.5m or less	——	4.2m or less	4.5m or less	4.2m or less	——

Values for ceiling height are provided as reference.

[Setting content] (Setting by number of air outlets used)

(Number of air outlets used)	Mode number	Setting switch number	Setting position number
3-way blow	13 (23)	1	02
2-way blow			03

[Setting content] (Setting for when corner air outlet is blocked with 4-way blow)

(Wind direction)	Mode number		Setting position number
Standard	13 (23)	4	02
Slightly downward			03

[Setting content] (Setting by ceiling height)

	Mode number		Setting position number
Standard	13 (23)	0	01
High ceiling ①			02
High ceiling ②			03

J : 1P191031A


KDBP55H160FA — Panel Spacer



- Using the panel spacer in areas of the ceiling with limited space makes it possible to install the air conditioner.
- Hides the gap between the decoration panel and the ceiling.

Model / Item	KDBP55H160FA
Exterior	Fresh White
Material	Outside frame: Resin Insulation: Foam polyethylene
Component	Panel spacer, Insulation, Sealant, Mounting screws, Installation manual
Mass (kg)	1.2

Dimensions **Unit:mm**



Combination table



Panel spacer	KDBP55H160FA	KDBP55H160WA KDB55K160WA
Decoration panel	BYCP125K-W1	BYCP125D-W1 BYC125K-W1 BYC125KJW1

Caution

- When the Panel Spacer is installed, it is not possible to have 2-way air outlet.
- Refer to the installation manual for both indoor unit and the Panel spacer for its installation.

Contents of kit

Check if following parts are included with your kit.

Name	Panel spacer frame	Resin corner part	Fixing metal	Screw
Quantity	4 PCS.	4 PCS.	4 PCS.	28 PCS.
Shape・number	① 	② 	③ 	④  M4×10 Tapping screw (Class 2)

Name	Sealing material		Caution label	Others
Quantity	2 PCS.	2 PCS.	1 PC.	
Shape・number	⑤ 	⑥ 	⑦ 	・This Installation Manual


❶ Preparation of the Decoration panel

- Handle the decoration panel with care.

Never place the panel face down, or lean the panel against wall or place on the projective object.
(It causes the dent or damage of the surface of the panel or damage of swing motor.)

(1) Remove the suction grill from the decoration panel.
(Refer to the installtion manual of the decoration panel how to remove.)


(2) Place the panel face down on the corrugated board or the vinyl sheet to protect the surface of the panel.



❷ Installation of the indoor unit

Adjust the height of the indoor unit.

Be sure the piping will not contact with the ceiling joist etc. after adjusting the height.



Decoration panel	A(mm)
BYCP125D-W1 BYC125K-W1 BYC125KJW1	145~150
BYCP125K-W1	125~130


Decoration panel	A(mm)
BYCP125D-W1 BYC125K-W1 BYC125KJW1	105~110
BYCP125K-W1	85~90

1P136564E


2

❸Assembly of panel spacer

(1)Assemble the panel spacer frame ① and the plastic corner joint ② temporarily.




(2)Fix with the screws ④ from the top.
(4 screws in each corner)




❹ Fixing to the Decoration panel

(1)Set the fixing metal ③ on each corner with screws ④.
(Screw positions change with decoration panels, as shown in the following figure.)


●In the case of BYCP125K-W1




●In the cases of other than the above.



(2)Place the panel spacer assembled in item ③Assembly of panel spacer of the above on the outer frame of the Decoration panel.





(3)Fix the panel spacer to the fixing metal ③ with screws ④(4 portions).



❺Adhesion of the sealing material

Adhere the sealing material ⑤ ⑥ on the upper face of the panel spacer in the order of ⑤ and ⑥.






❻Installation of the Decoration panel

(1) install the decoration panel to the indoor unit according to the installation manual of decoration panel.

The panel spacer is not firmly fixed to the decoration panel, so that never hold the panel spacer directly or lean the decoration panel extremely.

(2)After installation of the Decoration panel, adhere the caution sticker ⑦ next to the name plate of the indoor unit as shown on the right.



1P136564E

KDDP55K160(K) — Fresh Air Intake Kit


KDDP55K160 (without T-shape, without Fan)



Caution

1. Maximum length of the duct is 4 meters.
2. When installing this kit, an inspection hole is required (in order to maintain this kit). Establish an inspection holes on either side.
3. This kit is field assembly.
4. Install the hanging fixing for the T joint. Otherwise the load from T-shape pipe assembly, etc., could create a gap between the indoor unit and suction chamber.
5. When mounting the duct fan, be sure to use the wiring modification adaptor to interlock with the indoor unit fan.
6. With the intake wind volume, 10% or less of the “H” wind volume of the indoor unit is recommended.
7. This graph shows values from the inlet of the T joint through that of the indoor unit when KDDP55K160K (with a T joint) is connected.

Dimensions **Unit:mm**



Item \ Model	KDDP55K160
Fresh air intake method	Fresh air intake by air conditioning fan
Diameter of connection duct	ϕ150
Mass (kg)	4.5


KDDP55K160K (with T-shape, without Fan)



Caution

1. Maximum length of the duct is 4 meters.
2. When installing this kit, an inspection hole is required (in order to maintain this kit). Establish an inspection holes on either side.
3. This kit is field assembly.
4. Install the hanging fixing for the T joint. Otherwise the load from T-shape pipe assembly, etc., could create a gap between the indoor unit and suction chamber.
5. When mounting the duct fan, be sure to use the wiring modification adaptor to interlock with the indoor unit fan.
6. With the intake wind volume, 10% or less of the “H” wind volume of the indoor unit is recommended.
7. This graph shows values from the inlet of the T joint through that of the indoor unit when KDDP55K160K (with a T joint) is connected.

Dimensions **Unit:mm**



Item \ Model	KDDP55K160K
Fresh air intake method	Fresh air intake by air conditioning fan
Diameter of connection duct	ϕ150
Mass (kg)	6.5

2

⚠Caution After thoroughly reading these "Safety precautions", properly perform the installation.

- For the installation parts, accessory parts and specified components must always be used. If the specified components are not used, the kit may fall or an air leak may occur.
- After the completion of installation, perform a test run to check that no abnormality is present.

Combination table

Model name	Installable indoor unit / Panel model name	
KDDP55K160 (K)	SkyAir	FCQ(N)71·100·125·140KVEA
	VRV	FXFQ25~125PVE
	Panel	BYCP125K-W1


Recommendations

· This product can be mounted to a ceiling mounted cassette-type air conditioner <Round flow>.
· According to the table to the left, check the model name of the indoor unit, then mount the kit.
· At the time of mounting, also refer to the installation manual for the indoor unit and to the one for the decoration panel.
· When mounting the duct fan, be sure to use the wiring modification adaptor [KRP1C63] to interlock with the indoor unit fan.
For the intake wind volume, 10% or less of the indoor unit wind volume of "H" is recommended.
When the intake wind volume becomes excessive, operation noise may become louder or the intake temperature detection of the indoor unit may be affected.
· Be sure to mount the supplied sensor assembly.
<For the duct used for field connection, those in the table below are recommended.>

Part name	Part number
Flexible duct (Nominal diameter ϕ150)	K-FDS151D (1m) K-FDS152D (2m) K-FDS153D (3m) K-FDS154D (4m)


Name	⑭Partition plate	
Shape		
Number of pieces	KDDP55K160	1
	KDDP55K160K	1

Parts content Check the following parts. (Shaded part ⋯⋯ is included in a different package.)

Name	①Suction chamber	②Connecting chamber (left)	③Connecting chamber (right)	④Corner air outlet sealing material	⑤Corner air outlet tape for fixing the sealing material	⑥Mounting screw	⑦Sensor assembly	⑧Clamp	⑨Mounting screw (for sensor)	⑩T joint	⑪Flexible duct	⑫Sealing pad	⑬Installation manual
Shape						 M5 × 12							 (this document)
Number of pieces KDDP55K160	1	1	1	2	2	4	1	2	1	——	——	——	1
KDDP55K160K	1	1	1	2	2	4	1	2	1	1	2	4	1

❶ Selection of Installation Location and Establishment of Inspection Opening

(1) Refer to the figure below to select the installation location.




*1. Install the suspension bracket for the T joint section.
Because of the load from T joint, etc., a gap may be created in between the indoor unit and suction chamber.

	Indoor unit	A (mm)
BYCP125K-W1	classes 28 to 90	306
	classes 112 to 160	348

*2. Establish an inspection opening (□450 or more).
Establish an inspection opening to either side.

(2) Establish an inspection opening.




❷ Mounting of Sensor Assemblies and Suction Chamber

* When the indoor unit main body is already installed, perform the following operations, complying with precautions below.
- Shut off power supply before performing operation.
- Remove the decoration panel from the indoor unit main body.
(For details, refer to the installation manual attached to the decoration panel.)

<Mounting of sensor assembly>

(1) According to the installation manual attached to the indoor unit main body, remove the cover of the control box.
(2) Using the supplied screws, tighten the sensor assembly together with the bell mouth to the indoor unit main body.
(Mount without pinching the float switch lead wire.)
(3) Remove the connector (X16A) of the existing sensor from the PC board of the indoor unit main body.
(4) Connect the lead wire of the mounted sensor assembly to the connector (X16A) on the PC board of the indoor unit main body as shown in the figure below.
(5) As shown in the figure below, fix the lead wire using the supplied clamp.
(6) After all the wiring is completed, fit the control box cover according to the installation manual attached to the main body.
(7) Making sure that the control box cover is covered with the partition plate ⑭, tighten these together using the screws on the cover. (Hook the partition plate tab onto the cover.)



<Mounting of suction chamber>

* Figure shows an example where the indoor unit main body is newly installed.
(1) Stick the corner air outlet tape for fixing the sealing material ⑤ to the corner air outlet sealing material ④, then stick it to the air outlet of the indoor unit main body. (2 positions) (Figure 1) (Figure 2)
(2) Mount the suction chamber ① to the indoor unit main body using the hook (4 positions). (Figure 3) to (Figure 5)
For the fixing method of the hook, refer to (Figure 4), then mount at 4 positions.
* Mount so that the contours of the indoor unit main body and suction chamber match. (Figure 4) (Figure 6)

Figure 1




Figure 2 For 2 positions







Figure 3



JC : 3K017588C

Figure 4 Mounting status





Fixing method of hook

Figure 5 Status after mounting






Figure 6 Drawing of mounting at completion



3 Installation of Indoor Unit Main Body and Suction Chamber

- Install the indoor unit main body and suction chamber.
  At the time of installation, perform the engineering work according to the installation manual attached to the indoor unit main body. (For the installation height, refer to the figure to the right.)
- When mounting the suction chamber to the existing indoor unit main body, change the installation height of the indoor unit main body to height A in the figure to the right.



	A (mm)
BYCP125K-W1	180

4 Mounting of Connecting Chamber and Connection of Flexible Duct

Mount the connecting chamber. (1 piece each for left and right, a total of 2 pieces) Figure 7

(1) Press the square hole area of the connecting chamber (2) ((3)) into the hook section (tab) of the suction chamber (1). (2 positions)

(2) Using the supplied screws (6), fix the connecting chamber. (2 positions)






Figure 7 Mounting of connecting chamber
(This figure shows the connecting chamber (left) (2).)



<How to Tight Sealing Pad>



(1) Wrap the sealing pad to the position to be tightened.

(2) Insert the tip of the band through the gap of the split pin, then lightly tighten by hand.

(3) Using a standard tool (driver, pliers, etc.), turn the split pin to the direction shown in the figure to tighten the band.

(4) This completes the mounting.

Precautions

Because the split pin has a structure to prevent counter rotation, be careful with the turning direction. (When a counter rotation is forced, the ratchet will be damaged, and the tightening force will be weakened.)

In case of KDDP55K160K

(3) Connect the connecting chamber and T joint. Figure 8






Figure 8



To prevent applying weight to the connecting chamber, hang the T joint using the hanging band for the duct.


(4) Mount the supplied installation pattern paper to the indoor unit by using screws to cure the indoor unit.
(Refer to the installation manual of the indoor unit main body.)
(Refer to the figure below.)
(Mounting of installation pattern paper)



- Complete all the refrigerant and drain piping works for the indoor unit main body.

5 Duct Connection <<Duct: Nominal diameter φ150>>

(1) Connect the duct to the duct connection area.
(2) Wrap the connection area with vinyl tape, etc., (arrangement at site) to prevent an air leak.




Precautions

- For the duct, be sure to apply the insulation treatment to prevent condensation.
- Do not perform duct manipulations described in the figure to the right.
- Beware that, in accordance with the local law, there may be cases where the use of a nonflammable duct is compulsory.
- When a duct goes through fire protection areas including a fire proof structure, beware that, in accordance with the local law, it may be required to establish a damper or to build a structure that is not detrimental to fire protection.
- When penetrating a wooden construction wall with a metal duct, apply electrical insulation to the duct and wall.
- Mount the outside duct so that it has a downslope toward the outside, and prevent rainwater from leaking in with a hood, etc. (Gradient of 1/100 to 1/50)
- To prevent the intrusion of small animals, such as birds, and bugs, be sure to attach a netting to sections open to outside air.
- To protect the heat exchanger of the indoor unit, be sure to attach an air filter to sections open to outside air.

6 Mounting of Decoration Panel

- After temporarily hooking the decoration panel, pass the swing motor lead wire, which is coming out from the decoration panel, through the wiring hole of the suction chamber. However, when used in combination with the air purifier unit or streamer deodorization unit, perform wiring without routing through the wiring hole.
- Mount the decoration panel according to the installation manual attached to the decoration panel.



With wireless unit


- For details on connection method, refer to the installation manual attached to the wireless remote control kit (sold separately).

JC : 3K017588C

KDDP55X160 — Fresh Air Intake Kit



Dimensions **Unit:mm**



Item \ Model	KDDP55X160
Material	Hot-dip zinc-coated carbon steel sheet
Diameter of connection duct	ϕ100
Accessories	Mounting screws : 4 Insulating material : 1 unit Installation manual

Precautions
- This kit can be mounted to a ceiling mounted cassette-type air conditioner.
- When using this kit, a duct (nominal diameter: ϕ100) is required separately.

- Beware that, in accordance with the local law, there may be cases where the use of a nonflammable duct is compulsory.
- When a duct goes through fire protection areas including a fire proof structure, beware that, in accordance with the local law, it may be required to establish a damper or to build a structure that is not detrimental to fire protection.
- When penetrating a wooden construction wall with a metal duct, apply electrical insulation to the duct and wall.
- Mount the outside duct so that it has a downslope toward the outside, and prevent rainwater from leaking in. (Gradient of 1/100 to 1/50)
- To prevent the intrusion of small animals, such as birds, and bugs, be sure to attach a netting to sections open to outside air.

Parts content Check the following parts.

Name	① Duct flange	② Mounting screws	③ Duct flange insulator	④ Main body opening insulator	⑤ Sealing pad retainer	⑥ Installation manual
Number of pieces	1	4	1	1	1	1
Shape		 M4×12				

Tools needed for mounting Phillips-type screwdriver, nippers, and cutter, etc.

1 Mounting of Duct Flange

1) Cut off the side plate of the indoor unit main body along the dowel hole without damaging the internal insulator. (Figure 1)





Figure 1

2) Stick the main body's opening insulator ④ to the opening. (Figure 2)

Figure 2



JC : 2P137676B

2

3) After mounting the duct flange ① to the opening using the mounting screws ② (M4×12, 4 pieces), stick the duct flange insulator ③. (Figure 3)




Figure 3

4) Before mounting the decoration panel, remove the insulator, and stick the sealing pad retainer ⑤ to the indoor unit drain pan. (Figure 4)




Figure 4

② Duct Connection

<<Duct: Nominal diameter ϕ100>>

1) Connect the duct to the outside of the duct flange. (Figure 5)
2) After the connection, wrap the connection area with tape (field supplied) to prevent an air leak.





Figure 5

Precautions


- Perform insulation for all ducts.
- Do not perform duct manipulations shown to the right.

a) Extreme bending b) Multiple bending c) Reduction of connecting duct diameter




J : 2P137676B

KAFP556H80·160, KAFP557H80·160 — High Efficiency Filter



Dimensions **Unit:mm**



Caution

· Field setting by remote controller is necessary when the high efficiency filter is installed.

Item \ Model		KAFP556H80	KAFP556H160	KAFP557H80	KAFP557H160
Average efficiency (%)		65 (colorimetric method)		90 (colorimetric method)	
Number of sheets included		1	1	1	1
Air flow rate	l/sec	317	583	317	583
	m^3/min	19	35	19	35
Initial pressure loss (Pa)		34 or less			
Final pressure loss (Pa)		98 or less			
Filter element		Non-woven fabric of synthetic fiber			
Life (h)		2,500 (dust concentration 0.15 mg/m^3)		1,800 (dust concentration 0.15 mg/m^3)	
Mass (kg)		3.6	4.2	3.6	4.2

Replacement filter (optional Accessories)	KAFP552H80	KAFP552H160	KAFP553H80	KAFP553H160

2



⚠Caution After thoroughly reading these "Safety precautions", properly perform the installation.

- For the installation parts, accessory parts and specified components must always be used.
  If the specified components are not used, the kit may fall or an air leak may occur.
- After the completion of installation, perform a test run to check that no abnormality is present.

Recommendations

- This product can be mounted to a ceiling mounted cassette-type air conditioner <round flow >.
- According to the table below, check the model name of the indoor unit main body, then mount the product.
- At the time of mounting, also refer to the installation manual of the indoor unit and to the installation manual of the decoration panel.

Parts content Check the following parts.

Name	High efficiency filter unit	Sealing pad	Installation manual
Shape			
Number of pieces	1	2	1 (This document)

Combination table

Model name	Installable indoor unit model name / Panel model name	
KAFP556H80 KAFP557H80	SkyAir	FCQ(N)71KVEA
	VRV	FXFQ25·32·40·50·63·80PVE
KAFP556H160 KAFP557H160	SkyAir	FCQ(N)100·125·140KVEA
	VRV	FXFQ100·125PVE
Panel	BYCP125K-W1	

1 Mounting of High Efficiency Filter Unit


* When the indoor unit main body is already installed, perform the following operations, complying with precautions below.
  Shut off power supply before performing the operation.
  Remove the decoration panel from the indoor unit's main body.
  (For details, refer to the installation manual attached to the decoration panel.)


* When the indoor unit main body is newly installed

(1) Remove the high efficiency filter from the chamber. (Figure 1)
(2) Mount the high efficiency filter unit to the indoor unit main body using the hooks (4 positions). (Figure 2) to (Figure 4)
For the fixing method of the hooks, refer to the figure to the right. Mount at 4 positions.

* Mount so that the contours of the indoor unit main body and chamber match. (Figure 3) (Figure 5)


(Figure 1)






Fixing method of hooks


(Figure 2)




(Figure 3) Mounting status



(Figure 4) Status after mounting




(Figure 5) Drawing of mounting at completion



JC : 3K015220E


❷ Installation of Indoor Unit Main Body and High Efficiency Filter Unit

- Install the indoor unit main body and high efficiency filter unit.
  At the time of installation, perform engineering work according to the installation manual attached to the air conditioner's main body. (For the installation height, refer to the figure to the right.)
- When mounting the high efficiency filter unit to the existing indoor unit main body, change the installation height of the indoor unit main body to height A in the figure to the right.



	A (mm)
BYCP125K-W1	180

- Mount the supplied installation pattern paper to the indoor unit using screws to cure the indoor unit.
  (Refer to the installation manual for the indoor unit main body.)
  (Refer to the figure below.)



[Mounting of installation pattern paper]

- Complete all the refrigerant and drain piping work for the indoor unit main body.

❸ Mounting of Decoration Panel and Mounting of High Efficiency Filter

- After temporarily hooking the decoration panel, pass the swing motor lead wire, which is coming out from the decoration panel, through the wire through hole of the high efficiency filter unit.
- Mount the decoration panel according to the installation manual attached to the decoration panel.





Figure 6



- Mounting of high efficiency filter
  After the completion of wiring and sticking of sealing pad (2 positions), mount the high efficiency filter. (Figure 6) (Figure 7)




Figure 7

With wireless unit

- Route the connector of the receiver lead wire through the wire through hole, then connect the connector on the indoor PC board ass'y.
- For details on the connection method, refer to the installation manual attached to the wireless remote control kit (sold separately).

❹ Preparation of Indoor Unit

- With the mounting of a high efficiency filter unit, setting the indoor unit main body is required.
  Using the field setting mode on the remote control, switch to the setting position number as shown in the table to the right.
  For the field setting mode, refer to "How to perform field setting" attached to the remote control.


Mode number	Setting switch number	Setting position number	Remarks
13 or 23	0	02	80 only
	1	02	Both 80 and 160

JC : 3K015220E

KAFP552H80·160, KAFP553H80·160 — High Efficiency Filter




Dimensions Unit:mm




- Cannot be water-washed for reuse.
- The Filter Chamber (KDDFP55H160) is required when the high efficiency filter will be installed.

Item \ Model	KAFP552H80	KAFP552H160	KAFP553H80	KAFP553H160
Average efficiency (%)	65 (colorimetric method)		90 (colorimetric method)	
Number of sheets included	1	1	1	1
Air flow rate (m^3/min)	19	35	19	35
Initial pressure loss (Pa)	34			
Final pressure loss (Pa)	98			
Filter element	Non-woven fabric of synthetic fiber			
Life (h)	2,500 (dust concentration 0.15 mg/m^3)		1,800 (dust concentration 0.15 mg/m^3)	
Mass (kg)	0.6	1.2	0.6	1.2

KAFP55H160 — Ultra Long Life Filter Unit



Dimensions **Unit:mm**



Caution

- In order to mount a ultra long life filter unit, setting of the main unit of indoor unit should be made.
- Individual filter (KAFP55H160H) is available

Mounting locations	Filter cleaning period
Locations with much dust	Approximately every 5,000 hours
Locations with little dust (e.g. offices)	Approximately every 10,000 hours

Model / Item		KAFP55H160
Average efficiency (%)		50 (Gravity method)
Number of sheets included		1
Air flow rate	l/sec	492
	m^3/min	29.5
Initial pressure loss (Pa)		8 or less
Final pressure loss (Pa)		49 or less
Filter element		Polypropylene honeycomb (with mould-proof)
Life (h)		5,000 (dust concentration 0.3 mg/m^3)
Mass (kg)		4.7

2

⚠Caution After thoroughly reading these "Safety precautions", properly perform the installation.

- For the installation parts, accessory parts and specified components must always be used.
  If the specified components are not used, the kit may fall or an air leak may occur.
- After the completion of installation, perform a test run to check that no abnormality is present.



Recommendations

- This product can be mounted to a ceiling mounted cassette-type air conditioner <Round flow>.
- According to the table below, check the model name of the indoor unit main body, then mount the product.
- At the time of mounting, also refer to the installation manual for the indoor unit and to the one for the decoration panel.

Recommendations

The ultra-long life filter can be reused after cleaning.
After the engineering works are completed, provide instructions to the customer about the filter cleaning interval and how to remove the filter.

Parts content Check the following parts.

Name	Ultra-long life filter unit	Sealing pad	Installation manual
Shape			
Number of pieces	1	2	1 (This document)

Combination table

Model name	Installable indoor unit model name / Panel model name	
KAFP55H160	SkyAir	FCQ(N)71·100·125·140KVEA
	VRV	FXFQ25·32·40·50·63·80·100·125PVE
Panel	BYCP125K-W1	


1 Mounting of Ultra-Long Life Filter Unit


* When the indoor unit main body is already installed, perform the following operations, complying with precautions below.
  Shut off power supply before performing the operation.
  Remove the decoration panel from the indoor unit main body.
  (For details, refer to the installation manual attached to the decoration panel.)
* When the indoor unit main body is newly installed

(1) Remove the ultra-long life filter from the chamber. (Figure 1)
(2) Mount the ultra-long life filter unit to the indoor unit main body using the hooks (4 positions). (Figure 2) to (Figure 4)
For the fixing method of the hooks, refer to the figure to the right. Mount at 4 positions.

* Mount so that the contours of the indoor unit main body and chamber match. (Figure 3) (Figure 5)

Figure 1





Fixing method of hooks

Figure 2




Figure 3 Mounting status




Figure 4 Status after mounting






Figure 5: Drawing of mounting at completion



JC : 3K015221D


❷ Installation of Indoor Unit Main Body and Ultra-Long Life Filter Unit

- Install the indoor unit main body and ultra-long life filter unit.
  At the time of installation, perform engineering work according to the installation manual attached to the air conditioner's main body. (For the installation height, refer to the figure to the right.)
- When mounting the ultra-long life filter unit to the existing indoor unit main body, change the installation height of the indoor unit main body to height A in the figure to the right.



	A (mm)
BYCP125K-W1	180

- Mount the supplied installation pattern paper to the indoor unit by using screws to cure the indoor unit.
  (Refer to the installation manual of the indoor unit main body.)
  (Refer to the figure below.)





[Mounting of installation pattern paper]

- Complete all the refrigerant and drain piping work for the indoor unit main body.


❸ Mounting of Decoration Panel and Mounting of Ultra-Long Life Filter

- After temporarily hooking the decoration panel, pass the swing motor lead wire, which is coming out from the decoration panel, through the wire through hole of the ultra-long life filter unit.
- Mount the decoration panel according to the installation manual attached to the decoration panel.





- Mounting of ultra-long life filter
  After the completion of wiring and sticking of sealing pad (2 positions), mount the ultra-long life filter. (Figure 6) (Figure 7)



With wireless unit

- Route the connector of the receiver lead wire through the wire through hole, then connect the connector on the indoor printed circuit board assembly.
- For details on the connection method, refer to the installation manual attached to the wireless remote control kit (sold separately).

❹ Preparation of Indoor Unit

- With the mounting of a ultra-long life filter unit, setting the indoor unit main body is required.
  Using the field setting mode on the remote control, switch to the setting position number shown in the table to the right.
  For the field setting mode, refer to "How to perform field setting" attached to the remote control.


Mode number	Setting switch number	Setting position Number		Filter sign display interval time
10 or 20	0	Where there is minimal fouling (Example: Office, etc.)	01	Approximately every 10,000 hours
		Where there is considerable fouling (Example: Pachinko parlor, etc.)	02	Approximately every 5,000 hours
	1	02		Initial setting for ultra-long life filter

JC : 3K015221D

KAFP55H160H
— Replacement Ultra-Long Life Filter Unit (including Filter Chamber)




Dimensions **Unit:mm**




· Can be water-washed. Can be reused.
· The Filter Chamber (KDDFP55H160) is required when the ultra long-life filter will be installed.

Item \ Model		KAFP55H160H
Average efficiency (%)		50 (Gravity method)
Number of sheets included		1
Air flow rate	l/sec	492
	m^3/min	29.5
Initial pressure loss (Pa)		8 or less
Final pressure loss (Pa)		49 or less
Filter element		Mould-proof resin net
Life (h)		5,000 (dust concentration 0.3 mg/m^3)
Mass (kg)		3.4

KDDFP55H160 — Filter Chamber



Dimensions **Unit:mm**



Item			Model: KDDFP55H160
Inserted filter	High-efficiency filter	65% (colorimetric method)	KAFP552H80 KAFP552H160
		90% (colorimetric method)	KAFP553H80 KAFP553H160
	Ultra long-life filter		KAFP55H160H
Mass (kg)			8.0

2


⚠Caution After thoroughly reading these "Safety Precautions", properly perform the installation.

- For the installation parts, accessory parts and specified components must always be used.
  If the specified components are not used, the kit may fall or an air leak may occur.
- After the completion of installation, perform a test run to check that no abnormality is present.

Recommendations (When using ultra-long life filter)

The ultra-long life filter can be reused after cleaning.
After engineering work is completed, provide instructions to the customer about the filter cleaning interval and how to remove the filter.

Parts content Check the following parts.

Name	Filter chamber	Sealing pad	Installation manual
Shape			
Number of pieces	1	2	1 (This document)

Recommendations

- This product can be mounted to ceiling mounted cassette-type air conditioner <round flow>.
- According to the table below, check the model name of the indoor unit main body, then mount the product.
- At the time of mounting, also refer to the installation manual for the indoor unit and to the one for the decoration panel.

Combination table


Model name	High efficiency filter	Ultra-long life filter	Installable indoor unit model name / Panel model name	
KDDFP55H160	KAFP552H80 or KAFP553H80	KAFP55H160H	SkyAir	FCQ(N)71KVEA
			VRV	FXFQ25·32·40·50·63·80PVE
	KAFP552H160 or KAFP553H160		SkyAir	FCQ(N)100·125·140KVEA
			VRV	FXFQ100·125PVE
	Panel		BYCP125K-W1	

1 Mounting of Filter Chamber

* When the indoor unit main body is already installed, perform the following operations, complying with precautions below.
  Shut off power supply before performing the operation.
  Remove the decoration panel from the indoor unit main body.
  (For details, refer to the installation manual attached to the decoration panel.)
* When the indoor unit main body is newly installed


(1) Mount the filter chamber to the indoor unit main body using the hooks (4 positions). (Figure 1) to (Figure 3)
For the fixing method of the hooks, refer to the figure to the right. Mount at 4 positions.

* Mount so that the contours of the indoor unit main body and chamber are match. (Figure 2) (Figure 4)




Fixing method of hooks


(Figure 1)




(Figure 2) Mounting status



(Figure 3) Status after mounting




(Figure 4) Drawing of mounting at completion




JC : 3K015219E

❷ Installation of Indoor Unit Main Body and Filter Chamber

- Install the indoor unit main body and filter chamber.
  At the time of installation, perform engineering work according to the installation manual attached to the air conditioner's main body. (For the installation height, refer to the figure to the right.)
- When mounting the filter chamber to the existing indoor unit main body, change the installation height of the indoor unit main body to height A in the figure to the right.
- Mount the supplied installation pattern paper to the indoor unit using screws to cure the indoor unit.
  (Refer to the installation manual of the indoor unit main body.)
  (Refer to the figure below.)



[Mounting of installation pattern paper]



	A (mm)
BYCP125K-W1	180

- Complete all the refrigerant and drain piping work for the indoor unit main body.

❸ Mounting of Decoration Panel and Mounting of Filter Chamber

- After temporarily hooking the decoration panel, pass the swing motor lead wire, which is coming out from the decoration panel, through the wire through hole of the filter chamber.
- Mount the decoration panel according to the installation manual attached to the decoration panel.





Figure 5



- Mounting of filter
  After the completion of wiring and sticking of sealing pad (2 positions), mount the filter.
  Figure 5 Figure 6




Figure 6

With wireless unit

- Route the connector of the receiver lead wire through the wire through hole, then connect the connector on the indoor PC board assembly.
- For details on the connection method, refer to the installation manual attached to the wireless remote control kit (sold separately).

❹ Preparation of Indoor Unit

- Depending on the types of mounting filters, setting the indoor unit main body is may be required.
  Using the field setting mode on the remote control, switch to the setting position number shown in the table to the right.
  For the field setting mode, refer to "How to perform field setting" attached to the remote control.

Filter name		Mode number	Setting switch number	Setting position number		Filter sign display interval time
High performance filter	80 only	13 or 23	0	02		———
	Both 80 and 160		1	02		
Ultra-long life filter		10 or 20	0	Where there is minimal fouling (Example: Office, etc.)	01	Approximately every 10,000 hours
				Where there is considerable fouling (Example: Pachinko parlor, etc.)	02	Approximately every 5,000 hours
			1	02		Initial setting for ultra-long life filter


JC : 3K015219E

KAFP551K160 — Replacement Long Life Filter



· Can be water-washed. Can be reused.

Dimensions **Unit:mm**




Item \ Model		KAFP551K160
Average efficiency (%)		60 (Gravity method)
Number of sheets included		1
Air flow rate	l/sec	300
	m^3/min	18
Initial pressure loss (Pa)		4.9 or less
Final pressure loss (Pa)		49 or less
Filter element		Mould-proof and antibacterial resin net
Life (h)		5,000 (dust concentration 0.15 mg/m^3)
Mass (kg)		0.2

KDJP55H80·160 — Branch Duct Chamber




Dimensions **Unit:mm**

KDJP55H80



KDJP55H160



Item \ Model	KDJP55H80	KDJP55H160
Material	Hot-dip zinc-coated carbon steel sheet (with insulation)	

Caution

1. When mounting, refer to the installation manuals for the indoor unit and the decoration panel.




2

Precautions

- This product can be mounted to a ceiling mounted cassette-type air conditioner <round flow>. According to the table to the right, check the model name of the indoor unit, then mount the product.
- At the time of mounting, also refer to the installation manual for the indoor unit main body and to the one for the decoration panel.
- For the duct (field supplied) to be connected, those specified in the table to the right are recommended.

Parts content Check the following parts.

Name	Branch duct chamber	Mounting screw	Installation manual	Sealing material	Tape for fixing the sealing material
Shape/ Number		 M4×16			
Number of pieces 80	1	10	1	2	2
Number of pieces 160	1	10	1	2	2

Name	Main body insulator			Main body opening sealant		
Shape/ Number	① 	② 	③ 	④ 	⑤A (Small) 	⑤B (Large) 
Number of pieces 80	1	1	2	2	2	——
Number of pieces 160	1	1	2	2	1	1

Combination table

Model name		Installable indoor unit model name
KDJP55H80	SkyAir	FCQ(N)71KVEA
	VRV	FXFQ25~80PVE
KDJP55H160	SkyAir	FCQ(N)100·125·140KVEA
	VRV	FXFQ100 · 125PVE

Recommended duct

Branch duct chamber	Connecting duct kit name
KDJP55H80	K-FDK151B (1 m) or K-FDK152B (2 m) (Flexible duct: Nominal diameter of ϕ150)
KDJP55H160	K-FDK201B (1 m) or K-FDK202B (2 m) (Flexible duct: Nominal diameter of ϕ200)


1 Preparation Before Installation

With this branch duct, an independent 4-way and simultaneous 2-branch drawing are also possible.

- With this branch duct chamber, the blow directions shown in the figure to the right can be selected.
  Select the blow direction that is most appropriate for the room shape and installation position. (Blow directions other than those in the figure to the right cannot be selected.)
- From the external static pressure/air volume characteristics (refer to the technical guide), select the duct length and air outlet.

Precautions

- Be sure to securely block the air outlet of the indoor unit main body to which the branch duct chamber is mounted. If the blocking is incomplete, water spraying or condensation may occur. Do not block the corner sections.
  (Refer to 4 Mounting of Sealing Material to Indoor Unit .)
- When mounting the branch duct chamber, be sure to perform field setting of the indoor unit main body.
  (Refer to 5 Field Setting .)




2 Mounting of Branch Duct Chamber

When an installation is performed after mounting the branch duct chamber to the indoor unit main body (at new installation), do not apply force to the branch duct chamber. (Deformation may occur.)

(1) Select the position where the branch duct chamber is mounted.

(2) Mount the branch duct chamber to the indoor unit according to the following procedure. (Figure 2 is an example of the face ① side.)

1) Along the slit, cut the side plate of the indoor unit to which the branch duct chamber is mounted. Then, cut the internal insulator along the groove.
(Use nippers, etc., to cut the slit section, and cutter, etc., to cut the groove section.) Figure 2



⚠ For the port opening operation, do not use a tool that produces chips, such as a saw. The drain system may become clogged, and a water leak may occur.

2) Use the sealant for sticking so that the gaps between the side plate and internal insulator are filled around the full circumference. Figure 3

- First, stick the main body's opening sealant ④ to left and right of the opening, and the main body's opening sealant ⑤A (⑤B) to the upper and lower sides of the opening.
  At this time, fold the main body opening sealant towards the inside so that the gap between the side plate and internal insulator is no longer visible.





Figure 3



JC : 1P137894D

3) Mount the branch duct chamber. (Figure 4)





Figure 4

(3) Stick the main body insulator to the indoor unit. (The figure is an example of the face ① side) (Figure 5)

Stick with the left sides of the main body insulators ①, ②, and ③ aligned.



Be sure to stick the main body insulator from the top of the branch duct chamber flange (sheet metal section). Otherwise, condensation may occur.




Figure 5

❸ Duct Connection <<Duct: KDJP55H80 ··· Nominal diameter of ϕ150 KDJP55H160 ··· Nominal diameter of ϕ200>>

1) Connect the duct to the outside of the branch duct chamber. (Figure 6)
- After the connection, wrap the connection area with tape (field supplied) to prevent an air leak.

• Apply insulation for all the ducts.

2) Do not perform duct manipulation described below.

a) Extreme bending



b) Multiple bending



c) Reduction of connecting duct diameter







Figure 6

1. Beware that, in accordance with the local law, there may be cases where the use of a nonflammable duct is compulsory.
2. When a duct goes through fire protection areas, including a fire proof structure, beware that, in accordance with the local law, it may be required to establish a damper or to build a structure that is not detrimental to fire protection.
3. When penetrating a wooden construction wall with a metal duct, apply electrical insulation to the duct and wall.

❹ Mounting of Sealing Material to Indoor Unit <<With the sealing material supplied in this kit, blocking of two openings can be performed.>>


- For the block position, refer to ❶ Preparation Before Installation, then determine the position. Always block the branch duct mounting surface.



(1) Matching the longitudinal air outlets numbered from ① to ④ to be blocked, prepare the sealing material and tape for fixing the sealing material.
- Cut both the sealing material and tape for fixing the sealing material along the perforation (dotted line).
- Stick the sealing material to the tape for fixing the sealing material. (Stick so that the sealing material is at the centre of the tape for fixing the sealing material.)

Example) When blocking air outlet ② or ③


<Sealing material preparation>



Precautions

The sealing material has a directional property. Be sure to stick the sealing material to the tape for fixing the sealing material so that the printed number of the outlet to be blocked becomes visible.

(2) Stick the sealing material that was prepared in (1) to the air outlet of the indoor unit main body.



<Mounting to air outlet>

- When blocking the air outlet ①, sealing material preparation is not necessary.

❺ Mounting of Decoration Panel

For safety, be sure to shut off power supply before starting the decoration panel mounting operation and connecting the connectors for swinging.

Refer to the installation manual attached to the decoration panel.
After mounting the decoration panel, check that no gap is present between the decoration panel and the unit's main body.

❻ Field Setting

- When mounting the branch duct chamber, setting the indoor unit main body is required. After all the engineering work is completed, perform setting together with field setting of the indoor unit.
Using the field setting mode on the remote control, switch to the setting position number shown in the table to the right. For the field setting mode, refer to "How to perform field setting" attached to the remote control.


Branch blow pattern	Mode number	Setting switch number	Setting position number
1-way branching, 3-direction blow	13 or 23	1	02
1-way branching and 2-way blow or 2-way branching and 2-way blow			03

JC : 1P137894D

KKSJ55K160 — Chamber Connection Kit




Dimensions Unit:mm



Combining with option accessories (chamber-type)

- This chamber connection kit is for use with the multi-flow set. Refer to the catalog, etc. for details on the separately sold items (chamber-type) to be connected.
- Refer to the table at right for combinations of this kit and other option accessories(chamber-type). Also, be sure to install the fresh air intake (chamber-type) kit above.



	Option accessories (chamber-type)	Above: Fresh air intake kit
below	Air purification unit	○
below	High Effciency filter unit	○
below	Ultra-long life filter unit	○
below	Fresh air intake kit	

Combinations not listed in this table should not be attempted as they will cause malfunctions.

Contents of parts

Check the following parts


Name	Relay harness	Clamping material
Shape	① 	② 
Quantity	1 PC.	2 PCS.

Installation of the Chamber connection kit.

Refer to the installation (attachment) manuals included with the indoor unit, the option accessories (chamber-type), and Decoration panel for details on installation (attachment).

Caution

Extend the Decoration panel 's swing motor lead wire using the included relay harness ① and connect it to the indoor unit. When doing this, use the included clamping material ② to tie the lead wire so it does not droop.




3P089651D

KDTP55K80 · 160 — Installation Kit for High Humidity

Dimensions **Unit:mm**

Model	AA	AB
KDTP55K80	245	157
KDTP55K160	287	186



Item \ Model	KDTP55K80	KDTP55K160
Material	Polyethylene foam	
Maximum temperature	40°CDB, RH85%	
Accessories	Insulation for hanger bracket, Installation manual	

2

Precautions

- This kit can be mounted to an ceiling mounted cassette-type air conditioner <round flow>.
- According to the chart below, check the model name of indoor unit, then mount the kit.
- This kit cannot be used for the mounting of humidifier and branch duct.

Combination table

Model name	Installable indoor unit model name	
KDTP55K80	SkyAir	FCQ(N)71KVEA
	VRV	FXFQ25~80PVE
KDTP55K160	SkyAir	FCQ(N)100·125·140KVEA
	VRV	FXFQ100·125PVE

Parts content

Name	① Side insulator plate (1)	② Side insulator plate (2)	③ Side insulator plate (3)	④ Side insulator plate (4)	⑤ Top insulator plate (1)
Shape	778mm; 80 A=245mm; 160 A=287mm; A; Slit	765mm; 80 A=245mm; 160 A=287mm; A	769mm; 80 A=245mm; 160 A=287mm; A; Slit	772mm; 80 A=245mm; 160 A=287mm; A	
Number of pieces	1	1	1	1	1

Name	⑥ Top insulator plate (2)	⑦ Top insulator plate (3)	⑧ suspension bracket insulator	⑨ Panel insulator	Others
Shape					· This manual
Number of pieces	1	1	4	4	

1 Sticking Procedure

● Perform the work on soft cloth to prevent damage to the indoor unit and panel.

<Procedure>


(1) According to the sticking procedure for the side insulator plate, stick the side insulator plates (1 to 4) in sequential order without leaving any gap in between. (Figure 1)
(When mounting the fresh air intake kit (KDDP55X160), cut off the side insulator plate (2) with a cutter knife along the perforation. The cut-off insulator is no longer needed.)

(2) Stick the top insulator plates (1 to 3) without leaving any gap in between. Also, stick the top insulator plates without leaving any gap against the side insulator plates all the way around. (Figure 2)


(3) Hang the product.

(4) Stick the suspension bracket insulator to the suspension bracket together with the washer and bolt. (Figure 3)


(5) Lastly, stick the panel insulator to the backside of the panel. (Figure 4)




(Figure 1)



(Figure 2)



(Figure 3)



(Figure 4)

JC : 3P179341C

FXCQ-M
Ceiling Mounted Cassette Type (Double-Flow)

1. Features 124
2. Specifications 126
3. Dimensions 128
4. Piping Diagrams 132
5. Wiring Diagrams 133
6. Electric Characteristics 135
7. Capacity Tables 136
   7.1 Cooling Capacity 136
   7.2 Heating Capacity 137
8. Air Velocity and Temperature Distributions (Reference Data) 138
9. Sound Levels 140
10. Installation 141
11. Accessories 144

1. Features

= Drastic change of performance, function and design =




Line-up
FXCQ20MVE~FXCQ125MVE

<Features>

Compactness

- Lowest height in the industry with whisper quietness



Low operation sound
Less weight

Improvement in installation and design flexibility


- Reduction of weight of both main unit and panel
- Standardized sectional module
- Matching the center of main unit and panel

Less maintenance

- Flat type suction grille of easy cleaning
- Detachable blade
- To minimize the soiling of the ceiling

<Details>


(1) Main technical improvement for compactness



(2) Improvements for facilitating the installation and maintenance


Facilitating the installation

- **Lighter in weight**
  (Main unit and panel)
- **Center of the ceiling opening and the unit.**
  The same position
- **Checking the drainage flow**
  The cover of inspection hatch is detachable with one touch.
- **Facilitating the checking of drainage**





Facilitating the maintenance

- **Soiling of the ceiling**
  About 1/5 of the conventional model
- **Cleaning of the suction grille**
  Easy to clean because of flat shape
- **Cleaning of the air discharge flap (Detachability)**
  The flap can be detached with one touch without removing the panel
- **Detachment of air discharge flap**



- **2 different positions of auto-swing for more comfort.**

Position of Auto-Swing	Standard Position	Ceiling Soiling Prevention Position
Operation of Auto-Swing	 Flaps swing within the range of 0°~60°	
5 Steps of Direction	 5 steps within the range of 0°~60°	 5 steps within the range of 45°~60°
Prevention of Draft	 Prevents cold draft (heating operation)	—
Auto-set Air Direction	 The position of flaps is automatically set at the position of previous operation. (Initial position is 30° for cooling, and 60° for heating.)	

2. Specifications

Ceiling Mounted Cassette Type (Double-Flow)

Model			FXCQ20MVE	FXCQ25MVE	FXCQ32MVE	FXCQ40MVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	2,000	2,500	3,200	4,000
		Btu/h	7,800	9,900	12,600	16,000
		kW	2.3	2.9	3.7	4.7
∗2 Cooling Capacity (19.0°CWB)		kW	2.2	2.8	3.6	4.5
∗3 Heating Capacity		kcal/h	2,200	2,800	3,400	4,300
		Btu/h	8,500	10,900	13,600	17,100
		kW	2.5	3.2	4.0	5.0
Casing			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	305×775×600	305×775×600	305×775×600	305×990×600
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	2×10×1.5	2×10×1.5	2×10×1.5	2×10×1.5
	Face Area	m²	2×0.100	2×0.100	2×0.100	2×0.145
Fan	Model		D17K2AA1	D17K2AB1	D17K2AB1	2D17K1AA1
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	10×1	15×1	15×1	20×1
	Air Flow Rate (H/L)	m³/min	7/5	9/6.5	9/6.5	12/9
		cfm	247/177	318/230	318/230	424/318
	Drive		Direct Drive	Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Glass Wool/Urethane Foam	Glass Wool/Urethane Foam	Glass Wool/Urethane Foam	Glass Wool/Urethane Foam
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)
	Drain Pipe	mm	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)
Machine Weight (Mass)		kg	26	26	26	31
∗5 Sound Level (H/L) (220V)		dBA	32/27	34/28	34/28	34/29
Safety Devices			Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Decoration Panels (Option)	Model		BYBC32G-W1	BYBC32G-W1	BYBC32G-W1	BYBC50G-W1
	Panel Color		White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)
	Dimensions: (H×W×D)	mm	53×1,030×680	53×1,030×680	53×1,030×680	53×1,245×680
	Air Filter		Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
	Weight	kg	8	8	8	8.5
Standard Accessories			Operation Manual. Installation Manual. Paper Pattern for Installation. Washer for Hanging Brackets. Clamp Metal. Drain Hose. Insulation for Fitting. Washer Fixing Plates. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Washer for Hanging Brackets. Clamp Metal. Drain Hose. Insulation for Fitting. Washer Fixing Plates. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Washer for Hanging Brackets. Clamp Metal. Drain Hose. Insulation for Fitting. Washer Fixing Plates. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Washer for Hanging Brackets. Clamp Metal. Drain Hose. Insulation for Fitting. Washer Fixing Plates. Sealing Pads. Clamps. Screws. Washers.
Drawing No.			C : 3D039413			

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit center. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 135 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Ceiling Mounted Cassette Type (Double-Flow)

Model			FXCQ50MVE	FXCQ63MVE	FXCQ80MVE	FXCQ125MVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	5,000	6,300	8,000	12,500
		Btu/h	19,800	24,900	31,700	49,500
		kW	5.8	7.3	9.3	14.5
∗2 Cooling Capacity (19.0°CWB)		kW	5.6	7.1	9.0	14.0
∗3 Heating Capacity		kcal/h	5,400	6,900	8,600	13,800
		Btu/h	21,500	27,300	34,100	54,600
		kW	6.3	8.0	10.0	16.0
Casing			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	305×990×600	305×1,175×600	305×1,665×600	305×1,665×600
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	2×10×1.5	2×10×1.5	2×10×1.5	2×10×1.5
	Face Area	m²	2×0.145	2×0.184	2×0.287	2×0.287
Fan	Model		2D17K1AA1	2D17K2AA1VE	3D17K2AA1	3D17K2AB1
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	20×1	30×1	50×1	85×1
	Air Flow Rate (H/L)	m³/min	12/9	16.5/13	26/21	33/25
		cfm	424/318	582/459	918/741	1,165/883
	Drive		Direct Drive	Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Glass Wool/Urethane Foam	Glass Wool/Urethane Foam	Glass Wool/Urethane Foam	Glass Wool/Urethane Foam
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe	mm	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)
Machine Weight (Mass)		kg	32	35	47	48
∗5 Sound Level (H/L) (220V)		dBA	34/29	37/32	39/34	44/38
Safety Devices			Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Decoration Panels (Option)	Model		BYBC50G-W1	BYBC63G-W1	BYBC125G-W1	BYBC125G-W1
	Panel Color		White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)
	Dimensions: (H×W×D)	mm	53×1,245×680	53×1,430×680	53×1,920×680	53×1,920×680
	Air Filter		Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
	Weight	kg	8.5	9.5	12	12
Standard Accessories			Operation Manual. Installation Manual. Paper Pattern for Installation. Washer for Hanging Brackets. Clamp Metal. Drain Hose. Insulation for Fitting. Washer Fixing Plates. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Washer for Hanging Brackets. Clamp Metal. Drain Hose. Insulation for Fitting. Washer Fixing Plates. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Washer for Hanging Brackets. Clamp Metal. Drain Hose. Insulation for Fitting. Washer Fixing Plates. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Washer for Hanging Brackets. Clamp Metal. Drain Hose. Insulation for Fitting. Washer Fixing Plates. Sealing Pads. Clamps. Screws. Washers.
Drawing No.			C : 3D039413			

Note:


∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit center. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 135 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

3. Dimensions

FXCQ20M + BYBC32G-W1 (Decoration Panel)
FXCQ25M + BYBC32G-W1 (Decoration Panel)
FXCQ32M + BYBC32G-W1 (Decoration Panel)

Unit (mm)




Number	Name	Description
1	Liquid pipe connection port	φ6.4mm flare connection
2	Gas pipe connection port	φ12.7mm flare connection
3	Drain pipe connection port	VP25 (O.D. φ32, I.D. φ25)
4	Power wiring port	
5	Air discharge port	
6	Air suction grille	
7	Port for water supply	
8	Drain hose	O.D. φ32
9	Socket for drain	

3D039405A

Notes:
1. Location of unit's Name plate
   For Main body: Filter install plate inside surface of suction grille
   For decoration panel: Panel frame inside surface of suction grille.
2. When installing an optional accessory, refer to the installation drawings.
3. In case of using wireless remote controller, this position will be a signal receiver.
   Refer to the drawing of wireless remote controller in detail.
4. If it is assumed that the relative humidity above the ceiling exceeds 80%, stic the additional insulation to the unit.
   Insulation: 10mm thick or more,
   Glass fiber of polyethylene foam.

FXCQ40M + BYBC50G-W1 (Decoration Panel)
FXCQ50M + BYBC50G-W1 (Decoration Panel)




Number	Name	Description
1	Liquid pipe connection port	ϕ6.4mm flare connection
2	Gas pipe connection port	ϕ12.7mm flare connection
3	Drain pipe connection port	VP25 (O.D. ϕ32, I.D. ϕ25)
4	Power wiring port	
5	Air discharge port	
6	Air suction grille	
7	Port for water supply	
8	Drain hose	O.D. ϕ32
9	Socket for drain	

Notes:
1. Location of unit's Name plate
   For Main body: Filter install plate inside surface of suction grille
   For decoration panel: Panel frame inside surface of suction grille.
2. When installing an optional accessory, refer to the installation drawings.
3. In case of using wireless remote controller, this position will be a signal receiver.
   Refer to the drawing of wireless remote controller in detail.
4. If it is assumed that the relative humidity above the ceiling exceeds 80%, stic the additional insulation to the unit.
   Insulation: 10mm thick or more,
   Glass fiber of polyethylene foam.

FXCQ63M + BYBC63G-W1 (Decoration Panel)

Unit (mm)




Number	Name	Description
1	Liquid pipe connection port	φ9.5mm flare connection
2	Gas pipe connection port	φ15.9mm flare connection
3	Drain pipe connection port	VP25 (O.D. φ32, I.D. φ25)
4	Power wiring port	
5	Air discharge port	
6	Air suction grille	
7	Port for water supply	
8	Drain hose	O.D. φ32
9	Socket for drain	

Notes:
1. Location of unit's Name plate
   For Main body: Filter install plate inside surface of suction grille
   For decoration panel: Panel frame inside surface of suction grille.
2. When installing an optional accessory, refer to the installation drawings.
3. In case of using wireless remote controller, this position will be a signal receiver.
   Refer to the drawing of wireless remote controller in detail.
4. If it is assumed that the relative humidity above the ceiling exceeds 80%, stic the additional insulation to the unit.
   Insulation: 10mm thick or more,
   Glass fiber of polyethylene foam.

FXCQ80M + BYBC125G-W1 (Decoration Panel)
FXCQ125M + BYBC125G-W1 (Decoration Panel)

Unit (mm)




Number	Name	Description
1	Liquid pipe connection port	φ9.5mm flare connection
2	Gas pipe connection port	φ15.9mm flare connection
3	Drain pipe connection port	VP25 (O.D. φ32, I.D. φ25)
4	Power wiring port	
5	Air discharge port	
6	Air suction grille	
7	Port for water supply	
8	Drain hose	O.D. φ32
9	Socket for drain	

3D039409A

Notes:
1. Location of unit's Name plate
   For Main body: Filter install plate inside surface of suction grille
   For decoration panel: Panel frame inside surface of suction grille.
2. When installing an optional accessory, refer to the installation drawings.
3. In case of using wireless remote controller, this position will be a signal receiver.
   Refer to the drawing of wireless remote controller in detail.
4. If it is assumed that the relative humidity above the ceiling exceeds 80%, stic the additional insulation to the unit.
   Insulation: 10mm thick or more,
   Glass fiber of polyethylene foam.

4. Piping Diagrams



4D034245C


■ **Refrigerant pipe connection port diameters**

(mm)

Model	Gas	Liquid
FXCQ20 · 25 · 32 · 40 · 50M	ϕ12.7	ϕ6.4
FXCQ63 · 80 · 125M	ϕ15.9	ϕ9.5

5. Wiring Diagrams

FXCQ20 · 25 · 32 · 63MVE




INDOOR UNIT		RECEIVER/DISPLAY UNIT (ATTACHED TO WIRELESS REMOTE CONTROLLER)	
A1P	PRINTED CIRCUIT BOARD	A2P	PRINTED CIRCUIT BOARD
C1R	CAPACITOR (M1F)	A3P	PRINTED CIRCUIT BOARD
F1U	FUSE (Ⓑ, 5A, 250V)	BS1	PUSH BUTTON (ON/OFF)
HAP	LIGHT EMITTING DIODE (SERVICE MONITOR-GREEN)	H1P	LIGHT EMITTING DIODE (ON-RED)
K1R-K3R	MAGNETIC RELAY (M1F)	H2P	LIGHT EMITTING DIODE (TIMER-GREEN)
KAR	MAGNETIC RELAY (M1S)	H3P	LIGHT EMITTING DIODE (FILTER SIGN-RED)
KPR	MAGNETIC RELAY (M1P)	H4P	LIGHT EMITTING DIODE (DEFROST-ORANGE)
M1F	MOTOR (INDOOR FAN)	SS1	SELECTOR SWITCH (MAIN/SUB)
M1P	MOTOR (DRAIN PUMP)	SS2	SELECTOR SWITCH (WIRELESS ADDRESS SET)
M1S	MOTOR (SWING FLAP)	CONNECTOR FOR OPTIONAL PARTS	
Q1M	THERMO SWITCH (M1F EMBEDDED)	X18A	CONNECTOR (WIRING ADAPTOR FOR ELECTORICAL APPENDICES)
R1T	THERMISTOR (AIR)		
R2T : R3T	THERMISTOR (COIL)	X23A	CONNECTOR (WIRELESS REMOTE CONTROLLER)
S1L	FLOAT SWITCH		
S1Q	LIMIT SWITCH (SWING FLAP)		
T1R	TRANSFORMER (220-240V/22V)		
X1M	TERMINAL BLOCK (POWER)		
X2M	TERMINAL BLOCK (CONTROL)		
Y1E	ELECTRONIC EXPANSION VALVE		
WIRED REMOTE CONTROLLER			
R1T	THERMISTOR (AIR)		
SS1	SELECTOR SWITCH (MAIN/SUB)		

NOTES) 1. □□□ : TERMINAL BLOCK, ⊂⊃, ⊃– : CONNECTOR, –○– : TERMINAL
2. ═══ : FIELD WIRING
3. IN CASE USING CENTRAL REMOTE CONTROLLER, CONNECT IT TO THE UNIT IN ACCORDANCE WITH THE ATTACHED INSTRUCTION MANUAL.
4. X23A IS CONNECTED WHEN THE WIRELESS REMOTE CONTROLLER KIT IS BEING USED.
5. WHEN CONNECTING THE INPUT WIRES FROM OUTSIDE, FORCED OFF OR ON/OFF CONTROL OPERATION CAN BE SELECTED BY REMOTE CONTROLLER. IN DETAILS, REFER TO THE INSTALLATION MANUAL ATTACHED THE UNIT.
6. SYMBOLS SHOWS AS FOLLOWS.
(PNK : PINK WHT : WHITE YLW : YELLOW ORG : ORANGE BLU : BLUE BLK : BLACK RED : RED BRN : BROWN GRN : GREEN)
7. USE COPPER CONDUCTORS ONLY.

3D039556A

FXCQ40 · 50 · 80 · 125MVE



INDOOR UNIT		RECEIVER/DISPLAY UNIT (ATTACHED TO WIRELESS REMOTE CONTROLLER)	
A1P	PRINTED CIRCUIT BOARD	A2P	PRINTED CIRCUIT BOARD
C1R	CAPACITOR (M1F)	A3P	PRINTED CIRCUIT BOARD
F1U	FUSE (Ⓑ, 5A, 250V)	BS1	PUSH BUTTON (ON/OFF)
HAP	LIGHT EMITTING DIODE (SERVICE MONITOR-GREEN)	H1P	LIGHT EMITTING DIODE (ON-RED)
K1R-K3R	MAGNETIC RELAY (M1F)	H2P	LIGHT EMITTING DIODE (TIMER-GREEN)
KAR	MAGNETIC RELAY (M1S)	H3P	LIGHT EMITTING DIODE (FILTER SIGN-RED)
KPR	MAGNETIC RELAY (M1P)	H4P	LIGHT EMITTING DIODE (DEFROST-ORANGE)
M1F	MOTOR (INDOOR FAN)	SS1	SELECTOR SWITCH (MAIN/SUB)
M1P	MOTOR (DRAIN PUMP)	SS2	SELECTOR SWITCH (WIRELESS ADDRESS SET)
M1S	MOTOR (SWING FLAP)		CONNECTOR FOR OPTIONAL PARTS
Q1M	THERMO SWITCH (M1F EMBEDDED)	X18A	CONNECTOR (WIRING ADAPTOR FOR ELECTORICAL APPENDICES)
R1T	THERMISTOR (AIR)		
R2T · R3T	THERMISTOR (COIL)	X23A	CONNECTOR (WIRELESS REMOTE CONTROLLER)
S1L	FLOAT SWITCH		
S1Q	LIMIT SWITCH (SWING FLAP)		
T1R	TRANSFORMER (220-240V/22V)		
X1M	TERMINAL BLOCK (POWER)		
X2M	TERMINAL BLOCK (CONTROL)		
Y1E	ELECTRONIC EXPANSION VALVE		
	WIRED REMOTE CONTROLLER		
R1T	THERMISTOR (AIR)		
SS1	SELECTOR SWITCH (MAIN/SUB)		

NOTES) 1. □□□ : TERMINAL BLOCK, ⊡⊡, ⊡– : CONNECTOR, –○– : TERMINAL
2. ═══ : FIELD WIRING
3. IN CASE USING CENTRAL REMOTE CONTROLLER, CONNECT IT TO THE UNIT IN ACCORDANCE WITH THE ATTACHED INSTRUCTION MANUAL.
4. X23A IS CONNECTED WHEN THE WIRELESS REMOTE CONTROLLER KIT IS BEING USED.
5. WHEN CONNECTING THE INPUT WIRES FROM OUTSIDE, FORCED OFF OR ON/OFF CONTROL OPERATION CAN BE SELECTED BY REMOTE CONTROLLER. IN DETAILS, REFER TO THE INSTALLATION MANUAL ATTACHED THE UNIT.
6. SYMBOLS SHOWS AS FOLLOWS.
(PNK : PINK WHT : WHITE YLW : YELLOW ORG : ORANGE BLU : BLUE BLK : BLACK RED : RED BRN : BROWN GRN : GREEN)
7. USE COPPER CONDUCTORS ONLY.

3D039557A

6. Electric Characteristics

Units					Power supply		IFM		Input(W)	
Model	Type	Hz	Volts	Voltage range	MCA	MFA	KW	FLA	Cooling	Heating
FXCQ20M	VE	50	220-240	MAX. 264 Min. 198	0.5	15	0.010	0.4	77	44
FXCQ25 · 32M					0.5	15	0.015	0.4	92	59
FXCQ40 · 50M					0.8	15	0.020	0.6	130	97
FXCQ63M					0.9	15	0.030	0.7	161	126
FXCQ80M					1.1	15	0.050	0.9	209	176
FXCQ125M					1.3	15	0.085	1.0	256	223
FXCQ20M	VE	60	220	MAX. 242 Min. 198	0.5	15	0.010	0.4	81	48
FXCQ25 · 32M					0.5	15	0.015	0.4	95	62
FXCQ40 · 50M					0.8	15	0.020	0.6	132	99
FXCQ63M					0.9	15	0.030	0.7	157	124
FXCQ80M					1.3	15	0.050	1.0	216	183
FXCQ125M					1.5	15	0.085	1.2	278	245

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
KW : Fan Motor Rated Output(KW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

Note:

1. Voltage range

   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.

2. Maximum allowable voltage unbalance between phases is 2%.

3. MCA/MFA

   MCA = 1.25 X FLA

   MFA ≦ 4 X FLA

   (Next lower standard fuse rating. Min. 15A)

4. Select wire size based on the MCA.

5. Instead of fuse, use Circuit Breaker.

C : 4D034243A

7. Capacity Tables

7.1 Cooling Capacity

FXCQ-M **[50/60Hz]**

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	SHC	16.0°CWB 23°CDB TC	SHC	18.0°CWB 26°CDB TC	SHC	19.0°CWB 27°CDB TC	SHC	20.0°CWB 28°CDB TC	SHC	22.0°CWB 30°CDB TC	SHC	24.0°CWB 32°CDB TC	SHC
20	10.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.9	1.7
	12.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.9	1.7
	14.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.8	1.7
	16.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.8	1.7
	18.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.7	1.7
	20.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.7	1.6
	21.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.7	1.6
	23.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.6	1.6
	25.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.6	1.6
	27.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.6	1.6
	29.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.5	1.7	2.5	1.6
	31.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.4	1.7	2.5	1.5
	33.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.4	1.6	2.4	1.5
	35.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.7	2.4	1.6	2.4	1.5
	37.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.7	2.3	1.6	2.4	1.5
	39.0	1.5	1.4	1.8	1.5	2.1	1.7	2.2	1.7	2.2	1.7	2.3	1.7	2.3	1.5
25	10.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.4	2.2	3.7	2.2
	12.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.4	2.2	3.6	2.2
	14.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.4	2.2	3.6	2.2
	16.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.4	2.2	3.5	2.2
	18.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.4	2.2	3.5	2.1
	20.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.4	2.2	3.4	2.1
	23.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.4	2.2	3.4	2.1
	25.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.3	2.2	3.3	2.1
	27.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.2	2.2	3.3	2.0
	29.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.2	2.1	3.2	2.0
	31.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.1	2.1	3.2	2.0
	33.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.1	2.1	3.1	2.0
	35.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	3.0	2.2	3.0	2.1	3.1	1.9
	37.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	2.9	2.2	3.0	2.0	3.0	1.9
	39.0	1.9	1.7	2.3	1.9	2.6	2.1	2.8	2.2	2.9	2.2	2.9	2.0	3.0	1.9
32	10.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.3	2.7	4.7	2.7
	12.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.3	2.7	4.7	2.7
	14.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.3	2.7	4.6	2.7
	16.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.3	2.7	4.6	2.6
	18.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.3	2.7	4.5	2.6
	20.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.3	2.7	4.4	2.5
	21.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.3	2.7	4.4	2.5
	23.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.2	2.6	4.3	2.5
	25.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.2	2.6	4.3	2.5
	27.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.1	2.6	4.2	2.4
	29.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.1	2.5	4.2	2.4
	31.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	4.0	2.5	4.1	2.4
	33.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	3.9	2.5	4.0	2.4
	35.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.8	2.6	3.8	2.5	3.9	2.3
	37.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.7	2.6	3.8	2.4	3.8	2.3
	39.0	2.4	2.1	2.9	2.3	3.4	2.5	3.6	2.6	3.7	2.6	3.8	2.4	3.8	2.3
40	10.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.4	3.3	5.9	3.3
	12.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.4	3.3	5.8	3.3
	14.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.4	3.3	5.8	3.2
	16.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.4	3.3	5.7	3.2
	18.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.4	3.3	5.6	3.2
	20.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.4	3.3	5.5	3.1
	21.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.4	3.3	5.5	3.1
	23.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.3	3.3	5.4	3.1
	25.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.2	3.3	5.3	3.0
	27.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.2	3.2	5.3	3.0
	29.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.1	3.2	5.2	3.0
	31.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	5.0	3.1	5.1	2.9
	33.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.8	3.3	4.9	3.1	5.0	2.9
	35.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.7	3.3	4.9	3.1	5.0	2.9
	37.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.7	3.2	4.8	3.0	4.9	2.8
	39.0	3.0	2.5	3.6	2.8	4.2	3.1	4.5	3.2	4.6	3.2	4.7	3.0	4.8	2.8

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	SHC	16.0°CWB 23°CDB TC	SHC	18.0°CWB 26°CDB TC	SHC	19.0°CWB 27°CDB TC	SHC	20.0°CWB 28°CDB TC	SHC	22.0°CWB 30°CDB TC	SHC	24.0°CWB 32°CDB TC	SHC
50	10.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	7.4	4.0
	12.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	7.3	4.0
	14.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	7.2	3.9
	16.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	7.1	3.9
	18.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	7.0	3.9
	20.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	6.9	3.8
	21.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	6.8	3.8
	23.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.6	4.0	6.7	3.8
	25.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.5	4.0	6.6	3.7
	27.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.4	3.9	6.6	3.7
	29.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.3	3.9	6.5	3.6
	31.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.2	3.8	6.4	3.6
	33.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.1	3.8	6.3	3.6
	35.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.0	3.8	6.2	3.5
	37.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	5.9	4.0	5.9	3.7	6.1	3.5
	39.0	3.8	3.1	4.5	3.4	5.2	3.8	5.6	3.9	5.9	3.9	5.8	3.7	6.0	3.4
63	10.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.5	5.0	9.3	5.0
	12.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.5	5.0	9.2	5.0
	14.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.5	5.0	9.1	4.9
	16.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.5	5.0	9.0	4.9
	18.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.5	5.0	8.8	4.8
	20.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.5	5.0	8.7	4.7
	21.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.5	5.0	8.7	4.7
	23.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.4	4.9	8.5	4.6
	25.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.3	4.9	8.4	4.6
	27.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.1	4.8	8.3	4.5
	29.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	8.0	4.7	8.2	4.5
	31.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	7.9	4.7	8.1	4.4
	33.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.6	4.9	7.8	4.6	7.9	4.4
	35.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.5	4.8	7.7	4.6	7.8	4.4
	37.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.4	4.8	7.5	4.5	7.7	4.3
	39.0	4.8	3.8	5.7	4.2	6.6	4.7	7.1	4.9	7.2	4.7	7.4	4.5	7.6	4.3
80	10.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.8	6.8	11.8	6.7
	12.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.8	6.8	11.7	6.6
	14.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.8	6.8	11.5	6.6
	16.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.8	6.8	11.4	6.5
	18.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.8	6.8	11.2	6.4
	20.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.8	6.8	11.1	6.3
	21.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.8	6.8	11.0	6.3
	23.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.6	6.7	10.8	6.3
	25.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.5	6.6	10.7	6.2
	27.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.3	6.6	10.5	6.1
	29.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.2	6.5	10.4	6.0
	31.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	10.0	6.4	10.2	6.0
	33.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.6	6.5	9.8	6.3	10.1	5.9
	35.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.5	6.4	9.7	6.3	9.9	5.8
	37.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.3	6.4	9.5	6.2	9.8	5.7
	39.0	6.1	5.2	7.2	5.7	8.4	6.2	9.0	6.3	9.2	6.3	9.4	6.1	9.6	5.7
125	10.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	16.8	10.2	18.4	10.3
	12.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	16.8	10.2	18.2	10.2
	14.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	16.8	10.2	18.0	10.1
	16.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	16.8	10.2	17.7	9.9
	18.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	16.8	10.2	17.5	9.8
	20.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	16.8	10.2	17.2	9.7
	21.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	16.8	10.2	17.1	9.6
	23.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	16.5	10.1	16.9	9.5
	25.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	16.3	10.0	16.6	9.4
	27.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	16.1	9.8	16.4	9.3
	29.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	15.8	9.7	16.2	9.3
	31.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	15.6	9.6	15.9	9.2
	33.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.9	9.9	15.3	9.5	15.7	9.1
	35.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.8	9.9	15.1	9.4	15.4	9.0
	37.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.7	14.5	9.7	14.9	9.3	15.2	8.9
	39.0	7.8	6.1	11.3	8.6	13.1	9.5	14.0	9.8	14.3	9.6	14.6	9.2	15.0	8.8

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

7.2 Heating Capacity

FXCQ-M [50/60Hz]

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
20	-19.8	-20.0	1.5	1.5	1.5	1.5	1.5	1.5
	-18.8	-19.0	1.5	1.5	1.5	1.5	1.5	1.5
	-16.7	-17.0	1.6	1.6	1.6	1.6	1.6	1.6
	-14.7	-15.0	1.7	1.7	1.7	1.7	1.7	1.7
	-12.6	-13.0	1.8	1.8	1.8	1.8	1.8	1.8
	-10.5	-11.0	1.9	1.9	1.9	1.9	1.9	1.9
	-9.5	-10.0	1.9	1.9	1.9	1.9	1.9	1.9
	-8.5	-9.1	2.0	2.0	1.9	1.9	1.9	1.9
	-7.0	-7.6	2.0	2.0	2.0	2.0	2.0	2.0
	-5.0	-5.6	2.1	2.1	2.1	2.1	2.1	2.1
	-3.0	-3.7	2.2	2.2	2.2	2.2	2.2	2.2
	0.0	-0.7	2.3	2.3	2.3	2.3	2.3	2.2
	3.0	2.2	2.5	2.5	2.4	2.4	2.3	2.2
	5.0	4.1	2.5	2.5	2.5	2.4	2.3	2.2
	7.0	6.0	2.6	2.6	2.5	2.4	2.3	2.2
	9.0	7.9	2.7	2.7	2.5	2.4	2.3	2.2
	11.0	9.8	2.8	2.7	2.5	2.4	2.3	2.2
	13.0	11.8	2.8	2.7	2.5	2.4	2.3	2.2
	15.0	13.7	2.8	2.7	2.5	2.4	2.3	2.2
25	-19.8	-20.0	1.9	1.9	1.9	1.9	1.9	1.9
	-18.8	-19.0	1.9	1.9	1.9	1.9	1.9	1.9
	-16.7	-17.0	2.1	2.1	2.0	2.0	2.0	2.0
	-14.7	-15.0	2.2	2.2	2.2	2.2	2.2	2.1
	-12.6	-13.0	2.3	2.3	2.3	2.3	2.3	2.3
	-10.5	-11.0	2.4	2.4	2.4	2.4	2.4	2.4
	-9.5	-10.0	2.5	2.4	2.4	2.4	2.4	2.4
	-8.5	-9.1	2.5	2.5	2.5	2.5	2.5	2.5
	-7.0	-7.6	2.6	2.6	2.6	2.6	2.6	2.6
	-5.0	-5.6	2.7	2.7	2.7	2.7	2.7	2.7
	-3.0	-3.7	2.8	2.8	2.8	2.8	2.8	2.8
	0.0	-0.7	3.0	3.0	3.0	3.0	3.0	2.8
	3.0	2.2	3.1	3.1	3.1	3.1	3.0	2.8
	5.0	4.1	3.3	3.2	3.2	3.1	3.0	2.8
	7.0	6.0	3.4	3.4	3.2	3.1	3.0	2.8
	9.0	7.9	3.5	3.4	3.2	3.1	3.0	2.8
	11.0	9.8	3.6	3.4	3.2	3.1	3.0	2.8
	13.0	11.8	3.6	3.4	3.2	3.1	3.0	2.8
	15.0	13.7	3.6	3.4	3.2	3.1	3.0	2.8
32	-19.8	-20.0	2.4	2.4	2.3	2.3	2.3	2.3
	-18.8	-19.0	2.4	2.4	2.4	2.4	2.4	2.4
	-16.7	-17.0	2.6	2.6	2.6	2.6	2.6	2.5
	-14.7	-15.0	2.7	2.7	2.7	2.7	2.7	2.7
	-12.6	-13.0	2.9	2.8	2.8	2.8	2.8	2.8
	-10.5	-11.0	3.0	3.0	3.0	3.0	3.0	3.0
	-9.5	-10.0	3.1	3.1	3.1	3.1	3.0	3.0
	-8.5	-9.1	3.1	3.1	3.1	3.1	3.1	3.1
	-7.0	-7.6	3.2	3.2	3.2	3.2	3.2	3.2
	-5.0	-5.6	3.4	3.4	3.4	3.4	3.4	3.4
	-3.0	-3.7	3.5	3.5	3.5	3.5	3.5	3.5
	0.0	-0.7	3.7	3.7	3.7	3.7	3.7	3.5
	3.0	2.2	3.9	3.9	3.9	3.9	3.7	3.5
	5.0	4.1	4.1	4.1	4.0	3.9	3.7	3.5
	7.0	6.0	4.2	4.2	4.0	3.9	3.7	3.5
	9.0	7.9	4.3	4.3	4.0	3.9	3.7	3.5
	11.0	9.8	4.5	4.3	4.0	3.9	3.7	3.5
	13.0	11.8	4.5	4.3	4.0	3.9	3.7	3.5
	15.0	13.7	4.5	4.3	4.0	3.9	3.7	3.5
40	-19.8	-20.0	3.0	2.9	2.9	2.9	2.9	2.9
	-18.8	-19.0	3.0	3.0	3.0	3.0	3.0	3.0
	-16.7	-17.0	3.2	3.2	3.2	3.2	3.2	3.2
	-14.7	-15.0	3.4	3.4	3.4	3.4	3.4	3.4
	-12.6	-13.0	3.6	3.6	3.6	3.5	3.5	3.5
	-10.5	-11.0	3.7	3.7	3.7	3.7	3.7	3.7
	-9.5	-10.0	3.8	3.8	3.8	3.8	3.8	3.8
	-8.5	-9.1	3.9	3.9	3.9	3.9	3.9	3.9
	-7.0	-7.6	4.0	4.0	4.0	4.0	4.0	4.0
	-5.0	-5.6	4.2	4.2	4.2	4.2	4.2	4.2
	-3.0	-3.7	4.4	4.4	4.4	4.4	4.4	4.4
	0.0	-0.7	4.7	4.6	4.6	4.6	4.6	4.4
	3.0	2.2	4.9	4.9	4.9	4.8	4.7	4.4
	5.0	4.1	5.1	5.1	5.0	4.8	4.7	4.4
	7.0	6.0	5.2	5.2	5.0	4.8	4.7	4.4
	9.0	7.9	5.4	5.3	5.0	4.8	4.7	4.4
	11.0	9.8	5.6	5.3	5.0	4.8	4.7	4.4
	13.0	11.8	5.6	5.3	5.0	4.8	4.7	4.4
	15.0	13.7	5.6	5.3	5.0	4.8	4.7	4.4

Heating capacity


Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
50	-19.8	-20.0	3.7	3.7	3.7	3.7	3.7	3.7
	-18.8	-19.0	3.8	3.8	3.8	3.8	3.8	3.8
	-16.7	-17.0	4.1	4.0	4.0	4.0	4.0	4.0
	-14.7	-15.0	4.3	4.3	4.3	4.2	4.2	4.2
	-12.6	-13.0	4.5	4.5	4.5	4.5	4.5	4.5
	-10.5	-11.0	4.7	4.7	4.7	4.7	4.7	4.7
	-9.5	-10.0	4.8	4.8	4.8	4.8	4.8	4.8
	-8.5	-9.1	4.9	4.9	4.9	4.9	4.9	4.9
	-7.0	-7.6	5.1	5.1	5.1	5.1	5.1	5.1
	-5.0	-5.6	5.3	5.3	5.3	5.3	5.3	5.3
	-3.0	-3.7	5.5	5.5	5.5	5.5	5.5	5.5
	0.0	-0.7	5.9	5.9	5.8	5.8	5.8	5.5
	3.0	2.2	6.2	6.2	6.2	6.1	5.9	5.5
	5.0	4.1	6.4	6.4	6.3	6.1	5.9	5.5
	7.0	6.0	6.6	6.6	6.3	6.1	5.9	5.5
	9.0	7.9	6.8	6.7	6.3	6.1	5.9	5.5
	11.0	9.8	7.0	6.7	6.3	6.1	5.9	5.5
	13.0	11.8	7.1	6.7	6.3	6.1	5.9	5.5
	15.0	13.7	7.1	6.7	6.3	6.1	5.9	5.5
63	-19.8	-20.0	4.7	4.7	4.7	4.7	4.7	4.7
	-18.8	-19.0	4.9	4.9	4.8	4.8	4.8	4.8
	-16.7	-17.0	5.1	5.1	5.1	5.1	5.1	5.1
	-14.7	-15.0	5.4	5.4	5.4	5.4	5.4	5.4
	-12.6	-13.0	5.7	5.7	5.7	5.7	5.7	5.7
	-10.5	-11.0	6.0	6.0	6.0	6.0	6.0	5.9
	-9.5	-10.0	6.1	6.1	6.1	6.1	6.1	6.1
	-8.5	-9.1	6.3	6.3	6.2	6.2	6.2	6.2
	-7.0	-7.6	6.5	6.5	6.4	6.4	6.4	6.4
	-5.0	-5.6	6.8	6.7	6.7	6.7	6.7	6.7
	-3.0	-3.7	7.0	7.0	7.0	7.0	7.0	7.0
	0.0	-0.7	7.5	7.4	7.4	7.4	7.4	7.0
	3.0	2.2	7.9	7.8	7.8	7.7	7.5	7.0
	5.0	4.1	8.1	8.1	8.0	7.7	7.5	7.0
	7.0	6.0	8.4	8.4	8.0	7.7	7.5	7.0
	9.0	7.9	8.7	8.5	8.0	7.7	7.5	7.0
	11.0	9.8	8.9	8.5	8.0	7.7	7.5	7.0
	13.0	11.8	9.0	8.5	8.0	7.7	7.5	7.0
	15.0	13.7	9.0	8.5	8.0	7.7	7.5	7.0
80	-19.8	-20.0	5.9	5.9	5.9	5.9	5.9	5.8
	-18.8	-19.0	6.1	6.1	6.0	6.0	6.0	6.0
	-16.7	-17.0	6.4	6.4	6.4	6.4	6.4	6.4
	-14.7	-15.0	6.8	6.8	6.8	6.7	6.7	6.7
	-12.6	-13.0	7.1	7.1	7.1	7.1	7.1	7.1
	-10.5	-11.0	7.5	7.5	7.5	7.5	7.4	7.4
	-9.5	-10.0	7.7	7.7	7.6	7.6	7.6	7.6
	-8.5	-9.1	7.8	7.8	7.8	7.8	7.8	7.8
	-7.0	-7.6	8.1	8.1	8.1	8.1	8.0	8.0
	-5.0	-5.6	8.4	8.4	8.4	8.4	8.4	8.4
	-3.0	-3.7	8.8	8.8	8.7	8.7	8.7	8.7
	0.0	-0.7	9.3	9.3	9.3	9.3	9.3	8.7
	3.0	2.2	9.8	9.8	9.8	9.7	9.4	8.7
	5.0	4.1	10.2	10.1	10.0	9.7	9.4	8.7
	7.0	6.0	10.5	10.5	10.0	9.7	9.4	8.7
	9.0	7.9	10.8	10.6	10.0	9.7	9.4	8.7
	11.0	9.8	11.2	10.6	10.0	9.7	9.4	8.7
	13.0	11.8	11.3	10.6	10.0	9.7	9.4	8.7
	15.0	13.7	11.3	10.6	10.0	9.7	9.4	8.7
125	-19.8	-20.0	9.4	9.4	9.4	9.4	9.4	9.3
	-18.8	-19.0	9.7	9.7	9.7	9.7	9.6	9.6
	-16.7	-17.0	10.3	10.3	10.2	10.2	10.2	10.2
	-14.7	-15.0	10.9	10.8	10.8	10.8	10.8	10.7
	-12.6	-13.0	11.4	11.4	11.4	11.4	11.3	11.3
	-10.5	-11.0	12.0	12.0	11.9	11.9	11.9	11.9
	-9.5	-10.0	12.3	12.2	12.2	12.2	12.2	12.2
	-8.5	-9.1	12.5	12.5	12.5	12.5	12.4	12.4
	-7.0	-7.6	13.0	12.9	12.9	12.9	12.9	12.8
	-5.0	-5.6	13.5	13.5	13.5	13.4	13.4	13.4
	-3.0	-3.7	14.1	14.0	14.0	14.0	14.0	13.9
	0.0	-0.7	14.9	14.9	14.8	14.8	14.8	13.9
	3.0	2.2	15.7	15.7	15.7	15.5	15.0	13.9
	5.0	4.1	16.3	16.2	16.0	15.5	15.0	13.9
	7.0	6.0	16.8	16.8	16.0	15.5	15.0	13.9
	9.0	7.9	17.3	17.0	16.0	15.5	15.0	13.9
	11.0	9.8	17.9	17.0	16.0	15.5	15.0	13.9
	13.0	11.8	18.1	17.0	16.0	15.5	15.0	13.9
	15.0	13.7	18.1	17.0	16.0	15.5	15.0	13.9

Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

8. Air Velocity and Temperature Distributions (Reference Data)


FXCQ63M

(Heating · Air Velocity Distribution)
Discharge Angle : 60°



FXCQ63M


(Heating · Temperature Distribution)
Discharge Angle : 60°



Note:
The standard setup height of the double-flow type is 3 m maximum. Shown here is the measurement distribution at the ceiling height of 3 m.


FXCQ125M

(Heating · Air Velocity Distribution)
Discharge Angle : 60°



FXCQ125M

(Heating · Temperature Distribution)
Discharge Angle : 60°




Note:
The standard setup height of the double-flow type is 3 m maximum. Shown here is the measurement distribution at the ceiling height of 3 m.

9. Sound Levels

Overall

■ **Ceiling Mounted Cassette Type (Double-Flow)**



4D034329

dBA

Model	220V, 50/60Hz		240V, 50Hz	
	H	L	H	L
FXCQ20M	32	27	34	29
FXCQ25M FXCQ32M	34	28	36	30
FXCQ40M FXCQ50M	34	29	37	32
FXCQ63M	37	32	39	34
FXCQ80M	39	34	41	36
FXCQ125M	44	38	46	40


Note:

1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.

Octave Band Level


○——○ 220V 50/60Hz
○- - - -○ 240V 50Hz

FXCQ20MVE




4D034329

FXCQ25 · 32MVE




4D034330

FXCQ40 · 50MVE




4D034331

FXCQ63MVE




4D034332

FXCQ80MVE



4D034333

FXCQ125MVE




4D034334

10. Installation

Center of Gravity

Unit (mm)




MODEL	A	B
FXCQ20 • 25 • 32MVE	20	140
FXCQ40 • 50MVE	25	
FXCQ63MVE	30	
FXCQ80 • 125MVE	35	150

C : 4D034788B


Service Space

Unit (mm)



Note:
Above figure means minimum value. Please keep these value at least.

Bolt Pitch



(Unit : mm)

Model	A	B	C	D
FXCQ20 · 25 · 32MVE	990	820	775	1030
FXCQ40 · 50MVE	1205	1035	990	1245
FXCQ63MVE	1390	1220	1175	1430
FXCQ80 · 125MVE	1880	1710	1665	1920

3PR01906-7R

Drain Pump Kit


Indoor unit	Drain pump kit
FXCQ–M	Standard (Equipped with indoor unit)

Drain Piping Work

〈〈**Rig the drain pipe as shown below and take measures against condensation. Improperly rigged piping could lead to leaks and eventually wet furniture and belongings.**〉〉

(1) Carry out the drain piping


- The diameter of the drain pipe should be greater than or equal to the diameter of the connecting pipe (vinyl tube ; pipe size : 25 mm ; outer dimension : 32 mm).
- Keep the drain pipe short and sloping downwards at a gradient of at least 1 / 100 to prevent air pockets from forming.
- If the drain hose cannot be sufficiently set on a slope, execute the drain raising piping.
- To keep the drain hose from sagging, space hanging wires every 1 to 1.5 m.



⚠ CAUTION


Setting the unit at an angle opposite to the drain piping might cause leaks.

- Use the drain hose and the metal clamp.
  Insert the drain hose into the drain socket, up to the tape.
  Tighten the clamp until the screw head is less than 4 mm from the hose.
- Wrap the attached sealing pad over the clamp and drain hose to insulate.
- Insulate the drain hose inside the building.




〈 **PRECAUTIONS FOR DRAIN RAISING PIPING** 〉

- Install the drain raising pipes at a height of less than 310 mm.
- Install the drain raising pipes at a right angle to the indoor unit and no more than 300 mm from the unit.



- If converging multiple drain pipes, install according to the procedure shown below.




Select converging drain pipes whose gauge is suitable for the operating capacity of the unit.

3PR01906-7R

(2) After piping work is finished, check drainage flows smoothly.


- Open the water inlet lid, add approximately 2.5 liter of water gradually and check drainage flow.



[WHEN ELECTRIC WIRING WORK IS FINISHED]

- Check drainage flow during COOL running, explained under “TEST OPERATION.”

[WHEN ELECTRIC WIRING WORK IS NOT FINISHED]



- Remove the electric parts box lid, connect a power supply and remote controller to the terminals.
  (Refer to the “HOW TO CONNECT WIRINGS”)
  Be sure attach the electric parts box lid before turning on the power.
- Next, press the inspection / test operation button “ TEST ” on the remote controller. The unit will engage the test operation mode. Press the operation mode selector button “ ” until selecting FAN OPERATION “ ”. Then, press the ON / OFF button “ ”. The indoor unit fan and drain pump will start up. Check that the water has drained from the unit. Press “ TEST ” to go back to the first mode.
- **Be careful when doing so because the fan is turning at the same time.**
- Attach the electric parts box lid as before.

⚠ CAUTION



- Drain piping connections
  Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain pipes and corrode the heat exchanger.
- Keep in mind that it will become the cause of getting drain pipe blocked if water collects on drain pipe.

3PR01906-7R

11. Accessories

Standard Accessories

FXCQ20~125M

Name	Metal clamp	Paper pattern for installation	Drain hose	Insulation for fitting	Washer fixing plate	Sealing pad
Quantity	1 pc.	1 pc.	1 pc.	1 each	4 pcs.	1 each
Shape				 for gas pipe  for liquid pipe		 Large  Small

Name	Washer for hanging bracket	Clamp	Screws (M5)	
Quantity	8 pcs.	8 pcs.	4 pcs.	(Other) • Operation manual • Installation manual
Shape			For paper pattern for installation 	

• Screws for fixing panels are attached to decoration panel.

3PR01906-7R

Optional Accessories (For Unit)


Item \ Type			FXCQ20M FXCQ25M FXCQ32M	FXCQ40M	FXCQ50M	FXCQ63M	FXCQ80M	FXCQ125M
Decoration panel			BYBC32G-W1	BYBC50G-W1		BYBC63G-W1	BYBC125G-W1	
Filter related	∗1 High efficiency filter 65%		KAFJ532G36	KAFJ532G56		KAFJ532G80	KAFJ532G160	
	∗1 High efficiency filter 90%		KAFJ533G36	KAFJ533G56		KAFJ533G80	KAFJ533G160	
	Filter chamber	Bottom suction	KDDFJ53G36	KDDFJ53G56		KDDFJ53G80	KDDFJ53G160	
	Long life replacement filter		KAFJ531G36	KAFJ531G56		KAFJ531G80	KAFJ531G160	

3D035093C

Note:

∗1. Filter chamber is required if installing high efficiency filter.

Optional Accessories (For Controls) : Refer to P.807



Filter Chamber


Specifications

Item \ Model		KDDFJ53G36	KDDFJ53G56	KDDFJ53G80	KDDFJ53G160
External Dimensions (mm)	H	50	50	50	50
	W	780	995	1180	1670
	D	600	600	600	600
Applicable Models		20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 125 Class

Precaution at use

1. The filter chamber will be needed when the high efficiency filter will be built in. But, it is impossible to build in more than two kinds filter at the same time.

Installation



High Efficiency Filter (Filter chamber is required for the high efficiency filter)

Specifications

Item \ Model	KAFJ532G36	KAFJ532G56	KAFJ532G80	KAFJ532G160	KAFJ533G36	KAFJ533G56	KAFJ533G80	KAFJ533G160
External Dimensions (H×W×D)(mm)	(30×460×145) ×2	(30×675×145) ×2	(30×860×145) ×2	(30×660×145) ×4	(30×460×145) ×2	(30×675×145) ×2	(30×860×145) ×2	(30×660×145) ×4
Dust Collection Efficiency (%)	65% (Colorimetric method)				90% (Colorimetric method)			
Initial Pressure Loss (Pa)	29			39	39			49
Final Pressure Loss (Pa)	78				78			
Filter	Non-woven fabric of synthetic fiber				Non-woven fabric of synthetic fiber			
Life Time (h) ∗	2500 hours				2500 hours		2100 hours	2000 hours
Applicable Models	20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 125 Class	20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 125 Class


Note:

1. ∗ The life time at the dust density 0.15 mg/m³.
2. Replace the fan motor's capacitor in accordance with the guide in next page, when the high efficiency filter is used.

Installation


■ **Installation of the filter frame**

Attach the filter frame to the indoor unit, where the original filter was located. (Refer to the operation manual of the indoor unit how to remove the standard filter. The standard filter removed shall not be used.)




In case of KAFJ532G160 and KAFJ533G160


There are four filter frames of 2 kinds of each having different position of the metal bracket. Install the filter frames to the indoor unit as shown below.




1. Loose the screw of the metal bracket located on each end of the filter frame and hook the filter frame temporarily to the partition plate located at the center of the indoor unit.



2. Fasten the screw of the metal bracket tightly.



Replacement guide of capacitor for fan motor



■ **Capacity of a capacitor to be replaced.**

Model	Capacitor's Capacity	Applicable Models
KAFJ532 · 533G36	2 μF	20 · 25 · 32 Class
KAFJ532 · 533G56	2 μF	40 · 50 Class
KAFJ532 · 533G80	2 μF	63 Class
KAFJ532 · 533G160	4.5 μF	80 Class
	6 μF	125 Class

FXKQ-MA
Ceiling Mounted Cassette
Corner Type


1. Features 148
2. Specifications 149
3. Dimensions 150
4. Piping Diagrams 152
5. Wiring Diagrams 153
6. Electric Characteristics 154
7. Capacity Tables 155
   7.1 Cooling Capacity 155
   7.2 Heating Capacity 156
8. Air Velocity and Temperature Distributions (Reference Data) 157
9. Sound Levels 158
10. Installation 159
11. Accessories 162

1. Features


215 mm-thick body features discreet, slim design and offers a wide variety of discharge methods and mounting such as in corners or in suspended ceilings, etc.




- Single-flow type offers effective air discharge from corners of from a suspended ceiling.




- Thin, discreet design enables mounting when the ceiling pocket is as shallow as 22 cm
- Temperature Distribution (FXKQ63MA : downward discharge angle 65° in heating.).




- Air velocity Distribution (FXKQ63MA : downward discharge angle 65° in heating.)




- Air volume switch built into the main body allows mounting in ceilings as high as 3.8 m. This unit is even able to handle spaces with a split level ceiling by accurately adjusting air volume in accordance with the ceiling height.



- The 63 class (equivalent to 2.5 HP) features extremely quiet operation, only 42 dBA of sound level.
- In addition to downward discharge, front discharge (straight discharge, neither angled upward nor downward) can be provided by mounting an air discharge unit (optional) to the front of the body; can be mounted even with difficult elements such as suspended ceilings and sagging walls. A combination of front and downward discharge is also possible. (Auto-swing cannot be used with front discharge.)



* Set for front discharge using a suspended ceiling



Downward discharge is shut off and air is blown straight out (front discharge)

- Equipped with a programmed drying mechanism that dehumidifies while inhibiting changes in room temperature.
- Includes as standard equipment a long-life filter that is maintenance-free for approximately one year. (Treated to mold resistant.)
- Equipped with drain pump kit that makes possible draining in the upward direction up to 500 mm from the ceiling surface.
- Decoration panel is thin and unimposing, doesn't clash with interior design and provides an excellent finishing touch for the ceiling. (Available in white.)
- If the ceiling pocket is shallow and the main body will not fit, a thick panel that provides aesthetically appealing cover for the exposed portion (up to 20 mm) is available as an option.

2. Specifications

Ceiling Mounted Cassette Corner Type

Model				FXKQ25MAVE	FXKQ32MAVE	FXKQ40MAVE	FXKQ63MAVE
∗1 Cooling Capacity (19.5°CWB)			kcal/h	2,500	3,200	4,000	6,300
			Btu/h	9,900	12,600	16,000	24,900
			kW	2.9	3.7	4.7	7.3
∗2 Cooling Capacity (19.0°CWB)			kW	2.8	3.6	4.5	7.1
∗3 Heating Capacity			kcal/h	2,800	3,400	4,300	6,900
			Btu/h	10,900	13,600	17,100	27,300
			kW	3.2	4.0	5.0	8.0
Casing				Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)			mm	215×1,110×710	215×1,110×710	215×1,110×710	215×1,310×710
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch		mm	2×11×1.75	2×11×1.75	2×11×1.75	3×11×1.75
	Face Area		m²	0.180	0.180	0.180	0.226
Fan	Model			3D12H1AN1V1	3D12H1AN1V1	3D12H1AP1V1	4D12H1AJ1V1
	Type			Sirocco Fan	Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units		W	15×1	15×1	20×1	45×1
	Air Flow Rate (H/L)	50 Hz	m³/min	11/9	11/9	13/10	18/15
			cfm	388/318	388/318	459/353	635/530
		60 Hz	m³/min	11/8.5	11/8.5	13/10	18/13
			cfm	388/300	388/300	459/353	635/459
	Drive			Direct Drive	Direct Drive	Direct Drive	Direct Drive
Temperature Control				Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material				Polyethylene Foam	Polyethylene Foam	Polyethylene Foam	Polyethylene Foam
Piping Connections	Liquid Pipes		mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes		mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe		mm	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)
Machine Weight (Mass)			kg	31	31	31	34
∗5 Sound Level (H/L) (220V)			dBA	38/33	38/33	40/34	42/37
Safety Devices				Fuse. Thermal Fuse for Fan Motor.	Fuse. Thermal Fuse for Fan Motor.	Fuse. Thermal Fuse for Fan Motor.	Fuse. Thermal Fuse for Fan Motor.
Refrigerant Control				Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Units				R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Decoration Panels (Option)	Model			BYK45FJW1	BYK45FJW1	BYK45FJW1	BYK71FJW1
	Panel Color			White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)
	Dimensions: (H×W×D)		mm	70×1,240×800	70×1,240×800	70×1,240×800	70×1,440×800
	Air Filter			Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
	Weight		kg	8.5	8.5	8.5	9.5
Standard Accessories				Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers. Positioning Jig for Installation. Insulation for Hanger Bracket. Air Outlet Blocking Pad.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers. Positioning Jig for Installation. Insulation for Hanger Bracket. Air Outlet Blocking Pad.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers. Positioning Jig for Installation. Insulation for Hanger Bracket. Air Outlet Blocking Pad.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers. Positioning Jig for Installation. Insulation for Hanger Bracket. Air Outlet Blocking Pad.
Drawing No.				C : 3D038813A			


Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1 m in front of the unit and 1m downward. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 154 for Fan Motor Input.


Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

3. Dimensions


FXKQ25MA + BYK45FJW1 (Decoration Panel)
FXKQ32MA + BYK45FJW1 (Decoration Panel)
FXKQ40MA + BYK45FJW1 (Decoration Panel)



FXKQ63MA + BYK71FJW1 (Decoration Panel)



4. Piping Diagrams



4D034245C


■ **Refrigerant pipe connection port diameters**

(mm)

Model	Gas	Liquid
FXKQ25 · 32 · 40MA	ϕ12.7	ϕ6.4
FXKQ63MA	ϕ15.9	ϕ9.5

5. Wiring Diagrams

FXKQ25 · 32 · 40 · 63MAVE



INDOOR UNIT	
A1P	PRINTED CIRCUIT BOARD
A2P	TERMINAL BOARD
C1	CAPACITOR (M1F)
F1U	FUSE (Ⓑ, 5A, 250V)
HAP	LIGHT EMITTING DIODE (SERVICE MONITOR-GREEN)
K1R-K3R	MAGNETIC RELAY (M1F)
KAR	MAGNETIC RELAY (M1S)
KPR	MAGNETIC RELAY (M1P)
M1F	MOTOR (INDOOR FAN)
M1P	MOTOR (DRAIN PUMP)
M1S	MOTOR (SWING FLAP)
Q1M	THERMO SWITCH (M1F EMBEDDED)
R1T	THERMISTOR (AIR)
R2T · R3T	THERMISTOR (COIL)
S1L	FLOAT SWITCH
S1Q	LIMIT SWITCH (SWING FLAP)
T1R	TRANSFORMER (220-240V/22V)
X1M	TERMINAL BLOCK (POWER)
X2M	TERMINAL BLOCK (CONTROL)
Y1E	ELECTRONIC EXPANSION VALVE
	WIRED REMOTE CONTROLLER
R1T	THERMISTOR (AIR)
SS1	SELECTOR SWITCH (MAIN/SUB)
	CONNECTOR FOR OPTIONAL PARTS
X16A	CONNECTOR (ADAPTOR FOR WIRING)
X18A	CONNECTOR (WIRING ADAPTOR FOR ELECTORICAL APPENDICES)

NOTES) 1. □□□ : TERMINAL BLOCK, ⊡⊡, ⊃– : CONNECTOR, –○– : TERMINAL
2. ═══ : FIELD WIRING
3. IN CASE USING CENTRAL REMOTE CONTROLLER, CONNECT IT TO THE UNIT IN ACCORDANCE WITH THE ATTACHED INSTRUCTION MANUAL.
4. WHEN CONNECTING THE INPUT WIRES FROM OUTSIDE, FORCED OFF OR ON/OFF CONTROL OPERATION CAN BE SELECTED BY REMOTE CONTROLLER. IN DETAILS, REFER TO THE INSTALLATION MANUAL ATTACHED THE UNIT.
5. IN CASE HIGH E. S. P. OPERATION, CHANGE OVER THE WIRING CONNECTION FROM X2A TO X3A.
6. SYMBOLS SHOW AS FOLLOWS. (PNK : PINK WHT : WHITE YLW : YELLOW ORG : ORANGE BLU : BLUE BLK : BLACK RED : RED BRN : BROWN GRY : GRAY)
7. UES COPPER CONDUCTORS ONLY.

3D039564C

6. Electric Characteristics

Units					Power supply		IFM		Input(W)	
Model	Type	Hz	Volts	Voltage range	MCA	MFA	KW	FLA	Cooling	Heating
FXKQ25MA	VE	50	220-240	MAX. 264 Min. 198	0.3	15	0.015	0.2	66	46
FXKQ32MA					0.3	15	0.015	0.2	66	46
FXKQ40MA					0.3	15	0.020	0.2	76	56
FXKQ63MA					0.5	15	0.045	0.4	105	85
FXKQ25MA	VE	60	220	MAX. 242 Min. 198	0.4	15	0.015	0.3	69	49
FXKQ32MA					0.4	15	0.015	0.3	69	49
FXKQ40MA					0.5	15	0.020	0.4	92	72
FXKQ63MA					0.6	15	0.045	0.5	120	100

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
KW : Fan Motor Rated Output(KW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

Note:

1. Voltage range

   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.

2. Maximum allowable voltage unbalance between phases is 2%.

3. MCA/MFA

   MCA = 1.25 X FLA

   MFA ≦ 4 X FLA

   (Next lower standard fuse rating. Min. 15A)

4. Select wire size based on the MCA.

5. Instead of fuse, use Circuit Breaker.

C : 4D037076B

7. Capacity Tables

7.1 Cooling Capacity

FXKQ-MA **[50/60Hz]**

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	14.0°CWB 20°CDB SHC	16.0°CWB 23°CDB TC	16.0°CWB 23°CDB SHC	18.0°CWB 26°CDB TC	18.0°CWB 26°CDB SHC	19.0°CWB 27°CDB TC	19.0°CWB 27°CDB SHC	20.0°CWB 28°CDB TC	20.0°CWB 28°CDB SHC	22.0°CWB 30°CDB TC	22.0°CWB 30°CDB SHC	24.0°CWB 32°CDB TC	24.0°CWB 32°CDB SHC
25	10.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.4	2.5	3.7	2.5
	12.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.4	2.5	3.6	2.5
	14.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.4	2.5	3.6	2.5
	16.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.4	2.5	3.5	2.4
	18.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.4	2.5	3.5	2.4
	20.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.4	2.5	3.4	2.4
	21.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.4	2.5	3.4	2.4
	23.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.3	2.5	3.4	2.3
	25.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.3	2.5	3.3	2.3
	27.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.2	2.4	3.3	2.3
	29.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.2	2.4	3.2	2.3
	31.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.1	2.4	3.1	2.3
	33.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	3.0	2.5	3.0	2.4	3.1	2.3
	35.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	2.9	2.5	2.9	2.3	3.0	2.3
	37.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	2.9	2.5	2.9	2.3	3.0	2.2
	39.0	1.9	1.9	2.3	2.2	2.6	2.3	2.8	2.4	2.9	2.5	2.9	2.3	3.0	2.2
32	10.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.3	2.9	4.7	2.9
	12.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.3	2.9	4.7	2.9
	14.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.3	2.9	4.6	2.9
	16.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.3	2.9	4.6	2.8
	18.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.3	2.9	4.5	2.8
	20.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.3	2.9	4.4	2.8
	21.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.3	2.9	4.4	2.7
	23.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.2	2.9	4.3	2.7
	25.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.2	2.8	4.3	2.7
	27.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.1	2.8	4.2	2.7
	29.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.1	2.8	4.2	2.6
	31.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	4.0	2.7	4.1	2.6
	33.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	3.9	2.7	4.0	2.6
	35.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	3.9	2.7	4.0	2.6
	37.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.8	2.9	3.8	2.7	3.9	2.6
	39.0	2.4	2.2	2.9	2.5	3.4	2.6	3.6	2.7	3.7	2.8	3.8	2.7	3.8	2.6
40	10.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.5	5.9	3.5
	12.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.5	5.8	3.5
	14.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.5	5.8	3.4
	16.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.5	5.7	3.4
	18.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.5	5.6	3.3
	20.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.5	5.5	3.3
	21.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.5	5.5	3.3
	23.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.3	3.4	5.4	3.2
	25.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.2	3.3	5.3	3.2
	27.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.2	3.3	5.3	3.2
	29.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.1	3.3	5.2	3.1
	31.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	5.0	3.2	5.1	3.1
	33.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.8	3.3	4.9	3.2	5.0	3.1
	35.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.7	3.3	4.9	3.2	5.0	3.0
	37.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.7	3.2	4.8	3.1	4.9	3.0
	39.0	3.0	2.6	3.6	2.8	4.2	3.2	4.5	3.2	4.6	3.2	4.7	3.1	4.8	3.0
63	10.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.5	5.4	9.3	5.6
	12.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.5	5.4	9.2	5.5
	14.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.5	5.4	9.1	5.4
	16.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.5	5.4	9.0	5.3
	18.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.5	5.4	8.8	5.3
	20.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.5	5.4	8.7	5.2
	21.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.5	5.4	8.7	5.2
	23.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.4	5.3	8.5	5.1
	25.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.3	5.3	8.4	5.0
	27.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.1	5.2	8.3	5.0
	29.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	8.0	5.1	8.2	4.9
	31.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	7.9	5.1	8.1	4.9
	33.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.6	5.2	7.8	5.0	7.9	4.8
	35.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.2	7.5	5.2	7.7	5.0	7.8	4.8
	37.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.4	5.1	7.5	4.9	7.7	4.8
	39.0	4.8	4.0	5.7	4.5	6.6	5.0	7.1	5.1	7.2	5.0	7.4	4.9	7.6	4.7

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

4

7.2 Heating Capacity

FXKQ-MA **[50/60Hz]**

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
25	-19.8	-20.0	1.9	1.9	1.9	1.9	1.9	1.9
	-18.8	-19.0	1.9	1.9	1.9	1.9	1.9	1.9
	-16.7	-17.0	2.1	2.1	2.0	2.0	2.0	2.0
	-14.7	-15.0	2.2	2.2	2.2	2.2	2.2	2.1
	-12.6	-13.0	2.3	2.3	2.3	2.3	2.3	2.3
	-10.5	-11.0	2.4	2.4	2.4	2.4	2.4	2.4
	-9.5	-10.0	2.5	2.4	2.4	2.4	2.4	2.4
	-8.5	-9.1	2.5	2.5	2.5	2.5	2.5	2.5
	-7.0	-7.6	2.6	2.6	2.6	2.6	2.6	2.6
	-5.0	-5.6	2.7	2.7	2.7	2.7	2.7	2.7
	-3.0	-3.7	2.8	2.8	2.8	2.8	2.8	2.8
	0.0	-0.7	3.0	3.0	3.0	3.0	3.0	2.8
	3.0	2.2	3.1	3.1	3.1	3.1	3.0	2.8
	5.0	4.1	3.3	3.2	3.2	3.1	3.0	2.8
	7.0	6.0	3.4	3.4	3.2	3.1	3.0	2.8
	9.0	7.9	3.5	3.4	3.2	3.1	3.0	2.8
	11.0	9.8	3.6	3.4	3.2	3.1	3.0	2.8
	13.0	11.8	3.6	3.4	3.2	3.1	3.0	2.8
	15.0	13.7	3.6	3.4	3.2	3.1	3.0	2.8
32	-19.8	-20.0	2.4	2.4	2.3	2.3	2.3	2.3
	-18.8	-19.0	2.4	2.4	2.4	2.4	2.4	2.4
	-16.7	-17.0	2.6	2.6	2.6	2.6	2.6	2.5
	-14.7	-15.0	2.7	2.7	2.7	2.7	2.7	2.7
	-12.6	-13.0	2.9	2.8	2.8	2.8	2.8	2.8
	-10.5	-11.0	3.0	3.0	3.0	3.0	3.0	3.0
	-9.5	-10.0	3.1	3.1	3.1	3.1	3.1	3.1
	-8.5	-9.1	3.1	3.1	3.2	3.1	3.1	3.2
	-7.0	-7.6	3.2	3.2	3.2	3.2	3.2	3.2
	-5.0	-5.6	3.4	3.4	3.4	3.4	3.4	3.4
	-3.0	-3.7	3.5	3.5	3.5	3.5	3.5	3.5
	0.0	-0.7	3.7	3.7	3.7	3.7	3.7	3.5
	3.0	2.2	3.9	3.9	3.9	3.9	3.7	3.5
	5.0	4.1	4.1	4.1	4.0	3.9	3.7	3.5
	7.0	6.0	4.2	4.2	4.0	3.9	3.7	3.5
	9.0	7.9	4.3	4.3	4.0	3.9	3.7	3.5
	11.0	9.8	4.5	4.3	4.0	3.9	3.7	3.5
	13.0	11.8	4.5	4.3	4.0	3.9	3.7	3.5
	15.0	13.7	4.5	4.3	4.0	3.9	3.7	3.5
40	-19.8	-20.0	3.0	2.9	2.9	2.9	2.9	2.9
	-18.8	-19.0	3.0	3.0	3.0	3.0	3.0	3.0
	-16.7	-17.0	3.2	3.2	3.2	3.2	3.2	3.2
	-14.7	-15.0	3.4	3.4	3.4	3.4	3.4	3.4
	-12.6	-13.0	3.6	3.6	3.6	3.5	3.5	3.5
	-10.5	-11.0	3.7	3.7	3.7	3.7	3.7	3.7
	-9.5	-10.0	3.8	3.8	3.8	3.8	3.8	3.8
	-8.5	-9.1	3.9	3.9	3.9	3.9	3.9	3.9
	-7.0	-7.6	4.0	4.0	4.0	4.0	4.0	4.0
	-5.0	-5.6	4.2	4.2	4.2	4.2	4.2	4.2
	-3.0	-3.7	4.4	4.4	4.4	4.4	4.4	4.4
	0.0	-0.7	4.7	4.6	4.6	4.6	4.6	4.4
	3.0	2.2	4.9	4.9	4.9	4.8	4.7	4.4
	5.0	4.1	5.1	5.1	5.0	4.8	4.7	4.4
	7.0	6.0	5.2	5.2	5.0	4.8	4.7	4.4
	9.0	7.9	5.4	5.3	5.0	4.8	4.7	4.4
	11.0	9.8	5.6	5.3	5.0	4.8	4.7	4.4
	13.0	11.8	5.6	5.3	5.0	4.8	4.7	4.4
	15.0	13.7	5.6	5.3	5.0	4.8	4.7	4.4
63	-19.8	-20.0	4.7	4.7	4.7	4.7	4.7	4.7
	-18.8	-19.0	4.9	4.9	4.8	4.8	4.8	4.8
	-16.7	-17.0	5.1	5.1	5.1	5.1	5.1	5.1
	-14.7	-15.0	5.4	5.4	5.4	5.4	5.4	5.4
	-12.6	-13.0	5.7	5.7	5.7	5.7	5.7	5.7
	-10.5	-11.0	6.0	6.1	6.0	6.1	6.0	5.9
	-9.5	-10.0	6.1	6.1	6.1	6.1	6.1	6.1
	-8.5	-9.1	6.3	6.3	6.2	6.2	6.2	6.2
	-7.0	-7.6	6.5	6.5	6.4	6.4	6.4	6.4
	-5.0	-5.6	6.8	6.7	6.7	6.7	6.7	6.7
	-3.0	-3.7	7.0	7.0	7.0	7.0	7.0	7.0
	0.0	-0.7	7.5	7.4	7.4	7.4	7.4	7.0
	3.0	2.2	7.9	7.8	7.8	7.7	7.5	7.0
	5.0	4.1	8.1	8.1	8.0	7.7	7.5	7.0
	7.0	6.0	8.4	8.4	8.0	7.7	7.5	7.0
	9.0	7.9	8.7	8.5	8.0	7.7	7.5	7.0
	11.0	9.8	8.9	8.5	8.0	7.7	7.5	7.0
	13.0	11.8	9.0	8.5	8.0	7.7	7.5	7.0
	15.0	13.7	9.0	8.5	8.0	7.7	7.5	7.0


Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

8. Air Velocity and Temperature Distributions (Reference Data)

FXKQ63MA

(Heating · Air Velocity Distribution)


Lower Air Flow



FXKQ63MA

(Heating · Temperature Distribution)

Lower Air Flow




Note:

The corner type is applicable on a high ceiling. The standard setup height is 3 m. Shown here is the measurement distribution at the ceiling height of 3 m.

9. Sound Levels

Overall

■ **Ceiling Mounted Cassette Corner Type**



Note:
1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.


dBA

Model	220V, 50/60Hz		240V, 50Hz	
	H	L	H	L
FXKQ25MA FXKQ32MA	38	33	40	35
FXKQ40MA	40	34	42	36
FXKQ63MA	42	37	44	39

Octave Band Level


○———○ 220V 50/60Hz
○ - - - -○ 240V 50Hz

FXKQ25 · 32MAVE




4D037071

FXKQ40MAVE



4D037072

FXKQ63MAVE




4D037073

10. Installation

Center of Gravity

Unit (mm)




MODEL	A
FXKQ25・32・40MAVE	1110
FXKQ63MAVE	1310

C : 4D037079A


Service Space

Unit (mm)



Note:
Above figure means minimum value. Please keep these value at least.

Bolt Pitch



Model	A	B	C	D
FXKQ25 · 32 · 40MAVE	1110	1150	1200	1240
FXKQ63MAVE	1310	1350	1400	1440


3P086156-8V

Drain Pump Kit

Indoor unit	Drain pump kit
FXKQ-MA	Standard (Equipped with indoor unit)


Drain Piping Work

〈〈**Rig the drain pipe as shown below and take measures against condensation. Improperly rigged piping could lead to leaks and eventually wet furniture and belongings.**〉〉



(1) Carry out the drain piping.

- Keep piping as short as possible and slope it downwards so that air may not remain trapped inside the pipe.
- The diameter of the drain pipe should be greater than or equal to the diameter of the connecting pipe (vinyl tube; pipe size : 25 mm ; outer dimension : 32 mm).
- Use the drain hose and metal clamp. Insert the drain hose into the drain socket, up to the white tape. Tighten the metal clamp until the screw head is less than 4 mm from the hose.




CAUTION

Setting the unit at an angle opposite to the drain piping might cause leaks.


- Wrap the sealing pad over the clamp and drain hose to insulate.
- Insulate the drain hose inside the building.
  While referring to the figure on the right, insulate the clamp and drain hose with the large sealing pad.
- If the drain hose cannot be sufficiently set on a slope, execute the drain raising piping.
- Secure a downward gradient of 1 / 100 or more for the drain pipe. To accomplish this, mount supporting brackets at an interval of 1 - 1.5 m.

〈**Precautions when doing drain-up piping work.**〉

- Make sure the drain-up piping is at most 330 mm high.
- Stand the drain-up piping horizontally, and make sure it is not further than 300 mm from the base of the drain socket.




- Use the following outline if laying concentrated drain piping.
- If converging multiple drain pipes, install according to the procedure shown below.



Select converging drain pipes whose gauge is suitable for the operating capacity of the unit.

3P086156-8V

(2) After piping work is finished, check drainage flows smoothly.
- Open the inspection opening, add approximately 1liter of water slowly into the drain pan and check drainage flow.




NOTE
- Use the drain outlet for maintenance to drain water from the drain pan.

WHEN ELECTRIC WIRING WORK IS FINISHED
- Check drainage flow during COOL running, explained under “TEST OPERATION”.

WHEN ELECTRIC WIRING WORK IS NOT FINISHED
- Remove the electric parts box lid, connect a power supply and remote controller to the terminals. (Refer to the **HOW TO CONNECT WIRINGS**)

Be sure attach the electric parts box lid before turning on the power.
Next, press the inspection/test operation button “ TEST ” on the remote controller. The unit will engage the test operation mode. Press the operation mode selector button “ ” until selecting FAN OPERATION “ ”. Then, press the ON/OFF button “ ”. The indoor unit fan and drain pump will start up. Check that the water has drained from the unit. Press “ TEST ” to go back to the first mode.









CAUTION
- Drain piping connections
  Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain pipes and corrode the heat exchanger.
- Keep in mind that it will become the cause of getting drain pipe blocked if water collects on drain pipe.



3P086156-8V

11. Accessories

Standard Accessories

FXKQ25~63MA

Name	Metal clamp	Paper pattern for installation	Drain hose	Insulation for fitting	Sealing pad	Insulation for hanger bracket
Quantity	1pc.	1 pc.	1 pc.	1 each.	1 each.	4 pcs.
Shape		 Corrugated cardboard		For gas pipe  For liquid pipe 	Large  Small 	

Name	Washer for hanging bracket	Clamp	Positioning jig for installation	Air outlet blocking pad	
Quantity	8 pcs.	8 pcs.	2 each.	1 pc.	
Shape			 4 screws		(Other) • Operation manual • Installation manual

• Screws for fixing panels are attached to decoration panel.


3P086156-8V

Optional Accessories (For Unit)

Item	Type	FXKQ25MA FXKQ32MA FXKQ40MA	FXKQ63MA
Panel related	Decoration panel	BYK45FJW1	BYK71FJW1
	Long life replacement filter	KAFJ521F56	KAFJ521F80
Air inlet and air discharge outlet related	Air discharge grill	K-HV7AW	K-HV9AW
	Air discharge blind panel	KDBJ52F56W	KDBJ52F80W
	Panel spacer	KPBJ52F56W	KPBJ52F80W
	Flexible duct (with shutter)	KFDJ52FA56	KFDJ52FA80

C : 3D037081A

Optional Accessories (For Controls) : Refer to P.807




Panel Spacer


If the space above the ceiling is not available for more than 220 mm, use the panel spacer, which enables to install the unit in 200 mm space.

Specifications

Item \ Model		KPBJ52F56W	KPBJ52F80W
Color		White	
Dimensions (mm)	Height	20	
	Width	1,240	1,440
	Depth	800	
Materials		Outer Frame : Resin Molding Thermal Insulation : Foam Polyethylene	
Contents		Panel Spacer(1)(2)(3) Thermal Insulation (1)(2), Screws	
Applicable Decoration Panel		BYK45FJW1	BYK71FJW1
Applicable Model		For Indoor Unit 25~40 Class	For Indoor Unit 63 Class

Installation







Precaution at use

1. Be sure to stick insulators on the panel spacer after the panel spacer is assembled.
2. Secure 20 cm height in the space above ceiling.

Contents of Kit

Prior to installation check whether you have the complete kit of parts as shown below including the installation manual.

Name	Panel spacer (1)	Panel spacer (2)	Panel spacer (3)	Thermal insulation (1)
Quantity	2 pieces	2 pieces	4 pieces	2 pieces
Shape				


Name	Thermal insulation (2)	Screws	Installation manual
Quantity	2 pieces	18 pieces	1 piece
Shape			

Long Life Replacement Filter

Specifications

Items \ Model	KAFJ521F56	KAFJ521F80
Life Time, Average Efficiency	2,500 hours (dust density 0.15 mg/m³), 45% (Gravity method)	
Filter	Mildew Proof Resin Net	Mildew Proof Resin Net
Required Quantity (for One Unit)	Two pieces	Two pieces
Applicable Models	25 · 32 · 40 Class	63 Class

Dimensions



Model	A
KAFJ521F56	403
KAFJ521F80	503

JC : D3K1145A


Discharge Grille

This optional kit is used when the unit is installed with front air discharge. The direction of air can be adjusted flexibly. This discharge grille should be installed with the following flexible duct.


Specifications

Items \ Model	K-HV7AW	K-HV9AW
Air Flow Rate (m³/min)	5~12	7~17
Type	HV type (Horizontal blade and vertical blade movable)	
External Color	White	White
Materials	Steel plate (A cryptomeria only at the tip of the outlet + nylon flocking)	
Structural Parts	Discharge grille, Screws, Blade control tool	
Applicable Flexible Duct	KFDJ52F56	KFDJ52F80
Applicable Models	25 · 32 · 40 Class	63 Class

Dimension



Model	AA	AB	AC	AD	AE
K–HV7AW	523	483	466	500	488
K–HV9AW	723	683	666	700	688



JC : D3K1972C

Flexible Duct (with Shutter)

The built-in shutter's Open/Shut action makes it possible to regulate the air flow rate. Besides, the flexible duct helps the connection to the main unit to give more flexibility.


Specifications

Items \ Model		KFDJ52FA56	KFDJ52FA80
External Dimension (mm)	H	132	
	W	532	732
	D	Max. 353	
Materials		Outer frame : Steel plate Flexible Duct : Glass wool, Vinyl chloride sheet	
Contents		Flexible duct, Shutter, Duct's set plate, Insulator, Outlet seal pad, Set screw, Shutter Open/shut tool, Blade adjusting tool	
Applicable Models		25 · 32 · 40 Class	63 Class

Precaution at use


Be sure to seal out the opening of the drain pan with drain outlet seal materials after the front panel of the indoor unit is removed away.

Dimension



Model	Applicable Model	A	B	C	D	E	F
KFDJ52FA56	For Indoor Unit 25~40 Class	260	520	466	498	530	4-ϕ Hole
KFDJ52FA80	For Indoor Unit 63 Class	460	720	666	698	730	6-ϕ7 Hole

Installation




Air Discharge Blind Panel

This is the parts which closes the lower discharge outlet when the unit is used as a front discharge style.

Specifications

Items \ Model		KDBJ52F56W	KDBJ52F80W
External color		White	White
External Dimension (mm)	T	18	
	W	1,126	1,326
	D	119	
Materials		Steel plate	
Contents		Outlet decoration panel assembly, Decoration panel suspension plate, Name Plate, Caution plate set board	
Applied Decoration Panel		BYK45FJW1	BYK71FJW1
Applicable Models		25 · 32 · 40 Class	63 Class

External dimension






Model	A	B
KDBJ52F56	1125.5	1040
KDBJ52F80	1325.5	1240

Dimensions with the Optional Accessories

Panel Spacer

■ **FXKQ25~40MA**



Optional panel spacer


KPBJ52F56W	White 10Y 9/0.5

Note: When other optional kit is installed, refer to the installation drawing of its optional kit.

Number	Name	Description
3	Panel spacer	
2	Decoration panel	
1	Indoor unit	

JC : DU825-219A

■ **FXKQ63MA**



·Optional panel spacer

KPBJ52F80W	White 10Y 9/0.5

Note: When other optional kit is installed, refer to the installation drawing of its optional kit.

Number	Name	Description
3	Panel spacer	
2	Decoration panel	
1	Indoor unit	

JC : DU827-242A

FXDQ-PB, FXDQ-NB
Slim Ceiling Mounted Duct Type

1. Features 170
2. Specifications 171
   2.1 FXDQ-PB 171
   2.2 FXDQ-NB 172
3. Dimensions 173
   3.1 FXDQ-PB 173
   3.2 FXDQ-NB 175
4. Piping Diagrams 179
5. Wiring Diagrams 180
6. Electric Characteristics 182
7. Capacity Tables 183
   7.1 FXDQ-PB 183
   7.2 FXDQ-NB 184
8. Fan Performances 185
   8.1 FXDQ-PB 185
   8.2 FXDQ-NB 186
9. Sound Levels 187
   9.1 FXDQ-PB 187
   9.2 FXDQ-NB 188
10. Center of Gravity 189
   10.1 FXDQ-PB 189
   10.2 FXDQ-NB 190
11. Installation 191
12. Accessories 205
   12.1 FXDQ-PB, FXDQ-NB 205

1. Features

Slim Ceiling Mounted Duct Type




Slim design, quietness and static pressure switching

Suited to use in drop-ceilings!

New **FXDQ20PB/FXDQ25PB/FXDQ32PB**


- Only 700 mm in width and 23 kg in weight, this model is suitable to install in limited spaces like drop-ceilings in hotels.






New **FXDQ40NB/FXDQ50NB/ FXDQ63NB**

- Only 200 mm in height, this model can be installed in rooms with as little as 240 mm depth between the drop-ceiling and ceiling slab.



∗1,100 mm in width for the FXDQ63NB model.



*: To be obtained locally

New
- Control of the airflow rate has been improved from 2-step to 3-step control.

New
- Low operation sound level

(dB(A))

FXDQ-PB/NB	20	25	32	40	50	63
Sound level (HH/H/L)	33/31/29	33/31/29	33/31/29	34/32/30	35/33/31	36/34/32


∗The values of operation sound level represent those for rear-suction operation. Sound level values for bottom-suction operation can be obtained by adding 5 dB(A).
∗Values are based on the following conditions:
FXDQ-PB: external static pressure of 10 Pa; FXDQ-NB: external static pressure of 15 Pa.

- External static pressure selectable by remote controller switching make this indoor unit a very comfortable and flexible model.

  10 Pa-30 Pa/factory set: 10 Pa for FXDQ-PB models.
  15 Pa-44 Pa/factory set: 15 Pa for FXDQ-NB models.

- FXDQ-PB and FXDQ-NB models are available in two types to suit different installation conditions

  FXDQ-PBVE, FXDQ-NBVE:
  with a drain pump (750 mm lift) as a standard accessory
  FXDQ-P/NBVET: without a drain pump



2. Specifications

2.1 FXDQ-PB

Slim Ceiling Mounted Duct Type (VE: with Drain Pump, VET without Drain Pump)

Model			FXDQ20PBVE (T)	FXDQ25PBVE (T)	FXDQ32PBVE (T)
★1 Cooling Capacity (19.5°CWB)		kcal/h	2,000	2,500	3,200
		Btu/h	7,800	9,900	12,600
		kW	2.3	2.9	3.7
★2 Cooling Capacity (19.0°CWB)		kW	2.2	2.8	3.6
★3 Heating Capacity		kcal/h	2,200	2,800	3,400
		Btu/h	8,500	10,900	13,600
		kW	2.5	3.2	4.0
Casing			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	200×700×620	200×700×620	200×700×620
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	2×12×1.5	2×12×1.5	3×12×1.5
	Face Area	m^2	0.126	0.126	0.126
Fan	Model		—	—	—
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	62×1	62×1	62×1
	Air Flow Rate (HH/H/L)	m^3/min	8.0/7.2/6.4	8.0/7.2/6.4	8.0/7.2/6.4
	★5 External Static Pressure	Pa	30-10	30-10	30-10
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Foamed Polyethylene	Foamed Polyethylene	Foamed Polyethylene
Air Filter			Removal / Washable / Mildew Proof	Removal / Washable / Mildew Proof	Removal / Washable / Mildew Proof
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)
	Drain Pipe	mm	VP20 (External Dia. 26 Internal Dia. 20)	VP20 (External Dia. 26 Internal Dia. 20)	VP20 (External Dia. 26 Internal Dia. 20)
Machine Weight (Mass)		kg	23	23	23
★6 Sound Pressure Level (HH/H/L)		dBA	33/31/29	33/31/29	33/31/29
Safety Devices			Fuse, Thermal Protector for Fan Motor	Fuse, Thermal Protector for Fan Motor	Fuse, Thermal Protector for Fan Motor
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Standard Accessories			Operation Manual, Installation Manual, Drain Hose, Sealing Pads, Clamps, Washers, Insulation for Fitting, Clamp Metal, Washer Fixing Plate, Screws for Duct Flanges, Air Filter, (Product Quality Certificate ★7)	Operation Manual, Installation Manual, Drain Hose, Sealing Pads, Clamps, Washers, Insulation for Fitting, Clamp Metal, Washer Fixing Plate, Screws for Duct Flanges, Air Filter, (Product Quality Certificate ★7)	Operation Manual, Installation Manual, Drain Hose, Sealing Pads, Clamps, Washers, Insulation for Fitting, Clamp Metal, Washer Fixing Plate, Screws for Duct Flanges, Air Filter, (Product Quality Certificate ★7)
Drawing No.			3D060921A		

Note:

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m^3/min×35.3

★1 Indoor temp.: 27°CDB, 19.5°CWB / outdoor temp.: 35°CDB / Equivalent piping length: 7.5m, level difference: 0m.
★2 Indoor temp.: 27°CDB, 19.0°CWB / outdoor temp.: 35°CDB / Equivalent piping length: 7.5m, level difference: 0m.
★3 Indoor temp.: 20°CDB / outdoor temp.: 7°CDB, 6°CWB / Equivalent piping length: 7.5m, level difference: 0m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
★5 External static pressure is changeable to set by the remote controller. This pressure means “High static pressure - Standard static pressure”. (Factory setting is 10 Pa.)
★6 The operation sound levels are the conversion values in anechoic chamber. In practice, the sound tend to be larger than the specified values due to ambient noise or reflections.
When the place of suction is changed to the bottom suction, the sound level will increase by approx. 5dBA.
★7 FXDQ20 / 25 / 32PBVE only.
8 Refer to page 182 for Fan Motor Input.

2.2 FXDQ-NB

Slim Ceiling Mounted Duct Type (VE: with Drain Pump, VET without Drain Pump)

Model			FXDQ40NBVE(T)	FXDQ50NBVE(T)	FXDQ63NBVE(T)
★1 Cooling Capacity (19.5°CWB)		kcal/h	4,000	5,000	6,300
		Btu/h	16,000	19,800	24,900
		kW	4.7	5.8	7.3
★2 Cooling Capacity (19.0°CWB)		kW	4.5	5.6	7.1
★3 Heating Capacity		kcal/h	4,300	5,400	6,900
		Btu/h	17,100	21,500	27,300
		kW	5.0	6.3	8.0
Casing Color			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	200×900×620	200×900×620	200×1100×620
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	3×12×1.5	3×12×1.5	3×12×1.5
	Face Area	m²	0.176	0.176	0.227
Fan	Model		—	—	—
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	62×1	130×1	130×1
	Air Flow Rate (HH/H/L)	m³/min	10.5/9.5/8.5	12.5/11.0/10.0	16.5/14.5/13.0
	★5 External Static Pressure	Pa	44-15	44-15	44-15
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Foamed Polyethylene	Foamed Polyethylene	Foamed Polyethylene
Air Filter			Removal / Washable / Mildew Proof	Removal / Washable / Mildew Proof	Removal / Washable / Mildew Proof
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe	mm	VP20 (External Dia. 26 Internal Dia. 20)	VP20 (External Dia. 26 Internal Dia. 20)	VP20 (External Dia. 26 Internal Dia. 20)
Machine Weight (Mass)		kg	27	28	31
★6 Sound Pressure Level (HH/H/L)		dBA	34/32/30	35/33/31	36/34/32
Safety Devices			Fuse, Thermal Protector for Fan Motor	Fuse, Thermal Protector for Fan Motor	Fuse, Thermal Protector for Fan Motor
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Standard Accessories			Operation Manual, Installation Manual, Drain Hose, Sealing Pads, Clamps, Washers, Insulation for Fitting, Clamp Metal, Washer Fixing Plate, Screws for Duct Flanges, Air Filter, (Product Quality Certificate ★7)	Operation Manual, Installation Manual, Drain Hose, Sealing Pads, Clamps, Washers, Insulation for Fitting, Clamp Metal, Washer Fixing Plate, Screws for Duct Flanges, Air Filter, (Product Quality Certificate ★7)	Operation Manual, Installation Manual, Drain Hose, Sealing Pads, Clamps, Washers, Insulation for Fitting, Clamp Metal, Washer Fixing Plate, Screws for Duct Flanges, Air Filter, (Product Quality Certificate ★7)
Drawing No.			3D060921A		

Note:

Conversion Formulae
kcal/h=kW×860
Btu/h=kW×3412
cfm=m³/min×35.3


★1 Indoor temp.: 27°CDB, 19.5°CWB / outdoor temp.: 35°CDB / Equivalent piping length: 7.5m, level difference: 0m.
★2 Indoor temp.: 27°CDB, 19.0°CWB / outdoor temp.: 35°CDB / Equivalent piping length: 7.5m, level difference: 0m.
★3 Indoor temp.: 20°CDB / outdoor temp.: 7°CDB, 6°CWB / Equivalent piping length: 7.5m, level difference: 0m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
★5 External static pressure is changeable to set by the remote controller. This pressure means “High static pressure - Standard static pressure”. (Factory setting is 15 Pa.)
★6 The operation sound levels are the conversion values in anechoic chamber. In practice, the sound tend to be larger than the specified values due to ambient noise or reflections.
When the place of suction is changed to the bottom suction, the sound level will increase by approx. 5dBA.
★7 FXDQ40 / 50 / 63NBVE only.
8 Refer to page 182 for Fan Motor Input.

3. Dimensions

3.1 FXDQ-PB


FXDQ20 / 25 / 32PBVE (with Drain Pump)

Unit (mm)



FXDQ20 / 25 / 32PBVET (without Drain Pump)

Unit (mm)




NOTE) 1. IN CASE OF BACK-SUCTION, MOUNT CHAMBER COVER TO BOTTOM SIDE OF THE UNIT.
IN CASE OF BOTTOM-SUCTION, MOUNT CHAMBER COVER TO BACK SIDE OF THE UNIT.
2. LOCATION OF UNIT'S NAME PLATE: CONTROL BOX COVER
3. MOUNT THE AIR FILTER AT THE SUCTION SIDE.
(SELECT ITS COLORIMETHOD (GRAVITY METHOD) 50% OR MORE.)
IT CAN NOT BE EQUIPPED WITH AIR FILTER (ACCESSORY)
WHEN CONNECTING DUCT TO SUCTION SIDE.

NUMBER	NAME	DESCRIPTION
10	AIR FILTER (ACCESSORY)	
9	PROTECTION NET	
8	SUSPENSION BRACKET	
7	POWER SUPPLY CONNECTION	
6	TRANSMISSION WIRING CONNECTION	
5	CONTROL BOX	
4	DRAIN HOSE (ACCESSORY)	I. D. φ25(OUTLET)
3	SOCKET FOR DRAIN	VP20 (O. D. φ26/I. D. φ20)
2	GAS PIPE CONNECTION	φ12.7 (FLARE CONNECTION)
1	LIQUID PIPE CONNECTION	φ6.4 (FLARE CONNECTION)

3.2 FXDQ-NB

FXDQ40 / 50NBVE (with Drain Pump)

Unit (mm)




NOTE) 1. IN CASE OF BACK-SUCTION, MOUNT CHAMBER COVER TO BOTTOM SIDE OF THE UNIT.
IN CASE OF BOTTOM-SUCTION, MOUNT CHAMBER COVER TO BACK SIDE OF THE UNIT.
2. LOCATION OF UNIT'S NAME PLATE : CONTROL BOX COVER
3. MOUNT THE AIR FILTER AT THE SUCTION SIDE.
(SELECT ITS COLORIMETHOD (GRAVITY METHOD) 50% OR MORE.)
IT CAN NOT BE EQUIPPED WITH AIR FILTER (ACCESSORY)
WHEN CONNECTING DUCT TO SUCTION SIDE.

NUMBER	NAME	DESCRIPTION
11	AIR FILTER (ACCESSORY)	
10	SOCKET FOR DRAIN	
9	INSPECTION DOOR	
8	SUSPENSION BRACKET	
7	POWER SUPPLY CONNECTION	
6	TRANSMISSION WIRING CONNECTION	
5	CONTROL BOX	
4	DRAIN HOSE (ACCESSORY)	I. D. ϕ 25(OUTLET)
3	DRAIN PIPE CONNECTION	VP20 (O. D. ϕ 26/I. D. ϕ 20)
2	GAS PIPE CONNECTION	ϕ 12.7 (FLARE CONNECTION)
1	LIQUID PIPE CONNECTION	ϕ 6.4 (FLARE CONNECTION)


FXDQ63NBVE (with Drain Pump)

Unit (mm)




FXDQ40 / 50NBVET (without Drain Pump)

Unit (mm)




FXDQ63NBVET (without Drain Pump)

Unit (mm)



4. Piping Diagrams



4D060927


■ **Refrigerant pipe connection port diameters**

(mm)


Model	Gas	Liquid
FXDQ20 / 25 / 32PBVE(T), 40 / 50NBVE(T)	ϕ12.7	ϕ6.4
FXDQ63NBVE(T)	ϕ15.9	ϕ9.5

5. Wiring Diagrams

FXDQ20 / 25 / 32PBVE, 40 / 50 / 63NBVE (with Drain Pump)



FXDQ20 / 25 / 32PBVET, 40 / 50 / 63NBVET (without Drain Pump)



A1P	PRINTED CIRCUIT BOARD
C1	CAPACITOR (M1F)
F1U	FUSE (F5A/250V)
HAP	LIGHT EMITTING DIODE (SERVICE MONITOR GREEN)
M1F	MOTOR (INDOOR FAN)
Q1M	THERMAL PROTECTOR (M1F EMBEDDED)
R1T	THERMISTOR (AIR)
R2T	THERMISTOR (COIL-1)
R3T	THERMISTOR (COIL-2)
T1R	TRANSFORMER (220V/22V)
V1TR	PHASE CONTROL CIRCUIT
X1M	TERMINAL BLOCK
X2M	TERMINAL BLOCK
Y1E	ELECTRONIC EXPANSION VALVE
Z1C : Z2C	NOISE FILTER (FERRITE CORE)
	WIRED REMOTE CONTROLLER
R1T	THERMISTOR (AIR)
SS1	SELECTOR SWITCH (MAIN/SUB)
	CONNECTOR FOR OPTIONAL PARTS
X16A	CONNECTOR (ADAPTOR FOR WIRING)
X18A	CONNECTOR (WIRING ADAPTOR FOR ELECTRICAL APPENDICES)

NOTES)
1. : TERMINAL
: CONNECTOR
2. : FIELD WIRING
3. IN CASE USING CENTRAL REMOTE CONTROLLER, CONNECT IT TO THE UNIT IN ACCORDANCE WITH THE ATTACHED INSTALLATION MANUAL.
4. REMOTE CONTROLLER MODEL VARIES ACCORDING TO THE COMBINATION SYSTEM. CONFIRM ENGINEERING MATERIALS AND CATALOGS, ETC. BEFORE CONNECTING.
5. WHEN CONNECTING THE INPUT WIRES FROM OUTSIDE, FORCED OFF OR ON/OFF CONTROL OPERATION CAN BE SELECTED BY REMOTE CONTROLLER. IN DETAILS, REFER TO THE INSTALLATION MANUAL ATTACHED THE UNIT.
6. SYMBOLS SHOW AS FOLLOWS: RED : RED BLK : BLACK WHT : WHITE YLW : YELLOW PRP : PURPLE GRY : GRAY BLU : BLUE PNK : PINK ORG : ORANGE GRN : GREEN

6. Electric Characteristics

Model	Power supply					IFM		Input(W)	
	Hz	Volts	Voltage range	MCA	MFA	KW	FLA	Cooling	Heating
FXDQ20PBVE	50	220-240V	Max. 264V Min. 198V	0.8	15	0.062	0.6	86	67
FXDQ25PBVE				0.8	15	0.062	0.6	86	67
FXDQ32PBVE				0.8	15	0.062	0.6	89	70
FXDQ40NBVE				1.0	15	0.062	0.8	160	147
FXDQ50NBVE				1.0	15	0.13	0.8	165	152
FXDQ63NBVE				1.1	15	0.13	0.9	181	168
FXDQ20PBVE	60	220V	Max. 242V Min. 198V	0.9	15	0.062	0.7	92	73
FXDQ25PBVE				0.9	15	0.062	0.7	92	73
FXDQ32PBVE				0.9	15	0.062	0.7	95	76
FXDQ40NBVE				1.1	15	0.062	0.9	182	168
FXDQ50NBVE				1.3	15	0.13	1.0	185	170
FXDQ63NBVE				1.4	15	0.13	1.1	192	179
FXDQ20PBVET	50	220-240V	Max. 264V Min. 198V	0.7	15	0.062	0.6	67	67
FXDQ25PBVET				0.7	15	0.062	0.6	67	67
FXDQ32PBVET				0.7	15	0.062	0.6	70	70
FXDQ40NBVET				1.0	15	0.062	0.8	147	147
FXDQ50NBVET				1.0	15	0.13	0.8	152	152
FXDQ63NBVET				1.1	15	0.13	0.9	168	168
FXDQ20PBVET	60	220V	Max. 242V Min. 198V	0.8	15	0.062	0.7	73	73
FXDQ25PBVET				0.8	15	0.062	0.7	73	73
FXDQ32PBVET				0.8	15	0.062	0.7	76	76
FXDQ40NBVET				1.1	15	0.062	0.9	168	168
FXDQ50NBVET				1.3	15	0.13	1.0	170	170
FXDQ63NBVET				1.4	15	0.13	1.1	179	179

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
KW : Fan Motor Rated Output(kW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

Note:

1. Voltage range
   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.
2. Maximum allowable voltage unbalance between phases is 2%.
3. MCA/MFA
   MCA = 1.25 X FLA
   MFA ≦ 4 X FLA
   (Next lower standard fuse rating. Min. 15A)
4. Select wire size based on the MCA.
5. Instead of fuse, use circuit breaker.

4D060922

7. Capacity Tables

7.1 FXDQ-PB

[50/60Hz]

Heating capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
20	-19.8	-20.0	1.5	1.5	1.5	1.5	1.5
	-18.8	-19.0	1.5	1.5	1.5	1.5	1.5
	-16.7	-17.0	1.6	1.6	1.6	1.6	1.6
	-14.7	-15.0	1.7	1.7	1.7	1.7	1.7
	-12.6	-13.0	1.8	1.8	1.8	1.8	1.8
	-10.5	-11.0	1.9	1.9	1.9	1.9	1.9
	-9.5	-10.0	1.9	1.9	1.9	1.9	1.9
	-8.5	-9.1	2.0	1.9	1.9	1.9	1.9
	-7.0	-7.6	2.0	2.0	2.0	2.0	2.0
	-5.0	-5.6	2.1	2.1	2.1	2.1	2.1
	-3.0	-3.7	2.2	2.2	2.2	2.2	2.2
	0.0	-0.7	2.3	2.3	2.3	2.3	2.2
	3.0	2.2	2.5	2.4	2.4	2.3	2.2
	5.0	4.1	2.5	2.5	2.4	2.3	2.2
	7.0	6.0	2.6	2.5	2.4	2.3	2.2
	9.0	7.9	2.7	2.5	2.4	2.3	2.2
	11.0	9.8	2.8	2.5	2.4	2.3	2.2
	13.0	11.8	2.8	2.5	2.4	2.3	2.2
	15.0	13.7	2.8	2.5	2.4	2.3	2.2
25	-19.8	-20.0	1.9	1.9	1.9	1.9	1.9
	-18.8	-19.0	1.9	1.9	1.9	1.9	1.9
	-16.7	-17.0	2.1	2.0	2.0	2.0	2.0
	-14.7	-15.0	2.2	2.2	2.2	2.2	2.1
	-12.6	-13.0	2.3	2.3	2.3	2.3	2.3
	-10.5	-11.0	2.4	2.4	2.4	2.4	2.4
	-9.5	-10.0	2.5	2.4	2.4	2.4	2.4
	-8.5	-9.1	2.5	2.5	2.5	2.5	2.5
	-7.0	-7.6	2.6	2.6	2.6	2.6	2.6
	-5.0	-5.6	2.7	2.7	2.7	2.7	2.7
	-3.0	-3.7	2.8	2.8	2.8	2.8	2.8
	0.0	-0.7	3.0	3.0	3.1	3.0	2.8
	3.0	2.2	3.2	3.2	3.1	3.0	2.8
	5.0	4.1	3.4	3.2	3.1	3.0	2.8
	7.0	6.0	3.4	3.2	3.1	3.0	2.8
	9.0	7.9	3.5	3.2	3.1	3.0	2.8
	11.0	9.8	3.6	3.2	3.1	3.0	2.8
	13.0	11.8	3.6	3.2	3.1	3.0	2.8
	15.0	13.7	3.6	3.2	3.1	3.0	2.8
32	-19.8	-20.0	2.4	2.3	2.3	2.3	2.3
	-18.8	-19.0	2.4	2.4	2.4	2.4	2.4
	-16.7	-17.0	2.6	2.6	2.6	2.6	2.5
	-14.7	-15.0	2.7	2.7	2.7	2.7	2.7
	-12.6	-13.0	2.8	2.8	2.8	2.8	2.8
	-10.5	-11.0	3.0	3.0	3.0	3.0	3.0
	-9.5	-10.0	3.1	3.1	3.1	3.0	3.0
	-8.5	-9.1	3.1	3.1	3.1	3.1	3.1
	-7.0	-7.6	3.2	3.2	3.1	3.2	3.2
	-5.0	-5.6	3.4	3.4	3.4	3.4	3.4
	-3.0	-3.7	3.5	3.5	3.5	3.5	3.5
	0.0	-0.7	3.7	3.7	3.7	3.7	3.5
	3.0	2.2	3.9	3.9	3.9	3.7	3.5
	5.0	4.1	4.1	4.0	3.9	3.7	3.5
	7.0	6.0	4.2	4.0	3.9	3.7	3.5
	9.0	7.9	4.3	4.0	3.9	3.7	3.5
	11.0	9.8	4.5	4.0	3.9	3.7	3.5
	13.0	11.8	4.5	4.0	3.9	3.7	3.5
	15.0	13.7	4.5	4.0	3.9	3.7	3.5

Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	SHC	16.0°CWB 23°CDB TC	SHC	18.0°CWB 26°CDB TC	SHC	19.0°CWB 27°CDB TC	SHC	20.0°CWB 28°CDB TC	SHC	22.0°CWB 30°CDB TC	SHC	24.0°CWB 32°CDB TC	SHC
20	10.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.6	1.8	2.9	2.0
	12.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.6	1.8	2.9	2.0
	14.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.6	1.8	2.8	1.9
	16.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.6	1.8	2.8	1.9
	18.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.6	1.8	2.7	1.9
	20.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.6	1.8	2.7	1.9
	21.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.6	1.8	2.7	1.9
	23.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.6	1.8	2.6	1.9
	25.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.6	1.8	2.6	1.9
	27.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.5	1.8	2.5	1.8
	29.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.5	1.7	2.5	1.8
	31.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.4	1.7	2.5	1.8
	33.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.4	1.7	2.4	1.8
	35.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.4	1.7	2.4	1.8
	37.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.3	1.9	2.3	1.6	2.3	1.8
	39.0	1.5	1.4	1.8	1.6	2.1	1.8	2.2	1.9	2.2	1.9	2.3	1.6	2.3	1.8
25	10.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.4	2.2	3.7	2.3
	12.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.4	2.2	3.6	2.2
	14.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.4	2.2	3.6	2.2
	16.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.4	2.2	3.5	2.2
	18.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.4	2.2	3.5	2.2
	20.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.4	2.2	3.4	2.2
	21.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.4	2.2	3.4	2.2
	23.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.3	2.2	3.4	2.1
	25.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.3	2.2	3.3	2.1
	27.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.2	2.2	3.3	2.1
	29.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.2	2.1	3.2	2.1
	31.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.1	2.1	3.2	2.1
	33.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.1	2.1	3.1	2.1
	35.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	3.0	2.2	3.0	2.1	3.1	2.0
	37.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	2.9	2.2	3.0	2.0	3.0	2.0
	39.0	1.9	1.6	2.3	1.9	2.6	2.1	2.8	2.1	2.9	2.1	2.9	2.0	3.0	2.0
32	10.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.3	2.8	4.7	2.9
	12.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.3	2.8	4.7	2.9
	14.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.3	2.8	4.6	2.8
	16.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.3	2.8	4.6	2.8
	18.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.3	2.8	4.5	2.8
	20.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.3	2.8	4.4	2.8
	21.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.3	2.8	4.4	2.7
	23.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.2	2.8	4.3	2.7
	25.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.2	2.7	4.3	2.7
	27.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.1	2.7	4.2	2.7
	29.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.1	2.7	4.2	2.6
	31.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	4.0	2.6	4.1	2.6
	33.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	3.9	2.6	4.0	2.6
	35.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.8	2.7	3.9	2.6	4.0	2.5
	37.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.7	2.6	3.8	2.6	3.9	2.5
	39.0	2.4	2.0	2.9	2.3	3.4	2.4	3.6	2.6	3.7	2.6	3.8	2.5	3.8	2.5

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

7.2 FXDQ-NB

[50/60Hz]

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	SHC	16.0°CWB 23°CDB TC	SHC	18.0°CWB 26°CDB TC	SHC	19.0°CWB 27°CDB TC	SHC	20.0°CWB 28°CDB TC	SHC	22.0°CWB 30°CDB TC	SHC	24.0°CWB 32°CDB TC	SHC
40	10.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.4	3.3	5.9	3.5
	12.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.4	3.3	5.8	3.5
	14.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.4	3.3	5.8	3.5
	16.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.4	3.3	5.7	3.5
	18.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.4	3.3	5.6	3.4
	20.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.4	3.3	5.5	3.4
	21.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.4	3.3	5.5	3.4
	23.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.3	3.3	5.4	3.3
	25.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.2	3.3	5.3	3.3
	27.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.2	3.2	5.3	3.3
	29.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.1	3.2	5.2	3.3
	31.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	5.0	3.2	5.1	3.2
	33.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.8	3.2	4.9	3.2	5.0	3.2
	35.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.7	3.2	4.9	3.1	5.0	3.2
	37.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.7	3.2	4.8	3.1	4.9	3.1
	39.0	3.0	2.5	3.6	2.8	4.2	3.3	4.5	3.3	4.6	3.2	4.7	3.1	4.8	3.1
50	10.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.7	4.2	7.4	4.1
	12.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.7	4.2	7.3	4.1
	14.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.7	4.2	7.2	4.1
	16.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.7	4.2	7.1	4.0
	18.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.7	4.2	7.0	4.0
	20.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.7	4.2	6.9	4.0
	21.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.7	4.2	6.8	4.0
	23.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.6	4.2	6.7	3.9
	25.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.5	4.1	6.6	3.9
	27.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.4	4.1	6.6	3.9
	29.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.3	4.0	6.5	3.8
	31.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.2	4.0	6.4	3.8
	33.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	6.0	4.0	6.1	4.0	6.3	3.8
	35.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	5.9	4.0	6.0	3.9	6.2	3.7
	37.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	5.8	4.0	5.9	3.9	6.1	3.7
	39.0	3.8	3.1	4.5	3.5	5.2	3.9	5.6	4.0	5.7	3.9	5.8	3.9	6.0	3.7
63	10.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.5	5.1	9.3	5.7
	12.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.5	5.1	9.2	5.6
	14.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.5	5.1	9.1	5.5
	16.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.5	5.1	9.0	5.4
	18.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.5	5.1	8.8	5.4
	20.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.5	5.1	8.7	5.3
	21.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.5	5.1	8.7	5.3
	23.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.4	5.1	8.5	5.2
	25.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.3	5.0	8.4	5.1
	27.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.1	5.0	8.3	5.1
	29.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	8.0	4.9	8.2	5.0
	31.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	7.9	4.9	8.1	4.9
	33.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.6	4.9	7.8	4.8	7.9	4.9
	35.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.5	4.8	7.7	4.8	7.8	4.8
	37.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.4	4.8	7.5	4.7	7.7	4.8
	39.0	4.8	3.8	5.7	4.3	6.6	4.8	7.1	4.9	7.2	4.7	7.4	4.7	7.6	4.7

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

Heating capacity


Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
40	-19.8	-20.0	3.0	2.9	2.9	2.9	2.9	2.9
	-18.8	-19.0	3.0	3.0	3.0	3.0	3.0	3.0
	-16.7	-17.0	3.2	3.2	3.2	3.2	3.2	3.2
	-14.7	-15.0	3.4	3.4	3.4	3.4	3.4	3.4
	-12.6	-13.0	3.6	3.6	3.6	3.5	3.5	3.5
	-10.5	-11.0	3.7	3.7	3.7	3.7	3.7	3.7
	-9.5	-10.0	3.8	3.8	3.8	3.8	3.8	3.8
	-8.5	-9.1	3.9	3.9	3.9	3.9	3.9	3.9
	-7.0	-7.6	4.0	4.0	4.0	4.0	4.0	4.0
	-5.0	-5.6	4.2	4.2	4.2	4.2	4.2	4.2
	-3.0	-3.7	4.4	4.4	4.4	4.4	4.4	4.4
	0.0	-0.7	4.7	4.6	4.6	4.6	4.6	4.4
	3.0	2.2	4.9	4.9	4.9	4.8	4.7	4.4
	5.0	4.1	5.1	5.1	5.0	4.8	4.7	4.4
	7.0	6.0	5.2	5.2	5.0	4.8	4.7	4.4
	9.0	7.9	5.4	5.3	5.0	4.8	4.7	4.4
	11.0	9.8	5.6	5.3	5.0	4.8	4.7	4.4
	13.0	11.8	5.6	5.3	5.0	4.8	4.7	4.4
	15.0	13.7	5.6	5.3	5.0	4.8	4.7	4.4
50	-19.8	-20.0	3.7	3.7	3.7	3.7	3.7	3.7
	-18.8	-19.0	3.8	3.8	3.8	3.8	3.8	3.8
	-16.7	-17.0	4.1	4.0	4.0	4.0	4.0	4.0
	-14.7	-15.0	4.3	4.3	4.3	4.2	4.2	4.2
	-12.6	-13.0	4.5	4.5	4.5	4.5	4.5	4.5
	-10.5	-11.0	4.7	4.7	4.7	4.7	4.7	4.7
	-9.5	-10.0	4.8	4.8	4.8	4.8	4.8	4.8
	-8.5	-9.1	4.9	4.9	4.9	4.9	4.9	4.9
	-7.0	-7.6	5.1	5.1	5.1	5.1	5.1	5.1
	-5.0	-5.6	5.3	5.3	5.3	5.3	5.3	5.3
	-3.0	-3.7	5.5	5.5	5.5	5.5	5.5	5.5
	0.0	-0.7	5.9	5.9	5.8	5.8	5.8	5.5
	3.0	2.2	6.2	6.2	6.2	6.1	5.9	5.5
	5.0	4.1	6.4	6.4	6.3	6.1	5.9	5.5
	7.0	6.0	6.6	6.6	6.3	6.1	5.9	5.5
	9.0	7.9	6.8	6.7	6.3	6.1	5.9	5.5
	11.0	9.8	7.0	6.7	6.3	6.1	5.9	5.5
	13.0	11.8	7.1	6.7	6.3	6.1	5.9	5.5
	15.0	13.7	7.1	6.7	6.3	6.1	5.9	5.5
63	-19.8	-20.0	4.7	4.7	4.7	4.7	4.7	4.7
	-18.8	-19.0	4.9	4.9	4.8	4.8	4.8	4.8
	-16.7	-17.0	5.1	5.1	5.1	5.1	5.1	5.1
	-14.7	-15.0	5.4	5.4	5.4	5.4	5.4	5.4
	-12.6	-13.0	5.7	5.7	5.7	5.7	5.7	5.7
	-10.5	-11.0	6.0	6.0	6.0	6.0	6.0	5.9
	-9.5	-10.0	6.1	6.1	6.1	6.1	6.1	6.1
	-8.5	-9.1	6.3	6.3	6.2	6.2	6.2	6.2
	-7.0	-7.6	6.5	6.5	6.4	6.4	6.4	6.4
	-5.0	-5.6	6.8	6.7	6.7	6.7	6.7	6.7
	-3.0	-3.7	7.0	7.0	7.0	7.0	7.0	7.0
	0.0	-0.7	7.5	7.4	7.4	7.4	7.4	7.0
	3.0	2.2	7.9	7.8	7.8	7.7	7.5	7.0
	5.0	4.1	8.1	8.1	8.0	7.7	7.5	7.0
	7.0	6.0	8.4	8.4	8.0	7.7	7.5	7.0
	9.0	7.9	8.7	8.5	8.0	7.7	7.5	7.0
	11.0	9.8	8.9	8.5	8.0	7.7	7.5	7.0
	13.0	11.8	9.0	8.5	8.0	7.7	7.5	7.0
	15.0	13.7	9.0	8.5	8.0	7.7	7.5	7.0

Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.


8. Fan Performances

8.1 FXDQ-PB

FXDQ20 / 25PBVE(T)



FXDQ32PBVE(T)




Note:


1. The remote controller can be used to switch between “HH”, “H” and “L”.
2. The air flow is set to “standard” before leaving the factory.
   It is possible to switch between “standard ESP” and “high ESP” by the remote controller.

8.2 FXDQ-NB


FXDQ40NBVE(T)



FXDQ50NBVE(T)



FXDQ63NBVE(T)



Note:


1. The remote controller can be used to switch between “HH”, “H” and “L”.
2. The air flow is set to “standard” before leaving the factory.
   It is possible to switch between “standard ESP” and “high ESP” by the remote controller.

9. Sound Levels

9.1 FXDQ-PB

Overall

■ **Slim Ceiling Mounted Duct Type**



Note:
1. The operating conditions are assumed to be standard (JIS conditions)
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.


dBA

Model	220~240V 50Hz / 220V 60Hz		
	HH	H	L
FXDQ20PBVE(T)	33	31	29
FXDQ25PBVE(T)	33	31	29
FXDQ32PBVE(T)	33	31	29

Octave Band Level


○——○ 220V~240V 50Hz / 220V 60Hz

FXDQ20PBVE(T)




4D060945

FXDQ25PBVE(T)



4D060946

FXDQ32PBVE(T)




4D060947

9.2 FXDQ-NB

Overall

■ **Slim Ceiling Mounted Duct Type**



4D060948

Note:

1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.


dBA

Model	220~240V 50Hz / 220V 60Hz		
	HH	H	L
FXDQ40NBVE(T)	34	32	30
FXDQ50NBVE(T)	35	33	31
FXDQ63NBVE(T)	36	34	32

Octave Band Level


○——○ 220V~240V 50Hz / 220V 60Hz

FXDQ40NBVE(T)




4D060948

FXDQ50NBVE(T)



4D060949

FXDQ63NBVE(T)




4D060950

10. Center of Gravity

10.1 FXDQ-PB

FXDQ20 / 25 / 32PBVE(T)

Unit (mm)




4D049300D

10.2 FXDQ-NB

FXDQ40 / 50NBVE(T)


Unit (mm)



4D043886J

FXDQ63NBVE(T)

Unit (mm)



4D043887H

11. Installation

CONTENTS

1. SAFETY PRECAUTIONS 1
2. BEFORE INSTALLATION 2
3. SELECTING INSTALLATION SITE 3
4. PREPARATIONS BEFORE INSTALLATION 4
5. INDOOR UNIT INSTALLATION 5
6. REFRIGERANT PIPING WORK 5
7. DRAIN PIPING WORK 7
8. INSTALLING THE DUCT 9
9. ELECTRIC WIRING WORK 9
10. WIRING EXAMPLE 10
11. FIELD SETTING AND TEST RUN 13

1. SAFETY PRECAUTIONS

Please read these “SAFETY PRECAUTIONS” carefully before installing air conditioning equipment and be sure to install it correctly.
After completing installation, conduct a trial operation to check for faults and explain to the customer how to operate the air conditioner and take care of it with the aid of the operation manual. Ask the customer to store the installation manual along with the operation manual for future reference.
This air conditioner comes under the term “appliances not accessible to the general public”.
This unit is a class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.
Meaning of WARNING and CAUTION notices

⚠ **WARNING** ..... Failure to follow these instructions properly may result in personal injury or loss of life.

⚠ **CAUTION** ..... Failure to observe these instructions properly may result in property damage or personal injury, which may be serious depending on the circumstances.

⚠ WARNING

- Ask your dealer or qualified personnel to carry out installation work.
  Do not attempt to install the air conditioner yourself. Improper installation may result in water leakage, electric shocks or fire.
- Install the air conditioner in accordance with the instructions in this installation manual.
  Improper installation may result in water leakage, electric shocks or fire.
- Consult your local dealer regarding what to do in case of refrigerant leakage. When the air conditioner is to be installed in a small room, it is necessary to take proper measures so that the amount of any leaked refrigerant does not exceed the concentration limit in the event of a leakage.
  Otherwise, this may lead to an accident due to oxygen depletion.
- Be sure to use only the specified accessories and parts for installation work.
  Failure to use the specified parts may result in the unit falling, water leakage, electric shocks or fire.
- Install the air conditioner on a foundation strong enough to withstand the weight of the unit.
  A foundation of insufficient strength may result in the equipment falling and causing injury.
- Carry out the specified installation work after taking into account strong winds, typhoons or earthquakes.
  Failure to do so during installation work may result in the unit falling and causing accidents.
- Make sure that a separate power supply circuit is provided for this unit and that all electrical work is carried out by qualified personnel according to local laws and regulations and this installation manual.
  An insufficient power supply capacity or improper electrical construction may lead to electric shocks or fire.
- Make sure that all wiring is secured, the specified wires are used, and that there is no strain on the terminal connections or wires.
  Improper connections or securing of wires may result in abnormal heat build-up or fire.
- When wiring the power supply and connecting the remote controller wiring and transmission wiring, position the wires so that the control box lid can be securely fastened.
  Improper positioning of the control box lid may result in electric shocks, fire or the terminals overheating.
- If refrigerant gas leaks during installation, ventilate the area immediately.
  Toxic gas may be produced if the refrigerant comes into contact with fire.
- After completing installation, check for refrigerant gas leakage.
  Toxic gas may be produced if the refrigerant gas leaks into the room and comes into contact with a source of fire, such as a fan heater, stove or cooker.
- Be sure to switch off the unit before touching any electrical parts.
- Do not touch the switch with wet fingers.
  Touching the switch with wet fingers can cause electric shock.
- Be sure to earth the air conditioner.
  Do not earth the unit to a utility pipe, lightning conductor or telephone earth lead.
  Imperfect earthing may result in electric shocks or fire.
  A high surge current from lightning or other sources may cause damage to the air conditioner.
- Be sure to install an earth leakage breaker.
  Failure to install an earth leakage breaker may result in electric shocks or fire.

⚠ CAUTION

- While following the instructions in this installation manual, install drain piping to ensure proper drainage and insulate piping to prevent condensation.
  Improper drain piping may result in indoor water leakage and property damage.
- Install the indoor and outdoor units, power cord and connecting wires at least 1 meter away from televisions or radios to prevent picture interference and noise.
  (Depending on the incoming signal strength, a distance of 1 meter may not be sufficient to eliminate noise.)
- Remote controller (wireless kit) transmitting distance can be shorter than expected in rooms with electronic fluorescent lamps (inverter or rapid start types).
  Install the indoor unit as far away from fluorescent lamps as possible.
- Do not install the air conditioner in the following locations:
  1. Where there is a high concentration of mineral oil spray or vapour (e.g. a kitchen).
     Plastic parts will deteriorate, parts may fall off and water leakage could result.

3PN09042-1A

2. Where corrosive gas, such as sulphurous acid gas, is produced.
   Corroding of copper pipes or soldered parts may result in refrigerant leakage.
3. Near machinery emitting electromagnetic radiation.
   Electromagnetic radiation may disturb the operation of the control system and result in a malfunction of the unit.
4. Where flammable gas may leak, where there is carbon fibre or ignitable dust suspensions in the air, or where volatile flammables such as paint thinner or gasoline are handled.
   Operating the unit in such conditions may result in fire.

- Do not touch the heat exchanger fins.
  Improper handling may result in injury.
- Be very careful about product transportation.
  Some products use PP bands for packaging. Do not use any PP bands for a means of transportation. It is dangerous.
- Safely dispose of the packing materials.
  Packing materials, such as nails and other metal or wooden parts, may cause stabs or other injuries.
  Tear apart and throw away plastic packaging bags so that children will not play with them. If children play with a plastic bag which was not torn apart, they face the risk of suffocation.
- Do not turn off the power immediately after stopping operation.
  Always wait at least 5 minutes before turning off the power. Otherwise, water leakage and trouble may occur.
- In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

Follow national standards for installation work.

2. BEFORE INSTALLATION

The accessories needed for installation must be retained in your custody until the installation work is completed. Do not discard them!

1. Decide upon a line of transport.
2. Leave the unit inside its packaging while moving, until reaching the installation site. Where unpacking is unavoidable, use a sling of soft material or protective plates together with a rope when lifting, to avoid damage or scratches to the unit.

When moving the unit at or after opening, hold the unit by the hanger brackets. Do not apply force to the refrigerant piping, drain piping or flange parts.

Be sure to check the type of R410A refrigerant to be used before installing the unit.
(Using an incorrect refrigerant will prevent normal operation of the unit.)

For the installation of an outdoor unit, refer to the installation manual attached to the outdoor unit.

2-1 PRECAUTIONS


- Be sure to instruct customers how to properly operate the unit (operating different functions, and adjusting the temperature) by having them carry out operations themselves while looking at the operation manual.
- Do not install in locations where the air contains high levels of salt such as that near the ocean and where voltage fluctuates greatly such as that in factories, or in vehicles or vessels.

2-2 ACCESSORIES

Check the following accessories are included with your unit.

Name	Metal clamp (1)	Drain hose (2)	Insulation for fitting	Sealing pad
Quantity	1 pc.	1 pc.	1 each	1 each
Shape			 for liquid pipe (3)  for gas pipe (4)	 Large (5) mid. (6)

Name	Screws for duct flanges (7)	Washer for hanging bracket (8)	Clamp	Washer fixing plate (11)
Quantity	1 set	8 pcs.	1 set	4 pcs.
Shape	 26 pcs.		 Large (9) 8 pcs.  small (10) 4 pcs.	

Name	Sealing material (12)	Air filter (13)	(Other)
Quantity	2 pcs.	1 pc.	• Operation manual • Product quality certificate • Installation manual (this manual)
Shape			

2-3 OPTIONAL ACCESSORIES

- This indoor unit requires one of the operation remote controls listed below.

Remote controller	
Wired type	BRC1C62
Wireless type (Heat pump type/ Cooling only type)	BRC4C65/BRC4C66

FOR THE FOLLOWING ITEMS, TAKE SPECIAL CARE DURING CONSTRUCTION AND CHECK AFTER INSTALLATION IS FINISHED.

a. Items to be checked after completion of work

Items to be checked	If not properly done, what is likely to occur	Check
Are the indoor and outdoor unit fixed firmly?	The units may drop, vibrate or make noise.	
Is the gas leak test finished?	It may result in insufficient cooling.	
Is the unit fully insulated?	Condensate may drip.	
Does drainage flow smoothly?	Condensate may drip.	
Does the power supply voltage correspond to that shown on the name plate?	The unit may malfunction or the components burn out.	
Are wiring and piping correct?	The unit may malfunction or the components burn out.	
Is the unit safely grounded?	Imcomplete grounding may result in electric shocks.	
Is wiring size according to specifications?	The unit may malfunction or the components burn out.	

Is something blocking the air outlet or inlet of either the indoor or outdoor units?	It may result in insufficient cooling.	
Are refrigerant piping length and additional refrigerant charge noted down?	The refrigerant charge in the system is not clear.	

Also review the “SAFETY PRECAUTIONS”.

b. Items to be checked at time of delivery

Items to be checked	Check
Did you explain about operations while showing the operation manual to your customer?	
Did you hand the operation manual and warranty over to your customer?	
Did you explain about the way of maintaining and cleaning local procurements (air filter, grille (both air outlet and suction grille), etc.) to your customer?	
Did you hand manuals of local procurements (in case equipped) over to your customer?	

c. Points for explanation about operations

The items with ⚠ WARNING and ⚠ CAUTION marks in the operation manual are the items pertaining to possibilities for bodily injury and material damage in addition to the general usage of the product. Accordingly, it is necessary that you make a full explanation about the described contents and also ask your customers to read the operation manual.

3. SELECTING INSTALLATION SITE

⚠ CAUTION

- When moving the unit during or after unpacking, make sure to lift it by holding its lifting lugs. Do not exert any pressure on other parts, especially the refrigerant piping, drain piping and flange parts.
- If you think the humidity inside the ceiling might exceed 30˚C and RH80%, reinforce the insulation on the unit body. Use glass wool or polyethylene foam as insulation so that it is no thicker than 10mm and fits inside the ceiling opening.

(1) Select an installation site where the following conditions are fulfilled and that meets with your customer’s approval.
- Where optimum air distribution can be ensured.
- Where nothing blocks air passage.
- Where condensate can be properly drained.
- Where the ceiling is strong enough to bear the indoor unit weight.
- Where the false ceiling is not noticeably on an incline.
- Where there is no risk of flammable gas leakage.
- Where sufficient clearance for maintenance and service can be ensured. **(Refer to Fig. 1)**
- Where piping between indoor and outdoor units is possible within the allowable limit. (Refer to the installation manual for the outdoor unit.)




Fig. 1

(length : mm)

- *H1 dimension means the minimum height of the unit.
- Select the *H1, *H2 dimension such that a downward slope of at least 1/100 is ensured as indicated in “**7. DRAIN PIPING WORK**”.
- The maintenance space marked with “*” is required when the installation box for adaptor PC board (KRP1BA101) sold separately is used.

[PRECAUTION]
- Install the indoor and outdoor units, power supply wiring and connecting wires at least 1 m away from televisions or radios in order to prevent image interference or noise. (Depending on the radio waves, a distance of 1 m may not be sufficient enough to eliminate the noise.)
- If installing the wireless kit in a room with electronic fluorescent lighting (inverter or rapid start type), the remote controller’s transmission distance may be shortened. Indoor units should be installed as far away from fluorescent lighting as possible.

(2) Use suspension bolts for installation. Check whether the ceiling is strong enough to support the weight of the unit or not. If there is a risk, reinforce the ceiling before installing the unit.
(Installation pitch is marked on the carton box for installation. Refer to it to check for points requiring reinforcing.)

4. PREPARATIONS BEFORE INSTALLATION

(1) Confirm the positional relationship between the unit and suspension bolts. (Refer to Fig. 2)

- Install the inspection opening on the control box side where maintenance and inspection of the control box and drain pump are easy. Install the inspection opening also in the lower part of the unit.




Fig. 2

(length: mm)


Model	A	B
20 · 25 · 32 type	700	740
40 · 50 type	900	940
63 type	1100	1140

(2) Make sure the range of the unit's external static pressure is not exceeded.
(See the technical documentation for the range of the external static pressure setting.)

(3) Open the installation hole. (Pre-set ceilings)

- Once the installation hole is opened in the ceiling where the unit is to be installed, pass refrigerant piping, drain piping, transmission wiring, and remote controller wiring (It is not necessary if using a wireless remote controller) to the unit's piping and wiring holes.
  See "**6. REFRIGERANT PIPING WORK**", "**7. DRAIN PIPING WORK**", and "**10. WIRING EXAMPLE**".
- After opening the ceiling hole, make sure ceiling is level if needed. It might be necessary to reinforce the ceiling frame to prevent shaking.
  Consult an architect or carpenter for details.

(4) Install the suspension bolts.
(Use W3/8 to M10 suspension bolts.)
Use a hole-in-anchor for existing ceilings, and a sunken insert, sunken anchor or other part to be procured in the field to reinforce the ceiling to bearing the weight of the unit for new ceiling. **(Refer to Fig. 3)**



Note: All the above parts are field supplied.

Fig. 3

(5) For bottom intake, replace the chamber lid and protection net in the procedure listed in Fig. 4.
(1) Remove the protection net.
(6 locations)···PBVE(T) type only
Remove the chamber lid. (7 locations)
(2) Reattached the removed chamber lid in the orientation shown in Fig. 4. (7 locations)
Reattached the removed protection net in the orientation shown in Fig. 4.
(6 locations)···PBVE(T) type only
(3) Attach the air filter (accessory) in the manner shown in the diagram.
The four holes which cannot be covered by the air filter should be covered with commercially available tape.





Fig. 4

3PN09042-1A

(3)



In case of bottom side In case of back side

5. INDOOR UNIT INSTALLATION

⟨⟨As for the parts to be used for installation work, be sure to use the provided accessories and specified parts designated by our company.⟩⟩

(1) Install the indoor unit temporarily.

- Attach the hanger bracket to the suspension bolt. Be sure to fix it securely by using a nut and washer from the upper and lower sides of the hanger bracket. **(Refer to Fig. 5)**

[Securing the hanger bracket] [How to secure washers]




Fig. 5


[PRECAUTION]
Since the unit uses a plastic drain pan, prevent welding spatter and other foreign substances from the air outlet during installation.

(2) Adjust the height of the unit.

(3) Check the unit is horizontally level.

⚠ CAUTION

- **Make sure the unit is installed level using a level or a plastic tube filled with water. In using a plastic tube instead of a level, adjust the top surface of the unit to the surface of the water at both ends of the plastic tube and adjust the unit horizontally. (One thing to watch out for in particular is if the unit is installed so that the slope is not in the direction of the drain piping, this might cause leaking.)**



(4) Tighten the upper nut.

6. REFRIGERANT PIPING WORK

⟨For refrigerant piping of outdoor units, see the installation manual attached to the outdoor unit.⟩
⟨Execute heat insulation work completely on both sides of the gas piping and the liquid piping. Otherwise, a water leakage can result sometimes.
Use insulation that can withstand temperatures of at least 120˚C. Reinforce the insulation on the refrigerant piping according to the installation environment. If the temperature above the ceiling might reach 30˚C or the humidity RH80%. Condensation may form on the surface of the insulation.⟩

⚠ CAUTION

Follow the points at below.

- Use a pipe cutter and flare suitable for the type of refrigerant.
- Apply ester oil or ether oil to the flare section when using a flare connection.
- Only use the flare nuts included with the unit. Using different flare nuts may cause the refrigerant to leak.
- To prevent dust, moisture or other foreign matter from infiltrating the piping, either pinch the end or cover it with tape.
- Do not allow anything other than the designated refrigerant to get mixed into the refrigerant circuit, such as air, etc. If any refrigerant gas leaks while working on the unit, ventilate the room thoroughly right away.

(1) Connect the piping.

- The outdoor unit is charged with refrigerant.
- Be sure to use both a spanner and torque wrench together, as shown in the drawing, when connecting or disconnecting pipes to/from the unit. **(Refer to Fig. 6)**




Fig. 6





Fig. 7

- Refer to the Table 1 for the dimensions of flare nut spaces.
- Apply ether oil or ester oil only to inner side of the flare when using flare nut connections and then turn 3 or 4 times by hand. **(Refer to Fig. 7)**

C : 3PN09042-1A

• Refer to Table 1 for tightening torque.

Table 1

Pipe size	Tightening torque	Flare dimension A (mm)	Flare shape
ϕ 6.4 (1/4")	14.2 – 17.2 N·m (144 – 176 kgf·cm)	8.7 – 9.1	
ϕ 9.5 (3/8")	32.7 – 39.9 N·m (333 – 407 kgf·cm)	12.8 – 13.2	
ϕ 12.7 (1/2")	49.5 – 60.3 N·m (504 – 616 kgf·cm)	16.2 – 16.6	
ϕ 15.9 (5/8")	61.8 – 75.4 N·m (630 – 770 kgf·cm)	19.3 – 19.7	

⚠ CAUTION

Overtightening may damage the flare and cause leaks. Be careful for oil not to adhere to any portions other than a flare part. If oil adhere to resin parts etc., there is a possibility of damaging by deterioration.

• Refer to Table 2 if no torque wrench is available.
Using a wrench to tighten flare nuts causes the tightening torque to suddenly grow much tighter after a certain point. From there, tighten the nut further by the appropriate angle listed in Table 2.

(2) After the work is finished, make sure to check that there is no gas leak.

(3) After checking for gas leaks, be sure to insulate the pipe connections referring to Fig. 8.
- Insulate using the insulation for fitting (3) (4) included with the liquid and gas pipes. Besides, make sure the insulation for fitting (3) (4) on the liquid and gas piping has its seams facing up.
(Tighten both edges with clamp (9).)
- For the gas piping, wrap the mid. sealing pad (6) over the insulation for fitting (4) (flare nut part).




Fig. 8

⚠ CAUTION

Be sure to insulate any field piping all the way to the piping connection inside the unit. Any exposed piping may cause condensation or burns if touched.

• When brazing the refrigerant piping, perform nitrogen replacement first, or perform the brazing (CAUTION 2) while feeding nitrogen into the refrigerant piping (CAUTION 1), and finally connect the indoor unit using the flare connections. **(Refer to Fig. 9)**

⚠ CAUTION

1. When brazing a pipe while feeding nitrogen inside the pipe, make sure to set the nitrogen pressure to 0.02 MPa (0.2 kg/cm^2) using the pressure reducing valve. (This pressure is such that breeze is blown to your cheek.)
2. Do not use a flux when brazing the refrigerant pipe joints. Use phosphor copper brazer (BCuP-2: JIS Z 3264/B-Cu93P-710/795: ISO 3677) which does not require flux. (Using a flux containing chlorine may cause the piping to corrode. Using a welding flux containing fluorine may cause the refrigerant lubricant to deteriorate, and affect adversely the refrigerant piping system.)




Fig. 9

Not recommendable but in case of emergency

You must use a torque wrench but if you are obliged to install the unit without a torque wrench, you may follow the installation method mentioned below.

After the work is finished, make sure to check that there is no gas leak.

When you keep on tightening the flare nut with a spanner, there is a point where the tightening torque suddenly increases. From that position, further tighten the flare nut the angle shown below:

Table 2

Pipe size	Further tightening angle	Recommended arm length of tool
ϕ 6.4 (1/4")	60 to 90 degrees	Approx. 150mm
ϕ 9.5 (3/8")	60 to 90 degrees	Approx. 200mm
ϕ 12.7 (1/2")	30 to 60 degrees	Approx. 250mm
ϕ 15.9 (5/8")	30 to 60 degrees	Approx. 300mm


7. DRAIN PIPING WORK

In case of PBVE, NBVE type (with drain pump)

⚠ CAUTION

- The connection opening on the drain piping may vary depending on the model, so check the model name and use the right method for that model.
- Make sure all water is out before making the duct connection.

(1) Install the drain piping.



- Make sure the drain works properly.
- The diameter of the drain piping should be greater than or equal to the diameter of the connecting pipe (vinyl tube; pipe size: 20 mm; outer dimension: 26 mm).
  (not including the riser)
- Keep the drain piping short and sloping downwards at a gradient of at least 1/100 to prevent air pockets from forming. **(Refer to Fig. 10)**




Fig. 10

⚠ CAUTION

Water accumulating in the drain piping can cause the drain to clog.

- To keep the drain piping from sagging, space hanging bracket every 1 to 1.5 m.
- Use the drain hose (2) and the metal clamp (1). Insert the drain hose (2) fully into the drain socket and firmly tighten the metal clamp (1) with the upper part of the tape on the hose end. Tighten the metal clamp (1) until the screw head is less than 4 mm from the hose. **(Refer to Fig. 11, 12)**
- The two areas below should be insulated because condensation may form there causing water to leak.
  - Drain piping passing indoors
  - Drain socket

  Referring the figure below, insulate the metal clamp (1) and drain hose (2) using the included large sealing pad (5). **(Refer to Fig. 12)**




Fig. 11




Fig. 12

〈 PRECAUTIONS FOR DRAIN RAISING PIPE 〉

- Make sure the drain raising pipe height is no higher than 600mm.
- Place the drain raising pipe vertically and make sure it is no further than 300mm from the unit. **(Refer to Fig. 13)**




Fig. 13

〈 PRECAUTIONS 〉

Drain piping connections

- Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain piping and corrode the heat exchanger.
- Do not twist or bend the drain hose (2), so that excessive force is not applied to it.
  (This type of treatment may cause leaking.)
- If you are using central drain piping, follow the procedure outlined in the figure 10.
- Select central drain piping of proper size according to the capacity of the connected unit.

(2) After piping work is finished, check drainage flows smoothly, with manner described below.

⚠ CAUTION

- The electric wiring work shall be performed by qualified electricians.
- If workers not having the electrician qualification have performed the electric wiring work, the steps 3 to 7 shall be performed after the **TEST RUN**.

5

1. Remove the control box lid. Connect the remote controller and power supply (single-phase, 50 Hz 220-240 V or single-phase, 60Hz 220V) respectively to the terminal block and securely connect the earth also (as shown in the figure below).

⚠ CAUTION

Securely clamp the cables with the clamps (9)(10) offered as accessories as shown in Fig. 17 so that tension will not be applied on the cable connection areas.

2. Confirm that the control box lid is closed before turning on the power.
3. Remove the inspection lid.
4. Gradually pour approximately 1L of water from the inspection window into the drain pan to check drainage.


⚠ CAUTION

Be sure to prevent an external force from being exerted on the float switch.
(This may cause breakage.)

5. Attach the inspection lid.
6. Perform the following operation using the remote controller, and check drainage.
   - Select the inspection/test operation button "TEST" using the remote controller. The unit will engage the test operation. Press the operation selector button "", and select FAN OPERATION "".
   - Press the ON/OFF button "". (The indoor fan and drain pump will operate.)

⚠ CAUTION

The fan will turn also at the same time. Take due care.
Do not touch the drain pump to prevent electric shock.




7. Make sure to use the remote controller in finishing the operation.

In case of PBVET, NBVET type (without drain pump)

⚠ CAUTION

- The connection opening on the drain piping may vary depending on the model, so check the model name and use the right method for that model.
- Make sure all water is out before making the duct connection.

(1) Install the drain piping.



Connect the drain pipe after removing the rubber cap and insulation tubing attached to the connection hole.

- Make sure the drain works properly.
- The diameter of the drain piping should be greater than or equal to the diameter of the connecting pipe (vinyl tube; pipe size: 20 mm; outer dimension: 26 mm).
  (not including the riser)
- Keep the drain piping short and sloping downwards at a gradient of at least 1/100 to prevent air pockets from forming.
  (Refer to Fig. 14)




Fig. 14

⚠ CAUTION

Water accumulating in the drain piping can cause the drain to clog.

- To keep the drain piping from sagging, space hanging bracket every 1 to 1.5 m.
- Use the drain hose (2) and the metal clamp (1). Insert the drain hose (2) fully into the drain socket and firmly tighten the metal clamp (1) with the upper part of the tape on the hose end. Tighten the metal clamp (1) until the screw head is less than 4 mm from the hose. **(Refer to Fig. 15, 16)**
- The two areas below should be insulated because condensation may form there causing water to leak.
  - Drain piping passing indoors
  - Drain socket

  Referring the figure below, insulate the metal clamp (1) and drain hose (2) using the included large sealing pad (5).
  (Refer to Fig. 16)




Fig. 15





Fig. 16

〈 PRECAUTIONS 〉

Drain piping connections

- Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain piping and corrode the heat exchanger.
- Do not twist or bend the drain hose (2), so that excessive force is not applied to it.
  (This type of treatment may cause leaking.)
- If you are using central drain piping, follow the procedure outlined in the figure 14.
- Select central drain piping of proper size according to the capacity of the connected unit.

(2) After piping work is finished, check drainage flows smoothly, with manner described below.



- Gradually pour approximately 1L of water from the outlet hole into the drain pan to check drainage.
- Check the drainage.

8. INSTALLING THE DUCT

Connect the duct supplied in the field.

Air inlet side


- Attach the duct and intake-side flange (field supply).
- Connect the flange to the main unit with accessory screws (7).

Class	20 · 25 · 32	40 · 50	63
Number of positions	16	22	26

- Wrap the intake-side flange and duct connection area with aluminum tape or something similar to prevent air escaping.

⚠ CAUTION

When attaching a duct to the intake side, be sure to attach an air filter inside the air passage on the intake side. (Use an air filter whose dust collecting efficiency is at least 50% in a gravimetric technique.)
The included filter is not used when the intake duct is attached.



Air outlet side

- Connect the duct according to the air inside of the outlet-side flange.
- Wrap the outlet-side flange and the duct connection area with aluminum tape or something similar to prevent air escaping.

⚠ CAUTION

- Be sure to insulate the duct to prevent condensation from forming. (Material: glass wool or polyethylene foam, 25 mm thick)
- Use electric insulation between the duct and the wall when using metal ducts to pass metal laths of the net or fence shape or metal plating into wooden buildings.
- Be sure to explain about the way of maintaining and cleaning local procurements (air filter, grille (both air outlet and suction grille), etc.) to your customer.

9. ELECTRIC WIRING WORK

9-1 GENERAL INSTRUCTIONS

- Shut off the power before doing any work.
- All field supplied parts and materials, electric works must conform to local codes.
- Use copper wire only.
- See also the “Wiring Diagram plate” attached to the control box lid when laying electrical wiring.
- For details on hooking up the remote controller, refer to the “REMOTE CONTROLLER INSTALLATION MANUAL”.
- All wiring must be performed by an authorized electrician.
- This system consists of multiple indoor units. Mark each indoor unit as unit A, unit B . . . , and be sure the terminal board wiring to the outdoor unit and BS unit are properly matched. If wiring and piping between the outdoor unit and an indoor unit are mismatched, the system may cause a malfunction.
- A circuit breaker capable of shutting down power supply to the entire system must be installed.
- Refer to the installation manual attached to the outdoor unit for the size of power supply wiring connected to the outdoor unit, the capacity of the circuit breaker and switch, and wiring instructions.
- Be sure to ground the air conditioner.
- Do not the earth wire should come in contact with gas pipes, water pipes, lightning rods, or telephone earth wires.
  - Gas pipes: gas leaks can cause explosions and fire.
  - Water pipes: they cannot be grounded if hard vinyl pipes are used.
  - Telephone earth wire and lightning rods: the ground potential when struck by lightning gets extremely high.
- To avoid short circuiting the power supply wire, be sure to use insulated terminals.
- Do not turn on the power supply (circuit breaker or earth leakage breaker) until all other work is done.

9-2 SPECIFICATIONS FOR FIELD SUPPLIED FUSES AND WIRE

Power-related

Model	Power supply wiring (including earth wire)			
	Number of units	Field fuses	Wire	Size
20 · 25 · 32 type	1	15A	H05VV-U3G (NOTE 1)	Size must comply with local codes.
40 · 50 type				
63 type				

Model	Transmission wiring Remote controller wiring	
	Wire	Size (mm^2)
20 · 25 · 32 type	Sheathed vinyl cord or cable (2 wires) (NOTE 2)	0.75 - 1.25
40 · 50 type		
63 type		

NOTES
1. Shows only in case of protected pipes. Use H07RN-F in case of no protection.
2. Insulated thickness : 1mm or more.
3. If the wiring is in a place where people it can be easily touched by people, install an earth leakage breaker to prevent electric shock.
4. When using an earth leakage breaker, make sure to select one useful also to protection against overcurrent and short-circuit.
   When using an earth leakage breaker only for earth device, make sure to use a wiring interrupter together.

- The length of the transmission wiring and remote controller wiring are as follows.

Length of the transmission wiring and remote controller wiring

Outdoor unit – Indoor unit	Max. 1000m (Total wiring length: 2000m)
Indoor unit – Remote controller	Max. 500m

9-3 ELECTRICAL CHARACTERISTICS

Units				Power supply		Fan motor	
Model	Hz	Volts	Voltage range	MCA	MFA	KW	FLA
20 · 25 · 32 PBVE	50	220-240	Min. 198 Max. 264	0.8	15	0.062	0.6
20 · 25 · 32 PBVET				0.7		0.062	0.6
40 NBVE(T)				1.0		0.062	0.8
50 NBVE(T)				1.0		0.13	0.8
63 NBVE(T)				1.1		0.13	0.9
20 · 25 · 32 PBVE	60	220	Min. 198 Max. 242	0.9	15	0.062	0.7
20 · 25 · 32 PBVET				0.8		0.062	0.7
40 NBVE(T)				1.1		0.062	0.9
50 NBVE(T)				1.3		0.13	1.0
63 NBVE(T)				1.4		0.13	1.1

MCA: Minimum Circuit Amps (A) MFA:Max. Fuse Amps (A)
KW: Fan motor output (kW) FLA:Full Load Amps (A)

10. WIRING EXAMPLE

10-1 HOW TO CONNECT WIRINGS

- Wire only after removing the control box lid as shown in Fig. 17.




Fig. 17

⚠ CAUTION

- When clamping the wiring, use the included clamp material (9) and (10) as shown in the Fig.17 to prevent outside pressure being exerted on the wiring connections and clamp firmly.
- Be sure to attach power supply wiring and earth wire to the control box with the clamp.
- When doing the wiring, make sure the wiring is neat and does not cause the control box lid to stick up, then close the cover firmly. When attaching the control box lid, make sure you do not pinch any wires.
- Outside the air conditioners, separate the weak wiring (remote controller and transmission wiring) and strong wiring (earth wire and power supply wiring) at least 50 mm so that they do not pass through the same place together. Proximity may cause electrical interference, malfunctions, and breakage.

[PRECAUTIONS]

- Refer to the "REMOTE CONTROLLER INSTALLATION MANUAL" on how to install and lay the wiring for the remote controller.
- See also the "Wiring Diagram plate" attached to the control box lid when laying electrical wiring.
- Connect the remote controller and transmission wiring their respective terminal blocks.

⚠ CAUTION

- **Do not, under any circumstances, connect the power supply wiring to the remote controller or transmission wiring terminal block. Doing so can destroy the entire system.**

[Connecting electrical wiring, remote controller wiring, and transmission wiring] (Refer to Fig. 18)






Fig. 18

- **Power supply and Earth wiring**
  Remove the control box lid.
  Next, pull the wires into the unit through the wiring through hole and connect to the terminal block (3P).
  Be sure to put the part of the sheathed vinyl into the control box.
- **Remote controller and transmission wiring**
  Pull the wires into the unit through the wiring through hole and connect to the terminal block (6P).
  Be sure to put the part of the sheathed vinyl into the control box.

<Precautions when laying power supply wiring >

- Wiring of different thicknesses cannot be connected to the power supply wiring terminal block. (Slack in the power supply wiring may cause abnormal heat.)
- Use sleeve-insulated round crimp-style terminals for connections to the power supply wiring terminal block. When none are available, connect wires of the same diameter to both sides, as shown in the figure.





Follow the instructions are below if the wiring may get very hot due to slack in the power supply wiring.

- For wiring, use the designated power supply wiring and connect firmly, then secure to prevent outside pressure being exerted on the terminal board.
- Use the correct screwdriver for tightening the terminal screws. If the blade of screwdriver is too small, the head of the screw might be damaged, and the screw will not be properly tightened.
- If the terminal screws are tightened too hard, screws might be damaged.
- Refer to the table below for the tightening torque of the terminal screws.

Terminal block	Tightening torque (N·m)
Remote controller / transmission wiring terminal block (6P)	0.79 – 0.97
Power supply wiring terminal block (3P)	1.18 – 1.44

[WIRING EXAMPLE]

No. 1 system When using 1 remote controller for 1 indoor unit




Fig. 19

No. 2 system For group control or use with 2 remote controllers




Fig. 20

No. 3 system When including BS unit





Fig. 21

10-2 CONTROL BY 2 REMOTE CONTROLLERS (Controlling 1 indoor unit by 2 remote controllers)


- When using 2 remote controllers, one must be set to "MAIN" and the other to "SUB".

MAIN/SUB CHANGEOVER

(1) Insert a ⊖ screwdriver into the recess between the upper and lower part of remote controller and, working from the 2 positions, pry off the upper part (2 locations).
The remote controller PC board is attached to the upper part of remote controller.




(2) Turn the MAIN/SUB changeover switch on one of the two remote controller PC boards to "S".
(Leave the switch of the other remote controller set to "M".)



Wiring Method (See "9. ELECTRIC WIRING WORK")


(3) Remove the control box lid.

(4) Add remote controller 2 (SUB) to the terminal block for remote controller (P_1, P_2) in the control box. (There is no polarity.)




[PRECAUTIONS]

- Crossover wiring is needed when using group control and 2 remote controllers at the same time.
- Connect the indoor unit at the end of the crossover wire (P_1, P_2) to remote controller 2 (SUB).



10-3 REMOTE CONTROL (FORCED OFF AND ON/OFF OPERATION)

- Connect input lines from the outside to the terminals T_1 and T_2 on the terminal block (6P) for remote controller to achieve remote control.
- See the "**11. FIELD SETTING AND TEST RUN**" for details on operation.



Wire specification	Sheathed vinyl cord or cable (2 wires)
Gauge	0.75 - 1.25 mm^2
Length	Max. 100 m
External terminal	Contact that can ensure the minimum applicable load of 15 V DC, 1 mA.

10-4 CENTRALIZED CONTROL

- For centralized control, it is necessary to designate the group No. For details, refer to the manual of each optional controllers for centralized control.


11. FIELD SETTING AND TEST RUN

〈Field settings may have to be performed using the remote controller, depending on the type of installation.〉

(1) Make sure the control box lids are closed on the indoor and outdoor units.

(2) Depending on the type of installation, make the field settings from the remote controller after the power is turned on, following the "Field Settings" manual which came with the remote controller.

- The settings can select "Mode No.", "FIRST CODE NO." and "SECOND CODE NO.".
- The "Field Settings" included with the remote controller lists the order of the settings and method of operation.



- Lastly, make sure the customer keeps the "Field Settings" manual, along with the operating manual, in a safe place.

11-1 SETTING THE STATIC PRESSURE SELECTION

- Select the SECOND CODE NO. for the resistance of the connected duct.
  (The SECOND CODE NO. is set to "01" when shipped.)
- See the technical documentation for details.

External static pressure	Mode No.	FIRST CODE NO.	SECOND CODE NO.
Standard (10Pa)	13(23)	5	01
High static pressure setting (30Pa)			02

11-2 REMOTE CONTROL SETTING

- Forced off and ON/OFF operation should be selected by selecting the SECOND CODE NO. as shown in the table below.
  (The SECOND CODE NO. is set to "01" when shipped.)

External ON/OFF input	Mode No.	FIRST CODE NO.	SECOND CODE NO.
Forced off	12(22)	1	01
ON/OFF operation			02

- Input A of forced off and ON/OFF operation work as shown in the table below.

Forced off	ON/OFF operation
Input A "on" to force a stop (remote controller reception prohibited)	Unit operated by changing input A from "off" to "on"
Input A "off" to allow remote controller	Unit stopped by changing input A from "on" to "off"

11-3 SETTING THE FILTER SIGN DISPLAY INTERVAL

- Explain the following to the customer if the filter dirt settings have been changed.
- The filter sign display time is set to 2500 hours (equivalent to 1 year's use) when shipped.
- The settings can be changed to not display.
- When installing the unit in a place with much dusts, set the filter sign display time to shorter intervals (1,250 hours).
- Explain it to the customer that the filter needs to be cleaned regularly to prevent clogging and also the time that is set.

Mode No.	FIRST CODE NO.		SECOND CODE NO.	
			01	02
10 (20)	0	Filter dirt	low	high
	1 (low/high)	Displayed time (units: hours)	2500/1250	10000/5000
	3	Filter sign display	ON	OFF

11-4 SETTINGS FOR SEPARATELY SOLD ACCESSORIES

- See the instruction manuals included with separately sold accessories for the necessary settings.

〈 **When using a wireless remote controller** 〉

- A wireless remote controller address needs to be set when using a wireless remote controller. See the installation manual included with the wireless remote controller for details on how to make the settings.

(3) Perform a test run according to the outdoor unit's installation manual.

- The operation lamp of the remote controller will flash when a malfunction occurs. Check the malfunction code on the liquid crystal display to identify the point of trouble. An explanation of malfunction codes and the corresponding trouble is provided in "CAUTION FOR SERVICING" of the outdoor unit.
  If the display shows any of the following, there is a possibility that the wiring was done incorrectly or that the power is not on, so check again.

Remote control display	Content
"⚠" display	• There is a short circuit at the FORCED OFF terminals (T_1, T_2).
"U3" display	• The test-run has not been performed.
"U4" display "UA" display	• The power on the outdoor unit is off. • The outdoor unit has not been wired for power supply. • Wiring is incorrect for the transmission wiring and / or FORCED OFF wiring. • The transmission wiring is cut.
"UF" display	• Reversed transmission wiring
No display	• The power on the indoor unit is off. • The indoor unit has not been wired for power supply. • Wiring is incorrect for the remote controller wiring, the transmission wiring and / or the FORCED OFF wiring. • The remote controller wiring is cut.

⚠ CAUTION

- Always stop the test run using the remote controller to stop operation.



(4) After finishing the test run, make sure to check drainage in the drain pump according to "7. DRAIN PIPING WORK".

12. Accessories

12.1 FXDQ-PB, FXDQ-NB

Standard Accessories

Name	Metal clamp (1)	Drain hose (2)	Insulation for fitting	Sealing pad	Screws for duct flanges (7)	Washer for hanging bracket (8)	Clamp
Quantity	1 pc.	1 pc.	1 each	1 each	1 set	8 pcs.	1 set
Shape			 for liquid pipe (3)  for gas pipe (4)	 Large (5)  mid. (6)	 26 pcs.		 Large (9) 8 pcs.  small (10) 4 pcs.

Name	Washer fixing plate (11)	Sealing material (12)	Air filter (13)	
Quantity	4 pcs.	2 pcs.	1 pc.	(Other) • Operation manual • Product quality certificate • Installation manual (this manual)
Shape				

3PN09042-1A

Optional Accessories (For Unit)

Item \ Type	FXDQ20PBVE (T) FXDQ25PBVE (T) FXDQ32PBVE (T)	FXDQ40NBVE (T) FXDQ50NBVE (T)	FXDQ63NBVE (T)
Insulation kit for high humidity	KDT25N32	KDT25N50	KDT25N63

C : 4D060939


Optional Accessories (for Controls)

Item \ Type			FXDQ20PBVE (T) FXDQ25PBVE (T) FXDQ32PBVE (T)	FXDQ40NBVE (T) FXDQ50NBVE (T)	FXDQ63NBVE (T)
Remote controller	Wired		BRC1C62		
	Wireless	H/P	BRC4C65		
		C/O	BRC4C66		
Wired remote controller with weekly schedule timer			BRC1D61		
Simplified remote controller (Exposed type)			BRC2C51		
Remote controller for hotel use (Concealed type)			BRC3A61		
Adaptor for wiring			KRP1B56		
Wiring adaptor for electrical appendices (1)			KRP2A53		
Wiring adaptor for electrical appendices (2)			KRP4A54		
Remote sensor			KRCS01-1B		
Installation box for adaptor PCB			KRP1BA101		
Central remote controller			DCS302CA61		
Electrical box with earth terminal	2 blocks		KJB212AA		
	3 blocks		KJB311AA		
Unified ON / OFF controller			DCS301BA61		
Noise filter (for electromagnetic interface use only)			KEK26-1A		
Schedule timer			DST301BA61		
External control adaptor for outdoor unit (Must be installed on indoor units)			DTA104A53		

C : 4D060939

KDT25N32 / 50 / 63 – Insulation Kit for High Humidity

Dimensions **Unit: mm**



Model	Part Name	AA	AB	AA
KDT25N32	FOR TOP PLATE1	700	350	380
	FOR TOP PLATE2	700	350	240
	FOR BOTTOM PLATE	704	352	420
	FOR CHANBER	621	310	200
KDT25N50	FOR TOP PLATE1	900	450	380
	FOR TOP PLATE2	900	450	240
	FOR BOTTOM PLATE	904	452	420
	FOR CHANBER	821	410	200
KDT25N63	FOR TOP PLATE1	1100	550	380
	FOR TOP PLATE2	1100	550	240
	FOR BOTTOM PLATE	1104	552	420
	FOR CHANBER	1021	510	200

Item \ Model	KDT25N32	KDT25N50	KDT25N63
Material	Foam polyethylene (with Japanese paper)		
Accessories	Installation manual		


FXSQ-M
Ceiling Mounted Built-In Type

1. Features 208
2. Specifications 211
3. Dimensions 214
4. Piping Diagrams 222
5. Wiring Diagrams 223
6. Electric Characteristics 224
7. Capacity Tables 225
   7.1 Cooling Capacity 225
   7.2 Heating Capacity 226
8. Fan Performances 227
   8.1 50Hz 227
   8.2 60Hz 228
9. Sound Levels 229
10. Installation 231
11. Accessories 234

1. Features


A highly flexible air-conditioning system that is adaptable to a wide range of needs, and is designed to facilitate maintenance while providing a high-quality environment.

- Offers freedom of development for the body, outlets and inlets, and wide variety of optional functions, and gives you the freedom to choose the best set-up according to conditions and needs such as interior and layout design, maintenance, etc.




Installation Examples (∗Optional Parts)


●**Standard**




●**With duct** (case 1)




●**With duct** (case 2)




●**Cassette style** (standard filter)




●**Cassette style** (high efficiency filter)



●**Ceiling return**



- In addition to regular ducts, layout is unrestricted and design is easy. You can also use flexible ducts that do not require the duct work of regular ducts.
- Offers a selection of nine models ranging from 20 class (equivalent to 0.8 HP) to Maximum 125 class (equivalent to 5 HP).
- All models feature thin design (350 mm height) making them applicable to ceiling pockets that tend to be shallow.
- Lets you set external static pressure in three stages ranging from max. 10 to min. 2 mm H_2O (2 stages, min. 4 mm H_2O for 80 class) according to conditions such as duct height or whether a high-efficiency filter is used, etc.
- Equipped with a programmed drying mechanism that dehumidifies while inhibiting changes in room temperature
- Includes as standard equipment a long-life filter that is maintenance-free for approximately one year. (Treated to mold resistant.)
- Includes as standard equipment drain pump kit that makes possible draining in the upward direction up to 250 mm from the drain pipe opening.




- Quiet-type air-conditioner doesn't destroy the quiet mood of your office.

Capacity	20 type	25 type	32 type	40 type	50 type	63 type	80 type	100 type	125 type
Operating sound (dBA)	37/32	37/32	38/32	38/32	41/36	42/35	43/37	43/37	46/41

- Two types of high-efficiency filters, 65% and 90% (colorimetric method) are available. (Cannot be used if using rear suction type.)
- Suction half panel is thin and unimposing. Ceiling materials adhere to its surface and it provides an excellent finishing touch for the ceiling.
- A wide variety of optional accessories are available such as an auxiliary electric heater (except cooling only).
- If using duct air mounting, please consult with the local fire department for auxiliary heater installation.


Example of Installation (Built-In)

■ Direct installation of half panel




Model		FXSQ20M FXSQ25M FXSQ32M	FXSQ40M FXSQ50M	FXSQ63M	FXSQ80M FXSQ100M FXSQ125M
Necessary Options	Remote Controller	BRC1C62			
	Half Panel	BYBS32DJW1	BYBS45DJW1	BYBS71DJW1	BYBS125DJW1

■ Installation of Half panel and suction canvas




Model		FXSQ20M FXSQ25M FXSQ32M	FXSQ40M FXSQ50M	FXSQ63M	FXSQ80M FXSQ100M FXSQ125M
Necessary Options	Remote Controller	BRC1C62			
	Half Panel	BYBS32DJW1	BYBS45DJW1	BYBS71DJW1	BYBS125DJW1
	Air Suction Canvas	KSA-25K36	KSA-25K56	KSA-25K80	KSA-25L160

■ Installation like ceiling mounted cassette type with High efficiency filter



Model			FXSQ20M FXSQ25M FXSQ32M	FXSQ40M FXSQ50M	FXSQ63M	FXSQ80M FXSQ100M FXSQ125M
Necessary Options	Remote Controller		BRC1C62			
	Half Panel		BYBS32DJW1	BYBS45DJW1	BYBS71DJW1	BYBS125DJW1
	High Efficiency Filter	NBS65%	KAFJ252L36	KAFJ252L56	KAFJ252L80	KAFJ252L160
		NBS90%	KAFJ253L36	KAFJ253L56	KAFJ253L80	KAFJ253L160
	Air Suction Canvas		KSA-25K36	KSA-25K56	KSA-25K80	KSA-25L160
	Bottom Suction Filter Chamber		KAJ25L36D	KAJ25L56D	KAJ25L80D	KAJ25L160D


■ Installation with duct (A)



The access panel should be fitted beneath the main body of the unit.

Model			FXSQ20M FXSQ25M FXSQ32M	FXSQ40M FXSQ50M	FXSQ63M	FXSQ80M FXSQ100M FXSQ125M
Necessary Options	Remote Controller		BRC1C62			
	Access Panel		KTBJ25K36W	KTBJ25K56W	KTBJ25K80W	KTBJ25K160W
	Rear Suction Filter Chamber		KAJ25L36B	KAJ25L56B	KAJ25L80B	KAJ25L160B
	Screening Door		KBBJ25K36	KBBJ25K56	KBBJ25K80	KBBJ25K160
	High Efficiency Filter (If Necessary)	NBS65%	KAFJ252L36	KAFJ252L56	KAFJ252L80	KAFJ252L160
		NBS90%	KAFJ253L36	KAFJ253L56	KAFJ253L80	KAFJ253L160


■ Ceiling return



The access panel should be fitted beneath the main body of the unit.

Model		FXSQ20M FXSQ25M FXSQ32M	FXSQ40M FXSQ50M	FXSQ63M	FXSQ80M FXSQ100M FXSQ125M
Necessary Options	Remote Controller	BRC1C62			
	Access Panel	KTBJ25K36W	KTBJ25K56W	KTBJ25K80W	KTBJ25K160W

■ Installation with duct (B)



The access panel should be fitted beneath the main body of the unit.

Model		FXSQ20M FXSQ25M FXSQ32M	FXSQ40M FXSQ50M	FXSQ63M	FXSQ80M FXSQ100M FXSQ125M
Necessary Options	Remote Controller	BRC1C62			
	Access Panel	KTBJ25K36W	KTBJ25K56W	KTBJ25K80W	KTBJ25K160W
	Screening Door	KBBJ25K36	KBBJ25K56	KBBJ25K80	KBBJ25K160
	Air Suction Flange	KDJ2507K36	KDJ2507K56	KDJ2507K80	KDJ2507K160

2. Specifications

Ceiling Mounted Built-In Type

Model				FXSQ20MVE	FXSQ25MVE	FXSQ32MVE
∗1 Cooling Capacity (19.5°CWB)			kcal/h	2,000	2,500	3,200
			Btu/h	7,800	9,900	12,600
			kW	2.3	2.9	3.7
∗2 Cooling Capacity (19.0°CWB)			kW	2.2	2.8	3.6
∗3 Heating Capacity			kcal/h	2,200	2,800	3,400
			Btu/h	8,500	10,900	13,600
			kW	2.5	3.2	4.0
Casing				Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)			mm	300×550×800	300×550×800	300×550×800
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch		mm	3×14×1.75	3×14×1.75	3×14×1.75
	Face Area		m²	0.088	0.088	0.088
Fan	Model			D18H3A	D18H3A	D18H3A
	Type			Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units		W	50×1	50×1	50×1
	Air Flow Rate (H/L)	50 Hz	m³/min	9/6.5	9/6.5	9.5/7
			cfm	318/230	318/230	335/247
		60 Hz	m³/min	9/6.5	9/6.5	9.5/6.5
			cfm	318/230	318/230	335/230
	∗4 External Static Pressure	50 Hz	Pa	88-39-20	88-39-20	64-39-15
		60 Hz	Pa	73-24-10	73-24-10	86-42-10
	Drive			Direct Drive	Direct Drive	Direct Drive
Temperature Control				Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material				Glass Fiber	Glass Fiber	Glass Fiber
Air Filter				Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
Piping Connections	Liquid Pipes		mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)
	Gas Pipes		mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)
	Drain Pipe		mm	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)
Machine Weight (Mass)			kg	30	30	30
∗6 Sound Level (H/L) (220V)			dBA	37/32	37/32	38/32
Safety Devices				Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control				Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit				R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Decoration Panel (Option)	Model			BYBS32DJW1	BYBS32DJW1	BYBS32DJW1
	Panel Color			White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)
	Dimensions: (H×W×D)		mm	55×650×500	55×650×500	55×650×500
	Weight		kg	3	3	3
Standard Accessories				Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers.
Drawing No.				C : 3D039431		

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗4 External static pressure is changeable to change over the connectors inside electrical box, this pressure means "High static pressure-Standard -Low static pressure".
5 Capacities are net, including a deduction for cooling (an additional for heating) for indoor fan motor heat.
∗6 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit center. These values are normally somewhat higher during actual operation as a result of ambient conditions.
7 Refer to page 224 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860
Btu/h=kW×3412
cfm=m³/min×35.3

Ceiling Mounted Built-In Type

Model				FXSQ40MVE	FXSQ50MVE	FXSQ63MVE
∗1 Cooling Capacity (19.5°CWB)			kcal/h	4,000	5,000	6,300
			Btu/h	16,000	19,800	24,900
			kW	4.7	5.8	7.3
∗2 Cooling Capacity (19.0°CWB)			kW	4.5	5.6	7.1
∗3 Heating Capacity			kcal/h	4,300	5,400	6,900
			Btu/h	17,100	21,500	27,300
			kW	5.0	6.3	8.0
Casing				Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)			mm	300×700×800	300×700×800	300×1,000×800
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch		mm	3×14×1.75	3×14×1.75	3×14×1.75
	Face Area		m²	0.132	0.132	0.221
Fan	Model			D18H2A	D18H2A	2D18H2A
	Type			Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units		W	65×1	85×1	125×1
	Air Flow Rate (H/L)	50 Hz	m³/min	11.5/9	15/11	21/15.5
			cfm	406/318	530/388	741/547
		60 Hz	m³/min	11.5/9	15/11	21/14
			cfm	406/318	530/388	741/494
	∗4 External Static Pressure	50 Hz	Pa	88-49-20	88-59-29	88-49-20
		60 Hz	Pa	88-29-10	88-41-10	122-66-10
	Drive			Direct Drive	Direct Drive	Direct Drive
Temperature Control				Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material				Glass Fiber	Glass Fiber	Glass Fiber
Air Filter				Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
Piping Connections	Liquid Pipes		mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes		mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe		mm	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)
Machine Weight (Mass)			kg	30	31	41
∗6 Sound Level (H/L) (220V)			dBA	38/32	41/36	42/35
Safety Devices				Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control				Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit				R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Decoration Panel (Option)	Model			BYBS45DJW1	BYBS45DJW1	BYBS71DJW1
	Panel Color			White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)
	Dimensions: (H×W×D)		mm	55×800×500	55×800×500	55×1,100×500
	Weight		kg	3.5	3.5	4.5
Standard Accessories				Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers.
Drawing No.				C : 3D039431		

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗4 External static pressure is changeable to change over the connectors inside electrical box, this pressure means "High static pressure-Standard -Low static pressure".
5 Capacities are net, including a deduction for cooling (an additional for heating) for indoor fan motor heat.
∗6 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit center. These values are normally somewhat higher during actual operation as a result of ambient conditions.
7 Refer to page 224 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Ceiling Mounted Built-In Type

Model				FXSQ80MVE	FXSQ100MVE	FXSQ125MVE
∗1 Cooling Capacity (19.5°CWB)			kcal/h	8,000	10,000	12,500
			Btu/h	31,700	39,600	49,500
			kW	9.3	11.6	14.5
∗2 Cooling Capacity (19.0°CWB)			kW	9.0	11.2	14.0
∗3 Heating Capacity			kcal/h	8,600	10,800	13,800
			Btu/h	34,100	42,700	54,600
			kW	10.0	12.5	16.0
Casing				Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)			mm	300×1,400×800	300×1,400×800	300×1,400×800
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch		mm	3×14×1.75	3×14×1.75	3×14×1.75
	Face Area		m²	0.338	0.338	0.338
Fan	Model			3D18H2A	3D18H2A	3D18H2A
	Type			Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units		W	225×1	225×1	225×1
	Air Flow Rate (H/L)	50 Hz	m³/min	27/21.5	28/22	38/28
			cfm	953/759	988/777	1,341/988
		60 Hz	m³/min	27/20.5	28/21	38/27
			cfm	953/724	988/741	1,341/953
	∗4 External Static Pressure	50 Hz	Pa	113-82	107-75	78-39
		60 Hz	Pa	147-92	136-83	78-20
	Drive			Direct Drive	Direct Drive	Direct Drive
Temperature Control				Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material				Glass Fiber	Glass Fiber	Glass Fiber
Air Filter				Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
Piping Connections	Liquid Pipes		mm	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes		mm	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe		mm	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)
Machine Weight (Mass)			kg	51	51	52
∗6 Sound Level (H/L) (220V)			dBA	43/37	43/37	46/41
Safety Devices				Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control				Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit				R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Decoration Panel (Option)	Model			BYBS125DJW1	BYBS125DJW1	BYBS125DJW1
	Panel Color			White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)
	Dimensions: (H×W×D)		mm	55×1,500×500	55×1,500×500	55×1,500×500
	Weight		kg	6.5	6.5	6.5
Standard Accessories				Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Screws. Washers.
Drawing No.				C : 3D039431		

Note:


∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗4 External static pressure is changeable to change over the connectors inside electrical box, this pressure means "High static pressure-Standard".
5 Capacities are net, including a deduction for cooling (an additional for heating) for indoor fan motor heat.
∗6 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit center. These values are normally somewhat higher during actual operation as a result of ambient conditions.
7 Refer to page 224 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

3. Dimensions


FXSQ20M + BYBS32DJW1 (With Canvas Duct)
FXSQ25M + BYBS32DJW1 (With Canvas Duct)
FXSQ32M + BYBS32DJW1 (With Canvas Duct)

Unit (mm)




FXSQ40M + BYBS45DJW1 (With Canvas Duct)
FXSQ50M + BYBS45DJW1 (With Canvas Duct)

Unit (mm)



FXSQ63M + BYBS71DJW1 (With Canvas Duct)


Unit (mm)



FXSQ80M + BYBS125DJW1 (With Canvas Duct)
FXSQ100M + BYBS125DJW1 (With Canvas Duct)
FXSQ125M + BYBS125DJW1 (With Canvas Duct)


Unit (mm)

3D039440



FXSQ20M + BYBS32DJW1 (Without Canvas Duct)
FXSQ25M + BYBS32DJW1 (Without Canvas Duct)
FXSQ32M + BYBS32DJW1 (Without Canvas Duct)


Unit (mm)



FXSQ40M + BYBS45DJW1 (Without Canvas Duct)
FXSQ50M + BYBS45DJW1 (Without Canvas Duct)

Unit (mm)


3D039434



Number	Name	Description
1	Liquid pipe connection	ϕ5.4 flare connection
2	Gas pipe connection	ϕ12.7 flare connection
3	Drain pipe connection	VP25 (O. D. ϕ32 I. D. ϕ25)
4	Interunit wiring port	
5	Power wiring port	
6	Drain hole	VP25 (O. D. ϕ32 I. D. ϕ25)
7	Air filter	

FXSQ63M + BYBS71DJW1 (Without Canvas Duct)


Unit (mm)




FXSQ80M + BYBS125DJW1 (Without Canvas Duct)
FXSQ100M + BYBS125DJW1 (Without Canvas Duct)
FXSQ125M + BYBS125DJW1 (Without Canvas Duct)

Unit (mm)

3D039436



4. Piping Diagrams



4D034245C


■ **Refrigerant pipe connection port diameters**

(mm)

Model	Gas	Liquid
FXSQ20 · 25 · 32 · 40 · 50M	ϕ12.7	ϕ6.4
FXSQ63 · 80 · 100 · 125M	ϕ15.9	ϕ9.5

5. Wiring Diagrams

FXSQ20 · 25 · 32 · 40 · 50 · 63 · 80 · 100 · 125MVE



NOTES)
1. □□□ : TERMINAL BLOCK, ⊡⊡ , ⊃– : CONNECTOR, –○– : TERMINAL
2. ⫣⫣ : FIELD WIRING
3. IN CASE USING CENTRAL REMOTE CONTROLLER, CONNECT IT TO THE UNIT IN ACCORDANCE WITH THE ATTACHED INSTRUCTION MANUAL.
4. WHEN CONNECTING THE INPUT WIRES FROM OUTSIDE. FDRCED OFF OR ON/OFF CONTROL OPERATION CAN BE SELECTED BY REMOTE CONTROLLER. IN DETAILS, REFER TO THE INSTALLATION MANUAL ATTACHED THE UNIT.
5. IN CASE INSTALLING THE ELECTRIC HEATER, EXECUTE THE ADDITIONAL WIRING FOR HEATER CIRCUIT (K1M, E1H). IN THIS CASE, THE MAIN POWER SUPPLY HAS TO BE SUPPLIED INDEPENDENTLY.
6. IN CASE HIGH OR LOW E.S.P. OPERATION, CHANGE OVER THE WIRING CONNECTION FROM X4A (OF A2P) TO X3A OR X5A.
7. SYMBOLS SHOW AS FOLLOWS. (PNK : PINK WHT : WHITE YLW : YELLOW GRY : GRAY ORG : ORANGE BLU : BLUE BLK : BLACK RED : RED BRN : BROWN GRN : GREEN)
8. USE COPPER CONDUCTORS ONLY.
9. ONLY 80. 100. 125 TYPE.

6. Electric Characteristics

Units					Power supply		IFM		Input(W)	
Model	Type	Hz	Volts	Voltage range	MCA	MFA	KW	FLA	Cooling	Heating
FXSQ20M	VE	50	220-240	MAX. 264 Min. 198	0.5	15	0.05	0.4	110	90
FXSQ25M					0.5	15	0.05	0.4	110	90
FXSQ32M					0.5	15	0.05	0.4	114	94
FXSQ40M					0.6	15	0.065	0.5	127	107
FXSQ50M					0.9	15	0.085	0.7	143	123
FXSQ63M					1.1	15	0.125	0.9	189	169
FXSQ80M					1.4	15	0.225	1.1	234	214
FXSQ100M					1.5	15	0.225	1.2	242	222
FXSQ125M					2.0	15	0.225	1.6	321	301
FXSQ20M	VE	60	220	MAX. 242 Min. 198	0.6	15	0.05	0.5	128	108
FXSQ25M					0.6	15	0.05	0.5	128	108
FXSQ32M					0.8	15	0.05	0.6	136	116
FXSQ40M					0.9	15	0.065	0.7	155	135
FXSQ50M					1.0	15	0.085	0.8	200	180
FXSQ63M					1.4	15	0.125	1.1	254	234
FXSQ80M					1.8	15	0.225	1.4	315	295
FXSQ100M					1.9	15	0.225	1.5	326	306
FXSQ125M					2.5	15	0.225	2.0	435	415

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
KW : Fan Motor Rated Output(KW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

Note:

1. Voltage range

   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.

2. Maximum allowable voltage unbalance between phases is 2%.

3. MCA/MFA

   MCA = 1.25 X FLA

   MFA ≦ 4 X FLA

   (Next lower standard fuse rating. Min. 15A)

4. Select wire size based on the MCA.

5. Instead of fuse, use Circuit Breaker.

C : 4D036936A

7. Capacity Tables

7.1 Cooling Capacity

FXSQ-M **[50/60Hz]**

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	14.0°CWB 20°CDB SHC	16.0°CWB 23°CDB TC	16.0°CWB 23°CDB SHC	18.0°CWB 26°CDB TC	18.0°CWB 26°CDB SHC	19.0°CWB 27°CDB TC	19.0°CWB 27°CDB SHC	20.0°CWB 28°CDB TC	20.0°CWB 28°CDB SHC	22.0°CWB 30°CDB TC	22.0°CWB 30°CDB SHC	24.0°CWB 32°CDB TC	24.0°CWB 32°CDB SHC
20	10.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.6	1.9	2.9	1.9
	12.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.6	1.9	2.9	1.9
	14.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.6	1.9	2.8	1.8
	16.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.6	1.9	2.8	1.8
	18.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.6	1.9	2.7	1.8
	20.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.6	1.9	2.7	1.8
	21.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.6	1.9	2.7	1.8
	23.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.6	1.9	2.6	1.7
	25.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.6	1.8	2.6	1.7
	27.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.5	1.8	2.5	1.7
	29.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.5	1.8	2.5	1.7
	31.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.4	1.8	2.5	1.7
	33.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.9	2.4	1.8	2.4	1.7
	35.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.8	2.4	1.8	2.4	1.7
	37.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.3	1.8	2.3	1.7	2.3	1.6
	39.0	1.5	1.4	1.8	1.6	2.1	1.7	2.2	1.8	2.2	1.8	2.3	1.7	2.3	1.6
25	10.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.4	2.3	3.7	2.3
	12.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.4	2.3	3.6	2.2
	14.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.4	2.3	3.6	2.2
	16.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.4	2.3	3.5	2.2
	18.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.4	2.3	3.5	2.2
	20.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.4	2.3	3.4	2.1
	21.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.4	2.3	3.4	2.1
	23.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.3	2.2	3.3	2.1
	25.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.2	2.2	3.3	2.1
	27.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.2	2.2	3.2	2.0
	29.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.1	2.1	3.2	2.0
	31.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.1	2.1	3.1	2.0
	33.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.0	2.1	3.0	2.0
	35.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	3.0	2.2	3.0	2.1	3.0	2.0
	37.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	2.9	2.2	2.9	2.1	3.0	2.0
	39.0	1.9	1.7	2.3	1.9	2.6	2.0	2.8	2.1	2.9	2.2	2.9	2.1	3.0	2.0
32	10.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.3	2.8	4.7	2.8
	12.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.3	2.8	4.7	2.7
	14.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.3	2.8	4.6	2.7
	16.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.3	2.8	4.6	2.7
	18.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.3	2.8	4.5	2.6
	20.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.3	2.8	4.4	2.6
	21.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.3	2.8	4.4	2.6
	23.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.2	2.7	4.3	2.6
	25.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.2	2.7	4.3	2.5
	27.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.1	2.6	4.2	2.5
	29.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.1	2.6	4.2	2.5
	31.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	4.0	2.6	4.1	2.5
	33.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	3.9	2.6	4.0	2.4
	35.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.8	2.7	3.9	2.6	4.0	2.4
	37.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.7	2.7	3.8	2.5	3.9	2.4
	39.0	2.4	2.0	2.9	2.3	3.4	2.5	3.6	2.5	3.7	2.6	3.8	2.5	3.8	2.4
40	10.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.3	5.9	3.6
	12.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.3	5.8	3.6
	14.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.3	5.7	3.5
	16.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.3	5.6	3.5
	18.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.3	5.5	3.4
	20.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.4	3.3	5.5	3.4
	21.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.3	3.3	5.4	3.4
	23.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.3	3.2	5.4	3.3
	25.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.2	3.2	5.3	3.3
	27.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.2	3.2	5.2	3.3
	29.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.1	3.2	5.2	3.3
	31.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	5.0	3.1	5.1	3.2
	33.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.8	3.3	4.9	3.1	5.0	3.2
	35.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.2	4.7	3.3	4.8	3.0	4.9	3.1
	37.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.3	4.6	3.3	4.7	3.0	4.8	3.1
	39.0	3.0	2.6	3.6	3.0	4.2	3.2	4.5	3.3	4.6	3.3	4.5	3.0	4.7	3.0
50	10.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.7	4.0	7.4	4.4
	12.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.7	4.0	7.3	4.4
	14.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.7	4.0	7.2	4.3
	16.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.7	4.0	7.1	4.3
	18.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.7	4.0	7.0	4.3
	20.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.7	4.0	6.9	4.2
	21.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.7	4.0	6.8	4.2
	23.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.6	4.0	6.7	4.2
	25.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.5	4.0	6.6	4.1
	27.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.4	3.9	6.6	4.1
	29.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.3	3.9	6.5	4.0
	31.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.2	3.8	6.4	4.0
	33.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	6.0	4.3	6.1	3.8	6.3	3.9
	35.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	5.9	4.3	6.0	3.8	6.2	3.9
	37.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	5.8	4.3	5.9	3.7	6.1	3.9
	39.0	3.8	3.2	4.5	3.7	5.2	3.9	5.6	4.1	5.7	4.2	5.8	3.7	6.0	3.8

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	14.0°CWB 20°CDB SHC	16.0°CWB 23°CDB TC	16.0°CWB 23°CDB SHC	18.0°CWB 26°CDB TC	18.0°CWB 26°CDB SHC	19.0°CWB 27°CDB TC	19.0°CWB 27°CDB SHC	20.0°CWB 28°CDB TC	20.0°CWB 28°CDB SHC	22.0°CWB 30°CDB TC	22.0°CWB 30°CDB SHC	24.0°CWB 32°CDB TC	24.0°CWB 32°CDB SHC
63	10.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.5	5.6	9.3	5.6
	12.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.5	5.6	9.2	5.6
	14.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.5	5.6	9.1	5.5
	16.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.5	5.6	9.0	5.4
	18.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.5	5.6	8.8	5.3
	20.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.5	5.6	8.7	5.3
	21.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.5	5.6	8.7	5.2
	23.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.4	5.5	8.5	5.2
	25.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.3	5.5	8.4	5.1
	27.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.1	5.4	8.3	5.1
	29.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	8.0	5.3	8.2	5.1
	31.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	7.9	5.3	8.1	5.0
	33.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.6	5.5	7.9	5.2	7.9	5.0
	35.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.5	5.5	7.7	5.2	7.8	4.9
	37.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.4	5.4	7.5	5.2	7.7	4.9
	39.0	4.8	4.1	5.7	4.7	6.6	4.9	7.1	5.2	7.2	5.4	7.4	5.1	7.6	4.9
80	10.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.8	6.8	11.8	6.9
	12.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.8	6.8	11.7	6.8
	14.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.8	6.8	11.5	6.7
	16.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.8	6.8	11.4	6.6
	18.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.8	6.8	11.2	6.5
	20.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.8	6.8	11.1	6.4
	21.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.8	6.8	11.0	6.4
	23.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.6	6.7	10.8	6.2
	25.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.5	6.6	10.7	6.2
	27.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.3	6.5	10.5	6.2
	29.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.2	6.5	10.4	6.1
	31.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	10.0	6.4	10.2	6.1
	33.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.6	6.6	9.8	6.3	10.1	6.1
	35.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.3	9.5	6.6	9.7	6.3	9.9	6.0
	37.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.4	9.4	6.5	9.6	6.2	9.8	6.0
	39.0	6.1	5.0	7.2	5.7	8.4	6.1	9.0	6.4	9.2	6.5	9.4	6.2	9.6	5.9
100	10.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	13.4	8.5	14.7	8.5
	12.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	13.4	8.5	14.5	8.4
	14.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	13.4	8.5	14.4	8.3
	16.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	13.4	8.5	14.2	8.2
	18.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	13.4	8.5	14.0	8.1
	20.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	13.4	8.5	13.8	8.0
	21.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	13.4	8.5	13.7	7.9
	23.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	13.2	8.4	13.5	7.8
	25.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	13.0	8.3	13.3	7.7
	27.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	12.8	8.1	13.1	7.7
	29.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	12.6	8.0	12.9	7.6
	31.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	12.4	8.0	12.7	7.5
	33.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.9	8.3	12.2	7.9	12.5	7.5
	35.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.8	8.2	12.1	7.8	12.3	7.5
	37.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.6	8.1	11.9	7.8	12.2	7.4
	39.0	7.6	6.2	9.0	7.1	10.5	7.6	11.2	7.9	11.4	8.1	11.7	7.7	12.0	7.3
125	10.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	16.8	10.7	18.4	11.0
	12.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	16.8	10.7	18.2	10.9
	14.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	16.8	10.7	18.0	10.7
	16.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	16.8	10.7	17.7	10.6
	18.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	16.8	10.7	17.5	10.4
	20.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	16.8	10.7	17.2	10.3
	21.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	16.8	10.7	17.1	10.2
	23.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	16.5	10.6	16.9	10.1
	25.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	16.3	10.4	16.6	10.0
	27.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	16.1	10.3	16.4	9.9
	29.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	15.8	10.1	16.2	9.8
	31.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	15.6	10.0	15.9	9.6
	33.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.9	10.3	15.3	9.9	15.7	9.5
	35.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.8	10.2	15.1	9.8	15.4	9.4
	37.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	9.9	14.5	10.1	14.9	9.7	15.2	9.3
	39.0	9.5	7.8	11.3	8.9	13.1	9.6	14.0	10.0	14.3	9.9	14.6	9.6	15.0	9.2

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

7.2 Heating Capacity

FXSQ-M [50/60Hz]

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
20	-19.8	-20.0	1.5	1.5	1.5	1.5	1.5	1.5
	-18.8	-19.0	1.5	1.5	1.5	1.5	1.5	1.5
	-16.7	-17.0	1.6	1.6	1.6	1.6	1.6	1.6
	-14.7	-15.0	1.7	1.7	1.7	1.7	1.7	1.7
	-12.6	-13.0	1.8	1.8	1.8	1.8	1.8	1.8
	-10.5	-11.0	1.9	1.9	1.9	1.9	1.9	1.9
	-9.5	-10.0	1.9	1.9	1.9	1.9	1.9	1.9
	-8.5	-9.1	2.0	1.9	1.9	1.9	1.9	1.9
	-7.0	-7.6	2.0	2.0	2.0	2.0	2.0	2.0
	-5.0	-5.6	2.1	2.1	2.1	2.1	2.1	2.1
	-3.0	-3.7	2.2	2.2	2.2	2.2	2.2	2.2
	0.0	-0.7	2.3	2.3	2.3	2.3	2.3	2.2
	3.0	2.2	2.5	2.4	2.4	2.4	2.3	2.2
	5.0	4.1	2.6	2.5	2.5	2.4	2.3	2.2
	7.0	6.0	2.7	2.6	2.5	2.4	2.3	2.2
	9.0	7.9	2.8	2.7	2.5	2.4	2.3	2.2
	11.0	9.8	2.8	2.7	2.5	2.4	2.3	2.2
	13.0	11.8	2.8	2.7	2.5	2.4	2.3	2.2
	15.0	13.7	2.8	2.7	2.5	2.4	2.3	2.2
25	-19.8	-20.0	1.9	1.9	1.9	1.9	1.9	1.9
	-18.8	-19.0	1.9	1.9	1.9	1.9	1.9	1.9
	-16.7	-17.0	2.1	2.1	2.0	2.0	2.0	2.0
	-14.7	-15.0	2.2	2.2	2.2	2.2	2.2	2.1
	-12.6	-13.0	2.3	2.3	2.3	2.3	2.3	2.3
	-10.5	-11.0	2.4	2.4	2.4	2.4	2.4	2.4
	-9.5	-10.0	2.5	2.4	2.4	2.4	2.4	2.4
	-8.5	-9.1	2.5	2.5	2.5	2.5	2.5	2.5
	-7.0	-7.6	2.6	2.6	2.6	2.6	2.6	2.6
	-5.0	-5.6	2.7	2.7	2.7	2.7	2.7	2.7
	-3.0	-3.7	2.8	2.8	2.8	2.8	2.8	2.8
	0.0	-0.7	3.0	3.0	3.0	3.0	3.0	2.8
	3.0	2.2	3.1	3.1	3.1	3.1	3.0	2.8
	5.0	4.1	3.3	3.2	3.2	3.1	3.0	2.8
	7.0	6.0	3.4	3.4	3.2	3.1	3.0	2.8
	9.0	7.9	3.5	3.4	3.2	3.1	3.0	2.8
	11.0	9.8	3.6	3.4	3.2	3.1	3.0	2.8
	13.0	11.8	3.6	3.4	3.2	3.1	3.0	2.8
	15.0	13.7	3.6	3.4	3.2	3.1	3.0	2.8
32	-19.8	-20.0	2.4	2.4	2.3	2.3	2.3	2.3
	-18.8	-19.0	2.4	2.4	2.4	2.4	2.4	2.4
	-16.7	-17.0	2.6	2.6	2.6	2.6	2.6	2.5
	-14.7	-15.0	2.7	2.7	2.7	2.7	2.7	2.7
	-12.6	-13.0	2.9	2.8	2.8	2.8	2.8	2.8
	-10.5	-11.0	3.0	3.0	3.0	3.0	3.0	3.0
	-9.5	-10.0	3.1	3.1	3.1	3.1	3.0	3.0
	-8.5	-9.1	3.1	3.1	3.1	3.1	3.1	3.1
	-7.0	-7.6	3.2	3.2	3.2	3.2	3.2	3.2
	-5.0	-5.6	3.4	3.4	3.4	3.4	3.4	3.4
	-3.0	-3.7	3.5	3.5	3.5	3.5	3.5	3.5
	0.0	-0.7	3.7	3.7	3.7	3.7	3.7	3.5
	3.0	2.2	3.9	3.9	3.9	3.9	3.7	3.5
	5.0	4.1	4.1	4.2	4.0	3.9	3.7	3.5
	7.0	6.0	4.2	4.3	4.0	3.9	3.7	3.5
	9.0	7.9	4.3	4.3	4.0	3.9	3.7	3.5
	11.0	9.8	4.5	4.3	4.0	3.9	3.7	3.5
	13.0	11.8	4.5	4.3	4.0	3.9	3.7	3.5
	15.0	13.7	4.5	4.3	4.0	3.9	3.7	3.5

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
40	-19.8	-20.0	3.0	2.9	2.9	2.9	2.9	2.9
	-18.8	-19.0	3.0	3.0	3.0	3.0	3.0	3.0
	-16.7	-17.0	3.2	3.2	3.2	3.2	3.2	3.2
	-14.7	-15.0	3.4	3.4	3.4	3.4	3.4	3.4
	-12.6	-13.0	3.6	3.6	3.5	3.5	3.5	3.5
	-10.5	-11.0	3.7	3.7	3.7	3.7	3.7	3.7
	-9.5	-10.0	3.8	3.8	3.8	3.8	3.8	3.8
	-8.5	-9.1	3.9	3.9	3.9	3.9	3.9	3.9
	-7.0	-7.6	4.0	4.0	4.0	4.0	4.0	4.0
	-5.0	-5.6	4.2	4.2	4.2	4.2	4.2	4.2
	-3.0	-3.7	4.4	4.4	4.4	4.4	4.4	4.4
	0.0	-0.7	4.7	4.6	4.6	4.6	4.6	4.4
	3.0	2.2	4.9	4.9	4.8	4.8	4.7	4.4
	5.0	4.1	5.1	5.1	5.0	4.8	4.7	4.4
	7.0	6.0	5.2	5.2	5.0	4.8	4.7	4.4
	9.0	7.9	5.4	5.3	5.0	4.8	4.7	4.4
	11.0	9.8	5.6	5.3	5.0	4.8	4.7	4.4
	13.0	11.8	5.6	5.3	5.0	4.8	4.7	4.4
	15.0	13.7	5.6	5.3	5.0	4.8	4.7	4.4
50	-19.8	-20.0	3.7	3.7	3.7	3.7	3.7	3.7
	-18.8	-19.0	3.8	3.8	3.8	3.8	3.8	3.8
	-16.7	-17.0	4.1	4.0	4.0	4.0	4.0	4.0
	-14.7	-15.0	4.3	4.3	4.2	4.2	4.2	4.2
	-12.6	-13.0	4.5	4.5	4.5	4.5	4.5	4.5
	-10.5	-11.0	4.7	4.7	4.7	4.7	4.7	4.7
	-9.5	-10.0	4.8	4.8	4.8	4.8	4.8	4.8
	-8.5	-9.1	4.9	4.9	4.9	4.9	4.9	4.9
	-7.0	-7.6	5.1	5.1	5.1	5.1	5.1	5.1
	-5.0	-5.6	5.3	5.3	5.3	5.3	5.3	5.3
	-3.0	-3.7	5.5	5.5	5.5	5.5	5.5	5.5
	0.0	-0.7	5.9	5.9	5.8	5.8	5.8	5.5
	3.0	2.2	6.2	6.2	6.1	6.1	5.9	5.5
	5.0	4.1	6.4	6.4	6.3	6.1	5.9	5.5
	7.0	6.0	6.6	6.6	6.3	6.1	5.9	5.5
	9.0	7.9	6.8	6.7	6.3	6.1	5.9	5.5
	11.0	9.8	7.0	6.7	6.3	6.1	5.9	5.5
	13.0	11.8	7.1	6.7	6.3	6.1	5.9	5.5
	15.0	13.7	7.1	6.7	6.3	6.1	5.9	5.5
63	-19.8	-20.0	4.7	4.7	4.7	4.7	4.7	4.7
	-18.8	-19.0	4.9	4.9	4.8	4.8	4.8	4.8
	-16.7	-17.0	5.1	5.1	5.1	5.1	5.1	5.1
	-14.7	-15.0	5.4	5.4	5.4	5.4	5.4	5.4
	-12.6	-13.0	5.7	5.7	5.7	5.7	5.7	5.7
	-10.5	-11.0	6.0	6.0	6.0	6.0	6.0	5.9
	-9.5	-10.0	6.1	6.1	6.1	6.1	6.1	6.1
	-8.5	-9.1	6.3	6.2	6.2	6.2	6.2	6.2
	-7.0	-7.6	6.5	6.4	6.4	6.4	6.4	6.4
	-5.0	-5.6	6.8	6.7	6.7	6.7	6.7	6.7
	-3.0	-3.7	7.0	7.0	7.0	7.0	7.0	7.0
	0.0	-0.7	7.5	7.4	7.4	7.4	7.4	7.0
	3.0	2.2	7.9	7.8	7.7	7.7	7.5	7.0
	5.0	4.1	8.4	8.1	8.0	7.7	7.5	7.0
	7.0	6.0	8.7	8.5	8.0	7.7	7.5	7.0
	9.0	7.9	8.9	8.5	8.0	7.7	7.5	7.0
	11.0	9.8	9.0	8.5	8.0	7.7	7.5	7.0
	13.0	11.8	9.0	8.5	8.0	7.7	7.5	7.0
	15.0	13.7	9.0	8.5	8.0	7.7	7.5	7.0

Heating capacity


Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
80	-19.8	-20.0	5.9	5.9	5.9	5.9	5.9	5.8
	-18.8	-19.0	6.1	6.1	6.0	6.0	6.0	6.0
	-16.7	-17.0	6.4	6.4	6.4	6.4	6.4	6.4
	-14.7	-15.0	6.8	6.8	6.8	6.8	6.7	6.7
	-12.6	-13.0	7.1	7.1	7.1	7.1	7.1	7.1
	-10.5	-11.0	7.5	7.5	7.5	7.5	7.4	7.4
	-9.5	-10.0	7.7	7.7	7.6	7.6	7.6	7.6
	-8.5	-9.1	7.8	7.8	7.8	7.8	7.8	7.8
	-7.0	-7.6	8.1	8.1	8.1	8.1	8.0	8.0
	-5.0	-5.6	8.4	8.4	8.4	8.4	8.4	8.4
	-3.0	-3.7	8.8	8.8	8.7	8.7	8.7	8.7
	0.0	-0.7	9.3	9.3	9.3	9.3	9.3	8.7
	3.0	2.2	9.8	9.8	9.8	9.7	9.7	8.7
	5.0	4.1	10.2	10.1	10.0	9.7	9.4	8.7
	7.0	6.0	10.5	10.5	10.0	9.7	9.4	8.7
	9.0	7.9	10.8	10.6	10.0	9.7	9.4	8.7
	11.0	9.8	11.2	10.6	10.0	9.7	9.4	8.7
	13.0	11.8	11.3	10.6	10.0	9.7	9.4	8.7
	15.0	13.7	11.3	10.6	10.0	9.7	9.4	8.7
100	-19.8	-20.0	7.4	7.4	7.3	7.3	7.3	7.3
	-18.8	-19.0	7.6	7.6	7.6	7.5	7.5	7.5
	-16.7	-17.0	8.0	8.0	8.0	8.0	8.0	8.0
	-14.7	-15.0	8.5	8.5	8.4	8.4	8.4	8.4
	-12.6	-13.0	8.9	8.9	8.9	8.9	8.9	8.8
	-10.5	-11.0	9.4	9.3	9.3	9.3	9.3	9.3
	-9.5	-10.0	9.6	9.6	9.5	9.5	9.5	9.5
	-8.5	-9.1	9.8	9.8	9.7	9.7	9.7	9.7
	-7.0	-7.6	10.1	10.1	10.1	10.1	10.1	10.0
	-5.0	-5.6	10.6	10.5	10.5	10.5	10.5	10.5
	-3.0	-3.7	11.0	11.0	10.9	10.9	10.9	10.9
	0.0	-0.7	11.6	11.6	11.6	11.6	11.6	10.9
	3.0	2.2	12.3	12.2	12.2	12.1	11.7	10.9
	5.0	4.1	12.7	12.7	12.5	12.1	11.7	10.9
	7.0	6.0	13.1	13.1	12.5	12.1	11.7	10.9
	9.0	7.9	13.5	13.3	12.5	12.1	11.7	10.9
	11.0	9.8	14.0	13.3	12.5	12.1	11.7	10.9
	13.0	11.8	14.1	13.3	12.5	12.1	11.7	10.9
	15.0	13.7	14.1	13.3	12.5	12.1	11.7	10.9
125	-19.8	-20.0	9.4	9.4	9.4	9.4	9.4	9.3
	-18.8	-19.0	9.7	9.7	9.7	9.7	9.4	9.6
	-16.7	-17.0	10.3	10.2	10.2	10.2	10.2	10.2
	-14.7	-15.0	10.9	10.8	10.8	10.8	10.8	10.7
	-12.6	-13.0	11.4	11.4	11.4	11.4	11.3	11.3
	-10.5	-11.0	12.0	11.9	11.9	11.9	11.9	11.9
	-9.5	-10.0	12.3	12.2	12.2	12.2	12.2	12.2
	-8.5	-9.1	12.5	12.5	12.5	12.5	12.5	12.4
	-7.0	-7.6	13.0	12.9	12.9	12.9	12.9	12.8
	-5.0	-5.6	13.5	13.5	13.5	13.4	13.4	13.4
	-3.0	-3.7	14.1	14.0	14.0	14.0	14.0	13.9
	0.0	-0.7	14.9	14.9	14.8	14.8	14.8	13.9
	3.0	2.2	15.7	15.7	15.7	15.5	15.5	13.9
	5.0	4.1	16.3	16.2	16.0	15.5	15.5	13.9
	7.0	6.0	16.8	16.8	16.0	15.5	15.5	13.9
	9.0	7.9	17.3	17.0	16.0	15.5	15.0	13.9
	11.0	9.8	17.9	17.0	16.0	15.5	15.0	13.9
	13.0	11.8	18.1	17.0	16.0	15.5	15.0	13.9
	15.0	13.7	18.1	17.0	16.0	15.5	15.0	13.9

Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

8. Fan Performances


8.1 50Hz

FXSQ20 · 25M




C : 3D036959-5

FXSQ32M




C : 3D036960-5

FXSQ40M




C : 3D036961-5

FXSQ50M




C : 3D036962-5

FXSQ63M




C : 3D036963-5

FXSQ80M




C : 3D036964-5

FXSQ100M



C : 3D036965-5

FXSQ125M




C : 3D036966-5

Note:

1. The remote controller can be used to switch between “high” and “low”.
2. The air flow is set to “standard” before leaving the factory. It is possible to switch between “standard ESP” and “high ESP” by changing the terminals in the indoor unit electrical box.
3. The external static pressure indicates the characteristics of the fan when a suction panel (optional accessory) and a canvas for the suction panel (optional accessory) are incorporated into the main unit (with a long-life filter).


8.2 60Hz

FXSQ20 · 25M




C : 3D036959-6

FXSQ32M




C : 3D036960-6

FXSQ40M




C : 3D036961-6

FXSQ50M




C : 3D036962-6

FXSQ63M




C : 3D036963-6

FXSQ80M




C : 3D036964-6

FXSQ100M



C : 3D036965-6

FXSQ125M



C : 3D036966-6


Note:

1. The remote controller can be used to switch between “high” and “low”.
2. The air flow is set to “standard” before leaving the factory. It is possible to switch between “standard ESP” and “high ESP” by changing the terminals in the indoor unit electrical box.
3. The external static pressure indicates the characteristics of the fan when a suction panel (optional accessory) and a canvas for the suction panel (optional accessory) are incorporated into the main unit (with a long-life filter).

9. Sound Levels

Overall

■ **Ceiling Mounted Built-In Type**



Note:
1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.

dBA


Model	220V, 50/60Hz		240V, 50Hz	
	H	L	H	L
FXSQ20M FXSQ25M	37	32	39	34
FXSQ32M FXSQ40M	38	32	40	34
FXSQ50M	41	36	43	38
FXSQ63M	42	35	44	37
FXSQ80M FXSQ100M	43	37	45	39
FXSQ125M	46	41	48	43

6

Octave Band Level


○———○ 220V 50/60Hz
○ - - - -○ 240V 50Hz

FXSQ20 · 25MVE




4D036937

FXSQ32MVE




4D036938

FXSQ40MVE




4D036939

FXSQ50MVE




4D036940

FXSQ63MVE




4D036941

FXSQ80MVE




4D036942

FXSQ100MVE



4D036943

FXSQ125MVE





4D036944

10. Installation

Center of Gravity

Unit (mm)






MODEL	A	B
FXSQ20・25・32MVE	550	250
FXSQ40・50MVE	700	300
FXSQ63MVE	1000	460
FXSQ80・100・125MVE	1400	640

C : 4D036946F

6


Service Space

Unit (mm)



Note:
Above figure means minimum value. Please keep these value at least.

Bolt Pitch



(Unit : mm)

Model	A	B
FXSQ20 · 25 · 32MVE	550	600
FXSQ40 · 50MVE	700	750
FXSQ63MVE	1000	1050
FXSQ80 · 100 · 125MVE	1400	1450

・ For standard installation (air inlet on the bottom side), choose one of the below two means of installation.

Note: For other than standard installation, contact your Daikin dealer for details.

Drain Pump Kit

Indoor unit	Drain pump kit
FXSQ-M	Standard (Equipped with indoor unit)

Drain Piping Work

<<Rig the drain pipe as shown below and take measures against condensation. Improperly rigged piping could lead to leaks and eventually wet furniture and belongings.>>

(1) Carry out the drain piping


- The diameter of the drain pipe should be greater than or equal to the diameter of the connecting pipe (vinyl tube ; pipe size : 25 mm ; outer dimension : 32 mm).
- Keep the drain pipe short and sloping downwards at a gradient of at least 1 / 100 to prevent air pockets from forming.
- If the drain hose cannot be sufficiently set on a slope, execute the drain raising piping.
- To keep the drain hose from sagging, space hanging wires every 1 to 1.5 m.




⚠ CAUTION

Setting the unit at an angle opposite to the drain piping might cause leaks.

- Use the drain hose and the metal clamp. Tighten the clamp firmly. Insert the drain hose into the drain socket, up to the tape. Tighten the clamp until the screw head is less than 4 mm from the hose.
- Wrap the sealing pad over the metal clamp and drain hose to insulate.
- Insulate the drain hose inside the building.






〈 PRECAUTIONS FOR DRAIN RAISING PIPING 〉


〈HOW TO INSTALL PIPING〉

(1) Connect the drain hose to the drain raising pipes, and insulate them.
(2) Connect the drain hose to the drain outlet on the indoor unit, and tighten it with the metal clamp.
(3) Insulate both metal clamp and drain hose with the sealing pad.



	A (mm)
When canvas duct is installed	350 – 530
When air inlet panel is directly installed	275

- If converging multiple drain pipes, install according to the procedure shown below.



Select converging drain pipes whose gauge is suitable for the operating capacity of the unit.


⚠ CAUTION

- Drain piping connections
  Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain pipes and corrode the heat exchanger.
- Keep in mind that it will become the cause of getting drain pipe blocked if water collects on drain pipe.

3P086156-7D

(2) After piping work is finished, check drainage flows smoothly.

- Open the water inlet lid, add approximately 1 liter of water gradually and check drainage flow.




Note: Use this outlet to drain water from the drain pan.

[WHEN ELECTRIC WIRING WORK IS FINISHED]

- Check drainage flow during COOL running, explained under “TEST OPERATION.”

[WHEN ELECTRIC WIRING WORK IS NOT FINISHED]

- Remove the electric parts box lid, connect a power supply and remote controller to the terminals.
  (Refer to the “HOW TO CONNECT WIRINGS”)
  Be sure attach the electric parts box lid before turning on the power.
  Next, press the inspection / test operation button “ TEST ” on the remote controller. The unit will engage the test operation mode.
  Press the operation mode selector button “ ” until selecting FAN OPERATION “ ”. Then, press the ON/OFF button “ ”. The indoor unit fan and drain pump will start up. Check that the water has drained from the unit. Press “ TEST ” to go back to the first mode.




- You can check whether drainage is satisfactory or not by removing the access opening lid and checking the water level of the drain pan through the access opening.
- **Be careful when doing so because the fan is turning at the same time.**

3P086156-7D

11. Accessories

Standard Accessories

FXSQ20~125M

Name	Metal clamp	Paper pattern for installation	Drain hose	Insulation for fitting	Sealing pad	Screws for duct flanges
Quantity	1 pc.	1 pc.	1 pc.	1 each.	1 each.	1 set
Shape				 for gas pipe for liquid pipe	 Large  mid	

FXSQ20 · 25 · 32MVE	6
FXSQ40 · 50MVE	8
FXSQ63MVE	12
FXSQ80 · 100 · 125MVE	16

Name	Washer for hanging bracket	Clamp	Screws for fixing the paper pattern for installation	(Other)
Quantity	8 pcs.	6 pcs.	6 pcs.	• Operation manual • Installation manual • Sealing material (Small 35×150)
Shape				

• Screws for fixing panels are attached to decoration panel.

3P086156-7D

Optional Accessories (For Unit)


No.	Item	Type		FXSQ20M FXSQ25M FXSQ32M	FXSQ40M FXSQ50M	FXSQ63M	FXSQ80M FXSQ100M	FXSQ125M
1	Panel related	Decoration panel		BYBS32DJW1	BYBS45DJW1	BYBS71DJW1	BYBS125DJW1	
		Access panel		KTBJ25K36W	KTBJ25K56W	KTBJ25K80W	KTBJ25K160W	
2	∗1 Auxiliary electric heater	Model	240V/220V	KEA25K32VE	KEA25K50VE	KEA25K63VE	KEA25K100VE	KEA25K125VE
		Capacity	kW	0.75	1.2	1.4	2.1	2.8
3	Filter related	∗2 High efficiency filter 65%		KAFJ252L36	KAFJ252L56	KAFJ252L80	KAFJ252L160	
		∗2 High efficiency filter 90%		KAFJ253L36	KAFJ253L56	KAFJ253L80	KAFJ253L160	
		Long life replacement filter		KAFJ251K36	KAFJ251K56	KAFJ251K80	KAFJ251K160	
		Filter chamber	For bottom suction	KAJ25L36D	KAJ25L56D	KAJ25L80D	KAJ25L160D	
			For rear suction	KAJ25L36B	KAJ25L56B	KAJ25L80B	KAJ25L160B	
4	Air inlet and air discharge outlet related	Air suction canvas		KSA-25K36	KSA-25K56	KSA-25K80	KSA-25K160	
		Screening door		KBBJ25K36	KBBJ25K56	KBBJ25K80	KBBJ25K160	
		Air suction flange		KDJ2507K36	KDJ2507K56	KDJ2507K80	KDJ2507K160	
		Air discharge adaptor		KDAJ25K36A	KDAJ25K56A	KDAJ25K71A	KDAJ25K140A	
5	Natural evaporating pan type humidifier ∗1			KNM25K32V1	KNM25K50V1	KNM25K63V1	KNM25K125V1	

Note:

∗1 One adaptor for wiring (KRP1B61) per indoor unit is required if installing an electric heater or a natural evaporating pan type humidifier. An electric heater cannot be used for VRV system cooling only.

∗2 If installing a high filter in the ceiling mounted built-in type, an assembly chamber for either bottom or rear suction is required.

Optional Accessories (For Controls) : Refer to P.807




6

Access Panel

Specifications

Item \ Model	KTBJ25K36W	KTBJ25K56W	KTBJ25K80W	KTBJ25K160W
Color	White			
Applicable Model	20~32 Class	40 · 50 Class	63 Class	80~125 Class

Dimension




Model	A
KTBJ25K36W	626
KTBJ25K56W	776
KTBJ25K80W	1076
KTBJ25K160W	1476


Installation

[Before installation]

1. Make an opening on the ceiling



2. Install ceiling joist supports to fit the ceiling opening



Model	A
KTBJ25K36	606
KTBJ25K56	756
KTBJ25K80	1056
KTBJ25K160	1406


[Installation of the ceiling board]

The ceiling board can be installed into the inner frame assembly as follows.

1. Remove decoration panel retainer from the inner frame assembly.
2. Remove the decoration panel and substitute with the ceiling board.
3. Set the ceiling board by retainer removed in step 1 of above.

⚠ CAUTION

When the ceiling board is installed, the decoration panel is not needed.




Auxiliary Electric Heater (A wiring adaptor is needed)


Specifications

Items \ Model	KEA25K32VE	KEA25K50VE	KEA25K63VE	KEA25K100VE	KEA25K125VE
Heater Capacity (kW)	0.75	1.2	1.4	2.1	2.8
Power Supply	Single Phase, 220-240V/220V 50/60Hz				
Applicable Models	20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 100 Class	125 Class


Installation



Characteristics of filter



Wiring



Precaution at use

1. When the aux. electric heater will be installed, “Wiring adaptor (KRP1B61)” is separately needed for one indoor unit by one piece of the adaptor.

Natural Evaporating Pan Type Humidifier (Wiring adaptor is required.)

Specifications

Item \ Model	KNM25K32V1	KNM25K50V1	KNM25K63V1	KNM25K125V1
Humidifying Capacity (L/h)	0.4	0.6	1.0	1.8
Power Supply (W)	Single Phase, 220-240V 50Hz			
Power Consumption	12/9.6			
Water Inlet Port	1/2B			
Water Outlet Port	VP25 (External dia. ϕ32) (drain pipe at indoor unit)			
Applicable Models	20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 100 · 125 Class

Precaution at use

1. “Wiring adaptor (KRP1B61)” is separately needed for one indoor unit by one piece of the adaptor.
2. This humidifier will be built in a indoor unit, while the solenoid valve box will be mounted out of the unit's body (refer to the dimensions of optional accessories).
3. The field setting should be changed by a remote controller.

Note:

The value in JIS heating condition's standard.

Feed water piping


1. Provide a stop valve of feed water for the feed water circuit.
2. Supply clean water for the feed water. Contaminated water clogs a valve and the contaminants accumulate in a water tank, disturbing a normal operation of the humidifier. (Never use cooling water for a cooling tower or hot water for heating purpose). Moreover, since white powder will appear if the feed water contains much silica, it is recommended to install a water purifier or a water softener if these phenomena are found.
3. Use water in the range of water temperature 5 ~ 50°C and water pressure 0.049 ~ 0.294 MPa[0.5 ~3kg/cm²]. Provide a reducing valve between a strainer and this kit, in case of 0.294MPa or more for feed water pressure.
4. The feed water pipe can not be connected to a public water route. Accordingly, if water must be supplied through a public water by all means, provide a cistern tank (approved model only).

Wiring diagram


---------- Field wiring

Make wiring as shown on the right, if a humidity controller will be mounted.

Arrange the wiring shown right locally for that case. Set the turn-over switch to OFF for the choice of ON/OFF of group humidity controlling input on the "Wiring adaptor PC board" .



Characteristics of Filter




High Efficiency Filter

Specifications


Items \ Model	KAFJ252L36	KAFJ252L56	KAFJ252L80	KAFJ252L160	KAFJ253L36	KAFJ253L56	KAFJ253L80	KAFJ253L160
Dust Collection Efficiency (%)	Colorimetric method 65%				Colorimetric method 90%			
Initial Pressure Loss (Pa)	12 or less	14 or less		22 or less	21 or less	24 or less		34 or less
Final Pressure Loss (Pa)	98 or less				98 or less			
Filter	Non-woven fabric of synthetic fiber				Non-woven fabric of synthetic fiber			
Life Time (h)	2,500 hours (Dust density 0.15mg/m³)				1,800 hours (Dust density 0.15mg/m³)			
High Efficiency Filter Chamber (for the Bottom Suction)	KAJ25L36D	KAJ25L56D	KAJ25L80D	KAJ25L160D	KAJ25L36D	KAJ25L56D	KAJ25L80D	KAJ25L160D
High Efficiency Filter Chamber (for the Rear Suction)	KAJ25L36B	KAJ25L56B	KAJ25L80B	KAJ25L160B	KAJ25L36B	KAJ25L56B	KAJ25L80B	KAJ25L160B
External Dimension (mm) (T×W×D)	25×500×360	25×650×360	(25×475×360)×2	(25×700×360)×1 (25×650×360)×1	25×500×360	25×650×360	(25×475×360)×2	(25×700×360)×1 (25×650×360)×1
Applicable Models	20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 100 · 125 Class	20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 100 · 125 Class

Installation




Characteristics of Filter

■ 65% type



■ 90% type




Long-Life Replacement Filter

Specifications

Item \ Model		KAFJ251K36	KAFJ251K56	KAFJ251K80	KAFJ251K160
Average Efficiency (%)		50% (Gravity method)			
Pressure Loss (Pa)	Initial	10 or less		4.9 or less	
	Final	49		49 or less	
Materials		Mildew Proof Resin Net			
Number Required per Model		1	1	2	2
Life Time (h)		2,500 hours (dust particle concentration at 0.15 mg/m³)			
Applicable Model		20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 100 · 125 Class

Note:
The filter models for 20 ~ 50 Class can be used also as Rear-suction types.

Characteristics of filter




Canvas Duct (Air Suction Canvas)

Specifications


Item \ Model		KSA-25K36	KSA-25K56	KSA-25K80	KSA-25K160
Dimensions (mm)	H	255	255	255	255
	W	550	700	1000	1400
	D	405	405	405	405
Canvas Duct		TOYOBO · SL1000 · SIMVER Flame resistant			
Applicable Model		BYBS32DJW1	BYBS45DJW1	BYBS71DJW1	BYBS125DJW1

Installation



Suction Panel

Characteristics of Filter



Air Discharge Adaptor

Specifications

Item \ Model	KDAJ25K36A	KDAJ25K56A	KDAJ25K71A	KDAJ25K140A
Connection Dia. (ϕmm)	ϕ200×1 port	ϕ200×2 port	ϕ200×2 port	ϕ200×4 port
Applicable Models	20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 100 · 125 Class


Filter Chamber (for Rear-suction Type)

This kit will be used for the rear-suction type when the high efficiency filter or the long life filter will be built in.


Applicable Model

Model	Applicable Model
KAJ25L36B	20 · 25 · 32 Class
KAJ25L56B	40 · 50 Class
KAJ25L80B	63 Class
KAJ25L160B	80 · 100 · 125 Class

Installation



Be sure to remove the long life filter and attach the rear-suction type's sealing plate there when the filter chamber (for the rear-suction type) must be installed.



Model	A
KAJ25L36B	600
KAJ25L56B	750
KAJ25L80B	1050
KAJ25L160B	1450

Note:


Refer to the appearance figure of optional accessory describing later for further details.

Filter Chamber for Bottom Suction

Applicable Model

Model	Applicable Model
KAJ25L36D	20 · 25 · 32 Class
KAJ25L56D	40 · 50 Class
KAJ25L80D	63 Class
KAJ25L160D	80 · 100 · 125 Class


Dimension



JC : D3K1420A

Model	A
KAJ25L36D	550
KAJ25L56D	700
KAJ25L80D	1000
KAJ25L160D	1400

Installation



Note:
Refer to the appearance figure of optional accessory describing later for further details.


Air Suction Flange

When this kit will be used, the rear suction type's sealing plate will be required separately.

Specifications

Item	Model	Air Suction Flange			
		KDJ2507K36	KDJ2507K56	KDJ2507K80	KDJ2507K160
Dimensions (mm)	W	527	677	977	1377
	H	278			
	T	25			
Size of Connecting Duct (mm)	W	477	627	927	1327
	L	228			
Materials		Galvanized steel plate			
Applicable Model		20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 100 · 125 Class

Example of Installation




Blind Board (Screening Door) used for the rear-suction type

Specifications


Item	Model	KBBJ25K36	KBBJ25K56	KBBJ25K80	KBBJ25K160
Dimensions (mm)	W	535	685	985	1385
	D	404			
	T	10			
Materials		Galvanized Steel Plate			
Applicable Model		20 · 25 · 32 Class	40 · 50 Class	63 Class	80 · 100 · 125 Class

Dimension



Applicable Model	A
KBBJ25K36	535
KBBJ25K56	685
KBBJ25K80	985
KBBJ25K160	1385


Installation



Dimensions with the Optional Accessories

Natural evaporating pan type humidifier (Air discharge adaptor)

■ **FXSQ20~32M**




Number	Name	Description
5	Air discharge adaptor	
4	Feed water pipe connection	For natural evaporating pan type humidifier PT 1/2
3	Solenoid valve box	For natural evaporating pan type humidifier
2	Suction full panel	
1	Built-in unit body	

Note)
1. An access panel is needed when a half panel will be installed.
2. When optional accessory other than these kits will be built in, refer to external drawing with optional accessories.
3. Parts names ②~⑤ show optional accessories.

JC : DU220-245B

■ **FXSQ40 · 50M**



Number	Name	Description
4	Feed water pipe connection	For natural evaporating pan type humidifier PT 1/2
3	Solenoid valve box	For natural evaporating pan type humidifier
2	Suction full panel	
1	Built-in Hi type body	


Note)
1. An access panel is needed when a half panel will be installed.
2. When optional accessory other than these kits will be built in, refer to external drawing with optional accessories.
3. Parts names ②~④ show optional accessories.

JC : DU425-2111F

Dimensions with the Optional Accessories

Natural evaporating pan type humidifier (Air discharge adaptor)

■ **FXSQ63M**




Number	Name	Description
4	Feed water pipe connection	For natural evaporating pan type humidifier PT 1/2
3	Solenoid valve box	For natural evaporating pan type humidifier
2	Suction full panel	
1	Built-in Hi type body	

Note)
1. An access panel is needed when a half panel will be installed.
2. When optional accessory other than these kits will be built in, refer to external drawing with optional accessories.
3. Parts names ②~④ show optional accessories.

JC : DU427-2192G

■ **FXSQ80~125M**




Number	Name	Description
4	Feed water pipe connection	For natural evaporating pan type humidifier PT 1/2
3	Solenoid valve box	For natural evaporating pan type humidifier
2	Suction full panel	
1	Built-in Hi type body	

Note)
1. An access panel is needed when a half panel will be installed.
2. When optional accessory other than these kits will be built in, refer to external drawing with optional accessories.
3. Parts names ②~④ show optional accessories.

JC : DU428-2158G

High Efficiency Filter (Air discharge Adaptor)

■ FXSQ20~32M




Number	Name	Description
6	Air discharge adaptor	
5	Bottom suction filter chamber	
4	High efficiency filter	
3	Air suction canvas	
2	Suction half panel	
1	Built-in unit body	

Note)
1. When optional accessory other than these kits will be built in, refer to the external drawing with optional accessories.
2. Parts names ②~⑧ show optional accessories.

JC : DU820-238B

■ FXSQ40 · 50M




Number	Name	Description
5	Bottom suction filter chamber	
4	High efficiency filter	
3	Air suction canvas	
2	Suction half panel	
1	Built-in Hi type body	

Note)
1. When optional accessory other than these kits will be built in, refer to the external drawing with optional accessories.
2. Parts names ②~⑦ show optional accessories.

JC : DU823-226E

High Efficiency Filter (Air discharge Adaptor)

■ FXSQ63M




Number	Name	Description
5	Bottom suction filter chamber	
4	High efficiency filter	
3	Air suction canvas	
2	Suction half panel	
1	Built-in Hi type body	

Note)
1. When optional accessory other than these kits will be built in, refer to the external drawing with optional accessories.
2. Parts names ②~⑦ show optional accessories.

JC : DU826-207F

■ FXSQ80~125M




Number	Name	Description
5	Bottom suction filter chamber	
4	High efficiency filter	
3	Air suction canvas	
2	Suction half panel	
1	Built-in Hi type body	

Note)
1. When optional accessory other than these kits will be built in, refer to the external drawing with optional accessories.
2. Parts names ②~⑦ show optional accessories.

JC : DU828-215F

Duct Style Installation


■ FXSQ20~32M




Details of discharge outlet flange


Suction flange (filter chamber for rear-suction type) details

A view





At installation of suction flange




Suction flange details

Note)
1. When optional accessory other than these kits will be built in, refer to the external drawing with optional accessories.
2. Parts names ②~⑦ show optional accessories.

7	Suction inlet flange	
6	Long life filter	
5	High efficiency filter	
4	Rear-suction sealing plate	
3	Rear-suction filter chamber	(with rear-suction sealing plate)
2	Access panel	
1	Built-in unit body	
Number	Name	Description

JC : DU220-248B


■ FXSQ40 · 50M




Details of discharge outlet flange


Suction flange (filter chamber for rear-suction type) details

A view





At installation of suction flange



Suction flange details


Note)
1. When optional accessory other than these kits will be built in, refer to the external drawing with optional accessories.
2. Parts names ②~⑧ show optional accessories.

8	Suction inlet flange	
7	Suction flange	
6	Long life filter	
5	High efficiency filter	
4	Rear-suction sealing plate	
3	Rear-suction filter chamber	(with rear-suction sealing plate)
2	Access panel	
1	Built-in Hi type body	
Number	Name	Description

JC : DU425-2115F

Duct Style Installation

■ FXSQ63M




Note)
1. When optional accessory other than these kits will be built in, refer to the external drawing with optional accessories.
2. Parts names ②~⑧ show optional accessories.

Number	Name	Description
8	Suction flange	
7	Discharge outlet flange	
6	Long life filter for rear-suction type	
5	High efficiency filter	
4	Rear-suction sealing plate	
3	Rear-suction type filter chamber	(with rear-suction sealing plate)
2	Access panel	
1	Built-in Hi type body	

JC : DU826-208F

■ FXSQ80~125M



Note)
1. When optional accessory other than these kits will be built in, refer to the external drawing with optional accessories.
2. Parts names ②~⑧ show optional accessories.

Number	Name	Description
8	Suction flange	
7	Discharge outlet flange	
6	Long life filter for rear-suction type	
5	High efficiency filter	
4	Rear-suction sealing plate	
3	Rear-suction type filter chamber	(with rear-suction sealing plate)
2	Access panel	
1	Built-in Hi type body	

JC : DU828-216F

FXMQ-P
Ceiling Mounted Duct Type (Middle and High Static Pressure)

1. Features 252
2. Specifications 253
3. Dimensions 256
4. Piping Diagrams 261
5. Wiring Diagrams 262
6. Electric Characteristics 263
7. Capacity Tables 264
   7.1 Cooling Capacity 264
   7.2 Heating Capacity 266
8. Fan Performances 268
   8.1 Fan Performance 268
   8.2 “Air Flow Auto Adjustment” Characteristics 272
9. Sound Levels 276
10. Center of Gravity 278
11. Installation Manual 279
12. Accessories 293

1. Features

Ceiling Mounted Duct Type


New

FXMQ20P/FXMQ25P
FXMQ32P/FXMQ40P
FXMQ50P/FXMQ63P
FXMQ80P/FXMQ100P
FXMQ125P



Middle and high static pressure allows for flexible duct design


- A DC fan motor increases the external static pressure capacity range to include middle to high static pressures, increasing design flexibility.
  30 Pa–100 Pa for FXMQ20P-32P
  30 Pa–160 Pa for FXMQ40P
  50 Pa–200 Pa for FXMQ50P-125P
- All models are only 300 mm in height, an improvement over the 390 mm height of conventional models. The weight of the FXMQ40P has been reduced from 44 kg to 28 kg.
- Drain pump is equipped as standard accessory with 700 mm lift.



- Control of the airflow rate has been improved from 2-step to 3-step control.
- Low operation sound level (dB(A))

FXMQ-P	20	30	32	40	50	63	80	100	125
Sound level (HH/H/L)	33/31/29		34/32/30	39/37/35	41/39/37	42/40/38	43/41/39		44/42/40

- Energy-efficient
  - The adopted DC fan motor is much more efficient than the conventional AC motor, yielding an approximate 20% decrease in energy consumption. (FXMQ125P)



- Improved ease of installation
  - Airflow can be controlled using a remote controller. With the conventional model, the airflow rate was controlled from the PC board. It is automatically adjusted to the range between approximately ±10% of the rated HH tap airflow.
- Improved ease of maintenance
  - The drain pan can be detached for easy cleaning. A new antibacterial treatment that uses silver ions has been applied to the drain pan, preventing the growth of slime, mould and bacteria that cause blockages and odours.

2. Specifications

Ceiling Mounted Duct Type

Model			FXMQ20PVE	FXMQ25PVE	FXMQ32PVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	2,000	2,500	3,200
		Btu/h	7,800	9,900	12,600
		kW	2.3	2.9	3.7
∗2 Cooling Capacity (19.0°CWB)		kW	2.2	2.8	3.6
∗3 Heating Capacity		kcal/h	2,200	2,800	3,400
		Btu/h	8,500	10,900	13,600
		kW	2.5	3.2	4.0
Casing			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	300×550×700	300×550×700	300×550×700
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	3×16×1.75	3×16×1.75	3×16×1.75
	Face Area	m²	0.098	0.098	0.098
Fan	Model		—	—	—
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	90×1	90×1	90×1
	Air Flow Rate (HH/H/L)	m³/min	9/7.5/6.5	9/7.5/6.5	9.5/8/7
		cfm	318/265/230	318/265/230	335/282/247
	External Static Pressure	Pa	Standard 50 (100-30 ∗4)	Standard 50 (100-30 ∗4)	Standard 50 (100-30 ∗4)
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Air Filter			∗5	∗5	∗5
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)
	Drain Pipe	mm	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)
Mass (Weight)		kg	25	25	25
∗7 Sound Level (HH/H/L)	dBA	220V	33/31/29	33/31/29	34/32/30
		240V	33/31/29	33/31/29	34/32/30
Safety Devices			Fuse. Fan Driver Overload Protector.	Fuse. Fan Driver Overload Protector.	Fuse. Fan Driver Overload Protector.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Washers. Screws. Air Discharge Flange. Air Suction Flange.	Operation Manual. Installation Manual. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Washers. Screws. Air Discharge Flange. Air Suction Flange.	Operation Manual. Installation Manual. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Washers. Screws. Air Discharge Flange. Air Suction Flange.
Drawing No.			C : 3D060388A		

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗4 External static pressure is changeable in 13 or 14 stages within the ( ) range by remote controller.
∗5 Air filter is not standard accessory, but please mount it in the duct system of the suction side. Select its colorimetric method (gravity method) 50% or more.
6 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗7 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit centre. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
8 Refer to page 263 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Ceiling Mounted Duct Type

Model			FXMQ40PVE	FXMQ50PVE	FXMQ63PVE	FXMQ80PVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	4,000	5,000	6,300	8,000
		Btu/h	16,000	19,800	24,900	31,700
		kW	4.7	5.8	7.3	9.3
∗2 Cooling Capacity (19.0°CWB)		kW	4.5	5.6	7.1	9.0
∗3 Heating Capacity		kcal/h	4,300	5,400	6,900	8,600
		Btu/h	17,100	21,500	27,300	34,100
		kW	5.0	6.3	8.0	10.0
Casing			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	300×700×700	300×1,000×700	300×1,000×700	300×1,000×700
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	3×16×1.75	3×16×1.75	3×16×1.75	3×16×1.75
	Face Area	m²	0.148	0.249	0.249	0.249
Fan	Model		—	—	—	—
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	140×1	350×1	350×1	350×1
	Air Flow Rate (HH/H/L)	m³/min	16/13/11	18/16.5/15	19.5/17.5/16	25/22.5/20
		cfm	565/459/388	635/582/530	688/618/565	883/794/706
	External Static Pressure	Pa	Standard 100 (160-30 ∗4)	Standard 100 (200-50 ∗4)	Standard 100 (200-50 ∗4)	Standard 100 (200-50 ∗4)
	Drive		Direct Drive	Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Air Filter			∗5	∗5	∗5	∗5
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe	mm	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)	VP25 (External Dia. 32 Internal Dia. 25)
Mass (Weight)		kg	28	36	36	36
∗7 Sound Level (HH/H/L)	dBA	220V	39/37/35	41/39/37	42/40/38	43/41/39
		240V	39/37/35	41/39/37	42/40/38	43/41/39
Safety Devices			Fuse. Fan Driver Overload Protector.	Fuse. Fan Driver Overload Protector.	Fuse. Fan Driver Overload Protector.	Fuse. Fan Driver Overload Protector.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Washers. Screws. Air Discharge Flange. Air Suction Flange.	Operation Manual. Installation Manual. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Washers. Screws. Air Discharge Flange. Air Suction Flange.	Operation Manual. Installation Manual. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Washers. Screws. Air Discharge Flange. Air Suction Flange.	Operation Manual. Installation Manual. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Washers. Screws. Air Discharge Flange. Air Suction Flange.
Drawing No.			C : 3D060388A			

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗4 External static pressure is changeable in 13 or 14 stages within the ( ) range by remote controller.
∗5 Air filter is not standard accessory, but please mount it in the duct system of the suction side. Select its colorimetric method (gravity method) 50% or more.
6 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗7 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit centre. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
8 Refer to page 263 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Ceiling Mounted Duct Type

Model			FXMQ100PVE	FXMQ125PVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	10,000	12,500
		Btu/h	39,600	49,500
		kW	11.6	14.5
∗2 Cooling Capacity (19.0°CWB)		kW	11.2	14.0
∗3 Heating Capacity		kcal/h	10,800	13,800
		Btu/h	42,700	54,600
		kW	12.5	16.0
Casing			Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	300×1,400×700	300×1,400×700
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	3×16×1.75	3×16×1.75
	Face Area	m²	0.383	0.383
Fan	Model		—	—
	Type		Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	350×1	350×1
	Air Flow Rate (HH/H/L)	m³/min	32/27/23	39/33/28
		cfm	1,130/953/812	1,377/1,165/988
	External Static Pressure	Pa	Standard 100 (200-50 ∗4)	Standard 100 (200-50 ∗4)
	Drive		Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Air Filter			∗5	∗5
Piping Connections	Liquid Pipes	mm	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes	mm	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe	mm	VP25 (External Dia. 32 / Internal Dia. 25)	VP25 (External Dia. 32 / Internal Dia. 25)
Mass (Weight)		kg	46	46
∗7 Sound Level (HH/H/L)	dBA	220V	43/41/39	44/42/40
		240V	43/41/39	44/42/40
Safety Devices			Fuse. Fan Driver Overload Protector.	Fuse. Fan Driver Overload Protector.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Washers. Screws. Air Discharge Flange. Air Suction Flange.	Operation Manual. Installation Manual. Drain Hose. Clamp Metal. Insulation for Fitting. Sealing Pads. Clamps. Washers. Screws. Air Discharge Flange. Air Suction Flange.
Drawing No.			C : 3D060388A	

Note:


∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗4 External static pressure is changeable in 13 or 14 stages within the ( ) range by remote controller.
∗5 Air filter is not standard accessory, but please mount it in the duct system of the suction side. Select its colorimetric method (gravity method) 50% or more.
6 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗7 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit centre. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
8 Refer to page 263 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

3. Dimensions

FXMQ20P / 25P / 32PVE


Unit (mm)



ITEM	PART NAME	REMARK
12	Drain hose (Accessory)	O. D. φ 32 (Outlet)
11	Socket (For maintenance)	VP25 (O. D. φ 32, I. D. φ 25)
10	Hook	For M10
9	Air suction flange	
8	Air discharge flange	
7	Power supply connection	
6	Interunit wiring connection	
5	Control box (Inside)	
4	Ground terminal (Terminal in Control box)	M4
3	Drain pipe connection	VP25 (O. D. φ 32, I. D. φ 25)
2	Gas pipe connection	φ 12.7 flale connection
1	Liquid pipe connection	φ 6.4 flale connection

FXMQ40PVE

Unit (mm)




ITEM	PART NAME	REMARK
12	Drain hose (Accessory)	O. D. ϕ 32 (Outlet)
11	Socket (For maintenance)	VP25 (O. D. ϕ 32, I. D. ϕ 25)
10	Hook	For M10
9	Air suction flange	
8	Air discharge flange	
7	Power supply connection	
6	Interunit wiring connection	
5	Control box (Inside)	
4	Ground terminal (Terminal in Control box)	M4
3	Drain pipe connection	VP25 (O. D. ϕ 32, I. D. ϕ 25)
2	Gas pipe connection	ϕ 12.7 flale connection
1	Liquid pipe connection	ϕ 6.4 flale connection

7

FXMQ50PVE

Unit (mm)




ITEM	PART NAME	REMARK
12	Drain hose (Accessory)	O. D. φ 32 (Outlet)
11	Socket (For maintenance)	VP25 (O. D. φ 32, I. D. φ 25)
10	Hook	For M10
9	Air suction flange	
8	Air discharge flange	
7	Power supply connection	
6	Interunit wiring connection	
5	Control box (Inside)	
4	Ground terminal (Terminal in Control box)	M4
3	Drain pipe connection	VP25 (O. D. φ 32, I. D. φ 25)
2	Gas pipe connection	φ 12.7 flale connection
1	Liquid pipe connection	φ 6.4 flale connection

3D060159D

FXMQ63P / 80PVE

Unit (mm)




ITEM	PART NAME	REMARK
12	Drain hose (Accessory)	O. D. ϕ 32 (Outlet)
11	Socket (For maintenance)	VP25 (O. D. ϕ 32, I. D. ϕ 25)
10	Hook	For M10
9	Air suction flange	
8	Air discharge flange	
7	Power supply connection	
6	Interunit wiring connection	
5	Control box (Inside)	
4	Ground terminal (Terminal in Control box)	M4
3	Drain pipe connection	VP25 (O. D. ϕ 32, I. D. ϕ 25)
2	Gas pipe connection	ϕ 15.9 flale connection
1	Liquid pipe connection	ϕ 9.5 flale connection


7

FXMQ100P / 125PVE

Unit (mm)



4. Piping Diagrams



4D034245C

■ **Refrigerant pipe connection port diameters**


(mm)

Model	Gas	Liquid
FXMQ20P / 25P / 32P / 40P / 50PVE	ϕ12.7	ϕ6.4
FXMQ63P / 80P / 100P / 125PVE	ϕ15.9	ϕ9.5

7

5. Wiring Diagrams

FXMQ20P / 25P / 32P / 40P / 50P / 63P / 80P / 100P / 125PVE



INDOOR UNIT		PS	SWITCHING POWER SUPPLY (A1P, A2P)	X2M	TERMINAL STRIP (CONTROL)
A1P	PRINTED CIRCUIT BOARD	R1	RESISTOR (CURRENT LIMITING)	Y1E	ELECTRONIC EXPANSION VALVE
A2P	PRINTED CIRCUIT BOARD (FAN)	R2	CURRENT SENSING DEVICE	Z1C, Z2C	NOISE FILTER (FERRITE CORE)
A3P	PRINTED CIRCUIT BOARD (CAPACITOR)	R3, R4	RESISTOR (ELECTRIC DISCHARGE)	Z1F	NOISE FILTER
C1, C2, C3	CAPACITOR				CONNECTOR OPTIONAL ACCESSORY
F1U	FUSE (T, 3.15A, 250V)	R1T	THERMISTOR (SUCTION AIR)		
F2U	FUSE (T, 5A, 250V)	R2T	THERMISTOR (LIQUID)	X28A	CONNECTOR (POWER SUPPLY FOR WIRING)
F3U	FUSE (T, 6.3A, 250V)	R3T	THERMISTOR (GAS)		
F4U	FUSE (T, 6.3A, 250V)	R4T	THERMISTOR (DISCHARGE AIR)	X33A	CONNECTOR (FOR WIRING)
HAP	LIGHT EMITTING DIODE (SERVICE MONITOR-GREEN) (A1P, A2P)	R5T	THERMISTOR NTC (CURRENT LIMITING)	X35A	CONNECTOR (ADAPTER)
				WIRED	REMOTE CONTROLLER
KPR	MAGNETIC RELAY	S1L	FLOAT SWITCH	R1T	THERMISTOR (AIR)
K1R	MAGNETIC RELAY	V1R	DIODE BRIDGE	SS1	SELECTOR SWITCH (MAIN/SUB)
L1R	REACTOR	V2R	POWER MODULE		
M1F	MOTOR (FAN)	X1M	TERMINAL STRIP (POWER SUPPLY)		
M1P	MOTOR (DRAIN PUMP)				

NOTES) 1. : TERMINAL : CONNECTOR : FIELD WIRING
2. IN CASE USING CENTRAL REMOTE CONTROLLER, CONNECT IT TO THE UNIT IN ACCORDANCE WITH THE ATTACHED INSTALLATION MANUAL.
3. WHEN CONNECTING THE INPUT WIRES FROM OUTSIDE, FORCED OFF OR ON/OFF CONTROL OPERATION CAN BE SELECTED BY REMOTE CONTROLLER. IN DETAILS, REFER TO THE INSTALLATION MANUAL ATTACHED THE UNIT.
4. COLORS BLK : BLACK RED : RED BLU : BLUE WHT : WHITE
PNK : PINK YLW : YELLOW BRN : BROWN GRY : GRAY GRN : GREEN
ORG : ORANGE.

3D058783A

6. Electric Characteristics

Model	Power supply					IFM		Input(W)	
	Hz	Volts	Voltage range	MCA	MFA	KW	FLA	Cooling	Heating
FXMQ20PVE	50	220~240V	Max. 264V Min. 198V	0.6	16	0.090	0.5	81	69
FXMQ25PVE				0.6	16	0.090	0.5	81	69
FXMQ32PVE				0.6	16	0.090	0.5	85	73
FXMQ40PVE				1.4	16	0.140	1.1	194	182
FXMQ50PVE				1.6	16	0.350	1.3	215	203
FXMQ63PVE				1.8	16	0.350	1.4	230	218
FXMQ80PVE				2.3	16	0.350	1.8	298	286
FXMQ100PVE				2.9	16	0.350	2.3	376	364
FXMQ125PVE				3.4	16	0.350	2.7	461	449
FXMQ20PVE	60	220V	Max. 242V Min. 198V	0.6	16	0.090	0.5	80	69
FXMQ25PVE				0.6	16	0.090	0.5	80	69
FXMQ32PVE				0.6	16	0.090	0.5	84	73
FXMQ40PVE				1.4	16	0.140	1.1	193	182
FXMQ50PVE				1.6	16	0.350	1.3	214	203
FXMQ63PVE				1.8	16	0.350	1.4	229	218
FXMQ80PVE				2.3	16	0.350	1.8	297	286
FXMQ100PVE				2.9	16	0.350	2.3	375	364
FXMQ125PVE				3.4	16	0.350	2.7	460	449

Symbols:
MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
KW : Fan Motor Rated Output(kW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

Note:
1. Voltage range
Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.
2. Maximum allowable voltage unbalance between phases is 2%.
3. MCA/MFA
MCA = 1.25 X FLA
MFA ≦ 4 X FLA
(Next lower standard fuse rating. Min. 16A)
4. Select wire size based on the MCA.
5. Instead of fuse, use circuit breaker.

4D060439A

7

7. Capacity Tables

7.1 Cooling Capacity

FXMQ-P **[50/60Hz]**

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	14.0°CWB 20°CDB SHC	16.0°CWB 23°CDB TC	16.0°CWB 23°CDB SHC	18.0°CWB 26°CDB TC	18.0°CWB 26°CDB SHC	19.0°CWB 27°CDB TC	19.0°CWB 27°CDB SHC	20.0°CWB 28°CDB TC	20.0°CWB 28°CDB SHC	22.0°CWB 30°CDB TC	22.0°CWB 30°CDB SHC	24.0°CWB 32°CDB TC	24.0°CWB 32°CDB SHC
20	10.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.8	2.1
	12.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.7	2.0
	14.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.7	2.0
	16.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.6	2.0
	18.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.5	1.9	2.6	2.0
	20.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.5	1.9	2.6	2.0
	21.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.5	1.9	2.6	2.0
	23.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.5	1.9	2.5	1.9
	25.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.5	1.9	2.5	1.9
	27.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.4	1.9	2.5	1.9
	29.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.4	1.8	2.4	1.9
	31.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.4	1.8	2.4	1.8
	33.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.3	1.8	2.3	1.8
	35.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.2	1.9	2.3	1.8	2.3	1.8
	37.0	1.5	1.5	1.8	1.8	2.1	1.9	2.1	1.9	2.2	1.9	2.2	1.8	2.3	1.8
	39.0	1.5	1.5	1.8	1.8	2.1	1.9	2.1	1.9	2.2	1.9	2.2	1.8	2.3	1.8
25	10.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.3	2.4	3.5	2.4
	12.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.3	2.4	3.5	2.4
	14.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.3	2.4	3.4	2.4
	16.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.3	2.4	3.4	2.4
	18.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.2	2.3	3.3	2.3
	20.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.2	2.3	3.3	2.3
	21.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.2	2.3	3.2	2.3
	23.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.1	2.3	3.2	2.3
	25.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.1	2.2	3.2	2.3
	27.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.0	2.2	3.1	2.2
	29.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	3.0	2.3	3.0	2.2	3.1	2.2
	31.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	2.9	2.3	2.9	2.2	3.0	2.2
	33.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	2.9	2.3	2.9	2.2	3.0	2.2
	35.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	2.8	2.2	2.9	2.1	3.0	2.2
	37.0	1.9	1.8	2.3	2.0	2.6	2.3	2.8	2.3	2.8	2.2	2.9	2.1	2.9	2.1
	39.0	1.9	1.8	2.3	2.0	2.6	2.3	2.7	2.2	2.7	2.2	2.8	2.1	2.9	2.1
32	10.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.6	3.0
	12.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.5	3.0
	14.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.4	3.0
	16.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.4	3.0
	18.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	4.2	2.9	4.3	2.9
	20.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	4.2	2.9	4.3	2.9
	21.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	4.1	2.9	4.2	2.9
	23.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	4.1	2.9	4.2	2.9
	25.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	4.0	2.8	4.1	2.8
	27.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	3.9	2.8	4.0	2.8
	29.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.8	2.9	3.8	2.8	3.9	2.7
	31.0	2.4	2.2	2.9	2.5	3.4	2.8	3.6	2.9	3.7	2.8	3.8	2.7	3.8	2.7
	33.0	2.4	2.2	2.9	2.5	3.4	2.8	3.5	2.8	3.6	2.8	3.7	2.7	3.8	2.7
	35.0	2.4	2.2	2.9	2.5	3.4	2.8	3.5	2.8	3.5	2.7	3.6	2.6	3.7	2.6
	37.0	2.4	2.2	2.9	2.5	3.4	2.8	3.5	2.8	3.5	2.7	3.6	2.6	3.7	2.6
	39.0	2.4	2.2	2.9	2.5	3.4	2.8	3.5	2.8	3.5	2.7	3.6	2.6	3.7	2.6

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	14.0°CWB 20°CDB SHC	16.0°CWB 23°CDB TC	16.0°CWB 23°CDB SHC	18.0°CWB 26°CDB TC	18.0°CWB 26°CDB SHC	19.0°CWB 27°CDB TC	19.0°CWB 27°CDB SHC	20.0°CWB 28°CDB TC	20.0°CWB 28°CDB SHC	22.0°CWB 30°CDB TC	22.0°CWB 30°CDB SHC	24.0°CWB 32°CDB TC	24.0°CWB 32°CDB SHC
40	10.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	5.4	3.9	5.7	4.0
	12.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	5.4	3.9	5.6	4.0
	14.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	5.4	3.9	5.5	4.0
	16.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	5.4	3.9	5.5	3.9
	18.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	5.3	3.9	5.4	3.9
	20.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	5.2	3.8	5.3	3.9
	21.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	5.2	3.8	5.3	3.8
	23.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	5.1	3.8	5.2	3.8
	25.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	5.0	3.7	5.1	3.8
	27.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	4.9	3.7	5.0	3.7
	29.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.8	3.8	4.8	3.6	4.9	3.6
	31.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.7	3.8	4.7	3.6	4.8	3.6
	33.0	3.0	2.9	3.6	3.4	4.2	3.8	4.5	3.8	4.6	3.7	4.7	3.5	4.8	3.6
	35.0	3.0	2.9	3.6	3.4	4.2	3.8	4.4	3.8	4.5	3.6	4.6	3.4	4.7	3.5
	37.0	3.0	2.9	3.6	3.4	4.2	3.8	4.4	3.7	4.4	3.6	4.5	3.4	4.6	3.5
	39.0	3.0	2.9	3.6	3.4	4.2	3.8	4.4	3.7	4.4	3.6	4.5	3.4	4.6	3.5
50	10.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	6.0	4.6	6.7	4.8	7.1	4.3
	12.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	6.0	4.6	6.7	4.8	7.0	4.3
	14.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	6.0	4.6	6.7	4.8	6.9	4.2
	16.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	6.0	4.6	6.7	4.8	6.8	4.1
	18.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	6.0	4.6	6.5	4.7	6.7	4.1
	20.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	6.0	4.6	6.5	4.7	6.6	4.0
	21.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	6.0	4.6	6.4	4.6	6.6	4.0
	23.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	6.0	4.6	6.4	4.6	6.5	4.0
	25.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	6.0	4.6	6.3	4.5	6.4	3.9
	27.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	6.0	4.6	6.2	4.5	6.3	3.8
	29.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	5.9	4.6	6.1	4.4	6.2	3.8
	31.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	5.9	4.6	6.0	4.4	6.1	3.7
	33.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	5.8	4.5	5.9	4.3	6.0	3.7
	35.0	3.8	3.6	4.5	4.1	5.2	4.5	5.6	4.6	5.7	4.5	5.8	4.3	5.9	3.6
	37.0	3.8	3.6	4.5	4.1	5.2	4.5	5.5	4.5	5.6	4.4	5.7	4.2	5.8	3.6
	39.0	3.8	3.6	4.5	4.1	5.2	4.5	5.4	4.5	5.5	4.4	5.6	4.2	5.8	3.5
63	10.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.6	5.6	8.5	5.8	9.0	6.4
	12.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.6	5.6	8.5	5.8	8.9	6.3
	14.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.6	5.6	8.5	5.8	8.7	6.3
	16.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.6	5.6	8.5	5.8	8.6	6.3
	18.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.6	5.6	8.3	5.8	8.5	6.2
	20.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.6	5.6	8.2	5.7	8.4	6.2
	21.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.6	5.6	8.2	5.7	8.3	6.2
	23.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.6	5.6	8.1	5.6	8.2	6.1
	25.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.6	5.6	7.9	5.6	8.1	6.1
	27.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.6	5.6	7.8	5.5	8.0	6.1
	29.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.5	5.6	7.7	5.4	7.9	6.0
	31.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.4	5.5	7.6	5.4	7.8	6.0
	33.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.3	5.5	7.5	5.3	7.6	5.9
	35.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.2	5.4	7.4	5.3	7.5	5.9
	37.0	4.8	4.2	5.7	4.9	6.6	5.4	7.1	5.5	7.1	5.4	7.2	5.2	7.4	5.9
	39.0	4.8	4.2	5.7	4.9	6.6	5.4	7.0	5.4	7.0	5.3	7.1	5.1	7.3	5.8

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

FXMQ-P [50/60Hz]

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	14.0°CWB 20°CDB SHC	16.0°CWB 23°CDB TC	16.0°CWB 23°CDB SHC	18.0°CWB 26°CDB TC	18.0°CWB 26°CDB SHC	19.0°CWB 27°CDB TC	19.0°CWB 27°CDB SHC	20.0°CWB 28°CDB TC	20.0°CWB 28°CDB SHC	22.0°CWB 30°CDB TC	22.0°CWB 30°CDB SHC	24.0°CWB 32°CDB TC	24.0°CWB 32°CDB SHC
80	10.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.6	7.1	10.8	7.4	11.4	7.4
	12.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.6	7.1	10.8	7.4	11.2	7.4
	14.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.6	7.1	10.8	7.4	11.1	7.3
	16.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.6	7.1	10.7	7.4	10.9	7.2
	18.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.6	7.1	10.6	7.3	10.8	7.2
	20.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.6	7.1	10.4	7.2	10.6	7.1
	21.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.6	7.1	10.4	7.2	10.6	7.1
	23.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.6	7.1	10.2	7.1	10.4	7.0
	25.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.6	7.1	10.1	7.0	10.3	6.9
	27.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.6	7.1	9.9	7.0	10.1	6.9
	29.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.5	7.1	9.8	6.9	10.0	6.8
	31.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.4	7.0	9.6	6.8	9.8	6.7
	33.0	6.1	5.3	7.2	6.1	8.4	6.9	9.0	7.0	9.3	7.0	9.5	6.7	9.7	6.7
	35.0	6.1	5.3	7.2	6.1	8.4	6.9	8.9	7.0	9.1	6.9	9.3	6.6	9.5	6.6
	37.0	6.1	5.3	7.2	6.1	8.4	6.9	8.7	6.9	9.0	6.8	9.2	6.6	9.4	6.5
	39.0	6.1	5.3	7.2	6.1	8.4	6.9	8.7	6.8	8.8	6.7	9.0	6.5	9.3	6.5
100	10.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.7	13.4	9.0	14.2	8.9
	12.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.7	13.4	9.0	14.0	8.9
	14.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.7	13.4	9.0	13.8	8.8
	16.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.7	13.3	9.0	13.6	8.7
	18.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.7	13.2	8.9	13.4	8.6
	20.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.7	13.0	8.8	13.2	8.5
	21.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.7	12.9	8.8	13.2	8.5
	23.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.7	12.7	8.7	13.0	8.4
	25.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.7	12.5	8.6	12.8	8.3
	27.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.7	12.3	8.5	12.6	8.2
	29.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.9	8.6	12.2	8.4	12.4	8.1
	31.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.7	8.5	12.0	8.3	12.2	8.0
	33.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.5	8.5	11.8	8.2	12.1	7.9
	35.0	7.6	6.4	9.0	7.3	10.5	8.3	11.2	8.5	11.3	8.4	11.6	8.1	11.9	7.8
	37.0	7.6	6.4	9.0	7.3	10.5	8.3	11.0	8.4	11.2	8.3	11.4	8.0	11.7	7.7
	39.0	7.6	6.4	9.0	7.3	10.5	8.3	10.8	8.3	11.0	8.2	11.2	7.9	11.5	7.6
125	10.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.8	16.7	11.1	17.7	11.1
	12.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.8	16.7	11.1	17.5	11.0
	14.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.8	16.7	11.1	17.2	10.9
	16.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.8	16.7	11.1	17.0	10.8
	18.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.8	16.4	11.0	16.8	10.7
	20.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.8	16.2	10.9	16.6	10.6
	21.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.8	16.1	10.9	16.4	10.5
	23.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.8	15.9	10.8	16.2	10.4
	25.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.8	15.6	10.6	16.0	10.3
	27.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.8	15.4	10.5	15.8	10.2
	29.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.9	10.7	15.2	10.4	15.5	10.1
	31.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.6	10.6	15.0	10.3	15.3	10.0
	33.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.4	10.5	14.7	10.2	15.1	9.8
	35.0	9.4	8.0	11.3	9.2	13.1	10.3	14.0	10.5	14.2	10.4	14.5	10.1	14.9	9.7
	37.0	9.4	8.0	11.3	9.2	13.1	10.3	13.8	10.4	13.9	10.3	14.3	10.0	14.6	9.6
	39.0	9.4	8.0	11.3	9.2	13.1	10.3	13.5	10.3	13.7	10.2	14.1	9.9	14.4	9.5

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

7

7.2 Heating Capacity

FXMQ-P [50/60Hz]

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
20	-19.8	-20.0	1.5	1.5	1.5	1.5	1.5	1.5
	-18.8	-19.0	1.5	1.5	1.5	1.5	1.5	1.5
	-16.7	-17.0	1.6	1.6	1.6	1.6	1.6	1.6
	-14.7	-15.0	1.7	1.7	1.7	1.7	1.7	1.7
	-12.6	-13.0	1.8	1.8	1.8	1.8	1.8	1.8
	-10.5	-11.0	1.9	1.9	1.9	1.9	1.9	1.9
	-9.5	-10.0	1.9	1.9	1.9	1.9	1.9	1.9
	-8.5	-9.1	2.0	2.0	1.9	1.9	1.9	1.9
	-7.0	-7.6	2.0	2.0	2.0	2.0	2.0	2.0
	-5.0	-5.6	2.1	2.1	2.1	2.1	2.1	2.1
	-3.0	-3.7	2.2	2.2	2.2	2.2	2.2	2.2
	0.0	-0.7	2.3	2.3	2.3	2.3	2.3	2.2
	3.0	2.2	2.5	2.5	2.4	2.4	2.3	2.2
	5.0	4.1	2.5	2.6	2.5	2.4	2.3	2.2
	7.0	6.0	2.6	2.7	2.5	2.4	2.3	2.2
	9.0	7.9	2.7	2.7	2.5	2.4	2.3	2.2
	11.0	9.8	2.8	2.8	2.5	2.4	2.3	2.2
	13.0	11.8	2.8	2.7	2.5	2.4	2.3	2.2
	15.0	13.7	2.8	2.7	2.5	2.4	2.3	2.2
25	-19.8	-20.0	1.9	1.9	1.9	1.9	1.9	1.9
	-18.8	-19.0	1.9	1.9	1.9	1.9	1.9	1.9
	-16.7	-17.0	2.1	2.1	2.0	2.0	2.0	2.0
	-14.7	-15.0	2.2	2.2	2.2	2.2	2.2	2.1
	-12.6	-13.0	2.3	2.3	2.3	2.3	2.3	2.3
	-10.5	-11.0	2.4	2.4	2.4	2.4	2.4	2.4
	-9.5	-10.0	2.5	2.5	2.5	2.5	2.5	2.4
	-8.5	-9.1	2.5	2.5	2.5	2.5	2.5	2.5
	-7.0	-7.6	2.6	2.6	2.6	2.6	2.6	2.6
	-5.0	-5.6	2.7	2.7	2.7	2.7	2.7	2.7
	-3.0	-3.7	2.8	2.8	2.8	2.8	2.8	2.8
	0.0	-0.7	3.0	3.0	3.0	3.0	3.0	2.8
	3.0	2.2	3.1	3.1	3.1	3.1	3.0	2.8
	5.0	4.1	3.2	3.2	3.2	3.1	3.0	2.8
	7.0	6.0	3.4	3.4	3.2	3.1	3.0	2.8
	9.0	7.9	3.5	3.4	3.2	3.1	3.0	2.8
	11.0	9.8	3.6	3.4	3.2	3.1	3.0	2.8
	13.0	11.8	3.6	3.4	3.2	3.1	3.0	2.8
	15.0	13.7	3.6	3.4	3.2	3.1	3.0	2.8
32	-19.8	-20.0	2.4	2.4	2.3	2.3	2.3	2.3
	-18.8	-19.0	2.4	2.4	2.4	2.4	2.4	2.4
	-16.7	-17.0	2.6	2.6	2.6	2.6	2.6	2.5
	-14.7	-15.0	2.7	2.7	2.7	2.7	2.7	2.7
	-12.6	-13.0	2.9	2.8	2.8	2.8	2.8	2.8
	-10.5	-11.0	3.0	3.0	3.0	3.0	3.0	3.0
	-9.5	-10.0	3.1	3.1	3.1	3.1	3.0	3.0
	-8.5	-9.1	3.1	3.1	3.1	3.1	3.1	3.1
	-7.0	-7.6	3.2	3.2	3.2	3.2	3.2	3.2
	-5.0	-5.6	3.4	3.4	3.4	3.4	3.4	3.4
	-3.0	-3.7	3.5	3.5	3.5	3.5	3.5	3.5
	0.0	-0.7	3.7	3.7	3.7	3.7	3.7	3.5
	3.0	2.2	3.9	3.9	4.0	3.9	3.7	3.5
	5.0	4.1	4.1	4.1	4.0	3.9	3.7	3.5
	7.0	6.0	4.2	4.2	4.0	3.9	3.7	3.5
	9.0	7.9	4.3	4.3	4.0	3.9	3.7	3.5
	11.0	9.8	4.5	4.3	4.0	3.9	3.7	3.5
	13.0	11.8	4.5	4.3	4.0	3.9	3.7	3.5
	15.0	13.7	4.5	4.3	4.0	3.9	3.7	3.5

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
40	-19.8	-20.0	3.0	2.9	2.9	2.9	2.9	2.9
	-18.8	-19.0	3.0	3.0	3.0	3.0	3.0	3.0
	-16.7	-17.0	3.2	3.2	3.2	3.2	3.2	3.2
	-14.7	-15.0	3.4	3.4	3.4	3.4	3.4	3.4
	-12.6	-13.0	3.6	3.6	3.6	3.5	3.5	3.5
	-10.5	-11.0	3.7	3.7	3.7	3.7	3.7	3.7
	-9.5	-10.0	3.8	3.8	3.8	3.8	3.8	3.8
	-8.5	-9.1	3.9	3.9	3.9	3.9	3.9	3.9
	-7.0	-7.6	4.0	4.0	4.0	4.0	4.0	4.0
	-5.0	-5.6	4.2	4.2	4.2	4.2	4.2	4.2
	-3.0	-3.7	4.4	4.4	4.4	4.4	4.4	4.4
	0.0	-0.7	4.7	4.6	4.6	4.6	4.6	4.4
	3.0	2.2	4.9	4.9	4.9	4.8	4.7	4.4
	5.0	4.1	5.1	5.1	5.0	4.8	4.7	4.4
	7.0	6.0	5.4	5.2	5.0	4.8	4.7	4.4
	9.0	7.9	5.6	5.3	5.0	4.8	4.7	4.4
	11.0	9.8	5.6	5.3	5.0	4.8	4.7	4.4
	13.0	11.8	5.6	5.3	5.0	4.8	4.7	4.4
	15.0	13.7	5.6	5.3	5.0	4.8	4.7	4.4
50	-19.8	-20.0	3.7	3.7	3.7	3.7	3.7	3.7
	-18.8	-19.0	3.8	3.8	3.8	3.8	3.8	3.8
	-16.7	-17.0	4.1	4.0	4.0	4.0	4.0	4.0
	-14.7	-15.0	4.3	4.3	4.3	4.2	4.2	4.2
	-12.6	-13.0	4.5	4.5	4.5	4.5	4.5	4.5
	-10.5	-11.0	4.7	4.7	4.7	4.7	4.7	4.7
	-9.5	-10.0	4.8	4.8	4.8	4.8	4.8	4.8
	-8.5	-9.1	4.9	4.9	4.9	4.9	4.9	4.9
	-7.0	-7.6	5.1	5.1	5.1	5.1	5.1	5.1
	-5.0	-5.6	5.3	5.3	5.3	5.3	5.3	5.3
	-3.0	-3.7	5.5	5.5	5.5	5.5	5.5	5.5
	0.0	-0.7	5.9	5.9	5.8	5.8	5.8	5.5
	3.0	2.2	6.2	6.2	6.2	6.1	5.9	5.5
	5.0	4.1	6.4	6.4	6.3	6.1	5.9	5.5
	7.0	6.0	6.6	6.6	6.3	6.1	5.9	5.5
	9.0	7.9	6.8	6.7	6.3	6.1	5.9	5.5
	11.0	9.8	7.0	6.7	6.3	6.1	5.9	5.5
	13.0	11.8	7.1	6.7	6.3	6.1	5.9	5.5
	15.0	13.7	7.1	6.7	6.3	6.1	5.9	5.5
63	-19.8	-20.0	4.7	4.7	4.7	4.7	4.7	4.7
	-18.8	-19.0	4.9	4.9	4.8	4.8	4.8	4.8
	-16.7	-17.0	5.1	5.1	5.1	5.1	5.1	5.1
	-14.7	-15.0	5.4	5.4	5.4	5.4	5.4	5.4
	-12.6	-13.0	5.7	5.7	5.7	5.7	5.7	5.7
	-10.5	-11.0	6.0	6.0	6.0	6.0	6.0	5.9
	-9.5	-10.0	6.1	6.1	6.1	6.1	6.1	6.1
	-8.5	-9.1	6.3	6.3	6.2	6.2	6.2	6.2
	-7.0	-7.6	6.5	6.5	6.4	6.4	6.4	6.4
	-5.0	-5.6	6.8	6.7	6.7	6.7	6.7	6.7
	-3.0	-3.7	7.0	7.0	7.0	7.0	7.0	7.0
	0.0	-0.7	7.5	7.4	7.4	7.4	7.4	7.0
	3.0	2.2	7.9	7.8	7.8	7.7	7.5	7.0
	5.0	4.1	8.1	8.1	8.0	7.7	7.5	7.0
	7.0	6.0	8.4	8.4	8.0	7.7	7.5	7.0
	9.0	7.9	8.7	8.5	8.0	7.7	7.5	7.0
	11.0	9.8	8.9	8.5	8.0	7.7	7.5	7.0
	13.0	11.8	9.0	8.5	8.0	7.7	7.5	7.0
	15.0	13.7	9.0	8.5	8.0	7.7	7.5	7.0

Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

FXMQ-P [50/60Hz]

Heating capacity


Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
80	-19.8	-20.0	5.9	5.9	5.9	5.9	5.9	5.8
	-18.8	-19.0	6.1	6.1	6.0	6.0	6.0	6.0
	-16.7	-17.0	6.4	6.4	6.4	6.4	6.4	6.4
	-14.7	-15.0	6.8	6.8	6.8	6.7	6.7	6.7
	-12.6	-13.0	7.1	7.1	7.1	7.1	7.1	7.1
	-10.5	-11.0	7.5	7.5	7.5	7.5	7.4	7.4
	-9.5	-10.0	7.7	7.7	7.6	7.6	7.6	7.6
	-8.5	-9.1	7.8	7.8	7.8	7.8	7.8	7.8
	-7.0	-7.6	8.1	8.1	8.1	8.1	8.0	8.0
	-5.0	-5.6	8.4	8.4	8.4	8.4	8.4	8.4
	-3.0	-3.7	8.8	8.8	8.7	8.7	8.7	8.7
	0.0	-0.7	9.3	9.3	9.3	9.3	9.3	8.7
	3.0	2.2	9.8	9.8	9.8	9.7	9.4	8.7
	5.0	4.1	10.2	10.1	10.0	9.7	9.4	8.7
	7.0	6.0	10.5	10.5	10.0	9.7	9.4	8.7
	9.0	7.9	10.8	10.6	10.0	9.7	9.4	8.7
	11.0	9.8	11.2	10.6	10.0	9.7	9.4	8.7
	13.0	11.8	11.3	10.6	10.0	9.7	9.4	8.7
	15.0	13.7	11.3	10.6	10.0	9.7	9.4	8.7
100	-19.8	-20.0	7.4	7.4	7.3	7.3	7.3	7.3
	-18.8	-19.0	7.6	7.6	7.6	7.5	7.5	7.5
	-16.7	-17.0	8.0	8.0	8.0	8.0	8.0	8.0
	-14.7	-15.0	8.5	8.5	8.4	8.4	8.4	8.4
	-12.6	-13.0	8.9	8.9	8.9	8.9	8.9	8.8
	-10.5	-11.0	9.4	9.3	9.3	9.3	9.3	9.3
	-9.5	-10.0	9.6	9.6	9.5	9.5	9.5	9.5
	-8.5	-9.1	9.8	9.8	9.7	9.7	9.7	9.7
	-7.0	-7.6	10.1	10.1	10.1	10.1	10.1	10.0
	-5.0	-5.6	10.6	10.5	10.5	10.5	10.5	10.5
	-3.0	-3.7	11.0	11.0	10.9	10.9	10.9	10.9
	0.0	-0.7	11.6	11.6	11.6	11.6	11.6	10.9
	3.0	2.2	12.3	12.2	12.2	12.1	11.7	10.9
	5.0	4.1	12.7	12.7	12.5	12.1	11.7	10.9
	7.0	6.0	13.1	13.1	12.5	12.1	11.7	10.9
	9.0	7.9	13.5	13.3	12.5	12.1	11.7	10.9
	11.0	9.8	14.0	13.3	12.5	12.1	11.7	10.9
	13.0	11.8	14.1	13.3	12.5	12.1	11.7	10.9
	15.0	13.7	14.1	13.3	12.5	12.1	11.7	10.9
125	-19.8	-20.0	9.4	9.4	9.4	9.4	9.4	9.3
	-18.8	-19.0	9.7	9.7	9.7	9.7	9.6	9.6
	-16.7	-17.0	10.3	10.3	10.2	10.2	10.2	10.2
	-14.7	-15.0	10.9	10.8	10.8	10.8	10.8	10.7
	-12.6	-13.0	11.4	11.4	11.4	11.4	11.3	11.3
	-10.5	-11.0	12.0	12.0	11.9	11.9	11.9	11.9
	-9.5	-10.0	12.3	12.2	12.2	12.2	12.2	12.2
	-8.5	-9.1	12.5	12.5	12.5	12.5	12.4	12.4
	-7.0	-7.6	13.0	12.9	12.9	12.9	12.9	12.8
	-5.0	-5.6	13.5	13.5	13.5	13.4	13.4	13.4
	-3.0	-3.7	14.1	14.0	14.0	14.0	14.0	13.9
	0.0	-0.7	14.9	14.9	14.8	14.8	14.8	13.9
	3.0	2.2	15.7	15.7	15.7	15.5	15.0	13.9
	5.0	4.1	16.3	16.2	16.0	15.5	15.0	13.9
	7.0	6.0	16.8	16.8	16.0	15.5	15.0	13.9
	9.0	7.9	17.3	17.0	16.0	15.5	15.0	13.9
	11.0	9.8	17.9	17.0	16.0	15.5	15.0	13.9
	13.0	11.8	18.1	17.0	16.0	15.5	15.0	13.9
	15.0	13.7	18.1	17.0	16.0	15.5	15.0	13.9

Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

8. Fan Performances

8.1 Fan Performance


FXMQ20P / 25PVE



Notes:
1. As for this machine, setting is possible by 8 position of ESP.
2. Fan characteristics ① shows a fan characteristic at the time of the "maximum ESP" "rating ESP" "minimum ESP" as a representative.
3. Fan characteristics ② (for field setting of remote controller) shows a fan characteristic of each ESP of field setting possible air flow "HH".
4. Please choose ESP setting by using Fan characteristics ① and Fan characteristics ② by the resistance of a connected duct.
5. The remote controller can be used to change "HH" "H" and "L".
6. ESP : external static pressure
7. The value in this figure shows ESP in rating air flow.

3D062537


FXMQ32PVE



Notes:
1. As for this machine, setting is possible by 8 position of ESP.
2. Fan characteristics ① shows a fan characteristic at the time of the "maximum ESP" "rating ESP" "minimum ESP" as a representative.
3. Fan characteristics ② (for field setting of remote controller) shows a fan characteristic of each ESP of field setting possible air flow "HH".
4. Please choose ESP setting by using Fan characteristics ① and Fan characteristics ② by the resistance of a connected duct.
5. The remote controller can be used to change "HH" "H" and "L".
6. ESP : external static pressure
7. The value in this figure shows ESP in rating air flow.

3D062538


FXMQ40PVE



Notes:
1. As for this machine, setting is possible by 13 position of ESP.
2. Fan characteristics ① shows a fan characteristic at the time of the "maximum ESP" "rating ESP" "minimum ESP" as a representative.
3. Fan characteristics ② (for field setting of remote controller) shows a fan characteristic of each ESP of field setting possible air flow "HH".
4. Please choose ESP setting by using Fan characteristics ① and Fan characteristics ② by the resistance of a connected duct.
5. The remote controller can be used to change "HH" "H" and "L".
6. ESP : external static pressure
7. The value in this figure shows ESP in rating air flow.
8. Please set the external static pressure of the suction duct at 150Pa or less.

3D060456A


FXMQ50PVE



Notes:
1. As for this machine, setting is possible by 14 position of ESP.
2. Fan characteristics ① shows a fan characteristic at the time of the "maximum ESP" "rating ESP" "minimum ESP" as a representative.
3. Fan characteristics ② (for field setting of remote controller) shows a fan characteristic of each ESP of field setting possible air flow "HH".
4. Please choose ESP setting by using Fan characteristics ① and Fan characteristics ② by the resistance of a connected duct.
5. The remote controller can be used to change "HH" "H" and "L".
6. ESP : external static pressure
7. The value in this figure shows ESP in rating air flow.
8. Please set the external static pressure of the suction duct at 150Pa or less.

3D060457B


FXMQ63PVE



Notes:
1. As for this machine, setting is possible by 14 position of ESP.
2. Fan characteristics ① shows a fan characteristic at the time of the "maximum ESP" "rating ESP" "minimum ESP" as a representative.
3. Fan characteristics ② (for field setting of remote controller) shows a fan characteristic of each ESP of field setting possible air flow "HH".
4. Please choose ESP setting by using Fan characteristics ① and Fan characteristics ② by the resistance of a connected duct.
5. The remote controller can be used to change "HH" "H" and "L".
6. ESP : external static pressure
7. The value in this figure shows ESP in rating air flow.
8. Please set the external static pressure of the suction duct at 150Pa or less.

3D060458A


FXMQ80PVE



Notes:
1. As for this machine, setting is possible by 14 position of ESP.
2. Fan characteristics ① shows a fan characteristic at the time of the "maximum ESP" "rating ESP" "minimum ESP" as a representative.
3. Fan characteristics ② (for field setting of remote controller) shows a fan characteristic of each ESP of field setting possible air flow "HH".
4. Please choose ESP setting by using Fan characteristics ① and Fan characteristics ② by the resistance of a connected duct.
5. The remote controller can be used to change "HH" "H" and "L".
6. ESP : external static pressure
7. The value in this figure shows ESP in rating air flow.
8. Please set the external static pressure of the suction duct at 150Pa or less.

3D060459A


FXMQ100PVE



Notes:
1. As for this machine, setting is possible by 14 position of ESP.
2. Fan characteristics ① shows a fan characteristic at the time of the "maximum ESP" "rating ESP" "minimum ESP" as a representative.
3. Fan characteristics ② (for field setting of remote controller) shows a fan characteristic of each ESP of field setting possible air flow "HH".
4. Please choose ESP setting by using Fan characteristics ① and Fan characteristics ② by the resistance of a connected duct.
5. The remote controller can be used to change "HH" "H" and "L".
6. ESP : external static pressure
7. The value in this figure shows ESP in rating air flow.
8. Please set the external static pressure of the suction duct at 150Pa or less.

3D060460A

FXMQ125PVE




Notes:
1. As for this machine, setting is possible by 14 position of ESP.
2. Fan characteristics ① shows a fan characteristic at the time of the "maximum ESP" "rating ESP" "minimum ESP" as a representative.
3. Fan characteristics ② (for field setting of remote controller) shows a fan characteristic of each ESP of field setting possible air flow "HH".
4. Please choose ESP setting by using Fan characteristics ① and Fan characteristics ② by the resistance of a connected duct.
5. The remote controller can be used to change "HH" "H" and "L".
6. ESP : external static pressure
7. The value in this figure shows ESP in rating air flow.
8. Please set the external static pressure of the suction duct at 150Pa or less.

3D060461A

8.2 “Air Flow Auto Adjustment” Characteristics


FXMQ20P / 25PVE



Notes:
1. As for this machine, less than 10% of the volume of blow-off air is automatically adjusted to the rated quantity by airflow auto adjustment at the time of installation.
2. After duct construction completion, please perform local setting "airflow auto adjustment" by remote controller.
3. About the local setting method of the "airflow auto adjustment", look at the installation manual which is attached to an indoor unit.
4. External static pressure that can adjust by "airflow auto adjustment" function is 30Pa-100Pa (When air flow is HH).
5. It is not operated auto adjustment, operated in air flow that is different from rated quantity in the case of use out of external static pressure range mentioned above.
6. This figure shows a fan characteristics at the time of "HH" "H" and "L".
7. The remote controller can be used to change "HH" "H" and "L".
8. ESP : external static pressure.

3D062539


FXMQ32PVE



Notes:
1. As for this machine, less than 10% of the volume of blow-off air is automatically adjusted to the rated quantity by airflow auto adjustment at the time of installation.
2. After duct construction completion, please perform local setting "airflow auto adjustment" by remote controller.
3. About the local setting method of the "airflow auto adjustment", look at the installation manual which is attached to an indoor unit.
4. External static pressure that can adjust by "airflow auto adjustment" function is 30Pa-100Pa (When air flow is HH).
5. It is not operated auto adjustment, operated in air flow that is different from rated quantity in the case of use out of external static pressure range mentioned above.
6. This figure shows a fan characteristics at the time of "HH" "H" and "L".
7. The remote controller can be used to change "HH" "H" and "L".
8. ESP : external static pressure.

3D062540


FXMQ40PVE



Notes:
1. As for this machine, less than 10% of the volume of blow-off air is automatically adjusted to the rated quantity by airflow auto adjustment at the time of installation.
2. After duct construction completion, please perform local setting "airflow auto adjustment" by remote controller.
3. About the local setting method of the "airflow auto adjustment", look at the installation manual which is attached to an indoor unit.
4. External static pressure that can adjust by "airflow auto adjustment" function is 30Pa - 160Pa (When air flow is HH).
5. It is not operated auto adjustment, operated in air flow that is different from rated quantity in the case of use out of external static pressure range mentioned above.
6. This figure shows a fan characteristics at the time of "HH" "H" and "L".
7. The remote controller can be used to change "HH" "H" and "L".
8. ESP : external static pressure.
9. Please set the external static pressure of the suction duct at 150Pa or less.

3D060577A

FXMQ50PVE




Notes:
1. As for this machine, less than 10% of the volume of blow-off air is automatically adjusted to the rated quantity by airflow auto adjustment at the time of installation.
2. After duct construction completion, please perform local setting "airflow auto adjustment" by remote controller.
3. About the local setting method of the "airflow auto adjustment", look at the installation manual which is attached to an indoor unit.
4. External static pressure that can adjust by "airflow auto adjustment" function is 50Pa - 200Pa (When air flow is HH).
5. It is not operated auto adjustment, operated in air flow that is different from rated quantity in the case of use out of external static pressure range mentioned above.
6. This figure shows a fan characteristics at the time of "HH" "H" and "L".
7. The remote controller can be used to change "HH" "H" and "L".
8. ESP : external static pressure.
9. Please set the external static pressure of the suction duct at 150Pa or less.

3D060578A

7


FXMQ63PVE



Notes:
1. As for this machine, less than 10% of the volume of blow-off air is automatically adjusted to the rated quantity by airflow auto adjustment at the time of installation.
2. After duct construction completion, please perform local setting "airflow auto adjustment" by remote controller.
3. About the local setting method of the "airflow auto adjustment", look at the installation manual which is attached to an indoor unit.
4. External static pressure that can adjust by "airflow auto adjustment" function is 50Pa - 200Pa (When air flow is HH).
5. It is not operated auto adjustment, operated in air flow that is different from rated quantity in the case of use out of external static pressure range mentioned above.
6. This figure shows a fan characteristics at the time of "HH" "H" and "L".
7. The remote controller can be used to change "HH" "H" and "L".
8. ESP : external static pressure.
9. Please set the external static pressure of the suction duct at 150Pa or less.

3D060579A


FXMQ80PVE



Notes:
1. As for this machine, less than 10% of the volume of blow-off air is automatically adjusted to the rated quantity by airflow auto adjustment at the time of installation.
2. After duct construction completion, please perform local setting "airflow auto adjustment" by remote controller.
3. About the local setting method of the "airflow auto adjustment", look at the installation manual which is attached to an indoor unit.
4. External static pressure that can adjust by "airflow auto adjustment" function is 50Pa - 200Pa (When air flow is HH).
5. It is not operated auto adjustment, operated in air flow that is different from rated quantity in the case of use out of external static pressure range mentioned above.
6. This figure shows a fan characteristics at the time of "HH" "H" and "L".
7. The remote controller can be used to change "HH" "H" and "L".
8. ESP : external static pressure.
9. Please set the external static pressure of the suction duct at 150Pa or less.

3D060580A


FXMQ100PVE



Notes:
1. As for this machine, less than 10% of the volume of blow-off air is automatically adjusted to the rated quantity by airflow auto adjustment at the time of installation.
2. After duct construction completion, please perform local setting "airflow auto adjustment" by remote controller.
3. About the local setting method of the "airflow auto adjustment", look at the installation manual which is attached to an indoor unit.
4. External static pressure that can adjust by "airflow auto adjustment" function is 50Pa - 200Pa (When air flow is HH).
5. It is not operated auto adjustment, operated in air flow that is different from rated quantity in the case of use out of external static pressure range mentioned above.
6. This figure shows a fan characteristics at the time of "HH" "H" and "L".
7. The remote controller can be used to change "HH" "H" and "L".
8. ESP : external static pressure.
9. Please set the external static pressure of the suction duct at 150Pa or less.

3D060581A

FXMQ125PVE




Notes:
1. As for this machine, less than 10% of the volume of blow-off air is automatically adjusted to the rated quantity by airflow auto adjustment at the time of installation.
2. After duct construction completion, please perform local setting "airflow auto adjustment" by remote controller.
3. About the local setting method of the "airflow auto adjustment", look at the installation manual which is attached to an indoor unit.
4. External static pressure that can adjust by "airflow auto adjustment" function is 50Pa - 200Pa (When air flow is HH).
5. It is not operated auto adjustment, operated in air flow that is different from rated quantity in the case of use out of external static pressure range mentioned above.
6. This figure shows a fan characteristics at the time of "HH" "H" and "L".
7. The remote controller can be used to change "HH" "H" and "L".
8. ESP : external static pressure.
9. Please set the external static pressure of the suction duct at 150Pa or less.

3D060582A

9. Sound Levels

Overall

■ **Ceiling Mounted Duct Type**



4D060446

Note:

1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.


dBA

Model	220~240V 50Hz / 220V 60Hz		
	HH	H	L
FXMQ20P / 25P	33	31	29
FXMQ32P	34	32	30
FXMQ40P	39	37	35
FXMQ50P	41	39	37
FXMQ63P	42	40	38
FXMQ80P	43	41	39
FXMQ100P	43	41	39
FXMQ125P	44	42	40

Octave Band Level


○——○ 220~240V 50Hz / 220V 60Hz

FXMQ20P / 25PVE




4D062535

FXMQ32PVE




4D062536

FXMQ40PVE




4D060446

FXMQ50PVE




4D060428

FXMQ63PVE




4D060447

FXMQ80PVE




4D060429

FXMQ100PVE



4D060448

FXMQ125PVE




4D060449

7

10. Center of Gravity

FXMQ20P / 25P / 32P / 40P / 50P / 63P / 80P / 100P / 125PVE

Unit (mm)



MODEL NAME	A	B
FXMQ20・25・32PVE	550	210
FXMQ40PVE	700	280
FXMQ50・63・80PVE	1000	460
FXMQ100・125PVE	1400	600

4D060438A

11. Installation Manual

DAIKIN

VRV SYSTEM Inverter Air Conditioners Installation manual

CONTENTS

1. SAFETY PRECAUTIONS 1
2. BEFORE INSTALLATION 2
3. SELECTING INSTALLATION SITE 3
4. PREPARATIONS BEFORE INSTALLATION 4
5. INDOOR UNIT INSTALLATION 5
6. REFRIGERANT PIPING WORK 5
7. DRAIN PIPING WORK 7
8. DUCT WORK 8
9. ELECTRIC WIRING WORK 9
10. WIRING EXAMPLE AND HOW TO SET THE REMOTE CONTROLLER 10
11. FIELD SETTING 12
12. TEST OPERATION 14

1. SAFETY PRECAUTIONS

Please read these “SAFETY PRECAUTIONS” carefully before installing air conditioning unit and be sure to install it correctly. After completing installation, conduct a trial operation to check for faults and explain to the customer how to operate the air conditioner and take care of it with the aid of the operation manual. Ask the customer to store the installation manual along with the operation manual for future reference.

This air conditioner comes under the term “appliances not accessible to the general public”.

Safety Precaution
This unit is a class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

Meaning of WARNING and CAUTION notices

⚠ **WARNING** ..... Failure to follow these instructions properly may result in personal injury or loss of life.

⚠ **CAUTION** ..... Failure to observe these instructions properly may result in property damage or personal injury, which may be serious depending on the circumstances.

⚠ WARNING

- Ask your dealer or qualified personnel to carry out installation work.
  Do not attempt to install the air conditioner yourself. Improper installation may result in water leakage, electric shocks or fire.
- Install the air conditioner in accordance with the instructions in this installation manual.
  Improper installation may result in water leakage, electric shocks or fire.
- Consult your local dealer regarding what to do in case of refrigerant leakage. When the air conditioner is to be installed in a small room, it is necessary to take proper measures so that the amount of any leaked refrigerant does not exceed the concentration limit in the event of a leakage. Otherwise, this may lead to an accident due to oxygen depletion.
- Be sure to use only the specified accessories and parts for installation work.
  Failure to use the specified parts may result in the unit falling, water leakage, electric shocks or fire.
- Install the air conditioner on a foundation strong enough to withstand the weight of the unit.
  A foundation of insufficient strength may result in the equipment falling and causing injury.
- Carry out the specified installation work after taking into account strong winds, typhoons or earthquakes.
  Failure to do so during installation work may result in the unit falling and causing accidents.
- Make sure that a separate power supply circuit is provided for this unit and that all electrical work is carried out by qualified personnel according to local laws and regulations and this installation manual.
  An insufficient power supply capacity or improper electrical construction may lead to electric shocks or fire.
- Make sure that all wiring is secured, the specified wires are used, and that there is no strain on the terminal connections or wires.
  Improper connections or securing of wires may result in abnormal heat build-up or fire.
- When wiring the power supply and connecting the remote controller wiring and transmission wiring, position the wires so that the control box lid can be securely fastened.
  Improper positioning of the control box lid may result in electric shocks, fire or the terminals overheating.
- If refrigerant gas leaks during installation, ventilate the area immediately.
  Toxic gas may be produced if the refrigerant comes into contact with fire.
- After completing installation, check for refrigerant gas leakage.
  Toxic gas may be produced if the refrigerant gas leaks into the room and comes into contact with a source of fire, such as a fan heater, stove or cooker.
- Be sure to switch off the unit before touching any electrical parts.
- Be sure to earth the air conditioner.
  Do not earth the unit to a utility pipe, lightning conductor or telephone earth lead. Imperfect earthing may result in electric shocks or fire.
  A high surge current from lightning or other sources may cause damage to the air conditioner.
- Be sure to install an earth leakage breaker.
  Failure to install an earth leakage breaker may result in electric shocks or fire.

⚠ CAUTION

- While following the instructions in this installation manual, install drain piping to ensure proper drainage and insulate piping to prevent condensation.
  Improper drain piping may result in indoor water leakage and property damage.
- Install the indoor and outdoor units, power cord and connecting wires at least 1 meter away from televisions or radios to prevent picture interference and noise.
  (Depending on the incoming signal strength, a distance of 1 meter may not be sufficient to eliminate noise.)
- Remote controller (wireless kit) transmitting distance can be shorter than expected in rooms with electronic fluorescent lamps (inverter or rapid start types).
  Install the indoor unit as far away from fluorescent lamps as possible.

- Do not install the air conditioner in the following locations:
  1. Where there is a high concentration of mineral oil spray or vapour (e.g. a kitchen).
     Plastic parts will deteriorate, parts may fall off and water leakage could result.
  2. Where corrosive gas, such as sulphurous acid gas, is produced.
     Corroding of copper pipes or soldered parts may result in refrigerant leakage.
  3. Near machinery emitting electromagnetic radiation.
     Electromagnetic radiation may disturb the operation of the control system and result in a malfunction of the unit.
  4. Where flammable gas may leak, where there is carbon fibre or ignitable dust suspensions in the air, or where volatile flammables such as paint thinner or gasoline are handled.
     Operating the unit in such conditions may result in fire.

2. BEFORE INSTALLATION

- **When moving the unit while removing it from the carton box, be sure to lift it by holding on to the four lifting lugs without exerting any pressure on other parts, especially, the refrigerant piping, drain piping, flanges and other resin parts.**
- Be sure to check the type of R410A refrigerant to be used before installing the unit. (Using an incorrect refrigerant will prevent normal operation of the unit.)
- The accessories needed for installation must be retained in your custody until the installation work is completed. Do not discard them!
- Decide upon a line of transport.
- Leave the unit inside its packaging while moving, until reaching the installation site. Where unpacking is unavoidable, use a sling of soft material or protective plates together with a rope when lifting, to avoid damage or scratches to the unit.
- When moving the unit or affter opening, hold the unit by the hanger brackets (× 4). Do not apply force to the refrigerant piping, drain piping, flanges or plastic parts.
- For the installation of outdoor unit, refer to the installation manual attached to the outdoor unit.
- Do not install or operate the unit in rooms mentioned below.
  - **Laden with mineral oil, or filled with oil vapor or spray like in kitchens. (Plastic parts may deteriorate which could eventually cause the unit to fall out of place, or could lead to leaks.)**
  - **Where corrosive gas like sulfurous gas exists. (Copper tubing and brazed spots may corrode which could eventually lead to refrigerant leaks.)**
  - **Where exposed to combustible gases and where volatile flammable gas like thinner or gasoline is used. (Gas in the vicinity of the unit could ignite.)**
  - **Where machines can generate electromagnetic waves. (Control system may malfunction.)**
  - **Where the air contains high levels of salt such as that near the ocean and where voltage fluctuates greatly such as that in factories.**
    Also in vehicles or vessels.
- This unit, both indoor and outdoor, is suitable for installation in a commercial and light industrial environment.
  If installed as a household appliance it could cause electromagnetic interference.

2-1 PRECAUTIONS

- Be sure to read this manual before installing the indoor unit.
- Entrust installation to the place of purchase or a qualified serviceman. Improper installation could lead to leaks and, in worse cases, electric shock of fire.
- Use only parts provided with the unit or parts satisfying required specifications. Unspecified parts could cause the unit to fall out of place, or could lead to leaks and, in worse cases, electric shock or fire.
- Be sure to mount an air filter (part to be procured in the field) in the suction air passage in order to prevent water leaking, etc.

2-2 ACCESSORIES

Check that the following accessories are provided and that each accessory is correct in amount.
Refer to the Fig. 1 of this sheet.

[PRECAUTION]
The accessories are required for the installation of the air conditioner. Be sure to keep them until the installation work is completed.





Fig. 1

Name	Metal clamp (1)	Drain hose (2)	Screws for duct flanges (3)	Insulation for fitting
Quantity	1 pc.	1 pc.	As described in table below	1 each
Shape			 M5×16 20 • 25 • 32 type: 6 40 type: 10 50 • 63 • 80 type: 18 100 • 125 type: 26	 Thin for liquid pipe (4)  Thick for gas pipe (5)

Name	Sealing pad	Clamp (8)	Washer fixing plate (9)	Wire sealing material (10)
Quantity	–	9 pcs.	4 pcs.	2 pcs.
Shape	 1 pc. Large (Dark gray) (6)  2 pcs. Middle (Dark gray) (7)			 Small (Gray)

Name	Washer (11)	Wire fixing bracket (12)	Wire fixing screw (13)	(Other)
Quantity	8 pcs.	2 pcs.	2 pcs.	• Operation manual • Installation manual
Shape			M4×8 	

2-3 OPTIONAL ACCESSORIES

- These are two types of remote controllers: wired and wireless. Select a remote controller according to customer request and install in an appropriate place.

Table 1

Remote controller	
Wired type	
Wireless type	Heat pump type
	Cooling only type

NOTE

- If you wish to use a remote controller that is not listed in Table 1, select a suitable remote controller after consulting catalogs and technical materials.

FOR THE FOLLOWING ITEMS, TAKE SPECIAL CARE DURING CONSTRUCTION AND CHECK AFTER INSTALLATION IS FINISHED.

a. Items to be checked after completion of work

Items to be checked	If not properly done, what is likely to occur.	Check
Are the indoor and outdoor unit fixed firmly?	The units may drop, vibrate or make noise.	
Was the installation of the outdoor unit completed?	The unit may malfunction or the components burn out.	
Is the gas leak test finished?	No cooling or heating.	
Is the unit fully insulated? (Refrigerant piping, drain piping, and duct)	Condensate water may drip.	
Dose drainage flow smoothly?	Condensate water may drip.	
Does the power supply voltage conform to the indication on the name plate?	The unit may malfunction or the components burn out.	
Are wiring and piping correct?	The unit may malfunction or the components burn out.	
Is the air conditioner properly grounded?	Dangerous in case of current leakage.	
Is wiring size according to specifications?	The unit may malfunction or the components burn out.	
Is something blocking the air outlet or inlet of either the indoor or outdoor units?	No cooling or heating.	
Did you set the external static pressure?	No cooling or heating.	
Are refrigerant piping length and additional refrigerant charge noted down?	The refrigerant charge in the system is not clear.	
Did you check that no wiring connection screws were loose?	Electric shock or fire.	

Also review the “SAFETY PRECAUTIONS”.

b. Items to be checked at time of delivery

Items to be checked	Check
Are you sure the control box lid, air filter, air inlet grille, and air outlet grille are mounted?	
Did you explain about operations while showing the operation manual to your customer?	
Did you deliver the operation manual along with the installation manual to the customer?	
Did you explain the customer the handling and cleaning methods of the field supplies (e.g., the air filter, air inlet grilles, and air outlet grille)?	
Did you deliver instruction manual, if any, for the field supplies to the customer?	

c. Points for explanation about operations

The items with ⚠WARNING and ⚠CAUTION marks in the operation manual are the items pertaining to possibilities for bodily injury and material damage in addition to the general usage of the product. Accordingly, it is necessary that you make a full explanation about the described contents and also ask your customers to read the operation manual.

2-4 NOTE TO INSTALLER

- Be sure to instruct customers how to properly operate the unit (especially cleaning filters, operating different functions, and adjusting the temperature) by having them carry out operations themselves while looking at the manual.

3. SELECTING INSTALLATION SITE

〈**Hold the hanging brackets in the case of moving the indoor and outdoor units at the time of and after opening the packages. Do not impose undue force on other parts, such as the refrigerant piping, drain piping, or flanges, in particular.**〉
〈**Add heat insulation material to the indoor unit if the temperature above the ceiling is likely to exceed 30˚C and a relative humidity of 80%.**〉
〈**Make sure that the insulation material is made of glass wool or polyethylene foam, has a minimum thickness of 10 mm, and can be accommodated in the opening on the ceiling.**〉

(1) Select an installation site where the following conditions are fulfilled and that meets with your customer’s approval.
- A place where cool (warm) air is delivered to the entire room.
- Where nothing blocks the air passage.
- Where condensate can be properly drained.
- If supporting structural members are not strong enough to take the unit’s weight, the unit could fall out of place abd cause serious injury.
- Where the false ceiling is not noticeably on an incline.
- Where there is no risk of flammable gas leakage.
- Where sufficient clearance for maintenance and service can be ensured. **(Refer to Fig. 2-1)**
- Where piping between indoor and outdoor units is possible within the allowable limit. (Refer to the installation manual of the outdoor unit.)


⚠ CAUTION

- Install the indoor and outdoor units, power supply wiring and connecting wires at least 1 meter away from televisions or radios in order to prevent image interference or noise. (Depending on the radio waves, a distance of 1 meter may not be sufficient enough to eliminate the noise.)

- In the case of the installation of a wireless remote controller, the transmission distance of the wireless remote controller may be shortened if the room has a fluorescent light of electronic lighting type (i.e., an inverter or rapid-start fluorescent light). Keep the distance between the receiver and the fluorescent light as far as possible.

(2) Use hanging bolts to install the indoor unit. Check that the place of installation withstands the weight of the indoor unit. Secure the hanging bolts with proper beams if necessary.

(length: mm)



- The H1 dimension indicates the height of the product.
- Determine the H2 dimension by maintaining a downward slope of at least 1/100 as specified in "7. DRAIN PIPING WORK".

[Required installation place]

The dimensions indicate the minimum required space of installation.

Fig. 2-1

4. PREPARATIONS BEFORE INSTALLATION

(1) Check the positional relationship between the ceiling opening hole and the hanging bolt of the unit.
- For the maintenance, inspection, and other servicing purposes of the control box and drain pump, prepare one of the following service spaces.
  1. Inspection hatch 1 (450 × 450) for the control box and a minimum space of 300 mm for the lower part of the product. **(Refer to Fig. 2-2)**
  2. Inspection hatch 1 (450 × 450) for the control box and inspection hatch 2 for the lower part of the product (see axial direction view A-1). **(Refer to Fig. 2-3)**
  3. Inspection hatch 3 for the lower part of the product and the lower part of the control box (see axial direction view A-2). **(Refer to Fig. 2-3)**

Case 1





Fig. 2-2

Case 2, 3



Axial direction view A-1

Axial direction view A-2

Fig. 2-3

- Determine the H3 dimension by maintaining a downward slope of at least 1/100 as specified in "7. DRAIN PIPING WORK".

Model	B	C	D
20 • 25 • 32 type	550	583	850
40 type	700	738	1000
50 • 63 • 80 type	1000	1038	1300
100 • 125 type	1400	1438	1700


(length: mm)

(2) Mount the canvas ducts to the air outlet and inlet so that the vibration of the air conditioner will not be transmitted to the duct or ceiling. Apply a sound-absorbing material (insulation material) to the inner wall of the duct and vibration insulation rubber to the hanging bolts (refer to **8. DUCT WORK**).

(3) Open installation holes (if the ceiling already exists).
- Open the installation holes on the ceiling. Lay the refrigerant piping, drain piping, power line, transmission wiring, and remote controller wiring for the piping and wiring connection port of the unit.
  In the case of the installation of a wireless remote controller, refer to the installation manual provided with the wireless remote controller.
  Refer to **6. REFRIGERANT PIPING WORK**, **7. DRAIN PIPING WORK**, and **10. WIRING EXAMPLE AND HOW TO SET THE REMOTE CONTROLLER**.
- The ceiling framework may need reinforcement in order to keep the ceiling horizontal and prevent the vibration of the ceiling after the installation holes are opened. For details, consult your construction or interior contractor.

(4) Install the hanging bolts. Make sure that the hanging bolts are M10 in size.
- Use hole-in anchors if the hanging bolts already exist; otherwise use embedded inserts and embedded foundation bolts so that they will withstand the weight of the unit. Adjust the distance to the ceiling surface in advance.

〈 Installation example 〉



Note) All the above parts are field supplied.


5. INDOOR UNIT INSTALLATION

〈It may be easier to install accessories (sold separately) before installing the indoor unit. Refer to the installation manuals provided to the accessories as well.〉

Be sure to use the accessories and specified parts for installation work.

(1) Temporally install the indoor unit.
- Connect the hanging brackets to the hanging bolts. Be sure to use and tighten the nut and washer (11) for each hanging bracket from both upper and lower sides of the hanging bracket. **(Refer to Fig. 3)** At that time, the fall of the washer (11) for the hanging bracket can be prevented if the washing fixing plate (9) is used.

[Fixing hanging brackets]



[Fixing method of washers]





Fig. 3

⚠ CAUTION

- **During the installation work, perform the curing of the air outlet and protect the resin drain pan of the indoor unit from the intrusion of foreign substances, such as welding spatters.**
  Otherwise, water leakage may occur as a result of damage, such as hole damage, to the resin drain pan.

(2) Make adjustments so that the unit will be in the right position.
(3) Check the level of the unit.
(4) Remove the washer fixing plates for the falling prevention of the washers for the hanging brackets, tighten the nuts on the upper side, and securely fix the unit.



⚠ CAUTION

- Use the level and check that the unit is installed horizontally. (4-directions)
- In the case of using a vinyl tube in place of the level, put the both edges of the vinyl tube in close contact with the bottom of the product to make levelness adjustment.
  If the unit is installed at a slant with the drain pipe side set high, in particular, the float switch will not operate normally and water leakage may result.

6. REFRIGERANT PIPING WORK

〈As for the refrigerant piping of the outdoor unit, refer to the installation manual provided to the outdoor unit.〉
〈Perform heat insulation work on both gas piping and liquid piping, or otherwise water leakage may result.〉
〈Use the insulation material that withstands a temperature of 120˚C.〉
〈Reinforce the insulation material for the refrigerant piping if the ambient temperature is high, or otherwise dew condensation may result on the surface of the insulation material.〉
〈Make sure that the refrigerant is R410A before refrigerant piping work. If the refrigerant is different, the air conditioner will not operate normally.〉

⚠ CAUTION

This product uses new refrigerant (R410A) only. Be sure to keep the items on the right-hand side and conduct the installation work.
- **Use a dedicated pipe cutter and flare tool for R410A.**
- **When connecting the flare, apply ether oil or ester oil only to inner side of the flare.**
- **Be sure to use the flare nut provided with the unit. (Do not use a different flare nut (such as a type-1 flare nut), or otherwise refrigerant leakage may result.)**
- **Perform the curing of the piping with pinching or taping of the piping in order to prevent the intrusion of dirt, dust, and moisture into the piping.**

⚠ CAUTION

- **Be sure to use the specified type of refrigerant for the refrigeration cycle and do not contaminate the refrigerant with air.**
- **Ventilate the room in case of refrigerant leakage during installation work.**

(1) Connect the piping.
- The outdoor unit is filled with refrigerant.
- When connecting or disconnecting piping to or from the unit, **be sure to use two spanners and two torque wrenches. (Refer to Fig. 4)**




Fig. 4

- Refer to Table 2 for the processing dimensions of the flare.
- Use the flare nut provided with the unit.
- **Apply ether oil or ester oil only to inner side of the flare** and screw in the flare nut three to four turns first by hand at the time of connecting the flare nut. **(Refer to Fig. 5)**





Fig. 5

- Refer to Table 2 for the corresponding tightening torque.

Table 2

Pipe size	Tightening torque	Flare dimensions A (mm)	Flare shape
ϕ 6.4	14.2 – 17.2N·m	8.7 – 9.1	
ϕ 9.5	32.7 – 39.9N·m	12.8 – 13.2	
ϕ 12.7	49.5 – 60.3N·m	16.2 – 16.6	
ϕ 15.9	61.8 – 75.4N·m	19.3 – 19.7	

⚠ CAUTION

- **Do not excessively tighten the flare nut.**
  Doing so will break the flare nut and refrigerant leakage may result.
- **Make sure that all parts around the flare are free of oil.**
  The drain pan and the resin part may be deteriorated if oil is attached.

- If no torque wrenches are available, refer to Table 3 as a standard.
  When the flare nut is tightened with the spanner, the tightening torque should increase suddenly. Tighten the flare nut further for the corresponding angle shown in Table 3.

Table 3

Pipe size	Further tightening angle	Recommended arm length of tool
ϕ 6.4	60 to 90 degrees	Approx. 150mm
ϕ 9.5	60 to 90 degrees	Approx. 200mm
ϕ 12.7	30 to 60 degrees	Approx. 250mm
ϕ 15.9	30 to 60 degrees	Approx. 300mm

(2) On completion of installation work, **check that there is no gas leakage**.

(3) Refer to the illustration on the right-hand side and be sure to perform heat insulation work on the piping joints after gas leakage checks. **(Refer to Fig. 6)**




Fig. 6

- Use the insulation for fitting (4) and (5) provided to the liquid piping and gas piping, respectively, and conduct heat insulation work.
  (Tighten both edges of the insulation for fitting (4) and (5) for each joint with the clamp (8).)
- Make sure that the joint of the insulation for fitting (4) and (5) for the joint on the liquid piping and gas piping side faces upward.
- Wrap the middle sealing material (7) around the insulation for fitting (4) and (5) for the joint (flare nut part).

⚠ CAUTION

- **Be sure to perform the heat insulation of the local piping up to the piping joint.**
  If the piping is exposed, dew condensation may result. Furthermore, a burn may be caused if a human body comes in contact with the piping.

- Perform nitrogen substituent or apply nitrogen into the refrigerant piping (see NOTE 1) in the case of refrigerant piping blazing (see NOTE 2). Then perform the flare connection of the indoor unit. **(Refer to Fig. 7)**




Fig. 7

⚠ CAUTION

- **Do not use any antioxidant at the time of piping blazing.** The piping may be clogged with a residual antioxidant and parts may malfunction.


NOTE

1. At the time of blazing, set the pressure of nitrogen to approximately 0.02 MPa (close to the pressure of a breeze coming in contact with the cheek) with a decompression valve.
2. Do not use flux at the time of blazing and connecting the refrigerant piping. Use a copper phosphorus brazing alloy (BCuP-2: JIS Z 3264/BCu 93P-710/795: ISO3677), which does not require flux, for blazing.
   (Flux has a bad influence on the refrigerant piping. Chlorine-based flux will cause piping corrosion. Furthermore, if it contains fluorine, the flux will deteriorate refrigerant oil.)

- As for the branching of the refrigerant piping or refrigerant, refer to the installation manual provided with the outdoor unit.

7. DRAIN PIPING WORK

(1) Conduct drain piping work.
Check that the piping ensures proper draining.




- Make sure that the diameter of the piping excluding the rising part is the same as or larger than the diameter of the connecting pipe (vinyl chloride pipe with an outer diameter of 32 mm and a nominal inner diameter of 25 mm).
- Make sure that the piping is short enough **with a downward slope of at least 1/100** and that there is no air bank formed. No drain trap is required.


⚠ CAUTION

- The drain piping will be clogged with water and water leakage may result if the water is accumulated in the drain piping.

- Conduct drain-up piping work if the gradient is insufficient.
- Attach a support bracket at 1 to 1.5 m intervals for the prevention of piping deflection.




- Be sure to use the drain hose (2) and metal clamp (1). **Insert the drain hose (2) deep into the base of the drain socket, and securely fasten the metal clamp (1) within the taped part on the insertion front end of the hose.**
  Be sure to fasten the screw of the metal clamp (1) until the margin of the screw thread decreases to 4 mm or less.




NOTE

Be sure to follow the instructions as below.

- Do not connect the drain piping directly to a sewer that smells of ammonia.
  The ammonia in the sewer may reach through the drain piping and corrode the heat exchanger of the indoor unit.
- Do not bend or twist the provided drain hose (2) in order not to impose excessive force on the hose. (Doing so may result in water leakage.)
- Take the procedure shown in the following illustration to perform concentrated drain piping.



- Select the diameter of the concentrated drain piping to suit the capacity of equipment connecting to the concentrated drain piping (see the equipment design sheet).



7

(2) Check the smooth draining of the piping on completion of the installation of the piping.

[Before electrical work]

⚠ CAUTION

- **A licensed electrical engineering technician must conduct electrical wiring work (including grounding work).**
- **If no licensed electrical engineering technician is available, take steps 3 and 4 after the test operation of the air conditioner is finished.**

1. Remove the control box lid, **and connect the single-phase electric wires to terminals L and N of the terminal block and the ground wire to the ground terminal**. Perform wiring according to **10-1 CONNECTING POWER SUPPLY, GROUND, REMOTE CONTROLLER, AND TRANSMISSION WIRING** in **10. WIRING EXAMPLE AND HOW TO SET THE REMOTE CONTROLLER**.

⚠ CAUTION

- In order not to impose tension on the wire connections, perform clamping securely with the provided clamp (8) specified in 3 in **10-1 CONNECTING POWER SUPPLY, GROUND, REMOTE CONTROLLER, AND TRANSMISSION WIRING**.

2. Check that the control box lid is closed before turning the air conditioner ON.
3. Provide **approximately one liter of water** gradually into the drain pan through the water inlet on the bottom of the drain socket or the outlet. Make sure that the water is not spilled onto the drain pump.
4. The drain pump will operate with the power turned ON. Check that the pump drains water smoothly. (The drain pump will stop automatically in 10 minutes.)
   The drainage can be checked with the water level change in the drain pan through the water inlet.

⚠ CAUTION


- **Do not touch the drain pump.**
  Otherwise, an electric shock may be received.
- **Do not impose external force on the float switch.**
  Otherwise, a failure may result.

5. On completion of the drainage check, shut off the power supply and disconnect the power supply line.
6. Put the control box lid to the original position.


[After electrical work]

- After completion of **8. DUCT WORK** provide **approximately one liter of water** gradually into the drain pan through the water inlet on the bottom of the drain socket, and check that the water is drained while the air conditioner is in cooling operation according to **11. FIELD SETTING** and **12. TEST OPERATION** . Make sure that the water is not spilled onto the electric parts of the drain pump and others.

(3) Be sure to conduct heat insulation work on the following portions, or otherwise water leakage may occur as a result of dew condensation.
- **Drain piping indoors**
- **Drain socket**



- On completion of the drainage check, refer to the following illustration, and use the provided large sealing pad (6) and heat insulate the metal clamp (1) and drain hose (2).




8. DUCT WORK

Pay the utmost attention to the following items and conduct the ductwork.

- Check that the duct will not be in excess of the setting range of external static pressure for the unit. (Refer to the technical datasheet for the setting range.)
- Attach a canvas duct each to the air outlet and air inlet so that the vibration of the equipment will not be transmitted to the duct or ceiling.
  Use a sound-absorbing material (insulation material) for the lining of the duct and apply vibration insulation rubber to the hanging bolts.
- At the time of duct welding, perform the curing of the duct so that the sputter will not come in contact with the drain pan for the filter.
- If the metal duct pass through a metal lath, wire lath, or metal plate of a wooden structure, separate the duct and wall electrically.
- Be sure to heat insulate the duct for the prevention of dew condensation. (Material: Glass wool or styrene foam; Thickness: 25 mm)
- Be sure to attach the field supply air filter to the air inlet of the unit or field supply inlet in the air passage on the air suction side. (Be sure to select an air filter with a duct collection efficiency of 50 weight percent.)
- Explain the operation and washing methods of the locally procured components (i.e., the air filter, air inlet grille, and air outlet grille) to the customer.
- Locate the air outlet grille on the indoor side for the prevention of drafts in a position where indirect contact with people.
- The air conditioner incorporates a function to adjust the fan to rated speed automatically. **(11. FIELD SETTING)**
  Therefore, do not use booster fans midway in the duct.

Connection method of ducts on air inlet and outlet sides.

- Connect the field supply duct in alignment with the inner side of the flange.
- Connect the flange and unit with the flange connection screw (3).
- Wrap aluminum tape around the flange and duct joint in order to prevent air leakage.



⚠ CAUTION

Connect the flange and unit with the flange connection screw (3) regardless of whether the duct is connected to the air inlet side.

9. ELECTRIC WIRING WORK

9-1 GENERAL INSTRUCTIONS

- All field supplied parts and materials and electric works must conform to local codes.
- Use copper wire only.
- For electric wiring work, refer to also “Wiring diagram” attached to the control box lid.
- For remote controller wiring details, refer to the installation manual attached to the remote controller.
- All wiring must be performed by an authorized electrician.
- This system consists of multiple indoor units. Mark each indoor unit as unit A, unit B..., and be sure the terminal board wiring to the outdoor unit and BS unit are properly matched. If wiring and piping between the outdoor unit and an indoor unit are mismatched, the system may cause a malfunction.
- A circuit breaker capable of shutting down power supply to the entire system must be installed.
- Refer to the installation manual attached to the outdoor unit for the size of power supply wiring connected to the outdoor unit, the capacity of the circuit breaker and switch, and wiring instructions.
- Be sure to ground the air conditioner.
- Do not connect the ground wire to gas and water pipes, lightning rods, or telephone ground wires.
  - Gas pipes : might cause explosions or fire if gas leaks.
  - Water pipes : no grounding effect if hard vinyl piping is used.
  - Telephone ground wires or lightning rods : might cause abnormally high electric potential in the ground during lighting storms.

9-2 ELECTRICAL CHARACTERISTICS

Units				Power supply		Fan motor	
Model	Hz	Volts	Voltage range	MCA	MFA	kW	FLA
FXMQ20PVE	50	220-240	Max. 264 Min. 198	0.6	16	0.09	0.5
FXMQ25PVE				0.6	16	0.09	0.5
FXMQ32PVE				0.6	16	0.09	0.5
FXMQ40PVE				1.4	16	0.140	1.1
FXMQ50PVE				1.6	16	0.350	1.3
FXMQ63PVE				1.8	16	0.350	1.4
FXMQ80PVE				2.3	16	0.350	1.8
FXMQ100PVE				2.9	16	0.350	2.3
FXMQ125PVE				3.4	16	0.350	2.7
FXMQ20PVE	60	220	Max. 242 Min. 198	0.6	16	0.09	0.5
FXMQ25PVE				0.6	16	0.09	0.5
FXMQ32PVE				0.6	16	0.09	0.5
FXMQ40PVE				1.4	16	0.140	1.1
FXMQ50PVE				1.6	16	0.350	1.3
FXMQ63PVE				1.8	16	0.350	1.4
FXMQ80PVE				2.3	16	0.350	1.8
FXMQ100PVE				2.9	16	0.350	2.3
FXMQ125PVE				3.4	16	0.350	2.7

MCA: Min. Circuit Amps (A); MFA: Max. Fuse Amps (A)
kW: Fan Motor Rated Output (kW); FLA: Full Load Amps (A)

9-3 SPECIFICATIONS FOR FIELD SUPPLIED FUSES AND WIRE

Model	Power supply wiring			Remote controller wiring Transmission wiring	
	Field fuses	Wire	Size	Wire	Size
FXMQ20PVE	16A	H05VV-U3G	Size must comply with local codes.	Sheathed wire (2 wire)	0.75 - 1.25 mm²
FXMQ25PVE					
FXMQ32PVE					
FXMQ40PVE					
FXMQ50PVE					
FXMQ63PVE					
FXMQ80PVE					
FXMQ100PVE					
FXMQ125PVE					

Allowable length of transmission wirings and remote controller wiring are as follows.

(1) Outdoor unit – Indoor unit:
Max. 1000 m (Total wiring length: 2000 m)

(2) Indoor unit – Remote controller:
Max. 500 m

NOTE


1. Shows only in case of protected pipes. Use H07RN-F in case of no protection.
2. Vinyl cord with sheath or cable (Insulated thickness : 1mm or more)

10. WIRING EXAMPLE AND HOW TO SET THE REMOTE CONTROLLER


10-1 CONNECTING POWER SUPPLY, GROUND, REMOTE CONTROLLER, AND TRANSMISSION WIRING

(Remove the control box lid as shown below and connect each wire.)

(1) Remove the control box lid.




(2) Lay the wires in the control box through the wire inlet on the side of the control box.



⚠ CAUTION

- Do not lay the remote controller wiring or transmission wiring along with the power supply wiring or other electric wiring in the same route. Separate the remote controller wiring and transmission wiring at least 50 mm from the power supply wiring or other electric wiring, or otherwise malfunctions or failures may be caused by external electric noise that may interfere with the remote controller wiring and transmission wiring.
- For the installation and wiring of the remote controlle r, refer to the remote controller installation manual provided with the remote controller.
- For power supply wiring, refer to the wiring diagram as well.
- Be sure to connect the remote controller wiring and transmission wiring correctly to the right terminal block.

(3) Follow the instructions below, and lay the wires in the control box.




⚠ WARNING

Trim and lay the wiring neatly and attach the control box lid securely.

An electric shock or fire may result if the control box lid catches any wiring or the wires push up the lid.


(4) Put the control box lid, and wrap the wire sealing material (Small) (10) around the wires so as to block the wire through holes.



⚠ CAUTION


- After all the wiring connections are done, fill in any gaps in the through holes with putty or insulation (procured locally) to prevent small animals and insects from entering the unit from outside. (If any do get in, they could cause short circuits in the control box.)

(5) Mount the provided wire fixing bracket (12) with the wire fixing screw (13). Fix each wire with the provided clamp (8).




[Precautions for Power Supply Wiring]

- Connect round crimp-style terminals provided with insulation sleeves to the terminal block for power supply.



Be sure to follow the instructions provided below if the specified terminals cannot be used.
Otherwise, abnormal heat may be generated as a result of the loosening of the wires.



- If stranded wires are used, do not solder the front end of the wires.
- Connect proper wires securely and fix the wires so that external force will not be imposed on the terminals.
- Use an appropriate screwdriver to tighten the terminal screws. The screw heads may be damaged if the screwdriver is too small and the terminal screws will not be tightened properly.
- Do not tighten the terminal screws excessively, or otherwise the screw heads may be damaged.
- Refer to the table below for the required tightening torque values of the terminal screws.


	Tightening torque (N·m)
Terminal block for remote controller and transmission wires	0.80 - 0.96
Terminal block for power supply	1.18 - 1.44

10-2 WIRING EXAMPLE


⚠ WARNING

Install an earth leakage breaker.
The installation of an earth leakage breaker is imperative for the prevention of electric shocks and fire accidents.

No. 1 system: When using 1 remote controller for 1 indoor unit




No. 2 system: For group control or use with 2 remote controllers



7

No. 3 system: When including BS unit



[PRECAUTIONS]


1. If no earth leakage breaker is required, install a breaker or load switch with a fuse for the wiring. If an earth leakage breaker is required, make sure that the earth leakage breaker is designed to protect the air conditioner from ground faults, overloads, and short-circuiting.
2. The remote controller wiring (P1 and P2) and transmission wiring (F1 and F2) have no polarity.

10-3 CONTROL BY 2 REMOTE CONTROLLERS (Controlling 1 indoor unit by 2 remote controllers)


- Set one of the remote controllers to main and the other to sub in the case of remote control with two remote controllers.

Switching Main/Sub

(1) Insert a ⊖ screwdriver into the clearance between the grooves of the lower casing and the upper casing to remove the upper casing. (2 grooves) (The remote controller PCB is attached to the upper casing.)




(2) Set the main/sub switch on one of the remote controller PCBs to sub. (Keep the switch of the other remote controller PCB set to main.)



10-4 COMPUTERISED CONTROL (FORCED OFF AND ON/OFF OPERATION)

(1) Wire specifications and how to perform wiring
- Connect the input from outside to terminals T1 and T2 of the terminal block for remote controller.



Wire specification	Sheathed vinyl cord or cable (2 wire)
Gauge	0.75 - 1.25 mm^2
Length	Max. 100 m
External terminal	Contact that can ensure the minimum applicable load of 15 V DC, 10 mA.

(2) Actuation
- The following table explains FORCED OFF and ON/OFF OPERATIONS in response to Input A.

FORCED OFF	ON/OFF OPERATION
Input "ON" stops operation (impossible by remote controllers.)	Input OFF → ON turns ON unit.
Input OFF enables control by remote controller.	Input ON → OFF turns OFF unit.

(3) How to select FORCED OFF and ON/OFF OPERATION
- Turn the power on and then use the remote controller to select operation.

10-5 CENTRALIZED CONTROL

- For centralized control, it is necessary to designate the group No. For details, refer to the manual of each optional controllers for centralized control.

11. FIELD SETTING


NOTE

- Before the test operation of the outdoor unit as explained in **12. TEST OPERATION**, be sure to make the following field settings as explained in **11. FIELD SETTING**.

Make sure the control box lids are closed on the indoor and outdoor units.
Field setting must be made from the remote controller in accordance with the installation condition.

- Setting can be made by changing the "MODE NO.", "FIRST CODE NO.", and "SECOND CODE NO.".

- For setting and operation, refer to the “FIELD SETTING” in the installation manual of the remote controller.



  - Set the remote controller to the “FIELD SET MODE”. For details, refer to the “HOW TO SET IN THE FIELD”, in the remote controller manual.
  - When in the “FIELD SET MODE”, select “MODE NO. 12” , then set the “FIRST CODE NO.” to “1”. Then set “SECOND CODE NO.” to “01” for FORCED OFF and “02” for ON/OFF OPERATION. (FORCED OFF at factory set)

With Wireless Remote Controller Used

Set the wireless remote controller address before using the wireless remote controller.
For the setting method of the address, refer to the operation manual provided with the wireless remote controller.

NOTE

- A “MODE NO.” is set on a group basis. To make a mode setting on a room unit basis or check the setting made, however, set the corresponding mode number in the parentheses.

1. Settings for Optional Accessories

- In the case of connecting optional accessories, refer to the operation manuals provided with the optional accessories and make necessary settings.

2. External Static Pressure Settings

Make settings in either method (a) or method (b) as explained below.

(a) Use the airflow auto adjustment function to make settings.
Airflow auto adjustment: The volume of blow-off air is automatically adjusted to the rated quantity.

(1) Check that power supply wiring to the air conditioner is completed along with duct installation. If a closing damper is installed in the air-conditioning system, make sure that the closing damper is opened. Furthermore, check that the air filter as a field supply is attached to the air passage on the suction side.

(2) If there are a number of air outlets and inlets, adjust the throttles so that the airflow rate of each air outlet and inlet will coincide with the designed airflow rate. At that time, operate the air conditioner in “fan operation mode”. To change the airflow rate, press and set the airflow adjustment button of the remote controller to HH, H, or L.

(3) Make settings for airflow automatic adjustment. After setting the air conditioner to “fan operation mode”, stop the air conditioner, go to “FIELD SET MODE”, select “MODE NO. 21” (11 in the case of group settings), set the setting “FIRST CODE NO.” to 7, and set the setting “SECOND CODE NO.” to 03.
Return to normal mode after these settings, and press the ON/OFF OPERATION button. Then the operation lamp will be lit and the air conditioner will go into fan operation for airflow automatic adjustment. Do not adjust the throttles of the air outlets or inlets during automatic adjustment of the air conditioner. After the air conditioner runs approximately one to eight minutes, the air conditioner will finish airflow adjustment automatically, the operation lamp will be turned OFF, and the air conditioner will come to a stop.

Table 4

MODE NO.	FIRST CODE NO.	Setting contents
11 (**21**)	7	Airflow adjustment
SECOND CODE NO.		
01	02	03
OFF	Completion of airflow adjustment	Start of airflow adjustment

(4) After the air conditioner stops operating, check with “MODE NO. 21” on an indoor unit basis that 02 is set for the “SECOND CODE NO.” in Table 4. If the air conditioner does not stop operating automatically or the “SECOND CODE NO.” is not 02, repeat steps from (3). If the outdoor unit is not turned ON, U4 or UH as explained in Table 8 will be displayed. This display is not problematic, because this function is set for the indoor unit. Continue setting the function.
After setting this function, be sure to turn ON the outdoor unit before the test operation of the outdoor unit.
If any other error is displayed, refer to Table 8 and the operation manual provided with the outdoor unit and check the defective point.

⚠ CAUTION

- If there is any change after airflow adjustment in the ventilation paths (e.g., the duct and air outlet), be sure to make airflow auto adjustment again.
- Consult your Daikin representative if there is any change in the ventilation paths (e.g., the duct and air outlet) after the test operation of the outdoor unit is finished or the air conditioner is moved to another place.

(b) Select External Static Pressure with Remote Controller
Check that 01 (OFF) is set for the “SECOND CODE NO.” in “MODE NO. 21” for airflow adjustment on an indoor unit basis in Table 4. The “SECOND CODE NO.” is set to 01 (OFF) at factory set. Change the “SECOND CODE NO.” as shown in Table 5 according to the external static pressure of the duct to be connected.

(1) The “SECOND CODE NO.” is set to 07 (an external static pressure of 100 Pa) at factory set. (FXMQ40 · 50 · 63 · 80 · 100 · 125PVE)
The “SECOND CODE NO.” is set to 02 (an external static pressure of 50 Pa) at factory set. (FXMQ20 · 25 · 32PVE)

*1 The FXMQ50 · 63 · 80 · 100 · 125PVE cannot be set to 30 Pa.
*2 The FXMQ40PVE cannot be set to 180 or 200 Pa.
*3 The FXMQ20 · 25 · 32PVE cannot be set to 110-200 Pa.

7

Table 5

External Static Pressure	MODE NO.	FIRST CODE NO.	SECOND CODE NO.
30Pa (*1)	13 (23)	06	01
50Pa			02
60Pa			03
70Pa			04
80Pa			05
90Pa			06
100Pa			07
110Pa (*3)			08
120Pa (*3)			09
130Pa (*3)			10
140Pa (*3)			11
150Pa (*3)			12
160Pa (*3)			13
180Pa (*2)(*3)			14
200Pa (*2)(*3)			15

⚠ CAUTION

Keep in mind that a shortage of airflow quantity or water leakage will result because the air conditioner will be operated outside the rated range of airflow quantity if the external static pressure is wrongly set.

3. Filter Sign Settings

- The remote controller is provided with an LCD that tells the time of air filter cleaning.
- If the air conditioner is used in places with excessive dust, change the "SECOND CODE NO." as shown in Table 6. The "SECOND CODE NO." is set to 01 (standard) at factory set.

Table 6

Dirt	Time for display	MODE NO.	FIRST CODE NO.	SECOND CODE NO.
Standard	Approximately 2500 hours	10 (20)	0	01
Excessive dust	Approximately 1250 hours			02
No display (*)			3	

* Select "No display" under conditions in which the cleaning display is not required, such as the time of regular maintenance.

12. TEST OPERATION

Refer to the installation manual of the outdoor unit.

- The operation lamp of the remote controller will flash when an malfunction occurs. Check the malfunction code on the liquid crystal display to identify the point of trouble. An explanation of malfunction codes and the corresponding trouble is provided in "CAUTION FOR SERVICING" of the outdoor unit. If any of the items in Table 8 are displayed, there may be a problem with the wiring or power, so check the wiring again.

Table 7

Remote controller display	Contents
"A8" lit	Error in power supply voltage to indoor unit.
"C1" lit	Fan driver PCB of indoor unit ↔ indoor control PCB transmission error.
"C6" lit	Improper combination of fan driver PCB of indoor unit or setting failure in control PCB type.
"U3" lit	Test operation of outdoor unit has not been finished.

Table 8

Remote control display	Content
"⚠" is lit up	• There is a short circuit at the FORCED OFF terminals (T1, T2)
"U4" is lit up "UH" is lit up	• The power on the outdoor unit is off. • The outdoor unit has not been wired for power supply. • Incorrect wiring for the transmission wiring and / or FORCED OFF wiring.
No display	• The power on the indoor unit is off. • The indoor unit has not been wired for power supply. • Incorrect wiring for the remote controller wiring, the transmission wiring and / or the FORCED OFF wiring.

⚠ CAUTION

If interior finish work is continuing on completion of the test operation of the air conditioner, explain the customer not to operate the air conditioner until the interior finish work is completed for the protection of the air conditioner.
Otherwise, substances that will be generated from interior finish work materials, such as paint and adhesive agents, may contaminate the air conditioner.

12. Accessories

Standard Accessories
FXMQ20~125P

Name	Metal clamp (1)	Drain hose (2)	Screws for duct flanges (3)	Insulation for fitting	Sealing pad	Clamp (8)	Washer fixing plate (9)	Wire sealing material (10)
Quantity	1 pc.	1 pc.	As described in table below	1 each	–	9 pcs.	4 pcs.	2 pcs.
Shape			 M5×16 20 • 25 • 32 type: 6 40 type: 10 50 • 63 • 80 type: 18 100 • 125 type: 26	 Thin for liquid pipe (4)  Thick for gas pipe (5)	 1 pc. Large (Dark gray) (6)  2 pcs. Middle (Dark gray) (7)			 Small (Gray)

Name	Washer (11)	Wire fixing bracket (12)	Wire fixing screw (13)	(Other)
Quantity	8 pcs.	2 pcs.	2 pcs.	• Operation manual • Installation manual
Shape			M4×8 	

3PN06583-7L

Optional Accessories (For Unit)

Item \ Type		FXMQ20PVE	FXMQ25PVE	FXMQ32PVE	FXMQ40P	FXMQ50P	FXMQ63P	FXMQ80P	FXMQ100P	FXMQ125P
High efficiency filter	65%	KAF372AA36			KAF372AA56	KAF372AA80			KAF372AA160	
	90%	KAF373AA36			KAF373AA56	KAF373AA80			KAF373AA160	
Filter chamber		KDDF37AA36			KDDF37AA56	KDDF37AA80			KDDF37AA160	
Long life replacement filter		KAF371AA36			KAF371AA56	KAF371AA80			KAF371AA160	
Service panel		KTBJ25K36W			KTBJ25K56W	KTBJ25K80W			KTBJ25K160W	
		KTBJ25K36F			KTBJ25K56F	KTBJ25K80F			KTBJ25K160F	
		KTBJ25K36T			KTBJ25K56T	KTBJ25K80T			KTBJ25K160T	
Air discharge adapter		KDAJ25K36A			KDAJ25K56A	KDAJ25K71A			KDAJ25K140A	

3D060443B


Optional Accessories (For Controls) : Refer to P.807

KTBJ25K36·56·80·160W — Service Access Panel

KTBJ25K80W



Dimensions **Unit:mm**



Model	A	Ceiling opening
KTBJ25K36W(T)(F)	626	606 × 680
KTBJ25K56W(T)(F)	776	756 × 680
KTBJ25K80W(T)(F)	1,076	1,056 × 680
KTBJ25K160W(T)(F)	1,476	1,456 × 680

- The inspection hatch can be made to look nice with the service access panel.
- Thin 10 mm design for the exposed part.

Item \ Model		KTBJ25K36W(T)(F)	KTBJ25K56W(T)(F)	KTBJ25K80W(T)(F)	KTBJ25K160W(T)(F)
Main applicable models		20~32 Class	40 · 50 Class	63 · 80 Class	100 · 125 Class
Color		W : White, T : Brown, F : Fresh white			
Accessories		Installation manual			
Mass (weight)	kg	6.0	6.5	9.0	10.7

Caution

- Ceiling joist and ceiling joist support required. (Locally procured.)

Installation

DAIKIN

AIR CONDITIONER

Directions for Mounting Access Panels


READ THESE INSTRUCTIONS CAREFULLY BEFORE INSTALLATION.

●KEEP THIS MANUAL IN A HANDY PLACE FOR FUTURE REFERENCE.

Before Mounting the Panel


1. Prepare an opening on the ceiling.

Duct Type



kit No.	A
KTBJ25K36	606
KTBJ25K56 KTB25KA56	756
KTBJ25K80 KTB25KA80	1056
KTBJ25K160 KTB25KA160	1456

2. Mount the ceiling structure guide on the edge of the ceiling structure.



Service Works for Duct Type Models


Service works for maintenance shall be done (accessed) from the ※ space (the above).
Please prepare short-length screw drivers (100mm or less.)

C : 3P225173A


7

Mounting the Panel


1. Remove the inside frame assembly.
   - Turn the lock 90° to the left with a flat-top screw driver or a coin to open the inside frame assembly.



2. Mount the outside frame assembly on the ceiling.
   - Fasten the frame assembly to the ceiling and the guide with metal fittings and wing nuts.



3. Mount the inside frame assembly to the fixed outside frame assembly.



Mounting of Ceiling Materials


Ceiling materials can be optionaly mounted to the inside frame assembly.
Mounting methods are as follows:-

① Remove the decorative panel fixing metal of the inside frame assembly.

② Take out the decorative panel and mount the ceiling materials instead.

③ Put back the fixing metal (①) to hold the ceiling materials.

(Note) Decorative panel is not required when mounting ceiling materials.



3P225173A

KDAJ25K36·56·71·140A — Air Discharge Adaptor


KDAJ25K71A



Item \ Model		KDAJ25K36A	KDAJ25K56A	KDAJ25K71A	KDAJ25K140A
Duct connection diameter		ϕ200×1 port	ϕ200×2 port		ϕ200×4 port
Material		Steel plate	Hot-dip zinc coated steel sheets, EPS, and insulation		
Accessories			Screws, Installation manual		
Mass (weight)	kg	1.1	1.5	2.5	3.5
Component parts		Air discharge adaptor. Screws (except KDAJ25K36A). Installation manual.			


Dimensions **Unit:mm**

KDAJ25K36A




D3K06518

KDAJ25K56A




D3K06136

KDAJ25K71A




D3K06137

KDAJ25K140A



D3K06138A

Installation




7

Installation

Air discharge adapter installation manual

1. This kit contains the following parts and accessories.

Name	Quantity			
	KDAJ25K36A	KDAJ25K56A	KDAJ25K71A	KDAJ25K140A
	KDAJ25KA36	KDAJ25KA56	KDAJ25KA71	KDAJ25KA140
	KDA25D32	KDA25D45	KDA25D63	KDA25D125
Air discharge adapter	1	1	1	1
Installation manual	1	1	1	1
Screws	8	8	8	12




2. Required tools

Screwdriver ⊕

3. Operating procedures

1. Remove the air discharge flange from indoor unit.
2. Attach the air discharge adapter to the indoor unit.
   ① Tighten two installation screws to the indoor unit. (Leave about 20mm of the thread exposed.)
   ② Hang the air discharge adapter on the screws and then tighten all screws definitively.



4. Cautions for the installation

Fasten the screws tightly so as no gap between the indoor unit and the air discharge adapter.

3P012475C

KAF372AA36·56·80·160, KAF373AA36·56·80·160 — High efficiency filter





Item		Model KAF372 AA36	KAF373 AA36	KAF372 AA56	KAF373 AA56	KAF372 AA80	KAF373 AA80	KAF372 AA160	KAF373 AA160
Initial pressure loss	Pa	15 or less	21 or less	35 or less	54 or less	35 or less	54 or less	38 or less	56 or less
Final pressure loss	Pa	98 or less							
Average efficiency (colorimetric method)	%	65	90	65	90	65	90	65	90
Life ∗1	h	2,500	1,800	2,500	1,800	2,500	1,800	2,500	1,800
Filter element		Non-woven fabric of synthetic fiber							
Number of sheets included		1	1	2	2	3	3	4	4

Note:
∗1. Dust concentration 0.15 mg/m^3

- Cannot be water-washed for reuse.
- The Filter Chamber (for high efficiency filter) (KDDF37AA36 · 56 · 80 · 160) is required when the high efficiency filter will be installed.


Dimensions **Unit:mm**





AA	Applied Models
550	KAF372AA36 KAF373AA36
355	KAF372AA56, 80, 160 KAF373AA56, 80, 160

Note
KAF372AA36, KAF373AA36:
Without hook and loose fastener.



Filter connecting figure


J : D3K06645

7

KDDF37AA36·56·80·160 — High efficiency filter chamber

Item			Model	KDDF37AA36	KDDF37AA56	KDDF37AA80	KDDF37AA160
Inserted filter	High efficiency filter	65% (colorimetric method)		KAF372AA36	KAF372AA56	KAF372AA80	KAF372AA160
		90% (colorimetric method)		KAF373AA36	KAF373AA56	KAF373AA80	KAF373AA160
	Long life filter			KAF371AA36	KAF371AA56	KAF371AA80	KAF371AA160
Accessories				Mounting screws, Installation manual			
Mass (weight)			kg	4.4	4.5	5.5	7.5

Dimensions **Unit:mm**




Model	A	B	C	D	E	F	Connection duct opening
KDDF37AA36	582	520	500	P150 x 3=450	8	12	247 x 475
KDDF37AA56	732	670	650	P150×4=600	10	14	247×625
KDDF37AA80	1080	1020	950	P150×6=900	14	18	247×925
KDDF37A160	1440	1380	1350	P150×8=1200	18	22	247×1325

JC : D3K06642

KAF371AA36·56·80·160 — Long life filter



Dimensions **Unit:mm**



AA	Applied Models
548	KAF371AA36
353	KAF371AA56, 80, 160

J : D3K06644


7

- Can be water-washed. Can be reused.
- The Filter chamber (KDDF37AA36 · 56 · 80 · 160) is required when the long life filter will be installed.

Item \ Model		KAF371AA36	KAF371AA56	KAF371AA80	KAF371AA160
Initial pressure loss	Pa	3 or less	7 or less		8 or less
Final pressure loss	Pa	49 or less			
Average efficiency	%	50 (gravity method)			
Air flow rate / 1 sheet	m^3/min	9.8			
Life	h	2,500 (dust concentration 0.15 mg/m^3)			
Filter element		Mildew-proof resin net (Polypropylene)			
Filter frame		Polystyrene			
Number of sheets included		1	2	3	4

KRP4A96 — Mounting plate for adaptor PCB

Dimension



J : D3K06565

Item \ Model	KRP4A96
Material	Steel sheet (t=0.8 coating)
Adaptor for wiring	KRP1C64 KRP4AA51
Accessories	Mounting screws (M4×8) : 2, Sealing material : 2, Clamp : 8, Installation manual

AIR CONDITIONER Mounting plate for adaptor PCB. Installation manual

KRP4A96

READ THESE INSTRUCTIONS CAREFULLY BEFORE INSTALLATION.
KEEP THIS MANUAL IN A HANDY PLACE FOR FUTURE REFERENCE.

2P226887-1

Caution

- This plate is mountable on the ceiling mounted duct type unit. After confirming the indoor unit model name, mount this plate on the unit listed in the table shown bottom.
- When mounting the plate, see also the indoor unit installation manual and the adaptor PCB (Printed Circuit Board) mounting instruction.
- Fixing method is not on the installation manual attached to the adapter PCB. Please follow directions on this sheet.

Kit name	Indoor unit model that party crowded is possible		
KRP4A96	Ceiling mounted duct type unit	SPLIT	FHMP～ FBQ～
		VRV	FXYMP～ FXMQ～


*See the DAIKIN catalog for the details

Accessories

- Check if the following accessories are included with your kit.

<Precaution>

The accessories are required for the installation of the air conditioner. Be sure to keep them until the installation work is completed.

Name	Adaptor plate	Screw	Sealing material	Clamp	Installation manual
Quantity	1PC.	2PCS.	2PC.	8PCS.	1PC.
Shape		 M4×8			

<Caution>

- All field supplied parts and materials and electric works must conform to local codes.
- Use copper wire only.
- For electric wiring work, refer to also "Wiring diagram" attached to the control box lid.
- All wiring must be performed by an authorized electrician.
- A circuit breaker capable of shutting down power supply to the entire system must be installed.

❶ Mounting the adaptor plate

《Wiring to the indoor unit》

① Remove the control box lid. [Fig.1]


② Connect the wiring to the indoor unit. (The work is easier if the wiring is connected first.)

- See the instruction attached to the adaptor PCB for the place where to connect the wires on the indoor unit.
- Please see the connector location on (figure 1) on the ❷ How to mount the adaptor PCB and handle the wiring .


《Mounting the adaptor plate》

① Putting the claw of the adaptor plate into the hole of the box. [Fig.2]


② Fix the box with the attached fixing screws at two places. [Fig.3]



[Fig.1]



[Fig.2]




[Fig.3]

❷ How to mount the adaptor PCB and handle the wiring

《How To Lead-in External Wires 》

Lay the wires in the control box through the wire inlet on the side of the control box.




2P226887

《How to mount the adaptor PCB》

① Connect the wiring to the adaptor PCB.
(The work is easier if the wiring is connected to the PCB first.)
● See the instruction attached to the adaptor PCB for where to connect the wiring.

② Mount adapter PCB onto the mounting plate (in the direction) as shown on figure 1 & 2.
● Use PCB supports included in the package.
(for any of below adapters.)




《Caution》If (adapter PCB is) mounted in a wrong direction, electric noise may cause malfunction of the system, or may influence upon other devices.

Adaptor PCB		Place where to mount
Adaptor for wiring	KRP1C13 KRP1C64	(Fig. 1)
Wiring adaptor for electrical appendices (※1)	KRP4A1 KRP4AA51 KRP2A1 KRP2A61	(Fig. 1)
External control adaptor for outdoor unit (※1)	DTA104A1 DTA104A61	(Fig. 2)

(※1) adapter cannot be mounted 2 or more together.

〈Adaptor for wiring, Wiring adaptor for electrical appendices〉



(Fig. 1)


《How to handle the wiring》

《Caution》Do not make high-voltage and low-voltage wires run in parallel. Electric noise may cause malfunction of the system, or may influence upon other devices.


① Fix the internal wirings.
Bind the wiring from the adaptor plate to the indoor unit control box according to the drawing shown on the right with the attached clamp.
(Put the clamping materials through the corner holes to fix wires.)
● Bind the the surplus wires and the other wiring together with the clamp.

② Put the control box lid, and wrap the wire sealing material around the wires so as to block the wire through holes.
● Take precautions to prevent the wires from getting caught.
● After all the wiring connections are done, fill in any gaps in the through holes with putty or insulation (procured locally) to prevent small animals and insects from entering the unit from outside.
(If any do get in, they could cause short circuits in the control box.)

〈External control adaptor for outdoor unit〉




(Fig. 2)




⚠Warning
Trim and lay the wiring neatly and attach the control box lid securely.
An electric shock or fire may result if the control box lid catches any wiring or the wires push up the lid.

③ Connect round crimp-style terminals provided with insulation sleeves to the terminal block for power supply.
● See the instruction attached to the indoor unit.



〈Caution〉
- Connect proper wires securely and fix the wires so that external force will not be imposed on the terminals.
- Use an appropriate screwdriver to tighten the terminal screws. The screw heads may be damaged if the screwdriver is too small and the terminal screws will not be tightened properly.
- Do not tighten the terminal screws excessively, or otherwise the screw heads may be damaged.
- Refer to the table below for the required tightening torque values of the terminal screws.



	Tightening torque (N・m)
Terminal block for remote controller and transmission wires	1.18 – 1.44
Terminal block for power supply, and wiring the units	1.18 – 1.44

2P226887

FXMQ-MA
Ceiling Mounted Duct Type

1. Features 306
2. Specifications 307
3. Dimensions 308
4. Piping Diagrams 309
5. Wiring Diagrams 310
6. Electric Characteristics 311
7. Capacity Tables 312
   7.1 Cooling Capacity 312
   7.2 Heating Capacity 313
8. Fan Performances 314
   8.1 50Hz 314
   8.2 60Hz 314
9. Sound Levels 315
10. Installation 316
11. Accessories 320

1. Features

Ceiling mounted duct type is newly added to the line-up of the indoor unit for VRV series, which gives you much more flexibility in designing of the air conditioning system to satisfy the needs of individual air-conditioning even in the broad area.

■ **High external static pressure allows extensive duct work for flexible applications.**

Ceiling mounted duct type
FXMQ200MA FXMQ250MA



200 · 250 type

2. Specifications

Ceiling Mounted Duct Type

Model			FXMQ200MAVE	FXMQ250MAVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	19,800	24,800
		Btu/h	78,500	98,300
		kW	23.0	28.8
∗2 Cooling Capacity (19.0°CWB)		kW	22.4	28.0
∗3 Heating Capacity		kcal/h	21,500	27,100
		Btu/h	85,300	107,500
		kW	25.0	31.5
Casing			Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	470×1,380×1,100	470×1,380×1,100
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	3×26×2.0	3×26×2.0
	Face Area	m²	0.68	0.68
Fan	Model		D13/4G2DA1×2	D13/4G2DA1×2
	Type		Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	380×2	380×2
	Air Flow Rate (H/L)	m³/min	58/50	72/62
		cfm	2,047/1,765	2,542/2,189
	External Static Pressure 50Hz	Pa	221-132 ∗4	270-147 ∗4
	Drive		Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Glass Fiber	Glass Fiber
Air Filter			∗5	∗5
Piping Connections	Liquid Pipes	mm	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes	mm	ϕ19.1(Brazing Connection)	ϕ22.2 (Brazing Connection)
	Drain Pipe	mm	PS1B	PS1B
Machine Weight (Mass)		kg	137	137
∗7 Sound Level (H/L) (220V)		dBA	48/45	48/45
Safety Devices			Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Sealing Pads. Connection Pipes. Screws. Clamps.	Operation Manual. Installation Manual. Sealing Pads. Connection Pipes. Screws. Clamps.
Drawing No.			C : 3D038814A	

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗4 External static pressure is changeable to change over the connectors inside electrical box, this pressure means "High static pressure-Standard".
∗5 Air filter is not standard accessory, but please mount it in the duct system of the suction side. Select its colorimetric method (gravity method) 50% or more.
6 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗7 Anechoic chamber conversion value, measured at a point 1.5 m downward from the unit center. These values are normally somewhat higher during actual operation as a result of ambient conditions.
8 Refer to page 311 for Fan Motor Input.


Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

8


3. Dimensions

FXMQ200MA
FXMQ250MA

Unit (mm)



4. Piping Diagrams



4D034245B


■ **Refrigerant pipe connection port diameters**

(mm)

Model	Gas	Liquid
FXMQ200MA	ϕ19.1	ϕ9.5
FXMQ250MA	ϕ22.2	

5. Wiring Diagrams

FXMQ200 · 250MAVE



INDOOR UNIT		R1T	THERMISTOR (AIR)
A1P	PRINTED CIRCUIT BOARD	R2T·R3T	THERMISTOR (COIL)
C1R·C2R	CAPACITOR (M1F · 2F)	SS	SELECTOR SWITCH (STATIC PRESSURE)
F1U	FUSE (Ⓑ, 5A, 250V)		
HAP	LIGHT EMITTING DIODE (SERVICE MONITOR-GREEN)	T1R	TRANSFORMER (220-240V/22V)
K1M	MAGNETIC CONTACTOR (M1F · 2F)	X1M	TERMINAL BLOCK (POWER)
K2M	MAGNETIC CONTACTOR (M1F · 2F)	X2M·X3M	TERMINAL BLOCK
K3M	MAGNETIC CONTACTOR (M1F · 2F)	X4M	TERMINAL BLOCK (CONTROL)
K1R·K3R	MAGNETIC RELAY (M1F · 2F)	Y1E	ELECTRONIC EXPANSION VALVE
KPR	MAGNETIC RELAY (M1P)	OPTIONAL PARTS	
M1F·M2F	MOTOR (INDOOR FAN)	M1P	MOTOR (DRAIN PUMP)
Q1M·Q2M	THERMO SWITCH (M1F · 2F EMBEDDED)	WIRED REMOTE CONTROLLER	
		R1T	THERMISTOR (AIR)
		SS1	SELECTOR SWITCH (MAIN/SUB)
		CONNECTOR FOR OPTIONAL PARTS	
		X8A	CONNECTOR (FLOAT SWITCH)
		X18A	CONNECTOR (WIRING ADAPTOR FOR ELECTORICAL APPENDICES)

NOTES)
1. ▭ : TERMINAL BLOCK
   ⊙⊙, ▷ : CONNECTOR
   ⊂⊃ : SHORT CIRCUIT CONNECTOR
   —○— : TERMINAL
2. —▮▮— : FIELD WIRING
3. IN CASE USING CENTRAL REMOTE CONTROLLER, CONNECT IT TO THE THE UNIT IN ACCORDANCE WITH THE ATTACHED INSTRUCTION MANUAL.
4. WHEN CONNECTING THE INPUT WIRES FROM OUTSIDE, FORCED OFF OR ON/OFF CONTROL OPERATION CAN BE SELECTED BY REMOTE CONTROLLER. IN DETAILS, REFER TO THE INSTALLATION MANUAL ATTACHED THE UNIT.
5. IN CASE INSTALLING THE DRAIN PUMP, REMOVE THE SHORT CIRCUIT CONNECTOR OF X8A AND EXECUTE THE ADDITIONAL WIRING FOR FLOAT SWITCH AND DRAIN PUMP.
6. SYMBOLS SHOW AS FOLLOWS. (PNK : PINK WHT : WHITE YLW : YELLOW ORG : ORANGE BLU : BLUE BLK : BLACK RED : RED BRN : BROWN)
7. USE COPPER CONDUCTORS ONLY.
8. IN CASE HIGH E.S.P. OPERATION, CHANGE THE SWITCH (SS) FOR "H" .

6. Electric Characteristics

Units					Power supply		IFM		Input(W)	
Model	Type	Hz	Volts	Voltage range	MCA	MFA	KW	FLA	Cooling	Heating
FXMQ200MA	VE	50	220-240	MAX. 264 Min. 198	8.1	15	0.380×2	6.5	1294	1294
FXMQ250MA					9.0	15	0.380×2	7.2	1465	1465
FXMQ200MA	VE	60	220	MAX. 242 Min. 198	9.0	15	0.380×2	7.2	1490	1490
FXMQ250MA					10.1	15	0.380×2	8.1	1684	1684

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
KW : Fan Motor Rated Output(KW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

8

Note:

1. Voltage range

   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.

2. Maximum allowable voltage unbalance between phases is 2%.

3. MCA/MFA

   MCA = 1.25 X FLA

   MFA ≦ 4 X FLA
   (Next lower standard fuse rating. Min. 15A)

4. Select wire size based on the MCA.

5. Instead of fuse, use Circuit Breaker.

C : 4D040330A

7. Capacity Tables

7.1 Cooling Capacity

FXMQ-MA **[50/60Hz]**

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	14.0°CWB 20°CDB SHC	16.0°CWB 23°CDB TC	16.0°CWB 23°CDB SHC	18.0°CWB 26°CDB TC	18.0°CWB 26°CDB SHC	19.0°CWB 27°CDB TC	19.0°CWB 27°CDB SHC	20.0°CWB 28°CDB TC	20.0°CWB 28°CDB SHC	22.0°CWB 30°CDB TC	22.0°CWB 30°CDB SHC	24.0°CWB 32°CDB TC	24.0°CWB 32°CDB SHC
200	10.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	26.8	17.6	29.4	17.8
	12.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	26.8	17.6	29.0	17.6
	14.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	26.8	17.6	28.7	17.4
	16.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	26.8	17.6	28.3	17.2
	18.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	26.8	17.6	27.9	16.9
	20.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	26.8	17.6	27.5	16.7
	21.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	26.8	17.6	27.4	16.6
	23.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	26.4	17.3	27.0	16.4
	25.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	26.1	17.1	26.6	16.2
	27.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	25.7	16.8	26.2	16.1
	29.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	25.3	16.6	25.8	15.9
	31.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	24.9	16.4	25.4	15.7
	33.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.8	17.0	24.5	16.3	25.0	15.6
	35.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.6	17.0	24.2	16.1	24.6	15.4
	37.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	23.2	16.8	23.8	16.0	24.3	15.3
	39.0	15.1	13.4	18.0	14.9	21.0	16.3	22.4	16.8	22.8	16.6	23.4	15.8	23.9	15.1
250	10.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	33.5	22.1	36.8	22.1
	12.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	33.5	22.1	36.3	21.8
	14.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	33.5	22.1	35.9	21.6
	16.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	33.5	22.1	35.4	21.3
	18.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	33.5	22.1	34.9	21.0
	20.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	33.5	22.1	34.4	20.7
	21.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	33.5	22.1	34.2	20.6
	23.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	33.0	21.7	33.7	20.3
	25.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	32.6	21.5	33.2	20.2
	27.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	32.1	21.2	32.8	20.0
	29.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	31.6	20.9	32.3	19.9
	31.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	31.1	20.6	31.8	19.7
	33.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.8	21.2	30.6	20.4	31.3	19.5
	35.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.5	21.1	30.2	20.2	30.8	19.4
	37.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	20.9	29.0	20.9	29.7	20.0	30.4	19.2
	39.0	18.9	16.9	22.5	18.5	26.2	20.4	28.0	21.0	28.5	20.6	29.2	19.8	29.9	19.0

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

7.2 Heating Capacity

FXMQ-MA **[50/60Hz]**

Heating capacity


Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
200	-19.8	-20.0	14.8	14.7	14.7	14.7	14.6	14.6
	-18.8	-19.0	15.2	15.2	15.1	15.1	15.1	15.0
	-16.7	-17.0	16.1	16.0	16.0	16.0	16.0	15.9
	-14.7	-15.0	17.0	16.9	16.9	16.9	16.8	16.8
	-12.6	-13.0	17.9	17.8	17.8	17.7	17.7	17.7
	-10.5	-11.0	18.7	18.7	18.6	18.6	18.6	18.6
	-9.5	-10.0	19.2	19.1	19.1	19.1	19.0	19.0
	-8.5	-9.1	19.6	19.5	19.5	19.5	19.4	19.4
	-7.0	-7.6	20.2	20.2	20.2	20.1	20.1	20.1
	-5.0	-5.6	21.1	21.1	21.0	21.0	21.0	20.9
	-3.0	-3.7	22.0	21.9	21.9	21.9	21.8	21.8
	0.0	-0.7	23.3	23.2	23.2	23.2	23.2	21.8
	3.0	2.2	24.6	24.5	24.5	24.2	23.4	21.8
	5.0	4.1	25.4	25.4	25.0	24.2	23.4	21.8
	7.0	6.0	26.2	26.2	25.0	24.2	23.4	21.8
	9.0	7.9	27.1	26.6	25.0	24.2	23.4	21.8
	11.0	9.8	27.9	26.6	25.0	24.2	23.4	21.8
	13.0	11.8	28.2	26.6	25.0	24.2	23.4	21.8
	15.0	13.7	28.2	26.6	25.0	24.2	23.4	21.8
250	-19.8	-20.0	18.6	18.5	18.5	18.5	18.4	18.4
	-18.8	-19.0	19.2	19.1	19.0	19.0	19.0	18.9
	-16.7	-17.0	20.3	20.2	20.2	20.1	20.1	20.0
	-14.7	-15.0	21.4	21.3	21.3	21.2	21.2	21.2
	-12.6	-13.0	22.5	22.4	22.4	22.4	22.3	22.3
	-10.5	-11.0	23.6	23.6	23.5	23.5	23.4	23.4
	-9.5	-10.0	24.2	24.1	24.1	24.0	24.0	23.9
	-8.5	-9.1	24.7	24.6	24.6	24.5	24.5	24.4
	-7.0	-7.6	25.5	25.4	25.4	25.4	25.3	25.3
	-5.0	-5.6	26.6	26.6	26.5	26.5	26.4	26.4
	-3.0	-3.7	27.7	27.6	27.6	27.5	27.5	27.5
	0.0	-0.7	29.3	29.3	29.2	29.2	29.2	27.5
	3.0	2.2	31.0	30.9	30.8	30.5	29.5	27.5
	5.0	4.1	32.0	32.0	31.5	30.5	29.5	27.5
	7.0	6.0	33.1	33.0	31.5	30.5	29.5	27.5
	9.0	7.9	34.1	33.5	31.5	30.5	29.5	27.5
	11.0	9.8	35.2	33.5	31.5	30.5	29.5	27.5
	13.0	11.8	35.5	33.5	31.5	30.5	29.5	27.5
	15.0	13.7	35.5	33.5	31.5	30.5	29.5	27.5

Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.


8. Fan Performances

8.1 50Hz

FXMQ200MA



FXMQ250MA




Note:


1. The remote controller can be used to switch between “high” and “low”.
2. The air flow is set to “standard” before leaving the factory. It is possible to switch between “standard ESP” and “high ESP” by changing the switch in the indoor unit electrical box.

8.2 60Hz

FXMQ200MA



FXMQ250MA




Note:

1. The remote controller can be used to switch between “high” and “low”.
2. The air flow is set to “standard” before leaving the factory. It is possible to switch between “standard ESP” and “high ESP” by changing the switch in the indoor unit electrical box.

9. Sound Levels

Overall

■ **Ceiling Mounted Duct Type**



dBA

Model	220V 50/60Hz		240V 50Hz	
	H	L	H	L
FXMQ200MA FXMQ250MA	48	45	49	46


Note:

1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.

Octave Band Level


○——○ 220V 50/60Hz
○- - - -○ 240V 50Hz

FXMQ200MAVE



C : 4D035168

FXMQ250MAVE




C : 4D035169

8

10. Installation

Installation Example




3P086155-2B

Center of Gravity

FXMQ200 · 250MA

Unit (mm)



C : 4D035171

Service Space

Please attach additional thermal insulation material to the unit body when it is believed that the relative humidity in the ceiling exceeds 80%. Use glass wool, polyethylene foam, or similar with a thickness of 10 mm or more as thermal insulation material.

(1) Select an installation site where the following conditions are fulfilled and that meets with your customer's approval.
- In the upper space (including the back of the ceiling) of the indoor unit where there is no possible dripping of water from the refrigerant pipe, drain pipe, water pipe, etc.
- Where optimum air distribution can be ensured.
- Where nothing blocks the air passage.
- Where condensate can be properly drained.
- If supporting structural members are not strong enough to take the unit's weight, the unit could fall out of place and cause serious injury.
- Where the false ceiling is not noticeably on an incline.
- Where there is no risk of flammable gas leakage.
- Where sufficient clearance for maintenance and service can be ensured. **(Refer to Fig. 1)**
- Where piping between indoor and outdoor units is possible within the allowable limit. (Refer to the installation manual of the outdoor unit.)

⚠ CAUTION

- Install the indoor and outdoor units, power supply wiring and connecting wires at least 1 meter away from televisions or radios in order to prevent image interference or noise.
  (Depending on the radio waves, a distance of 1 meter may not be sufficient enough to eliminate the noise.)

8

(2) Use suspension bolts for installation. Check whether the ceiling is strong enough to support the weight of the unit or not. If there is a risk, reinforce the ceiling before installing the unit.

〈FXMQ200 · 250MAVE〉




Fig. 1 (length : mm)

C : 3P086156-6U

Note:
Above figure means minimum value. Please keep these value at least.

Bolt Pitch

(1) Relative positions of indoor unit and suspension bolt. **(Refer to Fig. 2)**

〈 FXMQ200 · 250MAVE 〉





Fig. 2 (length : mm)

(2) Install a canvass duct to the air discharge outlet and air inlet so that vibration from the machine body isn't transmitted to the duct or ceiling.
You should also apply acoustic (insulation material) to the inside of the duct, and vibration insulation rubber to the suspension bolts.

(3) Install suspension bolts. (Use bolts of 10 mm diameter.)
- Install the equipment where supporting structures are strong enough to bear the equipment's weight. Use embedded inserts or anchor bolts with new buildings and hole-in-anchors with old buildings.

〈 Installation example 〉



Note) All the above parts are field supplied.

C : 3P086156-6U

Drain Piping Work

〈〈**Rig the drain pipe as shown below and take measures against condensation. Improperly rigged piping could lead to leaks and eventually wet furniture and belongings.**〉〉
〈〈**Insulate the drain hose inside the building.**〉〉

(1) Carry out the drain piping.

FXMQ200 · 250MAVE

- A drain trap need not be installed.
- The diameter of the piping is the same as that of the connecting pipe (PS1B), and should be kept equal to or greater than that of the connecting pipe.

(2) After piping work is finished, check drainage flows smoothly.

FXMQ200 · 250MAVE

- Open the water supply port, add approximately 1 liter of water slowly into the drain pan and check drainage flow.

⚠ CAUTION


- Drain piping connections
  Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain pipes and corrode the heat exchanger.

C : 3P086156-6U

8

11. Accessories

Standard Accessories

Name	Attached piping (1)	(Other)
Quantity	1 set	• Operation manual • Installation manual • Screws for flange connection (M5) (48 pcs.) • Insulation material (for hanger)(2 pcs.) • Washers (8 pcs.) • Clamps (2 pcs.) • Hexagon head bolt for pipe flange (M10) (2 pcs.) • Spring washer for pipe flange (M10) (2 pcs.)
Shape		


C : 3P086156-6U

Optional Accessories (For Unit)

Item \ Type		FXMQ200MA	FXMQ250MA
Drain pump kit		KDU30L250VE	
High efficiency filter	65%	KAFJ372L280	
	90%	KAFJ373L280	
Filter chamber		KDJ3705L280	
Long life replacement filter		KAFJ371L280	

3D034598B

Optional Accessories (For Controls) : Refer to P.807



High Efficiency Filter

Specification


Model	65% type		90% type	
Items	KAFJ372L280		KAFJ373L280	
Filter Chamber	KDJ3705L280		KDJ3705L280	
Dimension (W×D×T) (mm)	684×445×60		684×445×60	
Average Dust Collection Efficiency (%)	Colorimetric method 65%		Colorimetric method 90%	
Initial Pressure Loss (Pa)	27	42	29	45
Final Pressure Loss (Pa)	98		98	
Filter	Non-woven fabric of synthetic fiber		Non-woven fabric of synthetic fiber	
Life Time (h)	2500 hours (dust density 0.15mg/m³)		1800 hours (dust density 0.15mg/m³)	
Seats Structured	2		2	
Applicable Models	200·250 Class		200·250 Class	

Note:
The filter chamber is separately required when the high efficiency filter will be installed.

8


Characteristics of filter

■KAFJ372L280,KAFJ373L280




Dimensions of filter

■KAFJ372L280, KAFJ373L280



Installation




- Meet the airflow direction and arrow mark putting on the High efficiency filter.
- It is impossible to be built in with the air cleaning unit together.

Long Life Replacement Filter

Specifications

Item \ Model		KAFJ371L280
Filter Chamber for Bottom Suction		KDJ3705L280
Dimensions (W×D×T) mm		684×445×30
Average Efficiency (%)		50% (Gravity method)
Pressure Loss (Pa)	Initial	9.8 (1mmH_2O)
	Final	49 (5mmH_2O)
Material		Mildew Proof Resin Net
Number Required per Unit		2
Life Time (h)		2,500 h (dust particle concentration at 0.15mg/m³)
Applicable Model		200·250 Class

Dimensions




Model	A×B	Quantity
KAFJ371L280	684×445	2

Note:
The filter chamber is required when the long life filter will be installed.

Characteristics of filter

■KDJ3705L280



Drain Pump Kit

Specification


Items \ Model	KDU30L250VE
Power Supply	Single phase 220V 60Hz
Power Consumption (W)	19/17 (50/60Hz)
Drain-up Lift (mm)	Standard drain outlet of the unit + 222 + 250
Drain Outlet	VP25 (Internal diameter ϕ25, external diameter ϕ32)
Safety Device	Float switch
Weight (kg)	10
Applied Models	200 · 250 Class

Precaution at use

1. When this kit will be used with the natural evaporation pan type humidifier together, the piping of unit's drain and humidifier's drain can be used in common.
2. Be sure to do test run (cooling) to make sure the drain flows out.
3. Prohibit providing a drain trap when the drain pump kit will be mounted.


Installation Space

KDU30L250VE




If the drain pump kit has already been installed, note the following when installing the indoor unit.


· Do not install the indoor unit on an incline against drainage flow (away from the drain outlet). This can lead to water leaks.



Internal Wiring Method


■ **KDU30L250VE**





Dimensions with the Optional Accessories

Drain pump kit, High efficiency filter, Long life filter



Number	Name	Description
8	Drain hose	Attached to Drain pump kit
7	Water inlet	
6	Drain piping connection	VP25(O.D.φ32,I.D.φ25)
5	Drain pump kit	Built in a body
4	Long life filter	
3	High efficiency filter	
2	Filter chamber	
1	Ceiling mounted duct type's body	

JC : 3D011124G

FXHQ-MA
Ceiling Suspended Type

1. Features 326
2. Specifications 327
3. Dimensions 328
4. Piping Diagrams 331
5. Wiring Diagrams 332
6. Electric Characteristics 333
7. Capacity Tables 334
   7.1 Cooling Capacity 334
   7.2 Heating Capacity 335
8. Air Velocity and Temperature Distributions (Reference Data) 336
9. Sound Levels 337
10. Installation 338
11. Accessories 341

9

1. Features


External Appearance



Slim body with quieter and wider air flow

●Adoption of newly designed QUIET STREAM FAN

Uses the new quiet stream fan and many more quiet technologies.




●Low operating sound

(dB(A))


Class	32	63	100
Operating sound (H/L)	36/31	39/34	45/37

●Installation is easy

- Drain-up kit (optional) can be easily incorporated



●Wide air discharge openings produce a spreading 100˚ air flow






●Maintenance is easy

- New Non-dew Frap with no implanted

Bristle-free Frap minimizes contamination and makes cleaning simpler.



- Easy to clean flat design
- Maintenance is easier because everything can be performed from below the unit
- A long-life filter (maintenance free up to one year) is equipped as standard

2. Specifications

Ceiling Suspended Type

Model			FXHQ32MAVE	FXHQ63MAVE	FXHQ100MAVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	3,200	6,300	10,000
		Btu/h	12,600	24,900	39,600
		kW	3.7	7.3	11.6
∗2 Cooling Capacity (19.0°CWB)		kW	3.6	7.1	11.2
∗3 Heating Capacity		kcal/h	3,400	6,900	10,800
		Btu/h	13,600	27,300	42,700
		kW	4.0	8.0	12.5
Casing Color			White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)
Dimensions: (H×W×D)		mm	195×960×680	195×1,160×680	195×1,400×680
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	2×12×1.75	3×12×1.75	3×12×1.75
	Face Area	m²	0.182	0.233	0.293
Fan	Model		3D12K1AA1	4D12K1AA1	3D12K2AA1
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	62×1	62×1	130×1
	Air Flow Rate (H/L)	m³/min	12/10	17.5/14	25/19.5
		cfm	424/353	618/494	883/688
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Glass Wool	Glass Wool	Glass Wool
Air Filter			Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe	mm	VP20 (External Dia. 26 Internal Dia. 20)	VP20 (External Dia. 26 Internal Dia. 20)	VP20 (External Dia. 26 Internal Dia. 20)
Machine Weight (Mass)		kg	24	28	33
∗5 Sound Level (H/L) (220-240V)		dBA	36/31	39/34	45/37
Safety Devices			Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Clamps. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Clamps. Washers.	Operation Manual. Installation Manual. Paper Pattern for Installation. Drain Hose. Clamp Metal. Insulation for Fitting. Clamps. Washers.
Drawing No.			C : 3D038815A		

Note:


∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1 m in front of the unit and 1 m downward. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 333 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

9


3. Dimensions

FXHQ32MA



FXHQ63MA

Unit (mm)




Number	Name	Description
1	Air discharge grille	
2	Air suction grille	
3	Air filter	
4	Gas pipe connection	ϕ15.9 flare
5	Liquid pipe connection	ϕ9.5 flare
6	Drain pipe connection	VP20
7	Earth terminal (Inside the electric components box)	M4
8	Suspention bracket	
9	Backward piping and wiring connection opening lid	
10	Upward piping and wiring connection opening lid	
11	Right side pipe connection	Slit hole
12	Left back drain pipe connection	Slit hole
13	Left side drain pipe connection	Slit hole
14	Right side drain pipe connection	Slit hole
15	Hole of wall for taking out in piping back	ϕ100
16	Upward drain pipe connection	ϕ60
17	Upward gas pipe connection	ϕ36
18	Upward liquid pipe connection	ϕ26

Note) 1. Location of unit's Name plate : Bottom of fan housing inside the suction grille.
2. In case of using wireless remote controller, this position will be a signal receiver.
Refer to the drawing of wireless remote controller in detail.
3. The remote control code is the standard <about 3m outside the machine> attached.
(0.5mm^2×2wicks×O.D.ϕ5.4)
(It is not attached to VRV.)

FXHQ100MA


Unit (mm)



Number	Name	Description
1	Air discharge grille	
2	Air suction grille	
3	Air filter	
4	Gas pipe connection	ϕ15.9 flare
5	Liquid pipe connection	ϕ9.5 flare
6	Drain pipe connection	VP20
7	Earth terminal (Inside the control box)	M4
8	Suspension bracket	
9	Backward piping and wiring connection opening lid	
10	Upward piping and wiring connection opening lid	
11	Right side pipe connection	Slit hole
12	Left back drain pipe connection	Slit hole
13	Left side drain pipe connection	Slit hole
14	Right side drain pipe connection	Slit hole
15	Hole of wall for taking out in piping back	ϕ100
16	Upward drain pipe connection	ϕ60
17	Upward gas pipe connection	ϕ36
18	Upward liquid pipe connection	ϕ26

Note) 1. Location of unit's Name plate : Bottom of fan housing inside the suction grille.
2. In case of using wireless remote controller, this position will be a signal receiver. Refer to the drawing of wireless remote controller in detail.

4. Piping Diagrams



4D034245C


■ **Refrigerant pipe connection port diameters**

(mm)

Model	Gas	Liquid
FXHQ32MA	ϕ12.7	ϕ6.4
FXHQ63 · 100MA	ϕ15.9	ϕ9.5

5. Wiring Diagrams

FXHQ32 · 63 · 100MAVE



6. Electric Characteristics

Units				Power supply		IFM		Input(W)	
Model	Hz	Volts	Voltage range	MCA	MFA	KW	FLA	Cooling	Heating
FXHQ32MAVE	50	220-240	MAX. 264 Min. 198	0.8	15	0.062	0.6	111	111
FXHQ63MAVE				0.8	15	0.062	0.6	115	115
FXHQ100MAVE				0.9	15	0.130	0.7	135	135
FXHQ32MAVE	60	220	MAX. 242 Min. 198	0.9	15	0.062	0.7	142	142
FXHQ63MAVE				0.9	15	0.062	0.7	145	145
FXHQ100MAVE				1.3	15	0.130	1.0	199	199

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
KW : Fan Motor Rated Output(KW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

Note:

1. Voltage range

   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.

2. Maximum allowable voltage unbalance between phases is 2%.

3. MCA/MFA

   MCA = 1.25 X FLA

   MFA ≦ 4 X FLA

   (Next lower standard fuse rating. Min. 15A)

4. Select wire size based on the MCA.

5. Instead of fuse, use Circuit Breaker.

C : 4D035304B

7. Capacity Tables

7.1 Cooling Capacity

FXHQ-MA **[50/60Hz]**

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB / 20°CDB TC	14.0°CWB / 20°CDB SHC	16.0°CWB / 23°CDB TC	16.0°CWB / 23°CDB SHC	18.0°CWB / 26°CDB TC	18.0°CWB / 26°CDB SHC	19.0°CWB / 27°CDB TC	19.0°CWB / 27°CDB SHC	20.0°CWB / 28°CDB TC	20.0°CWB / 28°CDB SHC	22.0°CWB / 30°CDB TC	22.0°CWB / 30°CDB SHC	24.0°CWB / 32°CDB TC	24.0°CWB / 32°CDB SHC
32	10.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.7	3.1
	12.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.7	3.0
	14.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.6	3.0
	16.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.6	3.0
	18.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.5	2.9
	20.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.4	2.9
	21.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.3	3.0	4.4	2.9
	23.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.2	3.0	4.3	2.8
	25.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.2	2.9	4.3	2.8
	27.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.1	2.9	4.2	2.7
	29.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.1	2.9	4.2	2.7
	31.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	4.0	2.8	4.1	2.7
	33.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.8	2.9	3.9	2.8	4.0	2.7
	35.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.7	2.9	3.8	2.8	3.9	2.7
	37.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.7	2.9	3.8	2.8	3.8	2.6
	39.0	2.4	2.3	2.9	2.6	3.4	2.8	3.6	2.9	3.7	2.9	3.8	2.7	3.8	2.6
63	10.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.5	5.5	9.3	5.6
	12.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.5	5.5	9.2	5.5
	14.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.5	5.5	9.1	5.4
	16.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.5	5.5	9.0	5.3
	18.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.5	5.5	8.8	5.3
	20.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.5	5.5	8.7	5.2
	21.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.5	5.5	8.7	5.2
	23.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.4	5.4	8.5	5.1
	25.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.3	5.4	8.4	5.1
	27.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.1	5.3	8.3	5.0
	29.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	8.0	5.2	8.2	5.0
	31.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	7.9	5.1	8.1	4.9
	33.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.6	5.3	7.8	5.1	7.9	4.9
	35.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.5	5.3	7.7	5.1	7.8	4.8
	37.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.4	5.2	7.5	5.0	7.7	4.8
	39.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.2	7.2	5.1	7.4	5.0	7.6	4.7
100	10.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	13.4	8.5	14.7	8.7
	12.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	13.4	8.5	14.5	8.5
	14.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	13.4	8.5	14.4	8.4
	16.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	13.4	8.5	14.2	8.3
	18.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	13.4	8.5	14.0	8.2
	20.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	13.4	8.5	13.8	8.1
	21.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	13.4	8.5	13.7	8.0
	23.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	13.2	8.3	13.5	7.9
	25.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	13.0	8.2	13.3	7.8
	27.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	12.8	8.1	13.1	7.7
	29.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	12.6	8.0	12.9	7.6
	31.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	12.4	7.9	12.7	7.6
	33.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.9	8.1	12.2	7.8	12.5	7.5
	35.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.8	8.1	12.1	7.7	12.3	7.4
	37.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.6	8.0	11.9	7.7	12.2	7.3
	39.0	7.6	6.2	9.0	6.9	10.5	7.8	11.2	8.0	11.4	7.9	11.7	7.6	12.0	7.2

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

7.2 Heating Capacity

FXHQ-MA **[50/60Hz]**

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
32	-19.8	-20.0	2.4	2.4	2.3	2.3	2.3	2.3
	-18.8	-19.0	2.4	2.4	2.4	2.4	2.4	2.4
	-16.7	-17.0	2.6	2.6	2.6	2.6	2.6	2.5
	-14.7	-15.0	2.7	2.7	2.7	2.7	2.7	2.7
	-12.6	-13.0	2.9	2.8	2.8	2.8	2.8	2.8
	-10.5	-11.0	3.0	3.0	3.0	3.0	3.0	3.0
	-9.5	-10.0	3.1	3.1	3.1	3.1	3.0	3.0
	-8.5	-9.1	3.1	3.1	3.1	3.1	3.1	3.1
	-7.0	-7.6	3.2	3.2	3.2	3.2	3.2	3.2
	-5.0	-5.6	3.4	3.4	3.4	3.4	3.4	3.4
	-3.0	-3.7	3.5	3.5	3.5	3.5	3.5	3.5
	0.0	-0.7	3.7	3.7	3.7	3.7	3.7	3.5
	3.0	2.2	3.9	3.9	3.9	3.9	3.7	3.5
	5.0	4.1	4.1	4.2	4.0	3.9	3.7	3.5
	7.0	6.0	4.2	4.3	4.0	3.9	3.7	3.5
	9.0	7.9	4.3	4.3	4.0	3.9	3.7	3.5
	11.0	9.8	4.5	4.3	4.0	3.9	3.7	3.5
	13.0	11.8	4.5	4.3	4.0	3.9	3.7	3.5
	15.0	13.7	4.5	4.3	4.0	3.9	3.7	3.5
63	-19.8	-20.0	4.7	4.7	4.7	4.7	4.7	4.7
	-18.8	-19.0	4.9	4.9	4.8	4.8	4.8	4.8
	-16.7	-17.0	5.1	5.1	5.1	5.1	5.1	5.1
	-14.7	-15.0	5.4	5.4	5.4	5.4	5.4	5.4
	-12.6	-13.0	5.7	5.7	5.7	5.7	5.7	5.7
	-10.5	-11.0	6.0	6.0	6.0	6.0	6.0	5.9
	-9.5	-10.0	6.1	6.1	6.1	6.1	6.1	6.1
	-8.5	-9.1	6.3	6.3	6.2	6.2	6.2	6.2
	-7.0	-7.6	6.5	6.5	6.4	6.4	6.4	6.4
	-5.0	-5.6	6.8	6.7	6.7	6.7	6.7	6.7
	-3.0	-3.7	7.0	7.0	7.0	7.0	7.0	7.0
	0.0	-0.7	7.5	7.4	7.4	7.4	7.4	7.0
	3.0	2.2	7.9	7.8	8.0	7.7	7.5	7.0
	5.0	4.1	8.1	8.1	8.0	7.7	7.5	7.0
	7.0	6.0	8.4	8.4	8.0	7.7	7.5	7.0
	9.0	7.9	8.7	8.5	8.0	7.7	7.5	7.0
	11.0	9.8	8.9	8.5	8.0	7.7	7.5	7.0
	13.0	11.8	9.0	8.5	8.0	7.7	7.5	7.0
	15.0	13.7	9.0	8.5	8.0	7.7	7.5	7.0
100	-19.8	-20.0	7.4	7.4	7.3	7.3	7.3	7.3
	-18.8	-19.0	7.6	7.6	7.6	7.5	7.5	7.5
	-16.7	-17.0	8.0	8.0	8.0	8.0	8.0	8.0
	-14.7	-15.0	8.5	8.5	8.4	8.4	8.4	8.4
	-12.6	-13.0	8.9	8.9	8.9	8.9	8.9	8.8
	-10.5	-11.0	9.4	9.3	9.3	9.3	9.3	9.3
	-9.5	-10.0	9.6	9.6	9.5	9.5	9.5	9.5
	-8.5	-9.1	9.8	9.8	9.7	9.7	9.7	9.7
	-7.0	-7.6	10.1	10.1	10.1	10.1	10.1	10.0
	-5.0	-5.6	10.6	10.5	10.5	10.5	10.5	10.5
	-3.0	-3.7	11.0	11.0	10.9	10.9	10.9	10.9
	0.0	-0.7	11.6	11.6	11.6	11.6	11.6	10.9
	3.0	2.2	12.3	12.3	12.2	12.1	11.7	10.9
	5.0	4.1	12.7	12.7	12.5	12.1	11.7	10.9
	7.0	6.0	13.1	13.1	12.5	12.1	11.7	10.9
	9.0	7.9	13.5	13.3	12.5	12.1	11.7	10.9
	11.0	9.8	14.0	13.3	12.5	12.1	11.7	10.9
	13.0	11.8	14.1	13.3	12.5	12.1	11.7	10.9
	15.0	13.7	14.1	13.3	12.5	12.1	11.7	10.9


Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

8. Air Velocity and Temperature Distributions (Reference Data)

FXHQ100MA

(Heating · Air Velocity Distribution)


Center Air Flow



FXHQ100MA

(Heating · Temperature Distribution)


Center Air Flow



9. Sound Levels

Overall

■ **Ceiling Suspended Type**



dBA

Model	220~240V 50Hz / 220V 60Hz	
	H	L
FXHQ32MA	36	31
FXHQ63MA	39	34
FXHQ100MA	45	37


Note:

1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.

Octave Band Level


○——○ 220~240V 50Hz / 220V 60Hz

FXHQ32MAVE




C : 4D035301

FXHQ63MAVE



C : 4D035302

FXHQ100MAVE




C : 4D035303A

9

10. Installation

Installation Example



C : 3PN02401-4Y

Service Space

(1) Select an installation site where the following conditions are fulfilled and that meets your customer's approval.

- In the upper space of the indoor unit where there is no possible dripping of water from the refrigerant pipe, drain pipe, water pipe, etc.
- Where optimum air distribution can be ensured.
- Where nothing blocks air passage.
- Where condensate can be properly drained.
- If supporting structural members are not strong enough to take the unit's weight, the unit could fall out of place and cause serious injury.
- Where the false ceiling is not noticeably on an incline.
- Where there is no risk of flammable gas leakage.
- Where sufficient clearance for maintenance and service can be ensured. **(Refer to Fig. 1)**
  If sufficient clearance could be ensured at*, leave a space of 200 mm or more between the unit and it's surroundings easier maintenance and service.
- Where piping between indoor and outdoor units is possible within the allowable limit. (Refer to the installation manual for the outdoor unit.)

⚠ CAUTION

- Install the indoor and outdoor units, power supply wiring and connecting wires at least 1 meter away from televisions or radios in order to prevent image interference or noise.
  (Depending on the radio waves, a distance of 1 meter may not be sufficient enough to eliminate the noise.)




Fig. 1

(2) This indoor unit may be installed on ceilings up to 3.5 m in height. However, if the ceiling is higher than 2.7m, the remote control will have to be set locally. (Refer to "FIELD SETTING")

(3) Use suspension bolts for installation. Check whether the ceiling is strong enough to support the weight of the unit or not. If there is a risk, reinforce the ceiling before installing the unit.
(Installation pitch is marked on the paper pattern for installation. Refer to it to check for points requiring reinforcing.)

C : 3PN01417-7P

Bolt Pitch

(1) Relative positions of indoor unit, suspension bolt, piping hole, drain piping hole, and electric wire hole position. (Refer to Fig. 2)




Fig. 2

Model	A	B	C	D	E	F	G
FXHQ32M(A)VE	960	920	390	375	310	400	375
FXHQ63M(A)VE	1160	1120	490	475	410	500	475
FXHQ100M(A)VE	1400	1360	610	595	530	620	595

(2) Make the suspension bolt hole, piping hole, drain piping hole.

- Refer to the paper pattern for installation for hole positions.
- Fix the positions for suspension bolt, piping hole, drain piping hole, and electric wire hole, and make the openings.

C : 3P172532-7

Drain Piping Work

Rig the drain pipe as shown below and take measures against condensation. Improperly rigged piping could lead to leaks and eventually wet furniture and belongings.

(1) Carry out the drain piping.

- For drain work, rig the pipes so that they drain reliably.
- The drain pipe outlet direction can be chosen from the right rear, right, left rear, and left. Refer to “REFRIGERANT PIPING WORK” for right rear and right direction, and refer to Fig. 20 for left rear and left direction.




Fig. 20

- For left drain pipe outlet, remove the rubber plug and the insulation on the drain pipe connecting opening on the left side of the unit and change the position to the right side.
- Insert the rubber stopper securely, all the way to the base, in order to prevent water leakage.
- The diameter of the drain pipe should be greater than or equal to the diameter of the connecting pipe. (Vinyl tube ; pipe size : 20 mm ; outer dimension : 26 mm)
- Keep the drain pipe short and sloping downwards at a gradient of at least 1/100 to prevent air pockets from forming. **(Refer to Fig. 21)**
- Use the drain hose (1) and the metal clamp (2).
  Insert the drain hose into the drain socket, up to the gray tape. **(Refer to Fig. 22)**
  Tighten the metal clamp until the screw head is less than 4 mm from the hose. **(Refer to Fig. 23)**
  (Be careful of the installation direction. Install so that the metal clamp does not contact the intake grill.)
- Wrap the sealing pad (8) (accessory) over the clamp and drain hose to insulate. **(Refer to Fig. 23)**
- No folding of drain hose inside the indoor unit. **(Refer to Fig. 24)**
  (If there is slack in the drain hose, it may cause damage to the intake grill.)

C : 3P172532-7




Fig. 21




Fig. 22





Fig. 23

NOTE

- To ensure no excessive pressure is applied to the included drain hose (1), do not bend or twist when installing. (This may cause leakage.)
- If converging multiple drain pipes, install according to the procedure shown below.



Select converging drain pipes whose gauge is suitable for the operating capacity of the unit.




Fig. 24

(2) Confirm that smooth drainage is achieved after the piping work.

- Add 0.6 liter of water in the drain pan from the air outlet for confirming drainage. **(Refer to Fig. 25)**




Fig. 25




⚠ CAUTION

- Drain piping connections
  Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain pipes and corrode the heat exchanger.
- Keep in mind that it will become the cause of getting drain pipe blocked if water collects on drain pipe.

11. Accessories

Standard Accessories

FXHQ32~100MA

Name	(1) Drain hose	(2) Metal clamp	(3) Washer for hanging bracket	(4) Clamp	(5) Paper pattern for installation	Insulation for fitting
Quantity	1 pc.	1 pc.	8 pcs.	6 pcs.	1 pc.	1 each
Shape						(6)For gas pipe  (7)For liquid pipe 

Name	Sealing pad	
Quantity	1 each	
Shape	(8) Large  (9) Small 	(Other) • Operation manual • Installation manual


C : 3P172532-7

Optional Accessories (For Unit)

No.	Model / Item	FXHQ32MAVE	FXHQ63MAVE	FXHQ100MAVE
1	Drain pump kit	KDU50M60VE	KDU50M125VE	
2	Replacement long-life filter (Resin net)	KAFJ501D56	KAFJ501D80	KAFJ501D112
3	L-type piping kit (for upward direction)	KHFP5M35	KHFP5M63	

C : 4D040446A

Optional Accessories (For Controls) : Refer to P.807



Drain Pump Kit

Specifications

Items \ Model		KDU50M60VE	KDU50M125VE	
Drain-up Lift (mm)		600		
Drain Con. Diameter		VP20 (Ex. dia. ϕ26, Int. dia. ϕ20)		
Pump	Power Supply	Single phase 220-240V/220V 50Hz (from Indoor Unit PC Board)		
	Power Consumption (W)	20/17 (50Hz)		
Applicable Models		32 class	63 class	100 class


Precaution at use

1. Don't turn off the power within 5 minutes after cooling operation stops.
2. The liquid crystal display blinks to inform us that safety device actuated.
3. When cooling operation's season is over, extract drain water.


Installation guide of the drain pump kit

<Changes in drain pump kit>

- Exit drain pipe has been changed from VP25 to VP20 (to meet the drain diameter of main frame).
- Attached drain pipe (450 mm chloride vinyl straight pipe bellow, elbow) -> only bellow hose for VP20
- All units of drain up height was unified to 600mm (From the bottom of the ceiling)



Wiring diagram




L Shape Connection Pipe Kit

Application purpose

This kit must be bent inside the unit as shown below, when the refrigerant piping is carried out in a ceiling space. This L shape kit is an optional accessory which has been developed for improving the work of the processing on site.

Installation



FXAQ-MA
Wall Mounted Type

1. Features 344
2. Specifications 345
3. Dimensions 347
4. Piping Diagrams 350
5. Wiring Diagrams 351
6. Electric Characteristics 352
7. Capacity Tables 353
   7.1 Cooling Capacity 353
   7.2 Heating Capacity 354
8. Sound Levels 355
9. Installation 356
10. Accessories 364


1. Features

External Appearance



- Compact and stylish design that does not detract from the decor of the room.

- More compact than compared with previous model. (50, 63 class)



  - Drastic 10 kg weight reduction from 24 kg to 14 kg.
  - Volume reduced by 22%.
  - Space savings of up to 47%.

- Low operating sound

(220V-240V)(dB(A))

Class	20	25	32	40	50	63
Operating sound (H/L)	35/29	36/29	37/29	39/34	42/36	46/39

- Drain pan and air filter can be kept clean by mildew-proof polystyrene.

- Washable grille, the front grille can be easily removed for washing.

- Auto-swing ensures efficiency of air distribution. The louver closes automatically when the unit stops.


- 5 steps of discharge angle can be set by remote controller.

- Discharge angle is automatically set at the same angle as the previous operation when restarts. (Initial setting; 10˚ for cooling and 70˚ for heating)



- Drain-pump kit is available as optional accessory, which lifts the drain 1,000mm from the bottom of the unit.

- Flexible installation.
  - Drain pipe can be fitted to from either left or right sides.



2. Specifications

Wall Mounted Type

Model			FXAQ20MAVE	FXAQ25MAVE	FXAQ32MAVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	2,000	2,500	3,200
		Btu/h	7,800	9,900	12,600
		kW	2.3	2.9	3.7
∗2 Cooling Capacity (19.0°CWB)		kW	2.2	2.8	3.6
∗3 Heating Capacity		kcal/h	2,200	2,800	3,400
		Btu/h	8,500	10,900	13,600
		kW	2.5	3.2	4.0
Casing Color			White (3.0Y8.5/0.5)	White (3.0Y8.5/0.5)	White (3.0Y8.5/0.5)
Dimensions: (H×W×D)		mm	290×795×230	290×795×230	290×795×230
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	2×14×1.4	2×14×1.4	2×14×1.4
	Face Area	m²	0.161	0.161	0.161
Fan	Model		QCL9661M	QCL9661M	QCL9661M
	Type		Cross Flow Fan	Cross Flow Fan	Cross Flow Fan
	Motor Output × Number of Units	W	40×1	40×1	40×1
	Air Flow Rate (H/L)	m³/min	7.5/4.5	8/5	9/5.5
		cfm	265/159	282/177	318/194
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Foamed Polystyrene / Foamed Polyethylene	Foamed Polystyrene / Foamed Polyethylene	Foamed Polystyrene / Foamed Polyethylene
Air Filter			Resin Net (Washable)	Resin Net (Washable)	Resin Net (Washable)
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)
	Drain Pipe	mm	VP13 (External Dia. 18 Internal Dia. 13)	VP13 (External Dia. 18 Internal Dia. 13)	VP13 (External Dia. 18 Internal Dia. 13)
Machine Weight (Mass)		kg	11	11	11
∗5 Sound Level (H/L) (220-240V)		dBA	35/29	36/29	37/29
Safety Devices			Fuse	Fuse	Fuse
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Installation Panel. Paper Pattern for Installation. Insulation Tape. Clamps. Screws.	Operation Manual. Installation Manual. Installation Panel. Paper Pattern for Installation. Insulation Tape. Clamps. Screws.	Operation Manual. Installation Manual. Installation Panel. Paper Pattern for Installation. Insulation Tape. Clamps. Screws.
Drawing No.			C : 3D039370B		

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length :7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1 m in front of the unit and 1 m downward. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 352 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

10

Wall Mounted Type

Model			FXAQ40MAVE	FXAQ50MAVE	FXAQ63MAVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	4,000	5,000	6,300
		Btu/h	16,000	19,800	24,900
		kW	4.7	5.8	7.3
∗2 Cooling Capacity (19.0°CWB)		kW	4.5	5.6	7.1
∗3 Heating Capacity		kcal/h	4,300	5,400	6,900
		Btu/h	17,000	21,500	27,300
		kW	5.0	6.3	8.0
Casing Color			White (3.0Y8.5/0.5)	White (3.0Y8.5/0.5)	White (3.0Y8.5/0.5)
Dimensions: (H×W×D)		mm	290×1,050×230	290×1,050×230	290×1,050×230
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	2×14×1.4	2×14×1.4	2×14×1.4
	Face Area	m²	0.213	0.213	0.213
Fan	Model		QCL9686M	QCL9686M	QCL9686M
	Type		Cross Flow Fan	Cross Flow Fan	Cross Flow Fan
	Motor Output × Number of Units	W	43×1	43×1	43×1
	Air Flow Rate (H/L)	m³/min	12/9	15/12	19/14
		cfm	424/318	530/424	671/494
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Foamed Polystyrene / Foamed Polyethylene	Foamed Polystyrene / Foamed Polyethylene	Foamed Polystyrene / Foamed Polyethylene
Air Filter			Resin Net (Washable)	Resin Net (Washable)	Resin Net (Washable)
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe	mm	VP13 (External Dia. 18 Internal Dia. 13)	VP13 (External Dia. 18 Internal Dia. 13)	VP13 (External Dia. 18 Internal Dia. 13)
Machine Weight (Mass)		kg	14	14	14
∗5 Sound Level (H/L) (220-240V)		dBA	39/34	42/36	46/39
Safety Devices			Fuse	Fuse	Fuse
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Installation Panel. Paper Pattern for Installation. Insulation Tape. Clamps. Screws.	Operation Manual. Installation Manual. Installation Panel. Paper Pattern for Installation. Insulation Tape. Clamps. Screws.	Operation Manual. Installation Manual. Installation Panel. Paper Pattern for Installation. Insulation Tape. Clamps. Screws.
Drawing No.			C : 3D039370B		

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1 m in front of the unit and 1 m downward. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 352 for Fan Motor Input.


Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

3. Dimensions

FXAQ20MA
FXAQ25MA
FXAQ32MA

Unit (mm)

3D034903C




No.	Name	Description
9	Left side pipe connection hole	
8	Right side pipe connection hole	
7	Grounding terminal	M4
6	Drain hose	VP13 (External dia. ϕ18)
5	Liquid pipe	ϕ6.4 Flare connection
4	Gas pipe	ϕ12.7 Flare connection
3	Air outlet	
2	Front grill	
1	Front panel	

10


FXAQ40MA
FXAQ50MA

Unit (mm)



FXAQ63MA


Unit (mm)



No.	Name	Description
9	Left side pipe connection hole	
8	Right side pipe connection hole	
7	Grounding terminal	M4
6	Drain hose	VP13 (External dia. φ18)
5	Liquid pipe	φ9.5 Flare connection
4	Gas pipe	φ15.9 Flare connection
3	Air outlet	
2	Front grill	
1	Front panel	

10

4. Piping Diagrams



JC : DU220-602J


■ **Refrigerant pipe connection port diameters**

(mm)

Model	Gas	Liquid
FXAQ20 · 25 · 32 · 40 · 50MA	ϕ12.7	ϕ6.4
FXAQ63MA	ϕ15.9	ϕ9.5

5. Wiring Diagrams

FXAQ20 · 25 · 32 · 40 · 50 · 63MAVE



6. Electric Characteristics

Units					Power supply		IFM		Input(W)	
Model	Type	Hz	Volts	Voltage range	MCA	MFA	kW	FLA	Cooling	Heating
FXAQ20MA	VE	50	220-240	MAX. 264 Min. 198	0.3	15	0.040	0.2	16	24
FXAQ25MA					0.4	15	0.040	0.3	22	27
FXAQ32MA					0.4	15	0.040	0.3	27	32
FXAQ40MA	VE				0.4	15	0.043	0.3	20	20
FXAQ50MA					0.4	15	0.043	0.3	27	32
FXAQ63MA					0.6	15	0.043	0.5	50	60
FXAQ20MA	VE	60	220	MAX. 242 Min. 198	0.3	15	0.040	0.2	16	24
FXAQ25MA					0.3	15	0.040	0.2	22	27
FXAQ32MA					0.4	15	0.040	0.3	27	32
FXAQ40MA	VE				0.4	15	0.043	0.3	20	20
FXAQ50MA					0.4	15	0.043	0.3	27	32
FXAQ63MA					0.6	15	0.043	0.5	50	60

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
kW : Fan Motor Rated Output(kW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

Note:

1. Voltage range
   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.
2. Maximum allowable voltage unbalance between phases is 2%.
3. MCA/MFA
   MCA = 1.25 X FLA
   MFA ≦ 4 X FLA
   (Next lower standard fuse rating. Min. 15A)
4. Select wire size based on the MCA.
5. Instead of fuse, use Circuit Breaker.

C : 4D034907E

7. Capacity Tables

7.1 Cooling Capacity

FXAQ-MA [50/60Hz]

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	SHC	16.0°CWB 23°CDB TC	SHC	18.0°CWB 26°CDB TC	SHC	19.0°CWB 27°CDB TC	SHC	20.0°CWB 28°CDB TC	SHC	22.0°CWB 30°CDB TC	SHC	24.0°CWB 32°CDB TC	SHC
20	10.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.9	1.9
	12.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.9	1.9
	14.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.8	1.9
	16.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.7	1.9
	18.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.7	1.9
	20.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.7	1.9
	21.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	2.0	2.7	1.9
	23.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	1.9	2.6	1.9
	25.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.6	1.9	2.6	1.9
	27.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.5	1.9	2.5	1.8
	29.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.5	1.9	2.5	1.8
	31.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.5	1.9	2.5	1.8
	33.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.4	1.9	2.4	1.8
	35.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.4	1.9	2.4	1.8
	37.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.3	1.9	2.4	1.9	2.4	1.7
	39.0	1.5	1.5	1.8	1.8	2.1	1.9	2.2	1.9	2.2	1.9	2.3	1.8	2.3	1.7
25	10.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.4	2.3	3.7	2.3
	12.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.4	2.3	3.6	2.2
	14.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.4	2.3	3.6	2.3
	16.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.4	2.3	3.5	2.2
	18.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.4	2.3	3.4	2.2
	20.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.4	2.3	3.4	2.2
	21.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.4	2.3	3.4	2.2
	23.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.3	2.2	3.3	2.2
	25.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.3	2.2	3.3	2.1
	27.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.2	2.2	3.2	2.1
	29.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.2	2.2	3.2	2.1
	31.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.1	2.2	3.1	2.1
	33.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.1	2.2	3.1	2.1
	35.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	3.0	2.2	3.0	2.2	3.0	2.0
	37.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	2.9	2.2	3.0	2.1	3.0	2.0
	39.0	1.9	1.8	2.3	2.0	2.6	2.2	2.8	2.2	2.9	2.2	2.9	2.1	3.0	2.0
32	10.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.3	2.8	4.7	2.8
	12.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.3	2.8	4.7	2.8
	14.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.3	2.8	4.6	2.8
	16.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.3	2.8	4.6	2.8
	18.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.3	2.8	4.5	2.7
	20.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.3	2.8	4.4	2.7
	21.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.3	2.8	4.4	2.7
	23.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.2	2.8	4.3	2.7
	25.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.2	2.8	4.3	2.6
	27.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.1	2.7	4.2	2.6
	29.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.1	2.7	4.2	2.6
	31.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	4.0	2.7	4.1	2.6
	33.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	3.9	2.6	4.0	2.5
	35.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.8	2.7	3.9	2.6	4.0	2.5
	37.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.7	2.6	3.8	2.6	3.9	2.5
	39.0	2.4	2.2	2.9	2.4	3.4	2.6	3.6	2.7	3.7	2.6	3.8	2.6	3.8	2.5

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	SHC	16.0°CWB 23°CDB TC	SHC	18.0°CWB 26°CDB TC	SHC	19.0°CWB 27°CDB TC	SHC	20.0°CWB 28°CDB TC	SHC	22.0°CWB 30°CDB TC	SHC	24.0°CWB 32°CDB TC	SHC
40	10.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.4	3.6	5.9	3.6
	12.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.4	3.6	5.8	3.5
	14.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.4	3.6	5.8	3.5
	16.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.4	3.6	5.7	3.5
	18.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.4	3.6	5.6	3.4
	20.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.4	3.6	5.5	3.4
	21.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.4	3.6	5.5	3.4
	23.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.3	3.6	5.4	3.3
	25.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.2	3.6	5.3	3.3
	27.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.2	3.5	5.3	3.3
	29.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.1	3.5	5.2	3.2
	31.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	5.0	3.4	5.1	3.2
	33.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.8	3.6	4.9	3.4	5.0	3.1
	35.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.7	3.6	4.9	3.4	4.9	3.1
	37.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.7	3.5	4.8	3.3	4.9	3.1
	39.0	3.0	2.9	3.6	3.3	4.2	3.7	4.5	3.5	4.6	3.5	4.7	3.3	4.8	3.0
50	10.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.7	4.4	7.4	4.4
	12.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.7	4.4	7.3	4.3
	14.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.7	4.4	7.2	4.3
	16.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.7	4.4	7.1	4.3
	18.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.7	4.4	7.0	4.2
	20.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.7	4.4	6.9	4.2
	21.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.7	4.4	6.8	4.2
	23.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.6	4.4	6.7	4.1
	25.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.5	4.3	6.6	4.1
	27.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.4	4.3	6.6	4.0
	29.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.3	4.2	6.5	4.0
	31.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.2	4.2	6.4	3.9
	33.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	6.0	4.3	6.1	4.2	6.3	3.9
	35.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	5.9	4.3	6.0	4.1	6.2	3.8
	37.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	5.8	4.3	5.9	4.1	6.1	3.8
	39.0	3.8	3.2	4.5	3.7	5.2	4.1	5.6	4.2	5.7	4.2	5.8	4.0	6.0	3.8
63	10.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.5	5.6	9.3	5.3
	12.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.5	5.6	9.2	5.3
	14.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.5	5.6	9.1	5.2
	16.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.5	5.6	9.0	5.2
	18.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.5	5.6	8.8	5.2
	20.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.5	5.6	8.7	5.1
	21.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.5	5.6	8.7	5.1
	23.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.4	5.5	8.5	5.0
	25.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.3	5.5	8.4	5.0
	27.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.1	5.4	8.3	4.9
	29.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	8.0	5.4	8.2	4.9
	31.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	7.9	5.3	8.1	4.8
	33.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.6	5.4	7.8	5.2	7.9	4.8
	35.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.5	5.4	7.7	5.2	7.8	4.7
	37.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.4	5.3	7.5	5.1	7.7	4.7
	39.0	4.8	4.1	5.7	4.6	6.6	5.1	7.1	5.3	7.2	5.3	7.4	5.1	7.6	4.6

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

10

7.2 Heating Capacity

FXAQ-MA [50/60Hz]

Heating capacity

Unit Size	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
	°CDB	°CWB	kW		kW		kW		kW		kW		kW	
20	-19.8	-20.0	1.5		1.5		1.5		1.5		1.5		1.5	
	-18.8	-19.0	1.5		1.5		1.5		1.5		1.5		1.5	
	-16.7	-17.0	1.6		1.6		1.6		1.6		1.6		1.6	
	-14.7	-15.0	1.7		1.7		1.7		1.7		1.7		1.7	
	-12.6	-13.0	1.8		1.8		1.8		1.8		1.8		1.8	
	-10.5	-11.0	1.9		1.9		1.9		1.9		1.9		1.9	
	-9.5	-10.0	1.9		1.9		1.9		1.9		1.9		1.9	
	-8.5	-9.1	2.0		2.0		1.9		1.9		1.9		1.9	
	-7.0	-7.6	2.0		2.0		2.0		2.0		2.0		2.0	
	-5.0	-5.6	2.1		2.1		2.1		2.1		2.1		2.0	
	-3.0	-3.7	2.2		2.2		2.2		2.2		2.2		2.2	
	0.0	-0.7	2.3		2.3		2.3		2.3		2.3		2.2	
	3.0	2.2	2.5		2.5		2.4		2.4		2.3		2.2	
	5.0	4.1	2.5		2.6		2.5		2.4		2.3		2.2	
	7.0	6.0	2.7		2.7		2.5		2.4		2.3		2.2	
	9.0	7.9	2.8		2.7		2.5		2.4		2.3		2.2	
	11.0	9.8	2.8		2.7		2.5		2.4		2.3		2.2	
	13.0	11.8	2.8		2.7		2.5		2.4		2.3		2.2	
	15.0	13.7	2.8		2.7		2.5		2.4		2.3		2.2	
25	-19.8	-20.0	1.9		1.9		1.9		1.9		1.9		1.9	
	-18.8	-19.0	1.9		1.9		1.9		1.9		1.9		1.9	
	-16.7	-17.0	2.1		2.1		2.0		2.0		2.0		2.0	
	-14.7	-15.0	2.2		2.2		2.2		2.2		2.2		2.1	
	-12.6	-13.0	2.3		2.3		2.3		2.3		2.3		2.3	
	-10.5	-11.0	2.4		2.4		2.4		2.4		2.4		2.4	
	-9.5	-10.0	2.5		2.5		2.4		2.4		2.4		2.4	
	-8.5	-9.1	2.5		2.5		2.5		2.5		2.5		2.5	
	-7.0	-7.6	2.6		2.6		2.6		2.6		2.6		2.6	
	-5.0	-5.6	2.7		2.7		2.7		2.7		2.7		2.7	
	-3.0	-3.7	2.8		2.8		2.8		2.8		2.8		2.8	
	0.0	-0.7	3.0		3.0		3.0		3.0		3.0		2.8	
	3.0	2.2	3.1		3.1		3.1		3.1		3.0		2.8	
	5.0	4.1	3.3		3.2		3.2		3.1		3.0		2.8	
	7.0	6.0	3.4		3.4		3.2		3.1		3.0		2.8	
	9.0	7.9	3.5		3.4		3.2		3.1		3.0		2.8	
	11.0	9.8	3.6		3.4		3.2		3.1		3.0		2.8	
	13.0	11.8	3.6		3.4		3.2		3.1		3.0		2.8	
	15.0	13.7	3.6		3.4		3.2		3.1		3.0		2.8	
32	-19.8	-20.0	2.4		2.4		2.3		2.3		2.3		2.3	
	-18.8	-19.0	2.4		2.4		2.4		2.4		2.4		2.4	
	-16.7	-17.0	2.6		2.6		2.6		2.6		2.6		2.5	
	-14.7	-15.0	2.7		2.7		2.7		2.7		2.7		2.7	
	-12.6	-13.0	2.9		2.8		2.8		2.8		2.8		2.8	
	-10.5	-11.0	3.0		3.0		3.0		3.0		3.0		3.0	
	-9.5	-10.0	3.1		3.1		3.1		3.0		3.0		3.0	
	-8.5	-9.1	3.1		3.1		3.1		3.1		3.1		3.1	
	-7.0	-7.6	3.2		3.2		3.2		3.2		3.2		3.2	
	-5.0	-5.6	3.4		3.4		3.4		3.4		3.4		3.4	
	-3.0	-3.7	3.5		3.5		3.5		3.5		3.5		3.5	
	0.0	-0.7	3.7		3.7		3.7		3.7		3.7		3.5	
	3.0	2.2	3.9		3.9		3.9		3.9		3.7		3.5	
	5.0	4.1	4.2		4.1		4.0		3.9		3.7		3.5	
	7.0	6.0	4.3		4.3		4.0		3.9		3.7		3.5	
	9.0	7.9	4.5		4.3		4.0		3.9		3.7		3.5	
	11.0	9.8	4.5		4.3		4.0		3.9		3.7		3.5	
	13.0	11.8	4.5		4.3		4.0		3.9		3.7		3.5	
	15.0	13.7	4.5		4.3		4.0		3.9		3.7		3.5	

Heating capacity


Unit Size	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
	°CDB	°CWB	kW		kW		kW		kW		kW		kW	
40	-19.8	-20.0	3.0		2.9		2.9		2.9		2.9		2.9	
	-18.8	-19.0	3.0		3.0		3.0		3.0		3.0		3.0	
	-16.7	-17.0	3.2		3.2		3.2		3.2		3.2		3.2	
	-14.7	-15.0	3.4		3.4		3.4		3.4		3.4		3.4	
	-12.6	-13.0	3.6		3.6		3.6		3.5		3.5		3.5	
	-10.5	-11.0	3.7		3.7		3.7		3.7		3.7		3.7	
	-9.5	-10.0	3.8		3.8		3.8		3.8		3.8		3.8	
	-8.5	-9.1	3.9		3.9		3.9		3.8		3.9		3.9	
	-7.0	-7.6	4.0		4.0		4.0		4.0		4.0		4.0	
	-5.0	-5.6	4.2		4.2		4.2		4.2		4.2		4.2	
	-3.0	-3.7	4.4		4.4		4.4		4.4		4.4		4.4	
	0.0	-0.7	4.7		4.6		4.6		4.6		4.6		4.4	
	3.0	2.2	4.9		4.9		4.9		4.8		4.7		4.4	
	5.0	4.1	5.1		5.1		5.0		4.8		4.7		4.4	
	7.0	6.0	5.2		5.2		5.0		4.8		4.7		4.4	
	9.0	7.9	5.4		5.3		5.0		4.8		4.7		4.4	
	11.0	9.8	5.6		5.3		5.0		4.8		4.7		4.4	
	13.0	11.8	5.6		5.3		5.0		4.8		4.7		4.4	
	15.0	13.7	5.6		5.3		5.0		4.8		4.7		4.4	
50	-19.8	-20.0	3.7		3.7		3.7		3.7		3.7		3.7	
	-18.8	-19.0	3.8		3.8		3.8		3.8		3.8		3.7	
	-16.7	-17.0	4.1		4.0		4.0		4.0		4.0		4.0	
	-14.7	-15.0	4.3		4.3		4.3		4.2		4.2		4.2	
	-12.6	-13.0	4.5		4.5		4.5		4.5		4.5		4.5	
	-10.5	-11.0	4.7		4.7		4.7		4.7		4.7		4.7	
	-9.5	-10.0	4.8		4.8		4.8		4.8		4.8		4.8	
	-8.5	-9.1	4.9		4.9		4.9		4.9		4.9		4.9	
	-7.0	-7.6	5.1		5.1		5.1		5.1		5.1		5.1	
	-5.0	-5.6	5.3		5.3		5.3		5.3		5.3		5.3	
	-3.0	-3.7	5.5		5.5		5.5		5.5		5.5		5.5	
	0.0	-0.7	5.9		5.9		5.8		5.8		5.8		5.8	
	3.0	2.2	6.2		6.2		6.2		6.1		5.9		5.9	
	5.0	4.1	6.4		6.4		6.3		6.1		5.9		5.9	
	7.0	6.0	6.6		6.6		6.3		6.1		5.9		5.9	
	9.0	7.9	6.8		6.7		6.3		6.1		5.9		5.9	
	11.0	9.8	7.0		6.7		6.3		6.1		5.9		5.9	
	13.0	11.8	7.1		6.7		6.3		6.1		5.9		5.9	
	15.0	13.7	7.1		6.7		6.3		6.1		5.9		5.9	
63	-19.8	-20.0	4.7		4.7		4.7		4.7		4.7		4.7	
	-18.8	-19.0	4.9		4.9		4.8		4.8		4.8		4.8	
	-16.7	-17.0	5.1		5.1		5.1		5.1		5.1		5.1	
	-14.7	-15.0	5.4		5.4		5.4		5.4		5.4		5.4	
	-12.6	-13.0	5.7		5.7		5.7		5.7		5.7		5.7	
	-10.5	-11.0	6.0		6.0		6.0		6.0		6.0		5.9	
	-9.5	-10.0	6.1		6.1		6.0		6.0		6.1		6.1	
	-8.5	-9.1	6.3		6.3		6.2		6.2		6.2		6.2	
	-7.0	-7.6	6.5		6.5		6.4		6.4		6.4		6.4	
	-5.0	-5.6	6.8		6.7		6.7		6.7		6.7		6.7	
	-3.0	-3.7	7.0		7.0		7.0		7.0		7.0		7.0	
	0.0	-0.7	7.5		7.4		7.4		7.4		7.4		7.0	
	3.0	2.2	7.9		7.8		7.8		7.7		7.5		7.0	
	5.0	4.1	8.1		8.4		8.0		7.7		7.5		7.0	
	7.0	6.0	8.4		8.4		8.0		7.7		7.5		7.0	
	9.0	7.9	8.7		8.5		8.0		7.7		7.5		7.0	
	11.0	9.8	8.9		8.5		8.0		7.7		7.5		7.0	
	13.0	11.8	9.0		8.5		8.0		7.7		7.5		7.0	
	15.0	13.7	9.0		8.5		8.0		7.7		7.5		7.0	

Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

8. Sound Levels

Overall

■ **Wall Mounted Type**



4D037087D

Note:
1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.

dBA


Model	220~240V 50Hz / 220V 60Hz	
	H	L
FXAQ20MA	35	29
FXAQ25MA	36	29
FXAQ32MA	37	29
FXAQ40MA	39	34
FXAQ50MA	42	36
FXAQ63MA	46	39

10

Octave Band Level


○——○ 220~240V 50Hz / 220V 60Hz

FXAQ20MAVE




4D037087D

FXAQ25MAVE




4D037088D

FXAQ32MAVE




4D037089D

FXAQ40MAVE




4D038513A

FXAQ50MAVE



4D038514A


FXAQ63MAVE



4D038515A

9. Installation


Installation Example



C : 3PN02401-8Q

Recommended mounting-plate retention spots and Dimensions


20 · 25 · 32 class



ITEM	ITEM MARK	AA	AB	AC	AD	REMARK
1	B	44.5	89	10	10	DIT
2	C	34.5	79	8	8	DIL,Shanghai ARAI

C : 1P079690-1C

40 · 50 · 63 class



C : 2P095003-1C

10

Service Space

(1) Select an installation site where the following conditions are fulfilled and that meets with your customer's approval.

- In the upper space (including the back of the ceiling) of the indoor unit where there is no possible dripping of water from the refrigerant pipe, drain pipe, water pipe, etc.
- Where the wall is strong enough to bear the indoor unit weight.
- Where sufficient clearance for installation and maintenance can be ensured. **(Refer to Fig. 1 and Fig. 2)**
- Where optimum air distribution can be ensured.
- Where nothing blocks the air passage.
- Where condensate can be properly drained.
- Where the wall is not significantly tilted.
- Where not exposed to combustible gases.
- Where pipe between indoor and outdoor units is possible within the allowable limit. (Refer to the installation manual of the outdoor unit.)
- Install the indoor and outdoor units, power cable and transmission wiring, at least 1 m from TVs and radios, to prevent distorted pictures and static. (Depending on the type and source of the electrical waves, static may be heard even when more than 1 m away.)
- Install the indoor unit no less than 2.5 m above the floor. Where unavoidably lower, take what measures are necessary to keep hands out of the air inlet.
- Where the cool (warm) air reaches all across the room.

[Space required for installation (mm)]




Fig. 1




Fig. 2

(2) Consider whether the place where the unit will be installed can support the full weight of the unit, and reinforce it with boards and beams, etc. if needed before proceeding with the installation. Also, reinforce the place to prevent vibration and noise before installing. (The installation pitch can be found on the paper pattern for installation (3), so refer to it when considering the necessity for reinforcing the location.)

(3) The indoor unit may not be directly installed on the wall. Use the attached installation panel (1) before installing the unit.

C : 3P156215-6D

Installation

(1) Open the piping through-hole.

- The refrigerant pipe and drain pipe can be passed out in one of 6 directions: left, bottom-left, back-left, right, bottom-right, and back-right. **(Refer to Fig. 3)**
- Using the paper pattern for installation (3), choose where to pass the piping out and open a through-hole (ϕ80) in the wall.
  Open the hole so that there is a downward slope for the drain piping. (See "DRAIN PIPING WORK")

(2) Remove the installation panel (1) from the unit and attach to the wall.

(The installation panel is temporarily attached to the unit with screw. (In case of 20-32 type))
(Refer to Fig. 3)

(a) Check the location for the hole using the included paper pattern for installation (3).
- Choose a location so that there is at least a 90 mm gap between the ceiling and the main unit.

(b) Temporarily attach the installation panel (1) at the temporary-securing position on the paper pattern for installation (3) and use a level to make sure the drain hose is either level or tilted slightly downward.

(c) Secure the installation panel (1) to the wall using either screws or bolts.
- If using the attachment screws for the installation panel (2), attach using at least 4 screws on either side (for a total of 8 screws (20-32 type), 9 screws (40-63 type)) of the recommended installation cleat position on the included paper pattern for installation (3).
- If using bolts, attach using a M8 - M10 bolt (for a total of 2 bolts) on either side.
- If dealing with concrete, use commercially available foundation bolts (M8 - M10).

(3) If using the left, bottom-left, right, or bottom-right positions for the piping, cut out the through-hole for the piping in the front grill. (Refer to Fig. 4)




Fig. 3




Fig. 4

(4) Remove the front panel and the service lid. (Refer to Fig. 5)

< How to remove the front panel and service lid >

(1) Open the front panel to the point where it stops.

(2) Push the axes on either side of the front panel towards the center of the main unit and remove. (You can also remove it by sliding the front panel either to the left or right and pulling it forward.)

(3) Remove the screw from the service lid and pull the handle forward.




Fig. 5

C : 3P156215-6D

(5) Point the pipe in the direction it will be passed out.

For right, bottom-right, and back-right piping (Refer to Fig. 6)

- Wrap the drain hose and the refrigerant piping together with the insulating tape (4) so that the drain hose is below the refrigerant piping.




Fig. 6

For left, bottom-left, and left-back piping

- Remove the front grill. **(Refer to Fig. 7)**

< How to remove the front grill >

Remove the front grill as described below when securing the indoor unit with screws or when attaching Optional Accessories (wireless remote controller, adapter PC board, etc.).

(1) Remove the front panel.

(2) Remove the screws (2 places in case of FXA(Q)20,25,32 type/3 places in case of FXA(Q)40,50,63 type) securing the front grill.

(3) Remove the tabs (3 places) securing the front grill by pushing them in the direction of the arrows.

(4) Making sure not to catch the horizontal flaps, remove the front grill by pulling in the direction of the arrow.




Fig. 7

- Remove the drain plug, the insulation tubing, and the drain hose from the drain pan and replace. **(Refer to Fig. 8)**
- Connect the local refrigerant piping ahead of time, matching it to the liquid pipe and gas pipe marks engraved on the installation panel (1).

< Replacing the drain hose and drain plug >

(1) Remove the drain plug and insulation tubing.
(2) Remove the drain hose and replace onto the left side.
(3) Replace the drain plug and the insulation tubing onto the right side.




Fig. 8

C : 3P156215-6D

(6) Hook the indoor unit onto the installation panel. (Refer to Fig. 9)

• Placing buffering material between the wall and the indoor unit at this time will make work easier.




Fig. 9

For right, bottom-right, and back-right piping

• Pass the drain hose and the refrigerant piping to the wall.

(7) Pass power supply wiring, transmission wiring, ground wiring, and remote controller wiring through the wiring guide in through the back of the indoor unit and to the front.

(8) Connect the piping. (See Fig. 10)




Fig. 10

• To avoid the influence of noise from the power supply line on the transmission wiring and the remote controller wiring, these wirings must be kept as far as possible from the power/ground wirings. As shown in the figure, keep the power supply wiring and the ground wiring together. Keep the transmission and remote controller wirings together and route them maintaining a good distance from the power supply/ground wirings (that is, on the other side of the power supply/ground wirings). Then, fix them securely on the refrigerant pipe.

• Seal the piping through-hole with putty corking material.

(9) Push on both bottom edges of the indoor unit using both hands and hook the tab on the back of the indoor unit onto the installation panel (1). (Refer to Fig. 9)

• At this time remove the buffering material placed in step (6).

C : 3P156215-6D

10

- Make sure power supply wiring, transmission wiring, ground wiring and remote controller wiring are not caught inside the indoor unit.

■ When screwing in the indoor unit

- Remove the front grill. **(Refer to Fig. 7)**
- Secure the indoor unit to the installation panel (1) with the securing screws (6). **(Refer to Fig. 11)**




Fig. 11

C : 3P156215-6D

Drain Piping Work

(1) Install the drain piping. (Refer to Fig. 16)

- The drain pipe should be short with a downward slope and should prevent air pockets from forming.
- Watch out for the points in the figure 16 when performing drain work.




Fig. 16

- When extending the drain hose, use a commercially available drain extension hose, and be sure to insulate the extended section of the drain hose which is indoors. **(Refer to Fig. 17)**




Fig. 17

- Make sure the diameter of the piping is the same as the piping (hard vinyl chloride, nominal diameter 13mm) or bigger.
- When directly connecting a hard vinyl chloride pipe joint (nominal diameter 13mm) to the drain hose connected to the indoor unit (i.e. for embedded piping, etc.), use a commercially available hard vinyl chloride pipe joint (nominal diameter 13mm). **(Refer to Fig. 18)**




Fig. 18

(2) Make sure the drain works properly.

- After drain work is complete, perform a drain check by opening the front panel, **removing the air filter**, pouring water into the drain pan, and making sure water flows smoothly out of the drain hose. **(Refer to Fig. 19)**




Fig. 19

⚠ CAUTION

Drain piping connections

Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain pipes and corrode the heat exchanger.




Keep in mind that it will become the cause of getting drain pipe blocked if water collects on drain pipe.

C : 3P156215-6D

10. Accessories

Standard Accessories

FXAQ20~63MA

Name	(1) Installation panel	(2) Attachment screws for the installation panel	(3) Paper pattern for installation	(4) Insulating tape	(5) Clamp
Quantity	1 set	8 pcs. → FXA(Q)20,25,32 type 9 pcs. → FXA(Q)40,50,63 type	1 pc.	1 pc.	1 large 3 small
Shape		 M4 × 25L			

Name	(6) Securing screws	(Other) • Operation manual • Installation manual
Quantity	2 pcs.	
Shape	 M4 × 12L	

C : 3P156215-6D

Optional Accessories (For Unit)

No.	Type / Item	FXAQ20MA	FXAQ25MA	FXAQ32MA	FXAQ40MA	FXAQ50MA	FXAQ63MA
1	Drain pump kit	K-KDU572EVE					

Optional Accessories (For Controls) : Refer to P.807

Drain Pump Kit — K-KDU572EVE (Supplying goods to order)

Operating sound as small as 25dB



Features


1. Silent operation with no sign of pump operation
2. Design matching with wall mounted type air conditioner
3. Can be interlocked with air conditioner.

Usage

- **Home, office, and store**
- **Optimum for redesign**

Caution :
- Drain pump kit is only for the air conditioner. Please use it for the drain treatment of the air conditioner.
- Be sure to lay the piping inclined down after drain-up, which is different from drain pump.
- Please do not use it in the place where soot such as kitchens is shrouded and the place where an organic solvent drifts.

Dimensions Unit : mm




Specification

	K-KDU572EVE
Drain pump head (mm) (Note 1)	1,000
Power supply	Single phase 220-240V/220V, 50/60Hz
Power consumption	14.1/12.9 (W)
Operating current	0.18/0.16 (A)
Insulation	Class E
Drain inlet connection pipe diameter	VP20 (Note 2)
Drain exit connection pipe diameter	VP20
Safety device	Float switch
Operating sound (dB)	25
Machine weight (Mass)(kg)	3.2
Drain exhaust flow rate (ml/min)	400

Note : 1. Height from bottom of drain pump kit up to the drain pipe.
2. Connect to the VP13 using the soft reducing socket.

Wiring Diagram



Application model	FAY71LVE FAYP71LV1	FXA20·25·32LVE(C) FXA40·50·63LVE FXAQ20·25·32MVE FXAQ40·50·63MVE	FAQ71BUV1B
Connection diagram	X2M Tes2 ⏚ 1 2 3	X2M ⏚ L N	X2M ⏚ 1 2 3

The earth wire (copper) should be at least 2.0mm² or ϕ 1.6mm.
When the relay wire harness is connected, remove the X15A short-circuit connector.

Note : 1. Don't forget to turn on the power. If it is not turned on, the air conditioner will perform an error stop and operation will not be possible.
2. Make sure that slide switch SS1 on the drain pump kit printed circuit board assembly is set to P2 and slide switch SS2 is set to P1.
3. The relay wire harness cannot be extended.
4. Turning on the power will close the K2R connector, making is a non-volt B connector.


Component Parts

Name	Shape	Quantity	Name	Shape	Quantity	Name	Shape	Quantity
Drain Pump Kit	①	1	Insulation	⑦ 50X300Xt10	1	Rigid polyvinyl chloride pipe (Note3)	⑬ VP13, 365	1
Relay wire harness	② (Green) (Red)	1	Clamp	⑧	2	Soft drain pipe	⑭ VP20, 200	1
Connecting harness	③ (White)	1	Clamp	⑨	1	Screw washer	⑮ (White)	1
Power cord	④ (Blue)	1	Soft reducing socket	⑩ VP13	1	Screw	⑯ M5X35	5
Insulation pipe cover	⑤	1	Drain hose	⑪ 150	1	Clamp material	⑰	4
Insulation	⑥ 90X300Xt2	1	Rigid polyvinyl chloride pipe joint	⑫ VP13, 57	1	Paper pattern for Installation	⑱	1
						Installation manual	⑲	1

Note 3: This pipe must be procured locally for the large capacity machine.


External drawing of drain pump kit and Service space

The drain pump kit can be installed to the left or the right of the air conditioner.
The diagram below illustrates a left installation.




When using centralized piping

- Follow the figure below to make sure there is absolutely no back-up when using centralized piping.




Description of operation

1: Operation at normal water level (Air conditioner operates when water level is at operation level, and when water level is at stop level, residual operation is performed.)



2: Operation at abnormal water level
(When water level is abnormal, the air conditioner stops. When abnormal water level is kept five minutes or longer, abnormal water level is established, and residual operation is performed.)



Note 1) When the float switch (for abnormal water level) is reset within five minutes, the air conditioner operates again with “normal water level”.
Note 2) When abnormal water level is fixed, power must be turned on again for operating again.
Note 3) When the cycle of operation 5 minutes - stop 5 seconds - operation 5 minutes is finished, if the float switch (for abnormal water level) is not reset, keep operation of drain pump until the switch is reset.

10


1 Pre-installation preparations

● See the indoor unit's installation manual for indoor unit work.

Drain pump kit preparations

● Remove the casing and the drain pump kit from the mounting plate.


1. Remove the casing fixed screw and pull the casing down and forward.
2. Remove 2 Screws of the drain pump kit and lift the drain pump kit out.



2 Indoor unit preparations

● Make sure the indoor unit is installed first.

1. Attaching of the indoor unit mounting plate
   After installing the mounting plate following the directions in the indoor unit, make sure it is plainness using a level.
2. Decide the left and the right piping extraction direction and cut off the exit hole for the piping on the bottom frame by the cutter etc.
3. Connecting the drain hose




In the case of a left installation

1. Connect the rigid polyvinyl chloride pipe joint (accessory ⑫) to the indoor unit drain hose using adhesive.
2. Connect the rigid polyvinyl chloride pipe (accessory ⑬ for small capacity machine. Local procurement for the large capacity) to the rigid polyvinyl chloride pipe joint (accessory ⑫) using adhesive.


In the case of a right installation

1. Remove the drain hose connected to the indoor unit and replace with a drain plug and insulation tube.
2. The drain hose removed from the indoor unit is attached to left side.
3. Connect the rigid polyvinyl chloride pipe joint (accessory ⑫) to the indoor unit drain hose using adhesive.
4. Connect the rigid polyvinyl chloride pipe (accessory ⑬ for small capacity machine. Local procurement for the large capacity) to the rigid polyvinyl chloride pipe joint (accessory ⑫) using adhesive.




Replacing the drain plug

① Remove the drain plug and the insulation tube.
② Remove the standard drain hose.
(The standard drain hose is not used to connect the drain pump kit.)
③ Replace the drain plug and the insulation tube onto the right side.




When using the drain hose (accessory ⑪)

① Remove the indoor unit drain hose and attach the drain hose (accessory ⑪).
② Connect the rigid polyvinyl chloride pipe (accessory ⑬) to the drain hose (accessory ⑪) using adhesive.




3 Installing the mounting plate


1. Install the indoor unit.




2. Cut out the indoor unit section from the paper pattern for installation (accessory ⑱) and attach to the installation position on the indoor unit.




3. Cut the rigid polyvinyl chloride pipe (accessory ⑬) attached to the indoor unit to the length indicated on the paper pattern for installation.



4. Determine the position to secure the mounting plate for the drain pump kit by matching to the paper pattern for installation. Remove the paper pattern for install once this is done.
   - ● If using screws (accessory ⑯), fix it at least 4 positions.
   - ● For concrete, attach it using commercially available anchors (M8) and bolts.



5. Attach the drain pump kit to the mounting plate and squeeze in the fixed screws.
6. Remove the circuit board cover.




4 Attaching the relay wire harness, the connection harness, and the power cord.

⚠ Caution Only connect after shutting off the power.

< Precautions when laying power and earth wiring >

Use ring type crimp style terminals for connections to the inter-unit wiring terminal block and the earth wiring. When none are available, follow the instructions below.

- ● Do not connect wiring of different thicknesses to the inter-unit wiring terminal block. (Looseness in the terminal may cause abnormal heat.)
- ● For wiring, use the designated power wire and connect firmly, then secure to prevent outside pressure being exerted on the terminal board.
- ● Use an appropriate screwdriver for tightening the terminal screws. A screwdriver with a small head will strip the head and make proper tightening impossible.
- ● Over-tightening the terminal screws may break them.
- ● See the table at right for tightening torque for the terminal screws.




Tightening torque(N·m)	
Inter-unit wiring terminal block	1.18 – 1.44
earth terminal	1.44 – 1.94

For the FXYA71LV, FAYP71LV1, FXA20·25·32LVE(C)
FXYA40·50·63LVE, FXAQ20·25·32·40·50·63MVE


- ● Connect the relay wire harness (accessory ②) and the power cord (accessory ④) to the indoor unit.

1. Remove the front grill according to the instruction manual that came with the indoor unit.




3K019617


2. Remove the service lid.




3. Remove the indoor circuit board assembly CN15 short-circuit connector and connect the relay wire harness (accessory②) connector.



4. Connect the power cord (accessory④) to the indoor unit inter-unit wiring terminal block.
- When connecting the terminal to the inter-unit wiring terminal block, make sure it is attached properly, as shown below. If the pressure terminals are mistakenly attached in the same direction, the surface of the terminal that is touching will be reduced, causing heat and perhaps burn damage.




5. Connect the earth wire (locally procured-copper wire at least 2mm²) between the unit and the drain up kit with the earth connection screw for the indoor unit.



For the FAQ71BUV1B

- Connect the relay wire harness (accessory②), the connecting harness (accessory③) , and the power cord (accessory④) to the indoor unit.

1. Remove the connecting harness on the relay wire harness (accessory②) and connect the included connecting harness (accessory③).




2. How to remove a front panel and the service lid according to the indoor unit installation manual.

[Removing the front panel and service lid]

(1)Open the front panel as far as it stops.


(2)Push the axes on either side of the front panel towards the center of the main unit and remove. (You can also remove it by sliding the front panel either to the left or right and pulling it forward.)

(3)Remove the screws from the service lid and pull the handle forward.




3K019617


3. Remove the indoor unit printed circuit board X15A Jumper connector and connect the relay wire harness (accessory②) connector.



4. Connect the power cord (accessory④) to the indoor unit inter-unit wiring terminal block.
- When connecting the terminal to the inter-unit wiring terminal block, make sure it is attached properly, as shown below. If the crimp styl terminals are mistakenly attached in the same direction, the surface of the terminal that is touching will be reduced, causing heat and perhaps burn damage.




5. Connect the earth wire (locally procured - copper wire at least 2mm²) between the indoor unit and the drain pump kit with the ground connection screw for the ndoor unit. Be sure to perform earthing. Make sure the earthing resistance is below 100 ohms.




⑤ Passing the wire through

1. See the figure below for how to pass the wire through. The relay wire harness, power cord and earth wire should be matched to the space inside the indoor unit.




2. Connect the relay wire harness (accessory ②) to the drain pump kit circuit board assembly connector (X6A).
3. Connect the power cord (accessory ④) to the drain pump kit circuit board assembly connector (X1A).
4. Secure the earth wire (locally procured-copper wire at least 2mm²) to the drain pump kit using the earth connection screw.
5. Tighten the relay wire harness (accessory ②) using the clamping material.
6. Make sure that slide switch SS1 on the drain pump kit printed circuit board is set to P2 and slide switch SS2 is set to P1.
7. Attach the circuit board cover.
8. Tighten the relay wire harness (accessory ②), power cord (accessory④), and earth wire (locally procured) using the clamping material.
9. Bundle excess relay wire harness (accessory ②) using the clamping material (accessory⑰) and store away.
10. Connect the earth wire.




3K019618

10




6 Installing the drain pump kit and drain piping.


1. When installing the drain pump kit to the right, transfer the drain plug and the insulating tubing from the left to the right.
   - When performing a left installation, there is no need to transfer these items.




2. Insert the clamp (accessory ⑨) and the soft reducing socket (accessory ⑩) into the indoor unit the rigid polyvinyl chloride pipe (accessory ⑬), then match the position and tighten up the clamp to match the length of the drain pump kit drain pan socket.




3. Matching the dimensions of the area required, cut the right length of insulation (accessory ⑥) for the drain hose rigid polyvinyl chloride pipe section and attach.




4. Insert the insulation pipe cover (accessory ⑤) as far into the drain hose as it can go.
   - There is a slit in one side of the insulation pipe cover. Position the slit side to the drain pump kit.
   - Cut the insulation pipe cover to match the length of the drain hose.






5. Insert the clamp (accessory ⑧) and the soft reducing socket (accessory ⑩) into the drain pump kit drain socket and tighten it.




6. Secure the insulation tubing and power line with tape.



7. Connect the exit pipe.
   - Be sure to use adhesive to connect the soft drain pipe (accessory ⑭) and the ceiling-side locally-procured the drain pipe.
   - Connections on the drain pump kit should be secured with a clamp (accessory ⑧) and wrapped with insulation (accessory ⑦).

⚠Caution
- Exit piping parts must be procured locally.
- Be sure to insulate the drain piping.
- Give the horizontal sections on the drain piping a downward slope of at least 1/100 and make sure no air bubbles accumulate.
- Secure long horizontal sections with support clamps to prevent them from shaking.



7 Test run

- Make sure the pump is running and water is draining.
- Make sure there are no leaks from the drain pipes when draining.


⚠Caution
- Before the work confirm the power off.
- After replacing the circuit board cover to its original location, turn on the power.

1. Remove the front cover on the drain pump kit and fill the drain pan halfway with water.
2. Turn on the power and make sure that the drain pump is working properly and the drain water is flowing smoothly.

Abnormal-stop confirmation

1. Turn on the air conditioner.
2. Lift the float switch (abnormal) and make sure the air conditioner is stopped.


⚠Caution Do not get the drain pump mechanism



- After checking, replace the front cover.
- Rebuild the indoor unit as it was.

8 Attaching the casing

- Cut out the piping exit hole from the casing.
- Secure the casing with the installation screws and washers as described below.
- When securing the casing in two places right and left, use the screws and washers (accessory ⑯).



3K019618

9 Checks after completion

You should re-check the following after completion of work.


Items to be checked	Check column
Are the indoor unit and drain pomp kit level?	
Is the drain piping properly connected? Is there any possibility of developing water leaks?	
Is the drain piping run on a downhill grade?(1/50~1/100)	
Is the drain hose properly insulated?	
Is the equipment wired correctly?	

After test running the air conditioner, use the operating in cooling and check the operating sound of the drain pump kit.

10 Cautions during operation

- The pump repeats an operation stop with the float switch for operation during airconditioning operation.
- After cooling is stopped, the residual water will be drained out, so do not turn off the power immediately.
- Wait at least 5 minutes after the unit has stopped before turning off the power. When not turning off a power supply, a remains operation about 20 minutes back drain pump stops.
  When a safe circuit operates, operation of an air conditioner is stopped.
- During air conditioning operation, when water leaks from the inside of an are conditioner or a drain pump kit, please stop operation immediately.
- Since the drain exit is choked up or there is possibility that the safe circuit may not operate normally, please inform the store of purchase.

Electric wiring



Application model	FAY71LVE FAYP71LV1	FXA20·25·32LVE(C) FXA40·50·63LVE FXAQ20·25·32MVE FXAQ40·50·63MVE	FAQ71BUV1B
Connection diagram	X2M Tes2 ⏚ 1 2 3	X2M ⏚ L N	X2M ⏚ 1 2 3

The earth wire (copper) should be at least 2.0mm² or ϕ 1.6mm.
When the relay wire harness is connected, remove the X15A short-circuit connector.

Note1: Don't forget to turn on the power. If it is not turned on, the air conditioner will perform an error stop and operation will not be possible.
Note2: Make sure that slide switch SS1 on the drain pump kit printed circuit board assembly is set to P2 and slide switch SS2 is set to P1.
Note3: The relay wire harness cannot be extended.
Note4: Turning on the power will close the K2R connector, making is a non-volt B connector.

3K019618

10


FXLQ-MA / FXNQ-MA Floor Standing Type / Concealed Floor Standing Type

1. Features 374
2. Specifications 375
   2.1 FXLQ-MA 375
   2.2 FXNQ-MA 377
3. Dimensions 379
   3.1 FXLQ-MA 379
   3.2 FXNQ-MA 382
4. Piping Diagrams 385
5. Wiring Diagrams 386
6. Electric Characteristics 387
7. Capacity Tables 388
   7.1 Cooling Capacity 388
   7.2 Heating Capacity 389
8. Sound Levels 390
9. Installation 392
10. Accessories 395

11


1. Features

Efficient for perimeter zone airconditioning.



FXLQ-MA

Can be built into pericounter




FXNQ-MA

(1) New round-shape adds the gentle feeling to office environment.

- Mild color is applied to the discharge grille and the bottom frame.
- The slimming top plate ensures elegance in dynamics.

(2) Improvement on the installation


- The piping connection work is facilitated drastically.




(3) Easy maintenance

When the unit is hung on the wall, it is easy to clean the floor. (Exposed type)

- The maintenance of the discharge grille is improved.
- The interval of filter cleaning is prolonged.





2. Specifications

2.1 FXLQ-MA

Floor Standing Type

Model			FXLQ20MAVE	FXLQ25MAVE	FXLQ32MAVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	2,000	2,500	3,200
		Btu/h	7,800	9,900	12,600
		kW	2.3	2.9	3.7
∗2 Cooling Capacity (19.0°CWB)		kW	2.2	2.8	3.6
∗3 Heating Capacity		kcal/h	2,200	2,800	3,400
		Btu/h	8,500	10,900	13,600
		kW	2.5	3.2	4.0
Casing Color			Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
Dimensions: (H×W×D)		mm	600×1,000×222	600×1,000×222	600×1,140×222
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	3×14×1.5	3×14×1.5	3×14×1.5
	Face Area	m²	0.159	0.159	0.200
Fan	Model		D14B20	D14B20	2D14B13
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	15×1	15×1	25×1
	Air Flow Rate (H/L)	m³/min	7/6	7/6	8/6
		cfm	247/212	247/212	282/212
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Glass Fiber/ Urethane Foam	Glass Fiber/ Urethane Foam	Glass Fiber/ Urethane Foam
Air Filter			Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)
	Drain Pipe	mm	ϕ21 O.D (Vinyl Chloride)	ϕ21 O.D (Vinyl Chloride)	ϕ21 O.D (Vinyl Chloride)
Machine Weight (Mass)		kg	25	25	30
∗5 Sound Level (H/L) (220V)		dBA	35/32	35/32	35/32
Safety Devices			Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.	Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.	Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.
Drawing No.			C : 3D038816A		

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1.5 m in front of the unit at a height of 1.5 m. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 387 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

11

Floor Standing Type

Model			FXLQ40MAVE	FXLQ50MAVE	FXLQ63MAVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	4,000	5,000	6,300
		Btu/h	16,000	19,800	24,900
		kW	4.7	5.8	7.3
∗2 Cooling Capacity (19.0°CWB)		kW	4.5	5.6	7.1
∗3 Heating Capacity		kcal/h	4,300	5,400	6,900
		Btu/h	17,100	21,500	27,300
		kW	5.0	6.3	8.0
Casing Color			Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
Dimensions: (H×W×D)		mm	600×1,140×222	600×1,420×222	600×1,420×222
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	3×14×1.5	3×14×1.5	3×14×1.5
	Face Area	m^2	0.200	0.282	0.282
Fan	Model		2D14B13	2D14B20	2D14B20
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	25×1	35×1	35×1
	Air Flow Rate (H/L)	m^3/min	11/8.5	14/11	16/12
		cfm	388/300	494/388	565/424
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Glass Fiber/ Urethane Foam	Glass Fiber/ Urethane Foam	Glass Fiber/ Urethane Foam
Air Filter			Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe	mm	ϕ21 O.D (Vinyl Chloride)	ϕ21 O.D (Vinyl Chloride)	ϕ21 O.D (Vinyl Chloride)
Machine Weight (Mass)		kg	30	36	36
∗5 Sound Level (H/L) (220V)		dBA	38/33	39/34	40/35
Safety Devices			Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.	Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.	Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.
Drawing No.			C : 3D038816A		

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1.5 m in front of the unit at a height of 1.5 m. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 387 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m^3/min×35.3

2.2 FXNQ-MA

Concealed Floor Standing Type

Model			FXNQ20MAVE	FXNQ25MAVE	FXNQ32MAVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	2,000	2,500	3,200
		Btu/h	7,800	9,900	12,600
		kW	2.3	2.9	3.7
∗2 Cooling Capacity (19.0°CWB)		kW	2.2	2.8	3.6
∗3 Heating Capacity		kcal/h	2,200	2,800	3,400
		Btu/h	8,500	10,900	13,600
		kW	2.5	3.2	4.0
Casing Color			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	610×930×220	610×930×220	610×1,070×220
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	3×14×1.5	3×14×1.5	3×14×1.5
	Face Area	m²	0.159	0.159	0.200
Fan	Model		D14B20	D14B20	2D14B13
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	15×1	15×1	25×1
	Air Flow Rate (H/L)	m³/min	7/6	7/6	8/6
		cfm	247/212	247/212	282/212
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Glass Fiber/ Urethane Foam	Glass Fiber/ Urethane Foam	Glass Fiber/ Urethane Foam
Air Filter			Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)
	Drain Pipe	mm	ϕ21 O.D (Vinyl Chloride)	ϕ21 O.D (Vinyl Chloride)	ϕ21 O.D (Vinyl Chloride)
Machine Weight (Mass)		kg	19	19	23
∗5 Sound Level (H/L) (220V)		dBA	35/32	35/32	35/32
Safety Devices			Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.	Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.	Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.
Drawing No.			C : 3D038817A		

Note:

∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1.5 m in front of the unit at a height of 1.5 m. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 387 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

11

Concealed Floor Standing Type

Model			FXNQ40MAVE	FXNQ50MAVE	FXNQ63MAVE
∗1 Cooling Capacity (19.5°CWB)		kcal/h	4,000	5,000	6,300
		Btu/h	16,000	19,800	24,900
		kW	4.7	5.8	7.3
∗2 Cooling Capacity (19.0°CWB)		kW	4.5	5.6	7.1
∗3 Heating Capacity		kcal/h	4,300	5,400	6,900
		Btu/h	17,100	21,500	27,300
		kW	5.0	6.3	8.0
Casing Color			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	610×1,070×220	610×1,350×220	610×1,350×220
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	3×14×1.5	3×14×1.5	3×14×1.5
	Face Area	m²	0.200	0.282	0.282
Fan	Model		2D14B13	2D14B20	2D14B20
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	25×1	35×1	35×1
	Air Flow Rate (H/L)	m³/min	11/8.5	14/11	16/12
		cfm	388/300	494/388	565/424
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Glass Fiber / Urethane Foam	Glass Fiber / Urethane Foam	Glass Fiber / Urethane Foam
Air Filter			Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)	Resin Net (with Mold Resistant)
Piping Connections	Liquid Pipes	mm	ϕ6.4 (Flare Connection)	ϕ6.4 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes	mm	ϕ12.7 (Flare Connection)	ϕ12.7 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe	mm	ϕ21 O.D (Vinyl Chloride)	ϕ21 O.D (Vinyl Chloride)	ϕ21 O.D (Vinyl Chloride)
Machine Weight (Mass)		kg	23	27	27
∗5 Sound Level (H/L) (220V)		dBA	38/33	39/34	40/35
Safety Devices			Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.	Fuse. Thermal Protector for Fan Motor.
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Connectable Outdoor Unit			R-410A P(A) Series	R-410A P(A) Series	R-410A P(A) Series
Standard Accessories			Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.	Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.	Operation Manual. Installation Manual. Insulation for Fitting. Drain Hose. Clamps. Screws. Washers. Level Adjustment Screw.
Drawing No.			C : 3D038817A		

Note:


∗1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5 m, level difference : 0 m.
∗3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5 m, level difference : 0 m.
4 Capacities are net, including a deduction for cooling (an addition for heating) for indoor fan motor heat.
∗5 Anechoic chamber conversion value, measured at a point 1.5 m in front of the unit at a height of 1.5 m. During actual operation, these values are normally somewhat higher as a result of ambient conditions.
6 Refer to page 387 for Fan Motor Input.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3


3. Dimensions

3.1 FXLQ-MA

FXLQ20MA
FXLQ25MA




FXLQ32MA
FXLQ40MA



FXLQ50MA
FXLQ63MA

Unit (mm)




11

3.2 FXNQ-MA

FXNQ20MA
FXNQ25MA

Unit (mm)




NUMBER	NAME	DESCRIPTION
1	LIQUID PIPE CONNECTION PORT	φ6.4 FLARE CONNECTION
2	GAS PIPE CONNECTION PORT	φ12.7 FLARE CONNECTION
3	DRAIN PIPE CONNECTION PORT	O. D. 21
4	SWITCH BOX	
5	AIR FILTER	

3D038863B

NOTE)
1. LOCATION OF UNIT'S NAME PLATE:
THE RIGHT LOWER CORNER OF FRONT PLATE.

FXNQ32MA
FXNQ40MA

Unit (mm)



NUMBER	NAME	DESCRIPTION
1	LIQUID PIPE CONNECTION PORT	φ6.4 FLARE CONNECTION
2	GAS PIPE CONNECTION PORT	φ12.7 FLARE CONNECTION
3	DRAIN PIPE CONNECTION PORT	O.D.21
4	SWITCH BOX	
5	AIR FILTER	


3D038864C

NOTE)
1. LOCATION OF UNIT'S NAME PLATE:
THE RIGHT LOWER CORNER OF FRONT PLATE.

11

FXNQ50MA
FXNQ63MA

Unit (mm)




NUMBER	NAME	DESCRIPTION
1	LIQUID PIPE CONNECTION PORT	FLARE CONNECTION
2	GAS PIPE CONNECTION	FLARE CONNECTION
3	DRAIN PIPE CONNECTION	O. D. 21
4	SWITCH BOX	
5	AIR FILTER	

3D038865C

1. LOCATION OF UNIT'S NAME PLATE:
   THE RIGHT LOWER CORNER OF FRONT PLATE.

4. Piping Diagrams



4D034245C

■ **Refrigerant pipe connection port diameters**


(mm)

Model	Gas	Liquid
FXLQ20 · 25 · 32 · 40 · 50MA FXNQ20 · 25 · 32 · 40 · 50MA	ϕ12.7	ϕ6.4
FXLQ63MA FXNQ63MA	ϕ15.9	ϕ9.5

11

5. Wiring Diagrams

FXLQ20 · 25 · 32 · 40 · 50 · 63MAVE
FXNQ20 · 25 · 32 · 40 · 50 · 63MAVE



INDOOR UNIT		X2M	TERMINAL BLOCK (CONTROL)
A1P	PRINTED CIRCUIT BOARD	Y1E	ELECTRONIC EXPANSION VALVE
C1	CAPACITOR (M1F)		WIRED REMOTE CONTROLLER
F1U	FUSE (Ⓑ, 5A, 250V)	R1T	THERMISTOR (AIR)
HAP	LIGHT EMITTING DIODE (SERVICE MONITOR-GREEN)	SS1	SELECTOR SWITCH (MAIN/SUB)
			CONNECTOR FOR OPTIONAL PARTS
K1R-K3R	MAGNETIC RELAY (M1F)	X18A	CONNECTOR (WIRING ADAPTOR FOR ELECTORICAL APPENDICES)
M1F	MOTOR (INDOOR FAN)		
Q1M	THERMO SWITCH (M1F EMBEDDED)		
R1T	THERMISTOR (AIR)		
R2T·R3T	THERMISTOR (COIL)		
T1R	TRANSFORMER (220-240V/22V)		
X1M	TERMINAL BLOCK (POWER)		

NOTES)
1. □□□ : TERMINAL BLOCK, ⊡⊡ , ⊃- : CONNECTOR, -○- : TERMINAL
2. ▬▮▬ : FIELD WIRING
3. IN CASE USING CENTRAL REMOTE CONTROLLER, CONNECT IT TO THE UNIT IN ACCORDANCE WITH THE ATTACHED INSTRUCTIO MANUAL.
4. WHEN CONNECTING THE INPUT WIRES FROM OUTSIDE, FORCED OFF OR ON/OFF CONTROL OPERATION CAN BE SELECTED BY REMOTE CONTROLLER. IN DETAILS, REFER TO THE INSTALLATION MANUAL ATTACHED THE UNIT.
5. SYMBOLS SHOW AS FOLLOWS. (PNK: PINK WHT: WHITE YLW: YELLOW ORG: ORANGE BLU: BLUE BLK: BLACK RED: RED BRN: BROWN)
6. USE COPPER CONDUCTORS ONLY.

6. Electric Characteristics

Units				Power supply		IFM		Input(W)	
Model	Hz	Volts	Voltage range	MCA	MFA	KW	FLA	Cooling	Heating
FXLQ・FXNQ20MAVE	50	220-240	MAX. 264 Min. 198	0.3	15	0.015	0.2	49	49
FXLQ・FXNQ25MAVE				0.3	15	0.015	0.2	49	49
FXLQ・FXNQ32MAVE				0.6	15	0.025	0.5	90	90
FXLQ・FXNQ40MAVE				0.6	15	0.025	0.5	90	90
FXLQ・FXNQ50MAVE				0.6	15	0.035	0.5	110	110
FXLQ・FXNQ63MAVE				0.6	15	0.035	0.5	110	110
FXLQ・FXNQ20MAVE	60	220	MAX. 242 Min. 198	0.3	15	0.015	0.2	47	47
FXLQ・FXNQ25MAVE				0.3	15	0.015	0.2	47	47
FXLQ・FXNQ32MAVE				0.5	15	0.025	0.4	79	79
FXLQ・FXNQ40MAVE				0.5	15	0.025	0.4	84	84
FXLQ・FXNQ50MAVE				0.6	15	0.035	0.5	105	105
FXLQ・FXNQ63MAVE				0.6	15	0.035	0.5	108	108

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
KW : Fan Motor Rated Output(KW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

11

Note:

1. Voltage range

   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.

2. Maximum allowable voltage unbalance between phases is 2%.

3. MCA/MFA

   MCA = 1.25 X FLA

   MFA ≦ 4 X FLA

   (Next lower standard fuse rating. Min. 15A)

4. Select wire size based on the MCA.

5. Instead of fuse, use Circuit Breaker.

C : 4D034579C

7. Capacity Tables

7.1 Cooling Capacity

FXLQ-MA / FXNQ-MA [50/60Hz]

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	SHC	16.0°CWB 23°CDB TC	SHC	18.0°CWB 26°CDB TC	SHC	19.0°CWB 27°CDB TC	SHC	20.0°CWB 28°CDB TC	SHC	22.0°CWB 30°CDB TC	SHC	24.0°CWB 32°CDB TC	SHC
20	10.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.8	2.9	1.8
	12.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.8	2.9	1.7
	14.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.8	2.8	1.7
	16.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.8	2.8	1.7
	18.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.8	2.7	1.7
	20.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.8	2.7	1.6
	21.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.8	2.7	1.6
	23.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.8	2.6	1.6
	25.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.6	1.7	2.6	1.6
	27.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.5	1.7	2.5	1.6
	29.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.5	1.7	2.5	1.6
	31.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.4	1.7	2.5	1.6
	33.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.8	2.4	1.7	2.5	1.6
	35.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.7	2.4	1.6	2.4	1.5
	37.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.3	1.7	2.3	1.6	2.4	1.6
	39.0	1.5	1.3	1.8	1.5	2.1	1.7	2.2	1.7	2.2	1.7	2.3	1.6	2.3	1.5
25	10.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.4	2.1	3.7	2.1
	12.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.4	2.1	3.6	2.1
	14.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.4	2.1	3.6	2.1
	16.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.4	2.1	3.5	2.1
	18.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.4	2.1	3.5	2.0
	20.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.4	2.1	3.4	2.0
	21.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.4	2.1	3.4	2.0
	23.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.3	2.1	3.3	2.0
	25.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.3	2.1	3.3	1.9
	27.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.2	2.1	3.2	1.9
	29.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.2	2.0	3.2	1.9
	31.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.1	2.0	3.2	1.9
	33.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.1	2.0	3.1	1.9
	35.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	3.0	2.1	3.0	2.0	3.0	1.9
	37.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	2.9	2.0	3.0	2.0	3.0	1.9
	39.0	1.9	1.6	2.3	1.8	2.6	2.0	2.8	2.1	2.9	2.0	2.9	2.0	3.0	1.9
32	10.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.3	2.6	4.7	2.6
	12.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.3	2.6	4.7	2.6
	14.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.3	2.6	4.6	2.5
	16.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.3	2.6	4.6	2.5
	18.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.3	2.6	4.5	2.5
	20.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.3	2.6	4.4	2.5
	21.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.3	2.6	4.4	2.5
	23.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.2	2.6	4.3	2.4
	25.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.2	2.5	4.2	2.4
	27.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.1	2.5	4.2	2.4
	29.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	4.0	2.5	4.1	2.4
	31.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.6	3.9	2.4	4.0	2.3
	33.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.8	2.5	3.9	2.4	4.0	2.3
	35.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.5	3.7	2.5	3.8	2.4	3.9	2.3
	37.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.6	3.7	2.5	3.8	2.4	3.8	2.3
	39.0	2.4	2.1	2.9	2.2	3.4	2.5	3.6	2.6	3.7	2.5	3.8	2.4	3.8	2.3

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	SHC	16.0°CWB 23°CDB TC	SHC	18.0°CWB 26°CDB TC	SHC	19.0°CWB 27°CDB TC	SHC	20.0°CWB 28°CDB TC	SHC	22.0°CWB 30°CDB TC	SHC	24.0°CWB 32°CDB TC	SHC
40	10.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.4	3.3	5.9	3.3
	12.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.4	3.3	5.8	3.3
	14.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.4	3.3	5.8	3.2
	16.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.4	3.3	5.7	3.2
	18.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.4	3.3	5.6	3.1
	20.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.4	3.3	5.5	3.1
	21.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.4	3.3	5.5	3.1
	23.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.3	3.2	5.4	3.0
	25.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.2	3.2	5.3	3.0
	27.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.2	3.1	5.3	3.0
	29.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.1	3.1	5.2	3.0
	31.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	5.0	3.1	5.1	2.9
	33.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.8	3.2	4.9	3.0	5.0	2.9
	35.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.7	3.2	4.9	3.1	4.9	2.9
	37.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.1	4.7	3.2	4.8	3.0	4.9	2.8
	39.0	3.0	2.5	3.6	2.7	4.2	3.1	4.5	3.2	4.6	3.1	4.7	3.0	4.8	2.8
50	10.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	7.4	4.1
	12.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	7.3	4.1
	14.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	7.2	4.0
	16.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	7.1	4.0
	18.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	7.0	3.9
	20.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	6.9	3.9
	21.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.7	4.1	6.8	3.8
	23.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.6	4.0	6.7	3.8
	25.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.5	4.0	6.6	3.7
	27.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.4	3.9	6.6	3.7
	29.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.3	3.9	6.5	3.7
	31.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.2	3.8	6.4	3.7
	33.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	6.0	4.0	6.1	3.8	6.3	3.6
	35.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	5.9	4.0	6.0	3.8	6.2	3.6
	37.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	5.8	3.9	5.9	3.7	6.1	3.6
	39.0	3.8	3.0	4.5	3.4	5.2	3.8	5.6	3.9	5.7	3.9	5.8	3.7	6.0	3.5
63	10.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.5	5.1	9.3	5.0
	12.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.5	5.1	9.2	5.0
	14.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.5	5.1	9.1	4.9
	16.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.5	5.1	9.0	4.8
	18.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.5	5.1	8.8	4.8
	20.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.5	5.1	8.7	4.7
	21.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.5	5.1	8.7	4.7
	23.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.4	5.0	8.5	4.6
	25.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.3	5.0	8.4	4.5
	27.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.1	4.9	8.3	4.5
	29.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	8.0	4.8	8.2	4.5
	31.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	7.9	4.7	8.1	4.4
	33.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.6	5.0	7.8	4.7	7.9	4.4
	35.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.5	4.9	7.7	4.7	7.8	4.3
	37.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.4	4.9	7.5	4.6	7.7	4.2
	39.0	4.8	3.7	5.7	4.2	6.6	4.8	7.1	4.9	7.2	4.8	7.4	4.6	7.6	4.2

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

7.2 Heating Capacity

FXLQ-MA / FXNQ-MA [50/60Hz]

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
20	-19.8	-20.0	1.5	1.5	1.5	1.5	1.5	1.5
	-18.8	-19.0	1.5	1.5	1.5	1.5	1.5	1.5
	-16.7	-17.0	1.6	1.6	1.6	1.6	1.6	1.6
	-14.7	-15.0	1.7	1.7	1.7	1.7	1.7	1.7
	-12.6	-13.0	1.8	1.8	1.8	1.8	1.8	1.8
	-10.5	-11.0	1.9	1.9	1.9	1.9	1.9	1.9
	-9.5	-10.0	1.9	1.9	1.9	1.9	1.9	1.9
	-8.5	-9.1	2.0	2.0	1.9	1.9	1.9	1.9
	-7.0	-7.6	2.0	2.0	2.0	2.0	2.0	2.0
	-5.0	-5.6	2.1	2.1	2.1	2.1	2.1	2.0
	-3.0	-3.7	2.2	2.2	2.2	2.2	2.2	2.1
	0.0	-0.7	2.3	2.3	2.3	2.3	2.3	2.2
	3.0	2.2	2.5	2.5	2.4	2.4	2.3	2.2
	5.0	4.1	2.6	2.6	2.5	2.5	2.3	2.2
	7.0	6.0	2.7	2.7	2.5	2.4	2.3	2.2
	9.0	7.9	2.8	2.7	2.5	2.4	2.3	2.2
	11.0	9.8	2.8	2.7	2.5	2.4	2.3	2.2
	13.0	11.8	2.8	2.7	2.5	2.4	2.3	2.2
	15.0	13.7	2.8	2.7	2.5	2.4	2.3	2.2
25	-19.8	-20.0	1.9	1.9	1.9	1.9	1.9	1.9
	-18.8	-19.0	1.9	1.9	1.9	1.9	1.9	1.9
	-16.7	-17.0	2.1	2.1	2.0	2.0	2.0	2.0
	-14.7	-15.0	2.2	2.2	2.2	2.2	2.2	2.1
	-12.6	-13.0	2.3	2.3	2.3	2.3	2.3	2.3
	-10.5	-11.0	2.4	2.4	2.4	2.4	2.4	2.4
	-9.5	-10.0	2.5	2.5	2.5	2.5	2.5	2.5
	-8.5	-9.1	2.5	2.5	2.6	2.6	2.6	2.6
	-7.0	-7.6	2.6	2.6	2.6	2.6	2.6	2.6
	-5.0	-5.6	2.7	2.7	2.7	2.7	2.7	2.7
	-3.0	-3.7	2.8	2.8	2.8	2.8	2.8	2.8
	0.0	-0.7	3.0	3.0	3.0	3.0	3.0	2.8
	3.0	2.2	3.1	3.1	3.2	3.1	3.0	2.8
	5.0	4.1	3.3	3.2	3.2	3.1	3.0	2.8
	7.0	6.0	3.4	3.4	3.2	3.1	3.0	2.8
	9.0	7.9	3.5	3.4	3.2	3.1	3.0	2.8
	11.0	9.8	3.6	3.4	3.2	3.1	3.0	2.8
	13.0	11.8	3.6	3.4	3.2	3.1	3.0	2.8
	15.0	13.7	3.6	3.4	3.2	3.1	3.0	2.8
32	-19.8	-20.0	2.4	2.4	2.3	2.3	2.3	2.3
	-18.8	-19.0	2.4	2.4	2.4	2.4	2.4	2.4
	-16.7	-17.0	2.6	2.6	2.6	2.6	2.6	2.5
	-14.7	-15.0	2.7	2.7	2.7	2.7	2.7	2.7
	-12.6	-13.0	2.9	2.8	2.8	2.8	2.8	2.8
	-10.5	-11.0	3.0	3.0	3.0	3.0	3.0	3.0
	-9.5	-10.0	3.1	3.1	3.1	3.1	3.0	3.0
	-8.5	-9.1	3.1	3.1	3.1	3.1	3.1	3.1
	-7.0	-7.6	3.2	3.2	3.2	3.2	3.2	3.2
	-5.0	-5.6	3.4	3.4	3.4	3.4	3.4	3.4
	-3.0	-3.7	3.5	3.5	3.5	3.5	3.5	3.5
	0.0	-0.7	3.7	3.7	3.7	3.7	3.7	3.5
	3.0	2.2	3.9	3.9	4.0	3.9	3.7	3.5
	5.0	4.1	4.2	4.1	4.0	3.9	3.7	3.5
	7.0	6.0	4.3	4.3	4.0	3.9	3.7	3.5
	9.0	7.9	4.5	4.3	4.0	3.9	3.7	3.5
	11.0	9.8	4.5	4.3	4.0	3.9	3.7	3.5
	13.0	11.8	4.5	4.3	4.0	3.9	3.7	3.5
	15.0	13.7	4.5	4.3	4.0	3.9	3.7	3.5

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
40	-19.8	-20.0	3.0	2.9	2.9	2.9	2.9	2.9
	-18.8	-19.0	3.0	3.0	3.0	3.0	3.0	3.0
	-16.7	-17.0	3.2	3.2	3.2	3.2	3.2	3.2
	-14.7	-15.0	3.4	3.4	3.4	3.4	3.4	3.4
	-12.6	-13.0	3.6	3.6	3.6	3.5	3.5	3.5
	-10.5	-11.0	3.7	3.7	3.7	3.7	3.7	3.7
	-9.5	-10.0	3.8	3.8	3.8	3.8	3.8	3.8
	-8.5	-9.1	3.9	3.9	3.9	3.9	3.9	3.9
	-7.0	-7.6	4.0	4.0	4.0	4.0	4.0	4.0
	-5.0	-5.6	4.2	4.2	4.2	4.2	4.2	4.2
	-3.0	-3.7	4.4	4.4	4.4	4.4	4.4	4.4
	0.0	-0.7	4.7	4.6	4.6	4.6	4.6	4.4
	3.0	2.2	4.9	4.9	4.8	4.8	4.7	4.4
	5.0	4.1	5.1	5.1	5.0	4.8	4.7	4.4
	7.0	6.0	5.2	5.2	5.0	4.8	4.7	4.4
	9.0	7.9	5.4	5.3	5.0	4.8	4.7	4.4
	11.0	9.8	5.6	5.3	5.0	4.8	4.7	4.4
	13.0	11.8	5.6	5.3	5.0	4.8	4.7	4.4
	15.0	13.7	5.6	5.3	5.0	4.8	4.7	4.4
50	-19.8	-20.0	3.7	3.7	3.7	3.7	3.7	3.7
	-18.8	-19.0	3.8	3.8	3.8	3.8	3.8	3.8
	-16.7	-17.0	4.1	4.0	4.0	4.0	4.0	4.0
	-14.7	-15.0	4.3	4.3	4.3	4.2	4.2	4.2
	-12.6	-13.0	4.5	4.5	4.5	4.5	4.5	4.5
	-10.5	-11.0	4.7	4.7	4.7	4.7	4.7	4.7
	-9.5	-10.0	4.8	4.8	4.8	4.8	4.8	4.8
	-8.5	-9.1	4.9	4.9	4.9	4.9	4.9	4.9
	-7.0	-7.6	5.1	5.1	5.1	5.1	5.1	5.1
	-5.0	-5.6	5.3	5.3	5.3	5.3	5.3	5.3
	-3.0	-3.7	5.5	5.5	5.5	5.5	5.5	5.5
	0.0	-0.7	5.9	5.9	5.8	5.8	5.8	5.5
	3.0	2.2	6.2	6.2	6.2	6.1	5.9	5.5
	5.0	4.1	6.4	6.4	6.3	6.1	5.9	5.5
	7.0	6.0	6.6	6.6	6.3	6.1	5.9	5.5
	9.0	7.9	6.8	6.7	6.3	6.1	5.9	5.5
	11.0	9.8	7.0	6.7	6.3	6.1	5.9	5.5
	13.0	11.8	7.1	6.7	6.3	6.1	5.9	5.5
	15.0	13.7	7.1	6.7	6.3	6.1	5.9	5.5
63	-19.8	-20.0	4.7	4.7	4.7	4.7	4.7	4.7
	-18.8	-19.0	4.9	4.9	4.8	4.8	4.8	4.8
	-16.7	-17.0	5.1	5.1	5.1	5.1	5.1	5.1
	-14.7	-15.0	5.4	5.4	5.4	5.4	5.4	5.4
	-12.6	-13.0	5.7	5.7	5.7	5.7	5.7	5.7
	-10.5	-11.0	6.0	6.0	6.0	6.0	6.0	5.9
	-9.5	-10.0	6.1	6.1	6.1	6.1	6.1	6.1
	-8.5	-9.1	6.3	6.3	6.2	6.2	6.2	6.2
	-7.0	-7.6	6.5	6.5	6.4	6.4	6.4	6.4
	-5.0	-5.6	6.8	6.7	6.7	6.7	6.7	6.7
	-3.0	-3.7	7.0	7.0	7.0	7.0	7.0	7.0
	0.0	-0.7	7.5	7.4	7.4	7.4	7.4	7.0
	3.0	2.2	7.9	7.8	7.8	7.7	7.5	7.0
	5.0	4.1	8.1	8.1	8.0	7.7	7.5	7.0
	7.0	6.0	8.4	8.4	8.0	7.7	7.5	7.0
	9.0	7.9	8.7	8.5	8.0	7.7	7.5	7.0
	11.0	9.8	8.9	8.5	8.0	7.7	7.5	7.0
	13.0	11.8	9.0	8.5	8.0	7.7	7.5	7.0
	15.0	13.7	9.0	8.5	8.0	7.7	7.5	7.0


Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

11

8. Sound Levels


Overall

■ **Floor Standing Type**



4D034528A

■ **Concealed Floor Standing Type**



4D034534B

dBA

Model	220V, 50/60Hz		240V, 50Hz		Model	220V, 50/60Hz		240V, 50Hz	
	H	L	H	L		H	L	H	L
FXLQ20MA FXLQ25MA FXLQ32MA	35	32	37	34	FXNQ20MA FXNQ25MA FXNQ32MA	35	32	37	34
FXLQ40MA	38	33	40	35	FXNQ40MA	38	33	40	35
FXLQ50MA	39	34	41	36	FXNQ50MA	39	34	41	36
FXLQ63MA	40	35	42	37	FXNQ63MA	40	35	42	37


Note:

1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.

Octave Band Level


○———○ 220V 50/60Hz
○ - - - -○ 240V 50Hz

FXLQ20 · 25MAVE




4D034528A

FXLQ32MAVE




4D034564A

FXLQ40MAVE




4D034565A

FXLQ50MAVE




4D034566A

FXLQ63MAVE




4D034567A

FXNQ20 · 25MAVE




4D034534B

FXNQ32MAVE




4D034535A

FXNQ40MAVE




4D034536B

FXNQ50MAVE



4D034537B

FXNQ63MAVE




4D034538B

11

9. Installation

Installation Example




Service Space

(1) Select an installation site where the following conditions are satisfied and that meets with your customer's approval.


- Where the floor is strong enough to dear the indoor unit weight.
- Where the floor is not significantly inclined.
- Where nothing blocks the air passage.
- Where condensate can be properly drained.
- Where sufficient clearance for installation and maintenance can be ensured.
- Where optimum air distribution can be ensured.
- Where there is no risk of flammable gas leakage.
- Where piping between indoor and outdoor units is possible within the allowable limit. (Refer to the installation manual of the outdoor unit.)

⚠ CAUTION

- Install the indoor and outdoor units, power supply wiring and connecting wires at least 1 meter away from televisions or radios in order to prevent image interference or noise.
  (Depending on the radio waves, a distance of 1 meter may not be sufficient enough to eliminate the noise.)



(length : mm)



(length : mm)

(IMPORTANT) Leave sufficient clearance for air inlet and maintenance.


Model		A (mm)	B (mm)
FXLQ20 · 25MAVE	FXNQ20 · 25MAVE	570	1030
FXLQ32 · 40MAVE	FXNQ32 · 40MAVE	710	1170
FXLQ50 · 63MAVE	FXNQ50 · 63MAVE	990	1450

C : 3P086154-2N

Center of Gravity

FXLQ

Unit (mm)




	A
FXLQ20•25MAVE	500
FXLQ32•40MAVE	570
FXLQ50•63MAVE	710

C : 4D034527C

FXNQ

Unit (mm)




	A
FXNQ20•25MAVE	395
FXNQ32•40MAVE	465
FXNQ50•63MAVE	505

C : 4D034533C


Bolt Pitch

(1) Positioning of holes for fastening to the wall



Model	A (mm)
FXNQ20 · 25MAVE	590
FXNQ32 · 40MAVE	730
FXNQ50 · 63MAVE	1010

(2) How to open / close the front panel



1. Open the lid of control panel (both left and right)
2. Remove screws (both left and right) that lock the knobs in position.
3. Push the knobs (both left and right) to the rear.
4. Lift the front of the top plate.
5. Lower the front panel towards the front of the unit.

- To close, perform the procedure in opposite order. Pull towards the front unit the knob snaps in place.

C : 3P086154-2N


11

Drain Piping Work


〈〈**Rig the drain pipe as shown below and take measures against condensation. Improperly rigged piping could lead to leaks and eventually wet furniture and belongings.**〉〉

(1) Carry out the drain piping.

Connect the drain hose (1) using the attached hose and parts, as shown in the right drawing.



- If converging multiple drain pipes, install according to the procedure shown below.



Select converging drain pipes whose gauge is suitable for the operating capacity of the unit.

(2) After piping work is finished, check drainage flows smoothly.
- Add approximately 1 liter of water slowly from the air outlet and check drainage flow.

(3) Be sure to insulate all indoor pipes.

⚠ CAUTION






- Drain piping connections
  Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain pipes and corrode the heat exchanger.
- Keep in mind that it will become the cause of getting drain pipe blocked if water collects on drain pipe.

C : 3P086154-2N

10. Accessories

Standard Accessories

FXLQ20~63MA
FXNQ20~63MA

Name	Drain hose	Insulation for fitting	Sealing pad	Clamp	Leveling	
Quantity	1 set	1 each.	1 pc.	8 pcs.	4 pcs.	
Shape	Hose × 1 Metal clamp × 1 (1) (2) 	(3)For gas pipe  (4)For liquid pipe 	(5) 	(6) 	(7) 	[Other] • Operation manual • Installation manual


C : 3P086154-2N

Optional Accessories (For Unit)

No.	Type / Item	FXLQ20MA FXNQ20MA	FXLQ25MA FXNQ25MA	FXLQ32MA FXNQ32MA	FXLQ40MA FXNQ40MA	FXLQ50MA FXNQ50MA	FXLQ63MA FXNQ63MA
1	Long life replacement filter	KAFJ361K28		KAFJ361K45		KAFJ361K71	

C : 4D034574B

Optional Accessories (For Controls) : Refer to P.807



FXUQ-MA
Ceiling Suspended Cassette Type (Connection Unit Series)

1. Features 398
2. Specifications 399
3. Dimensions 401
4. Piping Diagrams 404
5. Wiring Diagrams 405
6. Electric Characteristics 407
7. Capacity Tables 408
   7.1 Cooling Capacity 408
   7.2 Heating Capacity 409
8. Air Velocity and Temperature Distributions (Reference Data) 410
9. Sound Levels 413
10. Installation 414
   10.1 Indoor Units 414
   10.2 Connecting Units 419
11. Accessories 429

12


1. Features

Flexibility in installation location

Because the installation location, air flow direction and air flow rate can be selected according to the shape, lighting, and interior design of a room, the Ceiling Suspended Cassette Type air conditioner will create a comfortable environment throughout the room. This is a completely new air conditioning system that produces the comfort level of a four-way air flow, ceiling-mounted cassette type air conditioner with the ease of a ceiling-suspended unit.



Development back ground of FXUQ-MA



Flexible Design

- •Daikin unique cassette
- •Low Silhouette design:
  71 Type - 165mm thickness
  (Current Multi Flow Cassette:338mm)
- •Aesthetically pleasing design
- •High ceiling up 3.5m
- •Flexible air distribution by control of direction and volume


Easy Installation

- •Flexible piping installation (3 directions)
- •Ceiling space not required

Easy Maintenance

- •Long life filter (standard accessories)
- •Drain pump(standard accessories)

<Variable discharge direction and air volume>



2. Specifications

Ceiling Suspended Cassette Type

Model		Indoor Unit		FXUQ71MAV1	FXUQ100MAV1	FXUQ125MAV1
		Connection Unit		BEVQ71MAVE	BEVQ100MAVE	BEVQ125MAVE
★1 Cooling Capacity (19.5°CWB)			kcal/h	7,100	10,000	12,500
			Btu/h	28,300	39,600	49,500
			kW	8.3	11.6	14.5
★2 Cooling Capacity (19.0°CWB)			kW	8.0	11.2	14.0
★3 Heating Capacity (Max.)			kcal/h	7,700	10,800	12,000
			Btu/h	30,700	42,700	47,700
			kW	9.0	12.5	14.0
Casing Color				White (10Y9/0.5)	White (10Y9/0.5)	White (10Y9/0.5)
Dimensions: (H×W×D)			mm	165×895×895	230×895×895	230×895×895
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch		mm	3×6×1.5	3×8×1.5	3×8×1.5
	Face Area		m²	0.265	0.353	0.353
Fan	Model			QTS48A10M	QTS50B15M	QTS50B15M
	Type			Turbo Fan	Turbo Fan	Turbo Fan
	Motor Output × Number of Units		W	45×1	90×1	90×1
	Air Flow Rate (H/L)		m³/min	19/14	29/21	32/23
			cfm	671/494	1,024/741	1,130/812
	Drive			Direct Drive	Direct Drive	Direct Drive
Temperature Control				Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material				Heat Resistant Foamed Polyethylene, Regular Foamed Polyethylene	Heat Resistant Foamed Polyethylene, Regular Foamed Polyethylene	Heat Resistant Foamed Polyethylene, Regular Foamed Polyethylene
Piping Connections	Liquid Pipes		mm	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)	ϕ9.5 (Flare Connection)
	Gas Pipes		mm	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)	ϕ15.9 (Flare Connection)
	Drain Pipe		mm	VP20 (External Dia. 26 Internal Dia. 20)	VP20 (External Dia. 26 Internal Dia. 20)	VP20 (External Dia. 26 Internal Dia. 20)
Machine Weight			kg	25	31	31
★5 Sound Level (H/L) (230V)			dBA	40/35	43/38	44/39
Safety Devices				Thermal Protector for Fan Motor	Thermal Protector for Fan Motor	Thermal Protector for Fan Motor
Standard Accessories				Operation Manual, Installation Manual, Drain Hose, Clamp Metal, Insulation for Fitting, Sealing Pads, Clamps, Screws, Washers, Holding Plate.	Operation Manual, Installation Manual, Drain Hose, Clamp Metal, Insulation for Fitting, Sealing Pads, Clamps, Screws, Washers, Holding Plate.	Operation Manual, Installation Manual, Drain Hose, Clamp Metal, Insulation for Fitting, Sealing Pads, Clamps, Screws, Washers, Holding Plate.
Drawing No.				C : 4D045395A		

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp.: 35°CDB / Equivalent piping length: 7.5m, level difference: 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp.: 35°CDB / Equivalent piping length: 7.5m, level difference: 0m.
★3 Indoor temp. : 20°CDB / outdoor temp.: 7°CDB, 6°CWB / Equivalent piping length; 7.5m, level difference; 0m. (Heat pump only)
4 Capacities are net, including a deduction for cooling (an additional for heating) for indoor fan motor heat.
★5 Anechoic chamber conversion value, measured at a point 1.5m downward from the unit center. These values are normally somewhat higher during actual operation as a result of ambient conditions.
6 Refer to page 407 for Fan Motor Input.


Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

12

BEV Units

Model				BEVQ71MAVE	BEVQ100MAVE	BEVQ125MAVE
Power Supply				1 Phase 50Hz 220~240V	1 Phase 50Hz 220~240V	1 Phase 50Hz 220~240V
Casing				Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)			mm	100×350×225	100×350×225	100×350×225
Sound Absorbing Thermal Insulation Material				Flame and Heat Resistant Foamed Polyethylene	Flame and Heat Resistant Foamed Polyethylene	Flame and Heat Resistant Foamed Polyethylene
Piping Connection	Indoor Unit	Liquid Pipes		9.5mm (Flare Connection)	9.5mm (Flare Connection)	9.5mm (Flare Connection)
		Gas Pipes		15.9mm (Flare Connection)	15.9mm (Flare Connection)	15.9mm (Flare Connection)
	Outdoor Unit	Liquid Pipes		9.5mm (Flare Connection)	9.5mm (Flare Connection)	9.5mm (Flare Connection)
		Suction Gas Pipes		15.9mm (Flare Connection)	15.9mm (Flare Connection)	15.9mm (Flare Connection)
Machine Weight (Mass)			kg	3.0	3.0	3.5
Standard Accessories				Installation manual, Gas piping connections, Insulation for fitting, Sealing material, Clamps	Installation manual, Gas piping connections, Insulation for fitting, Sealing material, Clamps	Installation manual, Gas piping connections, Insulation for fitting, Sealing material, Clamps
Drawing No.				4D045387A	4D045387A	4D045388A

Connection Example



1. Wiring Work
- The connecting line between SkyAir Indoor Unit – BEV Unit : 3 cores…like a Transmission Line
- BEV Unit's power supply line; Single phase 2 line…like a VRV Indoor unit
- BEV Unit – other **VRV** indoor unit or outdoor unit – : 2 cores…DIII network wiring (super wiring)


2. Piping work
SkyAir side,Outdoor Unit Side,They are both flare connection.

Consideration matter


- When connecting centralized-control device, it is necessary to **install an interface adaptor for SkyAir series in an indoor unit.**

- Distance between indoor unit and –BEV unit must be **within 5m**.

Outline figure



Installation pattern / maintenance




*1; Service space for switch box.
(Service access panel is required for the bottom side. When there is nothing, 350 or more spaces are required.)
*2; For electric valve drive part's maintenance. (a control box is removed)

3. Dimensions

FXUQ71MAV1

Unit (mm)




Number	Name	Description
1	Liquid pipe connection	ϕ9.5 flare
2	Gas pipe connection	ϕ15.9 flare
3	Drain pipe connection	VP20
4	Air outlet	
5	Air suction grille	
6	Corner decoration cover	
7	Right pipe / wiring connection	
8	Rear pipe / wiring connection	
9	Pipe through cover	
10	Accessory drain elbow	

3D013860E

12


FXUQ100MAV1
FXUQ125MAV1

Unit (mm)



BEVQ71MA / 100MA / 125MAVE (When installing the unit on wall)

Unit (mm)



INSTALLATION FIGURE
(When installing the unit on wall)

7	Wire connection port (Transmission (VRV) • Gas pipe thermistor)	
6	Wire connection port (Power supply • Ground)	
5	Wire connection port (Indoor unit connection)	
4	Suspension bolt	
3	Electric parts box	
2	Gas pipe connection port	ϕ15.9mm flare connection
1	Liquid pipe connection port	ϕ9.5mm flare connection
Number	Part name	Description


Notes) 1. Be sure to install wire connection port to be sure to become downward.
2. Be sure to secure the space which can be the thinghtening work of the flare nut.

C : 3D045389

BEVQ71MA / 100MA / 125MAVE (When hanging the unit from the ceiling)

12

Unit (mm)



INSTALLATION FIGURE
(When hanging the unit from the ceiling)


7	Wire connection port (Transmission (VRV) • Gas pipe thermistor)	
6	Wire connection port (Power supply • Ground)	
5	Wire connection port (Indoor unit connection)	
4	Suspension bolt	
3	Electric parts box	
2	Gas pipe connection port	ϕ15.9mm flare connection
1	Liquid pipe connection port	ϕ9.5mm flare connection
Number	Part name	Description

Notes) 1. Be sure to install wire connection port to be sure to become downward.
2. Be sure to secure the space which can be the thinghtening work of the flare nut.
3. Be sure to secure the space of 400mm or more when you cannot install the inspection hatch right under the unit.

C : 3D045390


4. Piping Diagrams

Indoor unit



C: 4D037995H


Connection Unit



4D034127B

5. Wiring Diagrams

FXUQ71MAV1 / FXUQ100MAV1 / FXUQ125MAV1




NOTES)
1. □□□ : TERMINAL
   ⊡ : CONNECTOR
   ⏚ : FIELD WIRING
2. THE BEV UNIT SHOWS AN OUTLINE. PLEASE REFER TO A WIRING DIAGRAM OF BEV UNIT PASTING IN DETAIL.
3. IN CASE USING CENTRAL REMOTE CONTROLLER, CONNECT IT TO THE UNIT IN ACCORDANCE WITH THE ATTACHED INSTALLATION MANUAL.
4. X24A IS CONNECTED WHEN THE WIRELESS REMOTE CONTROLLER KIT IS BEING USED.
5. REMOTE CONTROLLER MODEL VARIES ACCORDING TO THE COMBINATION SYSTEM, CONFIRM ENGINEERING MATERIALS AND CATALOGS, ETC. BEFORE CONNECTING.
6. CONFIRM THE METHOD OF SETTING THE SELECTOR SWITCH (SS1, SS2) OF WIRED REMOTE CONTROLLER AND WIRELESS REMOTE CONTROLLER BY INSTALLATION MANUAL AND ENGINEERING DATA, ETC.
7. SYMBOLS SHOW AS FOLLOWS:
   RED : RED BLK : BLACK WHT : WHITE YLW : YELLOW GRN : GREEN BLU : BLUE

	INDOOR UNIT	
A1P	PRINTED CIRCUIT BOARD	
A2P	PRINTED CIRCUIT BOARD (TRANSFORMER 220~240V/16V)	
C1	CAPACITOR (M1F)	
HAP	LIGHT EMITTING DIODE (SERVICE MONITOR GREEN)	
HBP	LIGHT EMITTING DIODE (SERVICE MONITOR GREEN)	
M1S	MOTOR (SWING FLAP)	
M1F	MOTOR (INDOOR FAN)	
M1P	MOTOR (DRAIN PUMP)	
Q1M	THERMO SWITCH (M1F EMBEDDED)	
R1T	THERMISTOR (AIR)	
R2T	THERMISTOR (COIL)	
RyA	MAGNETIC RELAY (M1A)	
RyP	MAGNETIC RELAY (M1P)	
S1Q	LIMIT SWITCH (SWING FLAP)	
S1L	FLOAT SWITCH	
SS1	SELECTOR SWITCH (EMERGENCY)	
V1TR	PHASE CONTROL CIRCUIT	
X1M	TERMINAL STRIP	
X2M	TERMINAL STRIP	
(RC)	SIGNAL RECEIVER	
(TC)	SIGNAL TRANSMISSION CIRCUIT	
	WIRED REMOTE CONTROLLER	
R1T	THERMISTOR (AIR)	
SS1	SELECTOR SWITCH (MAIN/SUB)	
	RECEIVER/DISPLAY UNIT (ATTACHED TO WIRLESS REMOTE CONTROLLER)	
A3P	PRINTED CIRCUIT BOARD	
A4P	PRINTED CIRCUIT BOARD	
BS1	PUSH BUTTON (ON/OFF)	
H1P	LIGHT EMITTING DIODE (ON-RED)	
H2P	LIGHT EMITTING DIODE (TIMER-GREEN)	
H3P	LIGHT EMITTING DIODE (FILTER SIGN-RED)	
H4P	LIGHT EMITTING DIODE (DEFROST-ORANGE)	
SS1	SELECTOR SWITCH (MAIN/SUB)	
SS2	SELECTOR SWITCH (WIRELESS ADDRESS SET)	
	CONNECTOR FOR OPTIONAL PARTS	
X24A	CONNECTOR (WIRELESS REMOTE CONTROLLER)	
X30A	CONNECTOR (INTERFACE ADAPTOR FOR SKY AIR SERIES)	
X35A	CONNECTOR (GROUP CONTROL ADAPTOR)	

12

BEVQ71MAVE / BEVQ100MAVE / BEVQ125MAVE



BEV UNIT	
A1P	PRINTED CIRCUIT BOARD ASSY
A2P	POWER SUPPLY PRINTED CIRCUIT BOARD ASSY (220-240V/16V)
F1U	FUSE (Ⓑ, 10A, 250V)
HAP	LIGHT EMITTING DIODE (SERVICE MONITOR-GRREN)
R3T	THERMISTOR (GAS)
SS1	SELECTOR SWITCH (M/S)
X1M	TERMINAL STRIP (POWER)
X2M	TERMINAL STRIP (TRANSMISSION)
Y1E	ELECTRONIC EXPANSION VALVE
Z1C • Z2C Z3C • Z4F	NOISE FILTER

NOTES) 1. □□□ : TERMINAL ⊡⊡ : CONNECTOR
2. ═══ : FIELD WIRING
3. THIS WIRING DIAGRAM ONLY SHOWS THE BEV UNIT.
SEE THE WIRING DIAGRAMS AND INSTALLATION MANUALS FOR THE WIRING AND SETTINGS FOR THE INDOOR, OUTDOOR, AND BS UNITS.
4. SEE THE INDOOR UNIT'S WIRING DIAGRAM WHEN INSTALLING OPTIONAL PARTS FOR THE INDOOR UNIT.
5. ONLY ONE INDOOR UNIT MAY BE CONNECTED TO THE BEV UNIT.
SEE THE INDOOR UNIT'S WIRING DIAGRAM FOR WHEN CONNECTING THE REMOTE CONTROL.
6. ALWAYS USE THE SKY AIR CONNECTION ADAPTER FOR THE INDOOR UNIT WHEN USING A CENTRAL CONTROL UNIT.
REFER TO THE MANUAL ATTACHED THE UNIT WHEN CONNECTING.
7. COOL/HEAT CHANGEOVER OF INDOOR UNITS CONNECTED TO BEV UNIT CANNOT BE CARRIED OUT UNLESS THEY ARE CONNECTED TO BS UNIT.
IN CASE OF A SYSTEM WITH BEV UNIT ONLY, COOL/HEAT SELECTOR IS REQUIRED.
8. SET THE SS1 TO "M" ONLY FOR THE BEV UNIT CONNECTED TO THE INDOOR UNIT WHICH IS TO HAVE COOL/HEAT SWITCHING CAPABILITY, WHEN CONNECTING THE BS UNIT.
THE "M/S" ON THE SS1 STANDS FOR "MAIN/SUB".
THIS IS SET TO "S" WHEN SHIPPED FROM THE FACTORY.
9. CONNECT THE ATTACHED THERMISTOR TO THE R3T.
10. SYMBOLS SHOW AS FOLLOWS.
(BLU : BLUE RED : RED WHT : WHITE BLK : BLACK)

3D044901B

6. Electric Characteristics

Units				Power supply		IFM		Input(W)	
Model	Hz	Volts	Voltage range	MCA	MFA	KW	FLA	Cooling	Heating
BEVQ71M(A)VE + FXUQ71M(A)V1	50	220-240	MAX. 264 Min. 198	0.8	15	0.045	0.6	189	169
BEVQ100M(A)VE + FXUQ100M(A)V1				1.3	15	0.090	1.0	298	278
BEVQ125M(A)VE + FXUQ125M(A)V1									

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
KW : Fan Motor Rated Output(KW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

Note:

1. Voltage range
   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.
2. Maximum allowable voltage unbalance between phases is 2%.
3. MCA/MFA
   MCA = 1.25 X FLA
   MFA ≦ 4 X FLA
   (Next lower standard fuse rating. Min. 15A)
4. Select wire size based on the MCA.
5. Instead of fuse, use Circuit Breaker.

C: 4D034128B

12

7. Capacity Tables

7.1 Cooling Capacity

FXUQ-MA **[50Hz]**

Cooling capacity

Unit Size	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB 20°CDB TC	14.0°CWB 20°CDB SHC	16.0°CWB 23°CDB TC	16.0°CWB 23°CDB SHC	18.0°CWB 26°CDB TC	18.0°CWB 26°CDB SHC	19.0°CWB 27°CDB TC	19.0°CWB 27°CDB SHC	20.0°CWB 28°CDB TC	20.0°CWB 28°CDB SHC	22.0°CWB 30°CDB TC	22.0°CWB 30°CDB SHC	24.0°CWB 32°CDB TC	24.0°CWB 32°CDB SHC
71	10.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.6	6.2	10.5	6.3
	12.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.6	6.2	10.4	6.2
	14.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.6	6.2	10.3	6.2
	16.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.6	6.2	10.1	6.1
	18.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.6	6.2	10.0	6.0
	20.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.6	6.2	9.8	5.9
	21.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.6	6.2	9.8	5.9
	23.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.4	6.2	9.6	5.8
	25.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.3	6.1	9.5	5.7
	27.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.2	6.0	9.4	5.7
	29.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	9.0	5.9	9.2	5.7
	31.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	8.9	5.8	9.1	5.6
	33.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.5	6.0	8.7	5.8	8.9	5.6
	35.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.0	8.4	6.0	8.6	5.7	8.8	5.5
	37.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	5.9	8.3	6.0	8.5	5.8	8.7	5.4
	39.0	5.4	4.8	6.4	5.2	7.5	5.8	8.0	6.1	8.1	5.9	8.3	5.6	8.5	5.4
100	10.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	13.4	8.4	14.7	8.5
	12.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	13.4	8.4	14.5	8.4
	14.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	13.4	8.4	14.4	8.3
	16.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	13.4	8.4	14.2	8.2
	18.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	13.4	8.4	14.0	8.1
	20.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	13.4	8.4	13.8	8.0
	21.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	13.4	8.4	13.7	7.9
	23.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	13.2	8.2	13.5	7.8
	25.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	13.0	8.1	13.3	7.7
	27.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	12.8	8.0	13.1	7.7
	29.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	12.6	7.9	12.9	7.6
	31.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	12.4	7.9	12.7	7.6
	33.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.9	8.3	12.2	7.8	12.5	7.6
	35.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.8	8.3	12.1	7.7	12.3	7.4
	37.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.6	8.3	11.9	7.7	12.2	7.3
	39.0	7.6	6.6	9.0	7.1	10.5	8.0	11.2	8.2	11.4	8.2	11.7	7.6	12.0	7.3
125	10.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	16.8	10.7	18.4	10.8
	12.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	16.8	10.7	18.2	10.7
	14.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	16.8	10.7	18.0	10.5
	16.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	16.8	10.7	17.7	10.4
	18.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	16.8	10.7	17.5	10.2
	20.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	16.8	10.7	17.2	10.1
	21.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	16.8	10.7	17.1	10.0
	23.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	16.5	10.5	16.9	9.9
	25.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	16.3	10.4	16.6	9.9
	27.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	16.1	10.2	16.4	9.8
	29.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	15.8	10.1	16.2	9.7
	31.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	15.6	10.0	15.9	9.6
	33.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.9	10.6	15.3	9.9	15.7	9.6
	35.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.8	10.5	15.1	9.9	15.4	9.4
	37.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.5	10.5	14.9	9.8	15.2	9.4
	39.0	9.5	8.0	11.3	9.0	13.1	9.9	14.0	10.4	14.3	10.2	14.6	9.6	15.0	9.3

TC Total capacity ; kW
SHC Sensible heat capacity ; kW

Refer to Outdoor Unit Capacity Tables : on page 523~, 640~, for the actual performance data of each indoor and outdoor unit combination.

7.2 Heating Capacity

FXUQ-MA **[50Hz]**

Heating capacity

Unit Size	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 kW	18.0 kW	20.0 kW	21.0 kW	22.0 kW	24.0 kW
71	-19.8	-20.0	5.3	5.3	5.3	5.3	5.3	5.3
	-18.8	-19.0	5.5	5.5	5.4	5.4	5.4	5.4
	-16.7	-17.0	5.8	5.8	5.8	5.7	5.7	5.7
	-14.7	-15.0	6.1	6.1	6.1	6.1	6.1	6.1
	-12.6	-13.0	6.4	6.4	6.4	6.4	6.4	6.4
	-10.5	-11.0	6.7	6.7	6.7	6.7	6.7	6.7
	-9.5	-10.0	6.9	6.9	6.9	6.9	6.9	6.8
	-8.5	-9.1	7.1	7.0	7.0	7.0	7.0	7.0
	-7.0	-7.6	7.3	7.3	7.3	7.3	7.2	7.2
	-5.0	-5.6	7.6	7.6	7.6	7.6	7.5	7.5
	-3.0	-3.7	7.9	7.9	7.9	7.9	7.9	7.9
	0.0	-0.7	8.4	8.4	8.3	8.3	8.3	7.9
	3.0	2.2	8.9	8.8	8.8	8.7	8.4	7.9
	5.0	4.1	9.1	9.1	9.0	8.7	8.4	7.9
	7.0	6.0	9.5	9.4	9.0	8.7	8.4	7.9
	9.0	7.9	9.8	9.6	9.0	8.7	8.4	7.9
	11.0	9.8	10.1	9.6	9.0	8.7	8.4	7.9
	13.0	11.8	10.1	9.6	9.0	8.7	8.4	7.9
	15.0	13.7	10.1	9.6	9.0	8.7	8.4	7.9
100	-19.8	-20.0	7.4	7.4	7.3	7.3	7.3	7.3
	-18.8	-19.0	7.6	7.6	7.6	7.5	7.5	7.5
	-16.7	-17.0	8.0	8.0	8.0	8.0	8.0	8.0
	-14.7	-15.0	8.5	8.5	8.4	8.4	8.4	8.4
	-12.6	-13.0	8.9	8.9	8.9	8.9	8.9	8.8
	-10.5	-11.0	9.4	9.3	9.3	9.3	9.3	9.3
	-9.5	-10.0	9.6	9.6	9.5	9.5	9.5	9.5
	-8.5	-9.1	9.8	9.8	9.7	9.7	9.7	9.7
	-7.0	-7.6	10.1	10.1	10.1	10.1	10.1	10.0
	-5.0	-5.6	10.6	10.5	10.5	10.5	10.5	10.5
	-3.0	-3.7	11.0	11.0	10.9	10.9	10.9	10.9
	0.0	-0.7	11.6	11.6	11.6	11.6	11.6	10.9
	3.0	2.2	12.3	12.3	12.2	12.1	11.7	10.9
	5.0	4.1	12.7	12.7	12.5	12.1	11.7	10.9
	7.0	6.0	13.1	13.1	12.5	12.1	11.7	10.9
	9.0	7.9	13.5	13.3	12.5	12.1	11.7	10.9
	11.0	9.8	14.0	13.3	12.5	12.1	11.7	10.9
	13.0	11.8	14.1	13.3	12.5	12.1	11.7	10.9
	15.0	13.7	14.1	13.3	12.5	12.1	11.7	10.9
125	-19.8	-20.0	8.3	8.2	8.2	8.2	8.2	8.2
	-18.8	-19.0	8.5	8.5	8.4	8.4	8.4	8.4
	-16.7	-17.0	9.0	9.0	9.0	8.9	8.9	8.9
	-14.7	-15.0	9.5	9.5	9.5	9.4	9.4	9.4
	-12.6	-13.0	10.0	10.0	10.0	10.0	9.9	9.9
	-10.5	-11.0	10.5	10.5	10.4	10.4	10.4	10.4
	-9.5	-10.0	10.8	10.7	10.7	10.7	10.7	10.6
	-8.5	-9.1	11.0	10.9	10.9	10.9	10.9	10.8
	-7.0	-7.6	11.3	11.3	11.3	11.3	11.2	11.2
	-5.0	-5.6	11.8	11.8	11.8	11.8	11.7	11.7
	-3.0	-3.7	12.3	12.3	12.3	12.2	12.2	12.2
	0.0	-0.7	13.0	13.0	13.0	13.0	13.0	12.2
	3.0	2.2	13.8	13.7	13.7	13.6	13.1	12.2
	5.0	4.1	14.2	14.2	14.0	13.6	13.1	12.2
	7.0	6.0	14.7	14.7	14.0	13.6	13.1	12.2
	9.0	7.9	15.2	14.9	14.0	13.6	13.1	12.2
	11.0	9.8	15.6	14.9	14.0	13.6	13.1	12.2
	13.0	11.8	15.8	14.9	14.0	13.6	13.1	12.2
	15.0	13.7	15.8	14.9	14.0	13.6	13.1	12.2


Refer to Outdoor Unit Capacity Tables : on page 548~, 656~, for the actual performance data of each indoor and outdoor unit combination.

8. Air Velocity and Temperature Distributions (Reference Data)

FXUQ71MA


COOLING • AIR VELOCITY DISTRIBUTION

4 WAY DISCHARGE AIR FLOW DIRECTION : HORIZONTAL



COOLING • AIR TEMPERATURE DISTRIBUTION


4 WAY DISCHARGE AIR FLOW DIRECTION : HORIZONTAL



4D028396C


HEATING • AIR VELOCITY DISTRIBUTION

4 WAY DISCHARGE AIR FLOW DIRECTION : DOWN



HEATING • AIR TEMPERATURE DISTRIBUTION

4 WAY DISCHARGE AIR FLOW DIRECTION : DOWN




4D013863D

FXUQ100MA


COOLING • AIR VELOCITY DISTRIBUTION

4 WAY DISCHARGE AIR FLOW DIRECTION : HORIZONTAL



COOLING • AIR TEMPERATURE DISTRIBUTION


4 WAY DISCHARGE AIR FLOW DIRECTION : HORIZONTAL



4D028397C


HEATING • AIR VELOCITY DISTRIBUTION

4 WAY DISCHARGE AIR FLOW DIRECTION : DOWN



HEATING • AIR TEMPERATURE DISTRIBUTION

4 WAY DISCHARGE AIR FLOW DIRECTION : DOWN




4D014054D

12

FXUQ125MA


COOLING • AIR VELOCITY DISTRIBUTION

4 WAY DISCHARGE AIR FLOW DIRECTION : HORIZONTAL



COOLING • AIR TEMPERATURE DISTRIBUTION


4 WAY DISCHARGE AIR FLOW DIRECTION : HORIZONTAL



4D028398C


HEATING • AIR VELOCITY DISTRIBUTION

4 WAY DISCHARGE AIR FLOW DIRECTION : DOWN



HEATING • AIR TEMPERATURE DISTRIBUTION

4 WAY DISCHARGE AIR FLOW DIRECTION : DOWN




4D014055D

9. Sound Levels

Overall

■ **Ceiling Suspended Cassette Type**



dBA

Model	230V, 50Hz	
	H	L
FXUQ71MAV1	40	35
FXUQ100MAV1	43	38
FXUQ125MAV1	44	39


Notes:

1. The operating conditions are assumed to be standard (JIS conditions).
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.

Octave Band Level


○——○ 230V 50Hz

FXUQ71MAV1




4D014037D

FXUQ100MAV1



4D014038D

FXUQ125MAV1




4D014039D

12

10. Installation

10.1 Indoor Units

Installation Example



Service Space

Select an installation site where the following conditions are fulfilled and that meets your customer's approval.


- In the upper space (including the back of the ceiling) of the indoor unit where there is no possible dripping of water from the refrigerant pipe, drain pipe, water pipe, etc.
- Where optimum air distribution can be ensured.
- Where nothing blocks air passage.
- Where condensate can be properly drained.
- Where the ceiling is strong enough to bear the indoor unit weight.
- Where the false ceiling is not noticeably on an incline.
- Where sufficient clearance for maintenance and service can be ensured.
- Where there is no risk of flammable gas leakage.
- Where piping between indoor and outdoor units is possible within the allowable limit. (Refer to the installation manual for the outdoor and BEV units.)

[CAUTION]

Only use the included parts or parts which match the specifications when installing the unit.

- Install the indoor unit no less than 2.5 m above the floor. Where unavoidably lower, take what measures are necessary to keep hands out of the air outlet.

Space required for installation



(length: mm)

** Space is required to attach/detach corner covers.

Bolt Pitch

1. FOR 4-WAY AIR DISCHARGE

1. **Relation of holes for indoor unit, suspension bolt position, piping and wiring. (Refer to Fig. 2)**
   (Illustrations seen from ceiling)
   * Dimensions in ( ) for 100 and 125 models
   *** Suspension bolt pitch

2. **Make holes for suspension bolts, refrigerant and drain piping, and wiring. (Refer to Fig. 3)**
   - Refer to the paper patten for the locations.
   - Select the location for each of holes and open the holes in the ceiling.





Fig. 3






Fig. 2

NOTE
All the above parts are field supplied.

2. FOR 2-WAY OR 3-WAY AIR DISCHARGE

2-way and 3-way air discharge must be set from the remote controller. For details, see FIELD SETTING.

1. **Relation of holes for indoor unit, suspension bolt position, piping and wiring. (Refer to Fig. 8)**

NOTE
Illustrations seen from ceiling
* Dimension in ( ) for 100 and 125 models
***Suspension bolt pitch

2. **Make holes for suspension bolts, refrigerant and drain piping, and wiring. (Refer to Fig. 9)**
   - Refer to paper pattern for the locations.
   - Select the location for each of holes and open the holes in the ceiling.





Fig. 9






Fig. 8

12

Drain Piping Work

1. Rig drain piping (Refer to Fig. 26)

As for drain work, perform piping in such a manner that water can be drained properly.
As for drain piping, the connection can be made from three different directions.

- Employ a pipe with either the same diameter or with the diameter larger (excluding the raising section) than that of the connecting pipe (PVC pipe, nominal diameter 20 mm, outside diameter 26 mm).
- Keep the drain pipe short and sloping downwards at a gradient of at least 1/100 to prevent air pockets from forming. **(Refer to Fig. 27)**

⚠ CAUTION

Water pooling in the drainage piping can cause the drain to clog.




Fig. 26




Fig. 27

- To keep the drain hose from sagging, space hanging wires every 1 to 1.5 m. **(Refer to Fig. 26)**
- Use only the included drain hose (1), (for rightward running drain hose) or elbow (10) (for upward running drain hose) and clamp (2).
- Fit the drain hose (1) or elbow (10) over the drain pipe up to the neck and fasten tight with the clamp (2).
- Insulate the clamp (2) and drain hose or elbow (10) with the included sealing pad (8). **(Refer to Fig.28)**
- Make sure that heat insulation work is executed on the following 2 spots to prevent any possible water leakage due to dew condensation.
  - Insulate the drain hose inside the building.
  - Drain socket




Fig. 28

⚠ CAUTION

- Do not twist or bend the drain hose (1), so that excessive force is not applied to it, as this could cause leaks.

- If converging multiple drain piping, install according to the procedure shown below. **(Refer to Fig. 29)**

Select converging drain piping whose gauge is suitable for the operating capacity of the unit.





Fig. 29

PRECAUTIONS FOR UPWARD DRAIN RAISING PIPING

- Install the drain raising pipes at a height of less than 500 mm.
- Install the drain raising pipes at a right angle to the indoor unit. **(Refer to Fig. 30)**



WRONG


Fig. 30

⚠ CAUTION

If the upward running drain hose leans at a slant, the float switch will malfunction and water will leak.

2. After piping work is finished, check if drainage flows smoothly.

- Open the water inlet lid, add approximately 1 liter of water slowly and check drainage flow. **(Refer to Fig. 31)**



Method of adding water

Fig. 31

[Caution]

Drain piping connections

- Do not connect the drain piping directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the indoor unit through the drain pipes and corrode the heat exchanger.

12

⚠ CAUTION

- Electrical wiring work should be done by a certified electrician.
- If someone who does not have the proper qualifications performs the work, perform the following after the test run is complete.

- Remove the control box lid and change the emergency switch above the PC board assembly of the indoor unit from “NORM.” to “EMERG.”. Connect the single-phase power supply (1, 3) and ground wire to the inter-unit wiring (50Hz 220-240V) terminal block and confirm drain operation.Be sure to change the switch before turning on the power. **(Refer to Fig. 32)**

⚠ CAUTION

- Clamp solidly to clamp C to tension is not added to the wiring connections.
- Be aware that the fan will turn during the operation.

- After confirming drainage, turn off the power and be sure to change the emergency switch back to “NORM.”.




Fig. 32

10.2 Connecting Units

Before Installation

- **When moving the unit while removing it from the carton box, be sure to lift it by holding on to the two lifting lugs without exerting any pressure on other parts, especially, the refrigerant piping.**
- Be sure to check the type of R-410A refrigerant to be used before installing the unit. (Using an incorrect refrigerant will prevent normal operation of the unit.)
- BEV unit is an electronic expansion valve unit for allowing the indoor unit to be connected to the system for the VRV system.
- BEV unit may only be connected to the models shown in the table below. Do not attempt connection with other models.

Indoor unit
Ceiling Suspended Cassette Type

- See the included installation manuals on the VRV outdoor unit and the ceiling suspended cassette type indoor unit for details.
- For the indoor unit connected to the BEV unit, cooling/heating cannot be switched over with the remote controller.
- When the cooling/heating free system is connected to the BS unit, a cooling/heating selection right is allowed.
- When the ceiling suspended cassette type indoor unit and BEV unit are used for all indoor units, a separate “Cool/Heat SELECTOR” is needed to enable the cooling/heating switchover.

Service Space.

《 When hanging the unit from the ceiling 》

Install so that the control box lid is facing down.




Fig. 1


(length: mm)

12


.

《When installing the unit on a wall》

Make sure the wiring outtake is facing down, and no other direction.




* Make sure there is enough space to tighten the flare nuts.



《Direction of the gas piping connection piping》

Upright and diagonal position



Take the gas piping thermistor out from above.

Fig. 2
(length: mm)

Bolt Pitch

《 When hanging the unit from the ceiling 》

(1) Check the relative locations of ceiling hole, unit, and hanging bolts.





Fig. 3 (length: mm)



Note: All the above parts are field supplied.


Fig. 4

(2) Open the eyebolt holes or the holes for passing the piping and wiring out of the unit.
- Set the locations for the above holes, open them up and then lay the piping (refrigerant) and wiring (including both power supply and transmission wiring) up to the piping and wiring connections in the unit.
- It might be necessary to reinforce the ceiling frame to maintain the levelness and to prevent vibration. Consult an architect or carpenter for details.

(3) Install the hanging bolts. (Use M8 hanging bolts.)
- If it is pre-set, use hole-in anchors. Otherwise, use embedded inserts or embedded foundation bolts to make sure that the weight of the unit can be supported. Adjust the distance to the ceiling beforehand.

《 When installing the unit on a wall 》

(1) Check the relative locations of ceiling hole, unit, and hanging bolts.



(length: mm)

Fig. 5

- Use only accessories and parts which are of the designated specification when installing.

《 When hanging the unit from the ceiling 》

(1) Temporarily install the BEV unit.
- Mount the hanging fittings to hanging bolts. Secure the hanging fittings on the top and the bottom with nuts (M8, field supplied) and washers (M8: Outside diameter size 24 to 28 mm) (field supplied).

(2) Adjust the height of the main unit with the nut.
(3) Check that the main unit is installed on the level.
(4) Tighten the nut on both the top and the bottom to fix securely.




Fig. 6

《 When installing the unit on a wall 》

(1) Mount the hanging fittings with the mounting screws (4 pieces).
(2) Use M4 screws.




Fig. 7

12

Refrigerant Piping work


〈This shows the piping method between the outdoor unit and the BEV unit and the indoor unit. Select the pipe size and refrigerant branch kit depending on how the piping will be laid.〉
〈For refrigerant piping of outdoor units, see the installation manual attached to the outdoor unit.〉
〈Execute heat insulation work completely on both sides of the gas piping and the liquid piping. Otherwise, a water leakage can result sometimes.〉
〈When using a heat pump, the temperature of the gas piping can reach up to approximately 120˚C, so use insulation which is sufficiently resistant.〉
〈Improve the insulation on the refrigerant piping depending on the installation environment. If the insulation is not sufficient, condensation may form on the surface of the insulation.〉
〈Before refrigerant piping work, check which type of refrigerant is used. Proper operation is not possible if the types of refrigerant are not the same.〉

⚠ CAUTION


- **Use a pipe cutter and flare suitable for the type of refrigerant.**
- **Apply ester oil or ether oil around the flare section before connecting.**
- **To prevent dust, moisuture or other foreign matter from infiltrating the tube, either pinch the end or cover it with tape.**
- **Do not allow anything other than the designated refrigerant to get mixed into the refrigerant circuit, such as air, etc. If any refrigerant gas leaks while working on the unit, ventilate the room thoroughly right away.**


- The outdoor unit is charged with refrigerant.
- For the refrigerant piping and branching, follow the **"piping connection procedure"**.
- Be sure to use both a spanner and torque wrench together, as shown in the drawing, when connecting or disconnecting piping to/from the unit.
- Refer to the Table 1 for the dimensions of flare nut spaces.
- When connecting the flare nut, apply ether oil or ester oil only to inner side of the flare and initially tighten by hand 3 or 4 turns before tightening firmly.
- Refer to the Table 1 to determine the proper tightening torque.

Table 1

Pipe size	Tightening torque	Flare dimension A (mm)	Flare shape
ϕ9.5 (3/8")	32.7 – 39.9N·m (333 – 407 kgf·cm)	12.8 – 13.2	
ϕ15.9 (5/8")	61.8 – 75.4N·m (630 – 770 kgf·cm)	19.3 – 19.7	

NOTE
The flare nuts used must be those included with the main body.





⚠ CAUTION

Over-tightening may damage the flare and cause a refrigerant leakage.

Not recommendable but in case of emergency

You must use a torque wrench but if you are obliged to install the unit without a torque wrench, you may follow the installation method mentioned below.

When you keep on tightening the flare nut with a spanner, there is a point where the tightening torque suddenly increases. From that position, further tighten the flare nut the angle shown below:

Table 2

Pipe size	Further tightening angle	Recommended arm length of tool
ϕ 9.5 (3/8")	60 to 90 degrees	Approx. 200mm
ϕ15.9 (5/8")	30 to 60 degrees	Approx. 300mm

After the work is finished, make sure to check that there is no gas leak.

- Make absolutely sure to execute heat insulation works on the pipe-connecting section after checking gas leakage by thoroughly studying the following figure.
- Wrap the insulation for fitting (3) (4) around the insulation for the joints on the liquid piping side and the gas piping side. **(Refer to Fig. 9, 10)**
- When installing the unit onto the ceiling, make sure that the seam between the insulation for fitting (3) (4) faces up. (Fasten both ends with the clamps (2).) (Fig.9, 10 shows the case of installation on the wall.)
- Wrap the included sealing pad (5) (6) around the insulation for fitting (3) (4). **(Refer to Fig. 8)**

⚠ CAUTION

Be sure to insulate any field piping all the way to the piping connection inside the unit. Any exposed piping may cause condensation or burns if touched.




Fig. 8




Fig. 9




Fig. 10

12

⚠ CAUTION

CAUTION TO BE TAKEN WHEN BRAZING REFRIGERANT PIPING

Do not use flux when brazing refrigerant piping. Therefore, use the phosphor copper brazing filter metal (BCuP) which does not require flux.
(Flux has extremely harmful infulence on refrigerant piping sysems. For instance, if the chlorine based flux is used, it will cause piping corrosion or, in particular, if the flux contains fluorine, it will damage the refrigerant oil.)

- Before brazing local refrigerant piping, nitrogen gas shall be blown through the piping to expel air from the piping. If your brazing is done without nitrogen gas blowing, a large amount of oxide film develops inside the piping, and could cause system malfunction.
- When brazing the refrigerant piping, only begin brazing after having carried out nitrogen substitution or while inserting nitrogen into the refrigerant piping. Once this is done, connect the indoor unit with a flared connection.
- Nitrogen should be set to 0.02 MPa (0.2 kg/cm^2) with a pressure-reducing valve if brazing while inserting nitrogen into the piping.




Fig. 11

⚠ CAUTION

Do not use anti-oxidants when brazing the piping joints. Residue can clog piping and break equipment.

Piping connection procedure

- Make sure the length of the refrigerant piping between the BEV unit and the indoor unit is no more than 5m and that the difference in height is at least 4m.

(1) Connection example for the indoor unit

- Only one indoor unit may be connected to each BEV unit.




Fig. 12

(2) Height difference between indoor units

- Install the BEV unit in the 15m range of difference in height between the indoor units.
- Make sure the difference in height between the BEV unit and the indoor unit is no more than 4m.




Fig. 13

(3) Allowable length after split (actual piping length)

B+C≤35m (length from the first branch piping to the indoor unit)

(4) Additional refrigerant amount

When measuring the amount of additional to refrigerant to fill, include the length of the liquid piping between the BEV unit and the indoor unit.

Additional filling amount = a+b+c+d+e+f+g+h+i+j+k+l+m+n+p+q

Refer also to the installation manual included with the outdoor unit.

Example of refrigerant branch using a REFNET joint




Fig. 14

Wiring Example and How to Set the Remote Controller

1 HOW TO CONNECT WIRINGS

- Connect the piping only after finishing the refrigerant piping work.
- Make sure all power supply is shut down to the unit first.
- As shown in the Fig. 16, loosen the two screws in the control box lid, remove it, and do the wiring work.
- Once all wiring is done, attach the control box lid and secure it with the screws.
  If you are using “4. DEF AULT SETTINGS,” however, finish that and then attach the control box lid and secure it with the screws.

2 THE GAS PIPING THERMISTOR

- Connect to (X5A) on A1P.
- Bundle the gas piping thermistor lead wire and the branch wiring (transmission) using the included clamping material.
- Tension is not added to the gas pipe thermistor lead wire coming out of the unit.

• Power supply wiring • Ground wire

Connect the wiring to R (L) and S (N) on the power supply terminal block (X1M). Also, connect the ground wire to the ground terminal. Take the wiring and the ground wire into the unit through the wiring pass-through hole, and firmly secure them together using the included clamp (1).

• Indoor unit inter-unit wiring

Connect the wires to 1, 2, and 3 on the power supply terminal block (X1M). Take the wires into the unit through the wiring pass-through hole, and firmly secure them using the included clamp (1).

• Transmission wiring

Connect the wires to F1 and F2 on the transmission terminal block (X2M). Take them into the unit through the wiring pass-through hole, and firmly secure the gas piping thermister lead wire and the transmission wiring using the included clamp (1).




Fig. 16

[CAUTIONS]

- Do not under any circumstances connect the power supply wiring to the transmission terminal block (F1, F2), as this may cause damage to the entire system.


⚠ CAUTION

- When clamping wiring, use the included clamping material to prevent outside presure being exerted on the wiring connections and clamp firmly. When doing the wiring, make sure the wiring is neat and does not cause the control box lid to stick up, then close the cover firmly.
- When attaching the control box lid, make sure you do not pinch any wires.
- After all the wiring connections are done, fill in any gaps in the through holes with putty or insulation (procured locally) to prevent small animals and insects from entering the unit from outside. (If any do get in, they could cause short circuits in the control box.)
- Outside the machine, separate the weak wiring (gas piping thermistor lead wire, transmission wiring) and strong wiring (power supply wiring, inter-unit wiring, ground wire, and other power wiring) at least 50mm so that they do not pass through the same place together. Proximity may cause electrical interference, malfunctions, and breakage.

12

[PRECAUTIONS]

1. Use round crimp-style terminals for connecting wiring to the power supply terminal block.
   If unavailable, observe the following points when wiring.
   - Do not connect wiring of different gauge to the same power supply terminal. (Looseness in the connection may cause overheating.)
   - Use the specified electric wiring. Connect the wiring securely to the terminal. Lock the wiring down without applying excessive force to the terminal. (Tightening torque: 131N·cm ±10 %)



2. **Tightening torque for the terminal screws.**
   - Use the correct screwdriver for tightening the terminal screws. If the blade of screwdriver is too small, the head of the screw might be damaged, and the screw will not be properly tightened.
   - If the terminal screws are tightened too hard, screws might be damaged.
   - Refer to the table below for the tightening torque of the terminal screws.

Terminal	Size	Tightening torque
Transmission terminal block (2P)	M3.5	0.79 – 0.97N·m
Power supply and inter-unit wiring terminal block (6P)	M4	1.18 – 1.44N·m
Ground terminal	M4	1.44 – 1.94N·m

3. Do not connect wiring of different gauge to the same grounding terminal. Looseness in the connection may deteriorate protection.
4. Outside of the unit, keep the weak wiring (gas piping thermistor lead wire, transmission wiring) at least 50 mm away from strong wiring (power supply wiring, inter-unit wiring, ground wire, and other power wiring). The equipment may malfunction if subjected to electrical (external) noise.
5. For remote controller wiring, refer to the “INSTALLATION MANUAL OF REMOTE CONTROLLER” attached to the remote controller.
6. **Never connect power supply wiring to the terminal block for remote controller wiring. A mistake of the sort could damage the entire system.**
7. Use only specified wiring and tightly connect wiring to terminals. Be careful wiring do not place external stress on terminals. Keep wiring in neat order and so as not to obstruct other unit such as popping open the control box lid. Make sure the lid closes tight. Incomplete connections could result in overheating, and in worse case, electric shock or fire.

[WIRING EXAMPLE]

- Fit the power supply wiring of each unit with a switch and fuse as shown in the drawing.

COMPLETE SYSTEM EXAMPLE (3 systems)




Fig. 17

1. When using 1 remote controller for 1 indoor unit. (Normal operation)




Fig. 18

<Caution>

Group control is not possible between ceiling suspended cassette type units and normal VRV indoor units.

2. For group control or use with 2 remote controllers




Fig. 19

3. When including BS unit




Fig. 20

4. DEFAULT SETTINGS

1. Once piping work is completed, conduct the following settings as needed.

(1) When connecting the BEV unit to the BS unit in the heating/cooling free system, turn the SS1 on the A1P to M (Main) for only one of the BEV units connected to the remote controller on which heating/cooling switching is made possible. **(Refer to Fig. 21)**




Fig. 21

(2) For BEV unit-only systems
The Cool/Heat SELECTOR is needed.
Refer to the installation manual included with the Cool/Heat SELECTOR for details on how to set it.


2. Once all piping work is done, screw the control box lid shut using the mounting screws.


11. Accessories

Standard Accessories (Indoor Unit)

Check the following accessories are included with the unit.






Name	1) Drain hose	2) Metal Clamp	3) Washer for looking hanger	4) Clamp	5) Wahers fixing plate
Quantity	1 pc.	1 pc.	8 pcs.	6 pcs.	4 pcs.
Shape					

Name	Insulation for fitting	Sealing pad	10) Elbow	11) Paper pattern for installation	12) Blocking pad
Quantity	1 each	2 pcs.	1 pc.	1 pc.	2 pcs.
Shape	6) For gas pipe  7) For liquid pipe	8) Large  9) Small 		Also used as packing material 	

Name	13) Retainer for blocking pad	14) Retainer for blocking pad	15) Center retainer for blocking pad	(Other) • Operation manual • Installation manual
Quantity	2 pcs.	2 pcs.	2 pcs.	
Shape				

Standard Accessories (Connecting Unit)

Check if the following accessories are included with your unit.

Name	Clamp	Insulation for fitting	Sealing pad	(7) Gas piping connection piping
Quantity	9 pcs.	3 pcs.	3 pcs.	1 pc.
Shape	(1) 3 short pieces  (2) 6 long pieces	(3) For liquid piping × 2  (4) For gas piping × 1 	(5)  Small × 2 (6)  × 1	

Name	(8) Installation manual	(9) Nameplate
Quantity	1 pc.	1 pc.
Shape		

Optional Accessories (For Indoor Unit)


No.	Type / Item	FXUQ71MAV1	FXUQ100MAV1	FXUQ125MAV1
1	Sealing Member of Air Discharge Outlet	KDBHJ49F80	KDBHJ49F140	
2	Decoration Panel for Air Discharge	KDBTJ49F80	KDBTJ49F140	
3	Vertical Flap Kit	KDGJ49F80	KDGJ49F140	
4	Replacement Long Life Filter	KAFJ495F140		
5	L Connection Piping Kit	KHFP49M140		


C: 3D045452A

Optional Accessories (For Controls) Refer to P.807

Sealing Member of Air Discharge Outlet – KDBHJ49F80 · 140

Dimension







Model	A	B
KDBHJ49F80	100	100
KDBHJ49F140	155	155

Model	Material
KDBHJ49F80	Galvanized Steel Plate
KDBHJ49F140	(with Flocking)

Decoration Panel for Air Discharge – KDBTJ49F80 · 140

Dimension






Model	A	B
KDBTJ49F80	100	100
KDBTJ49F140	155	155

Model	Material
KDBTJ49F80	Galvanized Steel Plate
KDBTJ49F140	(with Flocking)


Vertical Flap Kit – KDGJ49F80 · 140

Dimension

KDGJ49F80




KDGJ49F140



Model	Packing Quantity
KDGJ49F80	4(each 2×2)
KDGJ49F140	

Replacement Long Life Filter – KAFJ495F140


Dimension



Item \ Model	KAFJ495F140
Initial Pressure Loss (Pa)	Less Than 7
Final Pressure Loss (Pa)	Less Than 49
Average Efficiency (%)	50 (Gravity Method)
Life Time (h)	2,500 (Dust Particle Concentration at 0.15mg/m^3)
Filter Pass Air Flow Rate	18.5m^3/min
Materials	Mildew Proof Resin Net
Number Required Per Model	1
Weight (kg)	0.4

L Connection Piping Kit – KHFP49M140


Dimension



Model	Liquid Side	Gas Side
KHFP49M140	ϕ9.5	ϕ15.9

Installation Box for Adaptor PCB – KRP1B97

Dimension



Item \ Model No.	KRP1B97
Adaptor for Wiring	KRP4A53

12

Part 3
Outdoor
Air Processing Unit

FXMQ-MF
Outdoor Air Processing Unit 435

FXMQ-MF
Outdoor Air Processing Unit

1. Features 436
2. Specifications 438
3. Dimensions 439
   3.1 Indoor Units 439
   3.2 Dimensions with Option 441
4. Piping Diagrams 443
5. Wiring Diagrams 444
6. Capacity Tables 445
7. Operation Limit 448
8. Electric Characteristics 450
9. Sound Levels 451
10. Fan Performances 452
11. Installation 454
12. Accessories 467

13

1. Features

Outdoor-Air Processing Unit


50 Hz only
For outdoor units of 8 HP and above

Combine fresh air treatment and air conditioning, supplied from a single system.

Model Names
FXMQ125MFV1, FXMQ200MFV1, FXMQ250MFV1




Fresh air treatment and air conditioning can be achieved with a single system by using heat pump technology—without the usual troublesome air supply and air discharge balance design. Fan coil units for air conditioning and an outdoor-air processing unit can be connected to the same refrigerant line. The results are enhanced design flexibility and a significant reduction in total system costs.



Combination with VRV Ⅲ

Air conditioning and outdoor air processing can be accomplished using a single system.



Connection Conditions

The following restrictions must be observed in order to maintain the indoor units connected to the same system.

- When outdoor-air processing units are connected, the total connection capacity must be within 50% to 100% of that of the outdoor units.
- When outdoor-air processing units and standard indoor units are connected, the total connection capacity of the outdoor-air processing units must not exceed 30% of that of the outdoor units.
- Outdoor-air processing units can be used without indoor units.
- Connectable outdoor units: VRV Ⅱ and Ⅲ systems.

•The unit introduces outdoor air and adjusts the outdoor air temperature via fixed discharge temperature control, thereby reducing the air conditioning load.

* The system can operate with outdoor-air temperatures ranging from -5 to 43˚C. Heating performance is somewhat adversely affected when the outdoor-air temperature is 0˚C or below.
* When shipped from the factory, the thermostat is set at 18˚C for cooling and 25˚C for heating. The set temperature can be varied within the range of 13–25˚C during cooling operation, and 18–30˚C during heating operation, in the local setting mode using the wired remote controller. The temperature, however, is not displayed on the remote controller.
* While in machine protection mode and depending on outdoor air conditions, discharge air temperature may not be at the set temperature.
* The fan stops when operating in defrosting, oil returning and hot start operations. The fan also may stop due to mechanical protection control.


• Ceiling mounted duct units with three differing capacities are available. These can be connected to VRV series outdoor units to meet a variety of different requirements.

Airflow rate

FXMQ125MFV1	1,080 m³/h
FXMQ200MFV1	1,680 m³/h
FXMQ250MFV1	2,100 m³/h

• Optional equipment includes long-life filters.

• Compatible with outdoor temperatures from -5˚C to 43˚C.



Notes
1. The data shown in the graph illustrates the supported operation ranges under the following conditions.
   Indoor and Outdoor Unit
   Effective piping length: 7.5 m
   Height differential: 0 m
2. The discharge temperature can be set using the remote controller. However, the actual temperature may not match the temperature setting under some circumstances due to the outdoor-air processing load or mechanical protection controls.
3. The system will not operate in fan mode when the outdoor air temperature is 5˚C or below.

• High-performance filters with dust collection efficiencies (JIS calorimetry) of 90% and 65% are also available as options.

• As with the VRVⅢ system, a variety of control systems can be deployed, including remote control from distances of up to 500 m.

* Group control is not possible between this unit and standard type indoor units. Connect remote controllers to each unit.



BRC1C62
Wired remote controller
(option)

• The "self-diagnosis function" indicates the occurrence and nature of abnormalities in the system by displaying codes on the remote controller.

• A central control system compatible with the VRVⅢ system can be installed.

* It is not possible to change the discharge air temperature settings from the central control system.
* Do not associate this equipment into zones with standard indoor units, as central control will not be possible.



DCS302CA61
Central remote controller
(option)

• As with the VRVⅢ system, the equipment employs the "super wiring system" so that the wiring linking indoor and outdoor units can also be utilised for central control.

Notes:
* Linked control of the product and the HRV is not supported.
* This equipment is intended for the treatment of outdoor air only. It is not to be used for maintaining indoor air temperature. Install and use with standard indoor units. Be sure to position the air discharge openings of the product in positions where the airflow will not blow on people directly. When outdoor-air processing is in excess, the unit switches to thermo-off mode, and outdoor air flows into the room directly.
* For outdoor ducts, be sure to provide heat insulation to prevent condensation.
* Group control of the product and the standard indoor units is not supported. A separate remote controller should be connected to each individual unit.
* The system will not operate in fan mode when the outdoor air temperature is 5˚C or below.
* If the product is allowed to operate 24 hours a day, maintenance (part replacement, etc.) must be performed periodically.
* Temperature setting and Power Proportional Distribution (PPD) are not possible even if the intelligent Touch Controller or the intelligent Manager III is installed.
* The remote controller wired to the outdoor-air processing unit must not be set as the master remote controller. Otherwise, when set to “Auto,” the operation mode will switch according to the outdoor air conditions, regardless of the indoor temperature.

13

2. Specifications

Model			FXMQ125MFV1	FXMQ200MFV1	FXMQ250MFV1
★1 Cooling Capacity		kcal/h	12,000	19,300	24,100
		Btu/h	47,800	76,400	95,500
		kW	14.0	22.4	28.0
★1 Heating Capacity		kcal/h	7,700	12,000	15,000
		Btu/h	30,400	47,400	59,400
		kW	8.9	13.9	17.4
Casing			Galvanized Steel Plate	Galvanized Steel Plate	Galvanized Steel Plate
Dimensions: (H×W×D)		mm	470×744×1,100	470×1,380×1,100	470×1,380×1,100
Coil (Cross Fin Coil)	Rows×Stages×Fin Pitch	mm	3×26×2.0	3×26×2.0	3×26×2.0
	Face Area	m²	0.28	0.65	0.65
Fan	Model		D13/4G2DA1	D13/4G2DA1	D13/4G2DA1
	Type		Sirocco Fan	Sirocco Fan	Sirocco Fan
	Motor Output × Number of Units	W	380×1	380×1	380×1
	Air Flow Rate (H/L)	m³/min	18	28	35
		cfm	635	988	1,236
	External Static Pressure ★4	Pa	185	225	205
	Drive		Direct Drive	Direct Drive	Direct Drive
Temperature Control			Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating	Microprocessor Thermostat for Cooling and Heating
Sound Absorbing Thermal Insulation Material			Glass Fiber	Glass Fiber	Glass Fiber
Air Filter			★2	★2	★2
Piping Connections	Liquid Pipes		9.5mm (Flare Connection)	9.5mm (Flare Connection)	9.5mm (Flare Connection)
	Gas Pipes		15.9mm (Flare Connection)	19.1mm (Brazing Connection)	22.2mm (Brazing Connection)
	Drain Pipe	(mm)	PS1B (female thread)	PS1B (female thread)	PS1B (female thread)
Machine Weight (Mass)		kg	86	123	123
Sound Level (220V) ★3,★4		dBA	42	47	47
Safety Devices			Fuse Thermal Protector for Fan Motor	Fuse Thermal Protector for Fan Motor	Fuse Thermal Protector for Fan Motor
Refrigerant Control			Electronic Expansion Valve	Electronic Expansion Valve	Electronic Expansion Valve
Standard Accessories			Operation Manual, Installation Manual, Sealing Pads, Screws, Clamps.	Operation Manual, Installation Manual, Sealing Pads, Connection Pipes, Screws, Clamps.	Operation Manual, Installation Manual, Sealing Pads, Connection Pipes, Screws, Clamps.
Connectable Outdoor Units ★5,★6			RXYQ8~54P(A)Y1	RXYQ8~54P(A)Y1	RXYQ10~54P(A)Y1
Drawing No.			C : 3D046147A	C : 3D046147A	C : 3D046147A

Notes:

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

★1. Specifications are based on the following conditions:
- Cooling: Outdoor temp. of 33°CDB, 28°CWB (68% RH). and discharge temp. of 18°CDB
- Heating: Outdoor temp. of 0°CDB, -2.9°CWB (50% RH). and discharge temp. of 25°CDB
- Equivalent reference piping length: 7.5m (0m Horizontal)
- At 220V

★2. Air intake filter is not supplied, so be sure to install the optional long-life filter or high-efficiency filter.
Please mount it in the duct system of the suction side. Select its colorimetric method (gravity method) 50% or more.

★3. Anechoic chamber conversion value, measured at a point 1.5m downward from the unit center.
These values (measured at 220V) are normally somewhat higher during actual operation as a result of ambient conditions.

★4. Values measured at 220 V.

★5. Within the range that the total capacity of indoor units is 50 to 100%, it is possible to connect to the outdoor unit.

★6. It is not possible to connect to the 5 HP outdoor unit. Not available for Heat Recovery type and VRV III-S series.
- This equipment cannot be incorporated into the remote group control of the VRV III system.

3. Dimensions

3.1 Indoor Units


FXMQ125MFV1

Unit (mm)

3D045129A


Number	Name	Description
11	Water supply port	
10	Discharge companion flange	
9	Hanger bracket	M10
8	Transmission wiring connection	
7	Power supply wiring connection	Note. 1
6	Name plate	M5 (Inside Control box)
5	Ground terminal	
4	Control box	PS1B Internal thread Major dia. ϕ33.349, Minor dia. ϕ30.391
3	Drain piping connection	ϕ15.9 Flare connection
2	Gas pipe connection	ϕ9.5 Flare connection
1	Liquid pipe connection	

Notes) 1. Location of unit's Name Plates:
Control box surface
2. Mount the air filter at the suction side.
(Select its colorimethod (gravity method) 50% or more.)



FXMQ200MFV1
FXMQ250MFV1

Unit (mm)




3.2 Dimensions with Option

FXMQ125MFV1

Unit (mm)

3D046155

Number	Name	Description
8	Drain hose	Attached to Drain pump kit
7	Water supply port	
6	Drain pipe connection (drain pump kit)	VP25(O. D ϕ32, I. D ϕ25)
5	Drain pump kit	Builted-in
4	Long-life replacement filter	
3	High-eficiency filter	
2	Filter chamber	
1	VRV D. P. Unit C. duct type	




FXMQ200MFV1
FXMQ250MFV1


Unit (mm)

3D046154

Number	Name	Description
8	Drain hose	Attached to Drain pump kit
7	Water supply port	
6	Drain pipe connection (drain pump kit)	VP25 (O. D φ32, I. D φ25)
5	Drain pump kit	Builted-in
4	Long-life replacement filter	
3	High-efficiency filter	
2	Filter chamber	
1	VRV D.P. Unit C. duct type	



4. Piping Diagrams




4D018650B

13

5. Wiring Diagrams

FXMQ125MFV1
FXMQ200MFV1
FXMQ250MFV1



INDOOR UNIT	
A1P	PRINTED CIRCUIT BOARD
C1, C2	CAPACITOR (M1F)
F1U	FUSE (Ⓑ, 5A, 250V) (A1P)
HAP	LIGHT EMMITING DIODE (SERVICE MONITOR-GREEN)
K1M	MAGNETIC RELAY (M1F)
K1R	MAGNETIC RELAY (M1F)
KPR	MAGNETIC RELAY (M1P)
KSR	MAGNETIC RELAY (Y1S)
M1F	MOTOR (FAN)
Q1M	THERMAL PROTECTOR (M1F EMBEDDED 135˚C)
R1T	THERMISTOR (SUCTION AIR)
R2T	THERMISTOR (COIL, LIQUID)
R3T	THERMISTOR (COIL, GAS)
R4T	THERMISTOR (DISCHARGE AIR)
T1R	TRANSFORMAR (220-240V/22V)
X1M	TERMINAL BLOCK (POWER)
X2M	TERMINAL BLOCK (CONTROL)
X3M	TERMINAL BLOCK
X51A, X52A	CONNECTOR
Y1E	ELECTRIC EXPANSION VALVE
Y1S	SOLENOID VALVE (HOT GAS)
	OPTIONAL PARTS
M1P	MOTOR (DRAIN PUMP)
S1L	FLOAT SWITCH (DRAIN PUMP)
	WIRED REMOTE CONTROLLER
SS1	SELECT SWITCH (MAIN/SUB)
	CONNECTOR FOR OPTIONAL PARTS
X18A	CONNECTOR (WIRING ADAPTOR FOR ELECTRICAL APPENDICES)

6. Capacity Tables

FXMQ125MFV1

Cooling

Outdoor temperature	°C WB							
°C DB	15.0	17.0	20.0	23.0	26.0	28.0	30.0	32.0
	Capacity							
	kW	kW	kW	kW	kW	kW	kW	kW
20.0	3.6	3.8	-	-	-	-	-	-
22.0	3.6	3.8	5.1	-	-	-	-	-
25.0	3.6	3.8	5.1	6.8	-	-	-	-
27.0	-	3.8	5.1	6.7	-	-	-	-
29.0	-	-	5.1	6.7	11.0	-	-	-
31.0	-	-	5.0	6.6	10.9	14.1	-	-
33.0	-	-	5.0	6.5	10.8	[14.0]	16.4	-
35.0	-	-	-	6.4	10.7	13.9	16.3	17.4

Heating

Outdoor temperature	°C WB								
°C DB	-7.0	-5.2	-2.9	0.0	2.0	4.0	6.0	10.0	14.0
	Capacity								
	kW	kW	kW	kW	kW	kW	kW	kW	kW
-5.0	9.7	9.7	-	-	-	-	-	-	-
0.0	-	-	[8.9]	-	-	-	-	-	-
3.0	-	-	7.9	7.9	7.9	-	-	-	-
7.0	-	-	-	-	6.4	6.4	6.4	-	-
11.0	-	-	-	-		5.0	5.0	5.0	-
15.0	-	-	-	-		-	3.6	3.6	3.6

Notes

1. The above capacities are based on the following conditions:
   Air discharge temperature setting: 18°C for cooling operation,
   25°C for heating (Factory setting).
   Equivalent piping length: 7.5m
   Level difference: 0m
2. The above capacities values are general average values which can be generated by each compressor operation level.
3. A value enclosed in [ ] means rated capacity.

13

4D046308

FXMQ200MFV1

Cooling

Outdoor temperature	°C WB							
°C DB	15.0	17.0	20.0	23.0	26.0	28.0	30.0	32.0
	Capacity							
	kW	kW	kW	kW	kW	kW	kW	kW
20.0	5.7	6.1	-	-	-	-	-	-
22.0	5.7	6.1	8.2	-	-	-	-	-
25.0	5.7	6.1	8.2	10.8	-	-	-	-
27.0	-	6.1	8.1	10.7	-	-	-	-
29.0	-	-	8.1	10.6	17.6	-	-	-
31.0	-	-	8.0	10.5	17.4	22.6	-	-
33.0	-	-	8.0	10.3	17.3	**22.4**	26.2	-
35.0	-	-	-	10.2	17.1	22.2	26.1	27.8

Heating

Outdoor temperature	°C WB								
°C DB	-7.0	-5.2	-2.9	0.0	2.0	4.0	6.0	10.0	14.0
	Capacity								
	kW	kW	kW	kW	kW	kW	kW	kW	kW
-5.0	15.0	15.0	-	-	-	-	-	-	-
0.0	-	-	**13.9**	-	-	-	-	-	-
3.0	-	-	12.2	12.2	12.2	-	-	-	-
7.0	-	-	-	-	10.0	10.0	10.0	-	-
11.0	-	-	-	-		7.8	7.8	7.8	-
15.0	-	-	-	-		-	5.6	5.6	5.6

Notes

1. The above capacities are based on the following conditions:
   Air discharge temperature setting: 18°C for cooling operation,
   25°C for heating (Factory setting).
   Equivalent piping length: 7.5m
   Level difference: 0m
2. The above capacities values are general average values which can be generated by each compressor operation level.
3. A value enclosed in **[ ]** means rated capacity.

4D046309

FXMQ250MFV1

Cooling

Outdoor temperature	°C WB							
°C DB	15.0	17.0	20.0	23.0	26.0	28.0	30.0	32.0
	Capacity							
	kW	kW	kW	kW	kW	kW	kW	kW
20.0	7.1	7.6	-	-	-	-	-	-
22.0	7.1	7.6	10.2	-	-	-	-	-
25.0	7.1	7.6	10.2	13.5	-	-	-	-
27.0	-	7.6	10.1	13.4	-	-	-	-
29.0	-	-	10.1	13.3	22.0	-	-	-
31.0	-	-	10.0	13.1	21.8	28.2	-	-
33.0	-	-	10.0	12.9	21.6	28.0	32.8	-
35.0	-	-	-	12.8	21.4	27.8	32.6	34.8

Heating

Outdoor temperature	°C WB								
°C DB	-7.0	-5.2	-2.9	0.0	2.0	4.0	6.0	10.0	14.0
	Capacity								
	kW	kW	kW	kW	kW	kW	kW	kW	kW
-5.0	18.8	18.8	-	-	-	-	-	-	-
0.0	-	-	17.4	-	-	-	-	-	-
3.0	-	-	15.3	15.3	15.3	-	-	-	-
7.0	-	-	-	-	12.5	12.5	12.5	-	-
11.0	-	-	-	-		9.8	9.8	9.8	-
15.0	-	-	-	-		-	7.0	7.0	7.0


Notes
1. The above capacities are based on the following conditions:
   Air discharge temperature setting: 18°C for cooling operation,
   25°C for heating (Factory setting).
   Equivalent piping length: 7.5m
   Level difference: 0m
2. The above capacities values are general average values which can be generated by each compressor operation level.
3. A value enclosed in [ ] means rated capacity.

13

4D046310

7. Operation Limit

FXMQ125MFV1



NOTE
1) These figures assume the following operating conditions. (Indoor and outdoor units)
Equivalent pipe length: 7.5m
Level difference: 0m


2) ▭ :The discharge air temperature may not match the temperature setting for too large outdoor-air processing capacity. Thermostat OFF may be carried out.

3) ▨: THe discharge air temperature may not match the temperature setting for too small outdoor-air processing capacity.

4) The system will not operate in fan mode when the outdoor-air temperature is 5˚C or below.

3D046312

FXMQ200MFV1



NOTE
1) These figures assume the following operating conditions. (Indoor and outdoor units)
Equivalent pipe length: 7.5m
Level difference: 0m


2) ▭ :The discharge air temperature may not match the temperature setting for too large outdoor-air processing capacity. Thermostat OFF may be carried out.

3) ▨: THe discharge air temperature may not match the temperature setting for too small outdoor-air processing capacity.

4) The system will not operate in fan mode when the outdoor-air temperature is 5˚C or below.

3D047750

FXMQ250MFV1



NOTE
1) These figures assume the following operating conditions. (Indoor and outdoor units)
Equivalent pipe length: 7.5m
Level difference: 0m

2) ▭ :The discharge air temperature may not match the temperature setting for too large outdoor-air processing capacity.
Thermostat OFF may be carried out.

3) ▨: THe discharge air temperature may not match the temperature setting for too small outdoor-air processing capacity.

4) The system will not operate in fan mode when the outdoor-air temperature is 5˚C or below.

C: 3D046313

13

8. Electric Characteristics

Units					Power supply		IFM		Input(W)	
Model	Type	Hz	Volts	Voltage range	MCA	MFA	KW	FLA	Cooling	Heating
FXMQ125MFV1	V1	50	220-240	MAX. 264 Min. 198	1.9	15	0.380	1.5	359	359
FXMQ200MFV1					3.3	15	0.380	2.6	548	548
FXMQ250MFV1					3.8	15	0.380	3.0	638	638

Symbols:

MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
KW : Fan Motor Rated Output(KW)
FLA : Full Load Amps(A)
IFM : Indoor Fan Motor

Note:

1. Voltage range

   Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.

2. Maximum allowable voltage unbalance between phases is 2%.

3. MCA/MFA

   MCA = 1.25 X FLA

   MFA ≦ 4 X FLA

   (Next lower standard fuse rating. Min. 15A)

4. Select wire size based on the MCA.


5. Instead of fuse, use Circuit Breaker.

4D046146A

9. Sound Levels

Overall

Measuring Location



dBA

Model	50Hz	
	220V	240V
FXMQ125MFV1	42	43
FXMQ200MFV1	47	48
FXMQ250MFV1	47	48

Notes:


1. The operating conditions are assumed to be standard (JIS conditions)
2. These operating values were obtained in a dead room (conversion values).
   Sound level will vary depending on a range of factors such as the construction (acoustic absorption coefficient) of the particular room in which the equipments installed.

Octave Band Level

○——○ 220V


○- - - -○ 240V

FXMQ125MFV1




4D046271

FXMQ200MFV1



4D046272

FXMQ250MFV1




4D046273


13

10. Fan Performances


FXMQ125MFV1



FXMQ200MFV1



FXMQ250MFV1




13

11. Installation

Center of Gravity

FXMQ125MFV1
FXMQ200MFV1
FXMQ250MFV1

Unit (mm)



MODEL	PRODUCT WEIGHT (Mass)	AA	AB	AC	AD	AE
FXMQ125MFV1	86Kg	780	696	600	250	330
FXMQ200MFV1	123Kg	1380	1296	570	250	600
FXMQ250MFV1	123Kg	1380	1296	570	250	600

C: 4D046143B

Service Space

Selecting Installation Site

When it may exceed 30°C and RH80% in the ceiling or fresh air is inducted into the ceiling, an additional insulation (Thickness 10mm or more of glass wool or polyethylene form) is required.

1. Select an installation site where the following conditions are fulfilled and that meets with your customer's approval.

- Where is resistible against weight of the unit.
- In the upper space (including the back of the ceiling) of the unit where there is no possible dripping of water from the refrigerant pipe, drain pipe, water pipe, etc.
- Where optimum air distribution can be ensured.
- Where nothing blocks the air passage.
- Where condensate can be properly drained.
- If supporting structural members are not strong enough to take the unit's weight, the unit could fall out of place and cause serious injury.
- Where the false ceiling is not noticeably on an incline.
- Where there is no risk of combustible gas leakage.
- Where sufficient clearance for maintenance and service can be ensured. **(Refer to Fig. 1)**
- Where the total piping length involving indoor unit and outdoor unit is below the allowable piping length. (See the installation manual included with the outdoor unit for "Refrigerant Piping Work")
- Locations where a maintenance hole can be installed. **(Refer to Fig. 2)**

CAUTION

- Install the indoor and outdoor units, power supply wires and transmission wires at least 1 meter away from televisions or radios in order to prevent image interference or noise. (Depending on the radio waves, a distance of 1 meter may not be sufficient enough to eliminate the noise.)

2. Use suspension bolts for installation. Check whether the ceiling is strong enough to support the weight of the unit or not. If there is a risk, reinforce the ceiling before installing the unit.





Fig. 1

Bolt Pitch

Preparations Before Installation

1. Relative positions of the unit and suspension bolt. (Refer to Fig. 2).




Unit	A	B
FXMQ125MFV1	744	685
FXMQ200·250MFV1	1380	1296

(length: mm)

Fig. 2

2. Install a canvas duct to the air outlet and air inlet so that vibration from the unit isn't transmitted to the duct or ceiling. You should also apply acoustic (insulation material) to the inside of the duct, and vibration insulation rubber to the suspension bolts.
3. Open the installation hole. (Pre-set ceilings)
   - Once the installation hole is opened in the ceiling where the unit is to be installed, pass refrigerant and drain pipe and the power supply, transmission, and remote controller wire to the unit's pipe and wire connection ports.
   - After opening the ceiling hole, it might be necessary to reinforce the ceiling frame to prevent shaking or to maintain the levelness of the ceiling.
     Consult an architect or carpenter for details.
4. Install suspension bolts.
   (Use bolts of 10 mm diameter.)
   - Install the unit where supporting structures are strong enough to bear the unit's weight. Use embedded inserts or anchor bolts with new buildings and hole-in-anchors with old buildings. Adjust the distance to the ceiling beforehand.

〈 Installation example 〉



Note) All the above parts are field supplied.

Fig. 3

Installation

Unit Installation

Installing optional accessories before installing the unit is easier. See the installation manuals included with the optional accessories.

As for the parts to be used for installation work, be sure to use the provided accessories and specified parts designated by our company.

1. Temporarily install the unit.

■ Mount the hanger brackets to suspension bolts. Secure the hanger brackets on the top and the bottom with nuts <1>~<3> (M10, field supplied) and washers (M10, accessory 9)).




Fig. 4

2. Adjust the height of the unit with the nut <2>.
   (Refer to Fig. 4)
3. Make sure the unit is level.

■ Use a level or a vinyl tube filled with water to make sure that the unit is level and that the tilt (downward slope) to the drain socket and air inlet side is within 1°.
(Refer to Fig. 5)




Fig. 5

4. Tighten both upper and lower nuts <1>, <3>.
   (Refer to Fig. 4)
5. Insulate the four hanger brackets with the sealing pad. (accessory 5) Insulate the hanger brackets so that the surface and edges of the hanger brackets cannot be seen. **(Refer to Fig. 6)**




Fig. 6

CAUTION

Setting the unit at an angle opposite to the drain socket or air inlet side might cause leaks.

Refrigerant Piping Work

<For refrigerant piping between outdoor unit and this unit, see the installation manual attached to the outdoor unit. (Refer to Table 1)>

<Execute heat insulation work completely on both sides of the gas pipe and the liquid pipe. Otherwise, a water leakage can result sometimes.>

<When using a heat pump, the temperature of the gas pipe can reach up to approximately 120°C, so use insulation which is sufficiently resistant.>

<Improve the insulation on the refrigerant piping depending on the installation environment. If the insulation is not sufficient, condensate may form on the surface of the insulation.>

<Before refrigerant piping work, check which type of refrigerant is used. Proper operation is not possible if the types of refrigerant are not the same.>

⚠ CAUTION


- **Use a pipe cutter and flare suitable for the type of refrigerant.**
- **Apply ester oil or ether oil around the flare portions before connecting. (Refer to Fig. 7)**
- **To prevent dust, moisture or other foreign matter from infiltrating the tube, either pinch the end or cover it with tape.**
- **Do not allow anything other than the designated refrigerant to get mixed into the refrigerant circuit, such as air, etc. If any refrigerant gas leaks while working on the unit, ventilate the room thoroughly right away.**

- The outdoor unit is charged with refrigerant.
- Be sure to use both a spanner and torque wrench together, as shown in the drawing, when connecting or disconnecting pipes to/from the unit. **(Refer to Fig. 8)**
- Refer to Table 2 for the dimensions of flare nut spaces.
- When connecting the flare nut, apply ether oil or ester oil only to inner side of the flare, rotate three or four times first, then screw in. **(Refer to Fig. 7)**
- Refer to Table 2 for tightening torque.

Table 1

Unit to be connected	Gas pipe diameter	Liquid pipe diameter
FXMQ125MFV1	15.9	ϕ9.5
FXMQ200MFV1	19.1 Use attached pipe.	ϕ9.5
FXMQ250MFV1	22.2 Use attached pipe.	ϕ9.5

Table 2

Pipe size	Tightening torque	Flare dimensions A (mm)	Flare shape
ϕ9.5 (3/8")	32.7 – 39.9N·m (333 – 407 kgf·cm)	12.8 – 13.2	
ϕ15.9 (5/8")	61.8 – 75.4N·m (630 – 770 kgf·cm)	19.3 – 19.7	

Note:

Use the flare nuts attached with the unit.

⚠ CAUTION

Over-tightening may damage the flare and cause a refrigerant leakage.




Fig. 7




Fig. 8

Not recommendable but in case of emergency

You must use a torque wrench but if you are obliged to install the unit without a torque wrench, you may follow the installation method mentioned below.

After the work is finished, make sure to check that there is no gas leak.

When you keep on tightening the flare nut with a spanner,
there is a point where the tightening torque suddenly increases. From that position, further tighten the flare nut the angle shown below:

Table 3

Pipe size	Further tightening angle	Recommended arm length of tool
9.5 (3/8")	60 to 90 degrees	Approx. 200mm
15.9 (5/8")	30 to 60 degrees	Approx. 300mm

- After checking the pipe-connection for gas leakage, be sure to insulate the liquid and gas pipe, referring to Fig.9, 10 and the following points.

FXMQ125MFV1

1. Insulate the liquid and gas pipes using the insulation for fitting (Accessory 2), 3))
   (Tighten both edges with clamping material.)
2. Make sure the insulation for fitting (Accessory 3)) on the gas pipe has its seams facing up.
3. For the gas pipe, wrap the sealing pad (Accessory 4)) around the insulation for fitting (Accessory 3)) (flare nut part).




Fig. 9

FXMQ200 · 250MFV1

1. Insulate the liquid pipe using the insulation for fitting (Accessory 2)).
   (Tighten both edges with clamping material.)
2. Use the attached pipe (Accessory 1)) for connecting the gas pipes and make sure to insulate the gas pipes (using field supplied insulation) all the way to the base where they connect to the unit.
3. The turning torque of the hexagon head bolts (Accessory 7)) to connect the attached pipe (Accessory 1)) to the unit is 21.5 – 28.9 N/m.




Fig. 10

13

⚠ CAUTION

Be sure to insulate any field pipe all the way to the pipe connection inside the unit. Any exposed pipe may cause condensate or burns if touched.

⚠ CAUTION

CAUTION TO BE TAKEN WHEN BRAZING REFRIGERANT PIPING

Do not use flux when brazing refrigerant piping. Therefore, use the phosphor copper brazing filler metal (BCuP-2:JIS Z 3264/B-Cu93P-710/795: ISO 3677) which does not require flux.

(Flux has extremely harmful influence on refrigerant piping systems. For instance, if the chlorine based flux is used, it will cause pipe corrosion or, in particular, if the flux contains fluorine, it will damage the refrigerant oil.)

- Before brazing local refrigerant piping, nitrogen gas shall be blown through the piping to expel air from the piping. If your brazing is done without nitrogen gas blowing, a large amount of oxide film develops inside the piping, and could cause system malfunction.
- When brazing the refrigerant piping, only begin brazing after having carried out nitrogen substitution or while inserting nitrogen into the refrigerant piping. Once this is done, connect the unit with a flared or a flanged connection.
- Nitrogen should be set to 0.02 MPa (0.2 kg/cm^2) with a pressure-reducing valve if brazing while inserting nitrogen into the piping.




Fig. 11

Drain Piping Work

<<Rig the drain pipe as shown below and take measures against condensate. Improperly rigged piping could lead to leaks and eventually wet furniture and belongings.>>
<<Insulate the drain pipes inside the building and the drain sockets.>>

1. Carry out the drain piping.

- The drain pipe should be short with a downward slope lower than 1/100 and should prevent air pockets from forming.
- The diameter of the pipe is the same as that of the connecting pipe (PS1B), and should be kept equal to or greater than that of the connecting pipe.

Note:

- If converging multiple drain pipes, install according to the procedure shown below. (Select an appropriate central drain pipe thickness for the units they will be connected to.)




Fig. 12

2. After piping work is finished, check drainage flow smoothly.

- Open the water supply port, add approximately 1 litter of water slowly into the drain pan and check drainage flow. **(Refer to Fig. 13)**
  Pools of drainage can cause the drain pipes to clog.




Fig. 13

CAUTION

- Do not connect the drain pipe directly to sewage pipes that smell of ammonia. The ammonia in the sewage might enter the unit through the drain pipes and corrode the heat exchanger.

13

Electric Wiring Work

GENERAL INSTRUCTIONS

- All field supplied parts and materials and electric works must conform to local codes.
- Use copper wire only.
- For electric wiring work, refer to also “WIRING DIAGRAM” label attached to the electric parts box lid.
- For remote controller wiring details, refer to the installation manual attached to the remote controller.
- All wiring must be performed by an authorized electrician.
- This system consists of multiple indoor units. Mark each indoor unit as unit A, unit B..., and be sure the terminal board wiring to the outdoor unit is properly matched. If wiring and piping between the outdoor unit and the indoor unit are mismatched, the system may cause a malfunction.
- A circuit breaker capable of shutting down power supply to the entire system must be installed.
- Refer to the installation manual attached to the outdoor unit for the size of power supply wire connected to the outdoor unit, the capacity of the circuit breaker and switch, and wire instructions.
- Be sure to ground the unit.
- Do not connect the ground wire to gas and water pipes, lightning rods, or telephone ground wires.
  - Gas pipes : might cause explosions or fire if gas leaks.
  - Water pipes : no grounding effect if hard vinyl piping is used.
  - Telephone ground wires or lightning rods : might cause abnormally high electric potential in the ground during lightning.

ELECTRICAL CHARACTERISTICS

Units				Power supply		Fan motor	
Model	Hz	Volts	Voltage range	MCA	MFA	KW	FLA
FXMQ125MFV1	50	220 - 240	Max. 264 Min. 198	1.9	15	0.380	1.5
FXMQ200MFV1				3.3	15	0.380	2.6
FXMQ250MFV1				3.8	15	0.380	3.0

MCA: Min. Circuit Amps (A); MFA: Max. Fuse Amps (A)

KW: Fan Motor Rated Output (kW); FLA: Full Load Amps (A)

SPECIFICATIONS FOR FIELD SUPPLIED FUSES AND WIRE

Model	Power supply wiring			Transmission wiring	
	Field fuses	Wire	Size	Wire	Size
FXMQ125MFV1	15A	H05VV-U3G	Size must comply with local codes.	Sheathed wire (2 wire)	0.75 - 1.25 mm²
FXMQ200MFV1					
FXMQ250MFV1					

NOTES

1. Select the particular size of electrical wire for power supply wire in accordance with the standards of the given nation and region.
2. Allowable length of transmission wire between indoor/out-door units and between the indoor unit and the remote con-troller is as follows.
   (1) Outdoor unit – Indoor unit:
   Max. 1000 m (Total wiring length: 2000 m)
   (2) Indoor unit – Remote controller:
   Max. 500 m
   (3) Max. branches No. of branches :16
3. Insulated thickness: 1mm or more
4. Up to 16 branches are possible for unit-to unit cabling. No branch is allowed after first branch. **(Refer to Fig. 15)**




Fig. 15

Wiring Example And How To Set The Remote Controller

HOW TO CONNECT WIRINGS (Remove the electric parts box lid and wire as shown in the figure below.)




Fig. 16

- **Power supply wire, Ground wire (Refer to Fig. 17)**
  Connect the wire to L and N on the power supply terminal block (X1M). Also, connect the ground wire to the ground terminal. Take the power supply wire and the ground wire into the unit through the wiring through hole <1>, and firmly secure them together using the clamp (Accessory 10)).
- **Transmission wire, Remote controller wire (Refer to Fig. 17)**
  Connect the transmission wire to F1 and F2 on the transmission terminal block (X2M). Connect the remote controller wire to P1 and P2 on the transmission terminal block (X2M). Take them into the unit through the wiring through hole <2>, and firmly secure the wires using the clamp (Accessory 10)).




Fig. 17

⚠ CAUTION


- Wire the electric parts box so that the wiring is at least 10 mm above the bottom of the electric parts box.
- Be sure to attach the sealing material or putty (field supplied) to the wiring through holes to prevent the infiltration of water as well as any insects and other small creatures from outside. Other-wise a short-circuit may occur inside the electric parts box.
- When clamping the wires, be sure no pressure is applied to the wire connections by using the included clamping material to make appropriate clamps. Also, when wiring, make sure the lid on the electric parts box fits snugly by arranging the wires neatly and attaching the electric parts box lid firmly. When attaching the electric parts box lid, make sure no wires get caught in the edges. Pass wire through the wiring through holes to prevent damage to them.
- Make sure the remote controller wire, the transmission wire and power supply wire, ground wire do not pass through the same locations outside of the unit, separating them by at least 50mm, otherwise electrical noise (external static) could cause mistaken operation or breakage.

13

PRECAUTIONS

1. Use round crimp-style terminals for connecting wires to the power supply terminal block. If unavailable, observe the following points when wiring.

- Do not connect wires of different gauge to the same power supply terminal. (Looseness in the connection may cause overheating.)
- Use the specified electric wire. Connect the wire securely to the terminal. Lock the wire down without applying excessive force to the terminal.



2. Tightening torque for the terminal screws.

- Use the correct screwdriver for tightening the terminal screws. If the blade of screwdriver is too small, the head of the screw might be damaged, and the screw will not be properly tightened.
- If the terminal screws are tightened too hard, screws might be damaged.

■ Refer to the table below for the tightening torque of the terminal screws.

Terminal	Size	Tightening torque
Transmission terminal block (X2M)	M3.5	0.79 – 0.97 N·m
Power supply terminal block (X1M)	M4	1.18 – 1.44 N·m
Ground terminal	M5	3.02 – 4.08 N·m

3. Do not connect wires of different gauge to the same ground terminal. Looseness in the connection may deteriorate protection.
4. Outside of the unit, keep transmission wire and remote controller wire at least 50 mm away from power supply wire and ground wire. The unit may malfunction if subjected to electrical noise (external static).
5. For remote controller wiring, refer to the “INSTALLATION MANUAL OF REMOTE CONTROLLER” attached to the remote controller.
6. Never connect power supply wire to the transmission terminal block (X2M). A mistake of the sort could damage the entire system.
7. Use only specified wire and tightly connect wires to terminals. Be careful wires do not place external stress on terminals. Keep wiring in neat order and so as not to obstruct other equipment such as the electric parts box lid. Make sure the lid closes tight. Incomplete connections could result in overheating, and in worse case, electric shock or fire.

WIRING EXAMPLE

Fit the power supply wiring of each unit with a switch and fuse as shown in the drawing.

COMPLETE SYSTEM EXAMPLE (3 SYSTEMS)




Fig. 18

1. When using 1 remote controller for 1 indoor unit. (Normal operation)




Fig. 19

2. For group control or control by 2 remote controllers





Fig. 20

[PRECAUTIONS]

1. A single switch can be used to supply power to units on the same system. However, branch switches and branch circuit breakers must be selected carefully.

Name of Each Part



3P086155-6G-3

13

Operation Range

Use the system in the following temperature and humidity ranges for safe and effective operation.

COOLING [°C]

OUTDOOR TEMPERATURE		
TEMPERATURE		HUMIDITY
DB	19 to 43 (Notes)	30% to 90% Long time operation in a humidity over 90% may cause condensation on the unit and dripping.
WB	32 or below	

DB: Dry Bulb Temperature
WB: Wet Bulb Temperature

Notes:

- The FAN OPERATION mode is set automatically for DB temperatures of 19°C and below.
- Do not use the COOLING OPERATION or FAN OPERATION modes when outdoor temperature is 5°C or lower. The unit will stop running to protect itself against cold damage. In such case, set the AUTOMATIC OPERATION or HEATING OPERATION mode.

HEATING [°C]

OUTDOOR TEMPERATURE	
DB	-5 to 15 (Note)


DB: Dry Bulb Temperature

Note:

The FAN OPERATION mode is set automatically for DB temperature of 15°C and above.

If the temperature or the humidity is beyond these conditions, safety devices may work and the air conditioner may not operate.


■ Restrictions in case of mixture connection with standard indoor units



1. Restrictions of the refrigerant piping system


1) The total capacity of standard indoor units + Outdoor-air processing units should be **50-100%** of Outdoor unit capacity. (In case of using only outdoor-air processing units, it is same.)

2) The capacity of outdoor-air processing units should be less than **30%** of the outdoor unit capacity.




2. Restrictions of the control system


1) In case of wiring is mixed with standard indoor units, group control by remote controller is not available, because the setting temperature are different.



2) When using the central remote controller, mixture of indoor units & Outdoor-air Processing units in the same zone is not available, because the setting temperature are different.








3) Don't set the R/C of Outdoor-air processing unit as the master remote controller.



Set one of these remote controllers as the master remote controller.

12. Accessories

Standard Accessories

Name	Attached pipe	Insulation for fitting	Sealing pad	Sealing pad	Others
Quantity	1	1 each	1	4	
Shape	1)  (Only FXMQ200 · 250MFV1)	2) for liquid pipe  Inside diameter ϕ25.4 3) for gas pipe  Inside diameter ϕ31.8 (Only FXMQ125MFV1)	4)  (Only FXMQ125MFV1)	5) 	6) Spring washer (M10) (2 pieces only for FXMQ200 · 250MFV1) 7) Hexagon head bolt (M10×40) (2 pieces only for FXMQ200 · 250MFV1) 8) Screws for flange connection (M5) (16 pieces for FXMQ125MFV1, 28 pieces for FXMQ200 250MFV1) 9) Washers (8 pieces) 10)Clamps (6 pieces) 11)Installation manual 12)Operation manual

3P086156-11Q-2

Optional Accessories (For Unit)

No.	Item / Type		FXMQ125MFV1	FXMQ200MFV1	FXMQ250MFV1
1	Drain pump kit		KDU30L250VE		
2	High efficiency filter	65%	KAFJ372L140	KAFJ372L280	
		90%	KAFJ373L140	KAFJ373L280	
3	Filter chamber ★1		KDJ3705L140	KDJ3705L280	
4	Long life replacement filter		KAFJ371L140	KAFJ371L280	

3D046270

Notes:

★1.Filter chamber has a suction-type flange. (Main unit does not have.)
- · Dimensions and weight of the equipment may vary depending on the options used.
- · Some options may not be usable due to the equipment installation conditions, so please confirm prior to ordering.
- · Some options may not be used in combination.
- · Operating sound may increase somewhat depending on the options used.

Optional Accessories (For Operation Controls)

No.	Item / Type	FXMQ-MF
1	Wired remote controller	BRC1C62
2	Central remote controller	DCS302CA61
3	Unified ON/OFF controller	DCS301BA61
4	Schedule timer	DST301BA61
5	Wiring adaptor for electrical appendices (1)	KRP2A61
6	Wiring adaptor for electrical appendices (2)	KRP4A51
7	Adaptor for wiring	KRP1B61

Part 4
Outdoor Units
Normal Series
(Space Saving Series)

RXYQ-P(A)
Heat Pump (50Hz/60Hz)
Normal Series (Space Saving Series). 471

RXYQ-P(A)
Heat Pump (50Hz/60Hz)
Normal Series
(Space Saving Series)

1. Specifications 472
   1.1 Heat Pump 50Hz/60Hz-Normal Series (Space Saving Series) <RXYQ-P(A)> 472
2. Dimensions 485
   2.1 Independent Unit 485
   2.2 Combination Unit 488
3. Service Space 492
4. Piping Diagrams 493
5. Wiring Diagrams 497
6. Field Wiring 507
7. Electric Characteristics 513
   7.1 50Hz 380-415V (RXYQ-PAY1) 513
   7.2 60Hz 380V (RXYQ-PAYL) 517
   7.3 60Hz 220V (RXYQ-PTL) 519
8. Capacity Tables (Heat Pump) 523
   8.1 Cooling Capacity (RXYQ-P(A)) 523
   8.2 Heating Capacity (RXYQ-P(A)) 548
   8.3 Capacity Correction Factor (RXYQ-P(A)) 598
   8.4 Notes for Heating Capacity Characteristics 605
9. Operation Limits 606
10. Sound Levels 607
   10.1 50Hz 607
   10.2 60Hz 608
11. Accessories 609
   11.1 Standard Accessories 609
   11.2 Optional Accessories 610
   11.3 Digital Pressure Gauge Kit BHGP26A1(E) 611

14

1. Specifications

1.1 Heat Pump 50Hz/60Hz-Normal Series (Space Saving Series) <RXYQ-P(A)>

Model Name		50Hz	Y1(E)	RXYQ5PAY1(E)	RXYQ8PAY1(E)
		60Hz	YL(E)	RXYQ5PAYL(E)	RXYQ8PAYL(E)
			TL(E)	RXYQ5PTL(E)	RXYQ8PTL(E)
★1 Cooling Capacity (19.5°CWB)			kcal / h	12,100	19,400
			Btu / h	48,100	76,800
			kW	14.1	22.5
★2 Cooling Capacity (19.0°CWB)			kW	14.0	22.4
★3 Heating Capacity			kcal / h	13,800	21,500
			Btu / h	54,600	85,300
			kW	16.0	25.0
Casing Color			Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	1680×635×765	1680×930×765
Heat Exchanger				Cross Fin Coil	Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m^3/h	Y1(E)	13.34	16.90
			YL(E)	13.34	16.90
			TL(E)	13.34	16.90
	Number of Revolutions	r.p.m	Y1(E)	6300	7980
			YL(E)	6300	7980
			TL(E)	6300	7980
	Motor Output×Number of Units		kW	2.8×1	4.5×1
	Starting Method			Soft Start	Soft Start
Fan	Type			Propeller Fan	Propeller Fan
	Motor Output		kW	0.35×1	0.75×1
	Air Flow Rate		m^3/min	95	180
	Drive			Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ9.5 (Brazing Connection)	ϕ9.5 (Brazing Connection)
	Gas Pipe		mm	ϕ15.9 (Brazing Connection)	ϕ19.1 (Brazing Connection)
Product Mass (Machine weight)			kg	160	205
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer	Deicer
Capacity Control			%	28~100	20~100
Refrigerant	Refrigerant Name			R-410A	R-410A
	Charge		kg	6.2	7.2
	Control			Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.		50Hz	Y1(E)	4D061005	4D061006
		60Hz	YL(E)	4D061025	4D061026
			TL(E)	4D060845A	4D060846A

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix “E” as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m^3/min×35.3

The Reference Number
C~: Partly corrected drawings.
J~: Original drawing is Japanese
V~: Printing Convenience

Model Name		50Hz	Y1(E)	RXYQ10PAY1(E)	RXYQ12PAY1(E)
		60Hz	YL(E)	RXYQ10PAYL(E)	RXYQ12PAYL(E)
			TL(E)	RXYQ10PTL(E)	RXYQ12PTL(E)
★1 Cooling Capacity (19.5°CWB)			kcal / h	24,300	29,000
			Btu / h	96,200	115,000
			kW	28.2	33.7
★2 Cooling Capacity (19.0°CWB)			kW	28.0	33.5
★3 Heating Capacity			kcal / h	27,100	32,300
			Btu / h	107,000	128,000
			kW	31.5	37.5
Casing Color			Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	1680×930×765	1680×1240×765
Heat Exchanger				Cross Fin Coil	Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m³/h	Y1(E)	13.34+10.53	13.34+10.53
			YL(E)	13.34+12.52	13.34+12.52
			TL(E)	13.34+12.52	13.34+12.52
	Number of Revolutions	r.p.m	Y1(E)	6300, 2900	6300, 2900
			YL(E)	6300, 3450	6300, 3450
			TL(E)	6300, 3450	6300, 3450
	Motor Output×Number of Units		kW	(1.4+4.5)×1	(2.5+4.5)×1
	Starting Method			Soft Start	Soft Start
Fan	Type			Propeller Fan	Propeller Fan
	Motor Output		kW	0.75×1	0.35×2
	Air Flow Rate		m³/min	185	233
	Drive			Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ9.5 (Brazing Connection)	ϕ12.7 (Brazing Connection)
	Gas Pipe		mm	ϕ22.2 (Brazing Connection)	ϕ28.6 (Brazing Connection)
Product Mass (Machine Weight)			kg	249	285
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer	Deicer
Capacity Control			%	14~100	14~100
Refrigerant	Refrigerant Name			R-410A	R-410A
	Charge		kg	7.9	9.5
	Control			Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.		50Hz	Y1(E)	4D061007	4D061008
		60Hz	YL(E)	4D061027	4D061028
			TL(E)	4D060847A	4D060848A

14

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix “E” as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Model Name		50Hz	Y1(E)	RXYQ14PAY1(E)	RXYQ16PAY1(E)
		60Hz	YL(E)	RXYQ14PAYL(E)	RXYQ16PAYL(E)
			TL(E)	RXYQ14PTL(E)	RXYQ16PTL(E)
★1 Cooling Capacity (19.5°CWB)			kcal / h	34,600	39,000
			Btu / h	137,000	155,000
			kW	40.2	45.3
★2 Cooling Capacity (19.0°CWB)			kW	40.0	45.0
★3 Heating Capacity			kcal / h	38,700	43,000
			Btu / h	154,000	171,000
			kW	45.0	50.0
Casing Color			Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	1680×1240×765	1680×1240×765
Heat Exchanger				Cross Fin Coil	Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m³/h	Y1(E)	13.34+10.53+10.53	13.34+10.53+10.53
			YL(E)	12.84+12.52+12.52	12.84+12.52+12.52
			TL(E)	12.84+12.52+12.52	12.84+12.52+12.52
	Number of Revolutions	r.p.m	Y1(E)	6300, 2900, 2900	6300, 2900, 2900
			YL(E)	6060, 3450, 3450	6060, 3450, 3450
			TL(E)	6060, 3450, 3450	6060, 3450, 3450
	Motor Output×Number of Units		kW	(1.6+4.5+4.5)×1	(2.7+4.5+4.5)×1
	Starting Method			Soft Start	Soft Start
Fan	Type			Propeller Fan	Propeller Fan
	Motor Output		kW	0.35×2	0.35×2
	Air Flow Rate		m³/min	233	233
	Drive			Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ12.7 (Brazing Connection)	ϕ12.7 (Brazing Connection)
	Gas Pipe		mm	ϕ28.6 (Brazing Connection)	ϕ28.6 (Brazing Connection)
Product Mass (Machine Weight)			kg	329	329
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer	Deicer
Capacity Control			%	10~100	10~100
Refrigerant	Refrigerant Name			R-410A	R-410A
	Charge		kg	11.3	11.5
	Control			Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.		50Hz	Y1(E)	4D061009	4D061010
		60Hz	YL(E)	4D061029	4D061030
			TL(E)	4D060849A	4D060850A

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix “E” as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Model Name (Combination Unit)				Y1(E)	RXYQ18PAY1(E)	RXYQ20PAY1(E)
Model Name (Independent Unit)					—	RXYQ8PAY1(E)+RXYQ12PAY1(E)
Model Name (Combination Unit)				YL(E)	RXYQ18PAYL(E)	RXYQ20PAYL(E)
Model Name (Independent Unit)					—	RXYQ8PAYL(E)+RXYQ12PAYL(E)
Model Name (Combination Unit)				TL(E)	RXYQ18PTL(E)	RXYQ20PTL(E)
Model Name (Independent Unit)					—	RXYQ8PTL(E)+RXYQ12PTL(E)
★1 Cooling Capacity (19.5°CWB)				kcal / h	42,400	48,300
				Btu / h	168,000	192,000
				kW	49.3	56.2
★2 Cooling Capacity (19.0°CWB)				kW	49.0	55.9
★3 Heating Capacity				kcal / h	48,600	53,800
				Btu / h	193,000	213,000
				kW	56.5	62.5
Casing Color				Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
				With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)				mm	1680×1240×765	(1680×930×765)+(1680×1240×765)
Heat Exchanger					Cross Fin Coil	Cross Fin Coil
Comp.	Type				Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m³/h		Y1(E)	16.90+10.53+10.53	(16.90)+(13.34+10.53)
				YL(E)	12.84+12.52+12.52	(16.90)+(13.34+12.52)
				TL(E)	12.84+12.52+12.52	(16.90)+(13.34+12.52)
	Number of Revolutions	r.p.m		Y1(E)	7980, 2900, 2900	(7980)+(6300, 2900)
				YL(E)	6060, 3450, 3450	(7980)+(6300, 3450)
				TL(E)	6060, 3450, 3450	(7980)+(6300, 3450)
	Motor Output×Number of Units			kW	(4.3+4.5+4.5)×1	(4.5×1)+((2.5+4.5)×1)
	Starting Method				Soft Start	Soft Start
Fan	Type				Propeller Fan	Propeller Fan
	Motor Output			kW	0.75×2	(0.75×1)+(0.35×2)
	Air Flow Rate			m³/min	239	180+233
	Drive				Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe			mm	ϕ15.9 (Brazing Connection)	ϕ15.9 (Brazing Connection)
	Gas Pipe			mm	ϕ28.6 (Brazing Connection)	ϕ28.6 (Brazing Connection)
Product Mass (Machine Weight)				kg	341	205+285
Safety Devices					High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method					Deicer	Deicer
Capacity Control				%	9~100	8~100
Refrigerant	Refrigerant Name				R-410A	R-410A
	Charge			kg	11.7	7.2+9.5
	Control				Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil					Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories					Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.		50Hz		Y1(E)	4D061011	
		60Hz		YL(E)	4D061031	
				TL(E)	4D060851A	

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix "E" as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

14

Model Name (Combination Unit)			**Y1(E)**	**RXYQ22PAY1(E)**	**RXYQ24PAY1(E)**
Model Name (Independent Unit)				**RXYQ10PAY1(E)+RXYQ12PAY1(E)**	**RXYQ8PAY1(E)+RXYQ16PAY1(E)**
Model Name (Combination Unit)			**YL(E)**	**RXYQ22PAYL(E)**	**RXYQ24PAYL(E)**
Model Name (Independent Unit)				**RXYQ10PAYL(E)+RXYQ12PAYL(E)**	**RXYQ8PAYL(E)+RXYQ16PAYL(E)**
Model Name (Combination Unit)			**TL(E)**	**RXYQ22PTL(E)**	**RXYQ24PTL(E)**
Model Name (Independent Unit)				**RXYQ10PTL(E)+RXYQ12PTL(E)**	**RXYQ8PTL(E)+RXYQ16PTL(E)**
★1 Cooling Capacity (19.5°CWB)			kcal / h	53,200	58,300
			Btu / h	211,000	231,000
			kW	61.9	67.8
★2 Cooling Capacity (19.0°CWB)			kW	61.5	67.4
★3 Heating Capacity			kcal / h	59,300	64,500
			Btu / h	235,000	256,000
			kW	69.0	75.0
Casing Color			Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	(1680×930×765)+(1680×1240×765)	(1680×930×765)+(1680×1240×765)
Heat Exchanger				Cross Fin Coil	Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m³/h	Y1(E)	(13.34+10.53)+(13.34+10.53)	(16.90)+(13.34+10.53+10.53)
			YL(E)	(13.34+12.52)+(13.34+12.52)	(16.90)+(12.84+12.52+12.52)
			TL(E)	(13.34+12.52)+(13.34+12.52)	(16.90)+(12.84+12.52+12.52)
	Number of Revolutions	r.p.m	Y1(E)	(6300, 2900)+(6300, 2900)	(7980)+(6300, 2900, 2900)
			YL(E)	(6300, 3450)+(6300, 3450)	(7980)+(6060, 3450, 3450)
			TL(E)	(6300, 3450)+(6300, 3450)	(7980)+(6060, 3450, 3450)
	Motor Output×Number of Units		kW	((1.4+4.5)×1)+((2.5+4.5)×1)	(4.5×1)+((2.7+4.5+4.5)×1)
	Starting Method			Soft Start	Soft Start
Fan	Type			Propeller Fan	Propeller Fan
	Motor Output		kW	(0.75×1)+(0.35×2)	(0.75×1)+(0.35×2)
	Air Flow Rate		m³/min	185+233	180+233
	Drive			Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ15.9 (Brazing Connection)	ϕ15.9 (Brazing Connection)
	Gas Pipe		mm	ϕ28.6 (Brazing Connection)	ϕ34.9 (Brazing Connection)
Product Mass (Machine Weight)			kg	249+285	205+329
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer	Deicer
Capacity Control			%	7~100	6~100
Refrigerant	Refrigerant Name			R-410A	R-410A
	Charge		kg	7.9+9.5	7.2+11.5
	Control			Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.					

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix "E" as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Model Name (Combination Unit)				Y1(E)	RXYQ26PAY1(E)	RXYQ28PAY1(E)
Model Name (Independent Unit)					RXYQ8PAY1(E)+RXYQ18PAY1(E)	RXYQ10PAY1(E)+RXYQ18PAY1(E)
Model Name (Combination Unit)				YL(E)	RXYQ26PAYL(E)	RXYQ28PAYL(E)
Model Name (Independent Unit)					RXYQ8PAYL(E)+RXYQ18PAYL(E)	RXYQ10PAYL(E)+RXYQ18PAYL(E)
Model Name (Combination Unit)				TL(E)	RXYQ26PTL(E)	RXYQ28PTL(E)
Model Name (Independent Unit)					RXYQ8PTL(E)+RXYQ18PTL(E)	RXYQ10PTL(E)+RXYQ18PTL(E)
★1 Cooling Capacity (19.5°CWB)				kcal / h	61,700	66,700
				Btu / h	250,000	264,000
				kW	71.8	77.5
★2 Cooling Capacity (19.0°CWB)				kW	71.4	77.0
★3 Heating Capacity				kcal / h	70,100	75,700
				Btu / h	278,000	300,000
				kW	81.5	88.0
Casing Color				Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
				With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)				mm	(1680×930×765)+(1680×1240×765)	(1680×930×765)+(1680×1240×765)
Heat Exchanger					Cross Fin Coil	Cross Fin Coil
Comp.	Type				Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m^3/h		Y1(E)	(16.90)+(16.90+10.53+10.53)	(13.34+10.53)+(16.90+10.53+10.53)
				YL(E)	(16.90)+(12.84+12.52+12.52)	(13.34+12.52)+(12.84+12.52+12.52)
				TL(E)	(16.90)+(12.84+12.52+12.52)	(13.34+12.52)+(12.84+12.52+12.52)
	Number of Revolutions	r.p.m		Y1(E)	(7980)+(7980, 2900, 2900)	(6300, 2900)+(7980, 2900, 2900)
				YL(E)	(7980)+(6060, 3450, 3450)	(6300, 3450)+(6060, 3450, 3450)
				TL(E)	(7980)+(6060, 3450, 3450)	(6300, 3450)+(6060, 3450, 3450)
	Motor Output×Number of Units			kW	(4.5×1)+((4.3+4.5+4.5)×1)	((1.4+4.5)×1)+((4.3+4.5+4.5)×1)
	Starting Method				Soft Start	Soft Start
Fan	Type				Propeller Fan	Propeller Fan
	Motor Output			kW	(0.75×1)+(0.75×2)	(0.75×1)+(0.75×2)
	Air Flow Rate			m^3/min	180+239	185+239
	Drive				Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe			mm	ϕ19.1 (Brazing Connection)	ϕ19.1 (Brazing Connection)
	Gas Pipe			mm	ϕ34.9 (Brazing Connection)	ϕ34.9 (Brazing Connection)
Product Mass (Machine Weight)				kg	205+341	249+341
Safety Devices					High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method					Deicer	Deicer
Capacity Control				%	6~100	5~100
Refrigerant	Refrigerant Name				R-410A	R-410A
	Charge			kg	7.2+11.7	7.9+11.7
	Control				Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil					Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories					Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.						

14

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix "E" as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m^3/min×35.3

Model Name (Combination Unit)			**Y1(E)**	**RXYQ30PAY1(E)**	**RXYQ32PAY1(E)**
Model Name (Independent Unit)				**RXYQ12PAY1(E)+RXYQ18PAY1(E)**	**RXYQ16PAY1(E)+RXYQ16PAY1(E)**
Model Name (Combination Unit)			**YL(E)**	**RXYQ30PAYL(E)**	**RXYQ32PAYL(E)**
Model Name (Independent Unit)				**RXYQ12PAYL(E)+RXYQ18PAYL(E)**	**RXYQ16PAYL(E)+RXYQ16PAYL(E)**
Model Name (Combination Unit)			**TL(E)**	**RXYQ30PTL(E)**	**RXYQ32PTL(E)**
Model Name (Independent Unit)				**RXYQ12PTL(E)+RXYQ18PTL(E)**	**RXYQ16PTL(E)+RXYQ16PTL(E)**
★1 Cooling Capacity (19.5°CWB)			kcal / h	71,400	77,800
			Btu / h	283,000	309,000
			kW	83.0	90.5
★2 Cooling Capacity (19.0°CWB)			kW	82.5	90.0
★3 Heating Capacity			kcal / h	80,800	86,000
			Btu / h	321,000	341,000
			kW	94.0	100
Casing Color			Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	(1680×1240×765)+(1680×1240×765)	(1680×1240×765)+(1680×1240×765)
Heat Exchanger				Cross Fin Coil	Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m³/h	Y1(E)	(13.34+10.53)+(16.90+10.53+10.53)	(13.34+10.53+10.53)+(13.34+10.53+10.53)
			YL(E)	(13.34+12.52)+(12.84+12.52+12.52)	(12.84+12.52+12.52)+(12.84+12.52+12.52)
			TL(E)	(13.34+12.52)+(12.84+12.52+12.52)	(12.84+12.52+12.52)+(12.84+12.52+12.52)
	Number of Revolutions	r.p.m	Y1(E)	(6300, 2900)+(7980, 2900, 2900)	(6300, 2900, 2900)+(6300, 2900, 2900)
			YL(E)	(6300, 3450)+(6060, 3450, 3450)	(6060, 3450, 3450)+(6060, 3450, 3450)
			TL(E)	(6300, 3450)+(6060, 3450, 3450)	(6060, 3450, 3450)+(6060, 3450, 3450)
	Motor Output×Number of Units		kW	((2.5+4.5)×1)+((4.3+4.5+4.5)×1)	((2.7+4.5+4.5)×1)+((2.7+4.5+4.5)×1)
	Starting Method			Soft Start	Soft Start
Fan	Type			Propeller Fan	Propeller Fan
	Motor Output		kW	(0.35×2)+(0.75×2)	(0.35×2)+(0.35×2)
	Air Flow Rate		m³/min	233+239	233+233
	Drive			Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ19.1 (Brazing Connection)	ϕ19.1 (Brazing Connection)
	Gas Pipe		mm	ϕ34.9 (Brazing Connection)	ϕ34.9 (Brazing Connection)
Product Mass (Machine Weight)			kg	285+341	329+329
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer	Deicer
Capacity Control			%	5~100	5~100
Refrigerant	Refrigerant Name			R-410A	R-410A
	Charge		kg	9.5+11.7	11.5+11.5
	Control			Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.					

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix “E” as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Model Name (Combination Unit)			Y1(E)	RXYQ34PAY1(E)	RXYQ36PAY1(E)
Model Name (Independent Unit)				RXYQ16PAY1(E)+RXYQ18PAY1(E)	RXYQ18PAY1(E)+RXYQ18PAY1(E)
Model Name (Combination Unit)			YL(E)	RXYQ34PAYL(E)	RXYQ36PAYL(E)
Model Name (Independent Unit)				RXYQ16PAYL(E)+RXYQ18PAYL(E)	RXYQ18PAYL(E)+RXYQ18PAYL(E)
Model Name (Combination Unit)			TL(E)	RXYQ34PTL(E)	RXYQ36PTL(E)
Model Name (Independent Unit)				RXYQ16PTL(E)+RXYQ18PTL(E)	RXYQ18PTL(E)+RXYQ18PTL(E)
★1 Cooling Capacity (19.5°CWB)			kcal / h	81,400	85,100
			Btu / h	323,000	338,000
			kW	94.6	99.0
★2 Cooling Capacity (19.0°CWB)			kW	94.0	98.0
★3 Heating Capacity			kcal / h	92,000	97,200
			Btu / h	365,000	386,000
			kW	107	113
Casing Color			Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	(1680×1240×765)+(1680×1240×765)	(1680×1240×765)+(1680×1240×765)
Heat Exchanger				Cross Fin Coil	Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m³/h	Y1(E)	(13.34+10.53+10.53)+(16.90+10.53+10.53)	(16.90+10.53+10.53)+(16.90+10.53+10.53)
			YL(E)	(12.84+12.52+12.52)+(12.84+12.52+12.52)	(12.84+12.52+12.52)+(12.84+12.52+12.52)
			TL(E)	(12.84+12.52+12.52)+(12.84+12.52+12.52)	(12.84+12.52+12.52)+(12.84+12.52+12.52)
	Number of Revolutions	r.p.m	Y1(E)	(6300, 2900, 2900)+(7980, 2900, 2900)	(7980, 2900, 2900)+(7980, 2900, 2900)
			YL(E)	(6060, 3450, 3450)+(6060, 3450, 3450)	(6060, 3450, 3450)+(6060, 3450, 3450)
			TL(E)	(6060, 3450, 3450)+(6060, 3450, 3450)	(6060, 3450, 3450)+(6060, 3450, 3450)
	Motor Output×Number of Units		kW	((2.7+4.5+4.5)×1)+((4.3+4.5+4.5)×1)	((4.3+4.5+4.5)×1)+((4.3+4.5+4.5)×1)
	Starting Method			Soft Start	Soft Start
Fan	Type			Propeller Fan	Propeller Fan
	Motor Output		kW	(0.35×2)+(0.75×2)	(0.75×2)+(0.75×2)
	Air Flow Rate		m³/min	233+239	239+239
	Drive			Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ19.1 (Brazing Connection)	ϕ19.1 (Brazing Connection)
	Gas Pipe		mm	ϕ34.9 (Brazing Connection)	ϕ41.3 (Brazing Connection)
Product Mass (Machine Weight)			kg	329+341	341+341
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer	Deicer
Capacity Control			%	5~100	4~100
Refrigerant	Refrigerant Name			R-410A	R-410A
	Charge		kg	11.5+11.7	11.7+11.7
	Control			Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.					

14

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix "E" as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Model Name (Combination Unit)			**Y1(E)**	**RXYQ38PAY1(E)**	**RXYQ40PAY1(E)**
Model Name (Independent Unit)				**RXYQ8PAY1(E)+RXYQ12PAY1(E)+RXYQ18PAY1(E)**	**RXYQ8PAY1(E)+RXYQ16PAY1(E)+RXYQ16PAY1(E)**
Model Name (Combination Unit)			**YL(E)**	**RXYQ38PAYL(E)**	**RXYQ40PAYL(E)**
Model Name (Independent Unit)				**RXYQ8PAYL(E)+RXYQ12PAYL(E)+RXYQ18PAYL(E)**	**RXYQ8PAYL(E)+RXYQ16PAYL(E)+RXYQ16PAYL(E)**
Model Name (Combination Unit)			**TL(E)**	**RXYQ38PTL(E)**	**RXYQ40PTL(E)**
Model Name (Independent Unit)				**RXYQ8PTL(E)+RXYQ12PTL(E)+RXYQ18PTL(E)**	**RXYQ8PTL(E)+RXYQ16PTL(E)+RXYQ16PTL(E)**
★1 Cooling Capacity (19.5°CWB)			kcal / h	91,200	97,200
			Btu / h	362,000	386,000
			kW	106	113
★2 Cooling Capacity (19.0°CWB)			kW	105	112
★3 Heating Capacity			kcal / h	102,000	108,000
			Btu / h	406,000	427,000
			kW	119	125
Casing Color			Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	(1680×930×765)+(1680×1240×765)+(1680×1240×765)	(1680×930×765)+(1680×1240×765)+(1680×1240×765)
Heat Exchanger				Cross Fin Coil	Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m³/h	Y1(E)	(16.90)+(13.34+10.53)+(16.90+10.53+10.53)	(16.90)+(13.34+10.53+10.53)+(13.34+10.53+10.53)
			YL(E)	(16.90)+(13.34+12.52)+(12.84+12.52+12.52)	(16.90)+(12.84+12.52+12.52)+(12.84+12.52+12.52)
			TL(E)	(16.90)+(13.34+12.52)+(12.84+12.52+12.52)	(16.90)+(12.84+12.52+12.52)+(12.84+12.52+12.52)
	Number of Revolutions	r.p.m	Y1(E)	(7980)+(6300, 2900)+(7980, 2900, 2900)	(7980)+(6300, 2900, 2900)+(6300, 2900, 2900)
			YL(E)	(7980)+(6300, 3450)+(6060, 3450, 3450)	(7980)+(6060, 3450, 3450)+(6060, 3450, 3450)
			TL(E)	(7980)+(6300, 3450)+(6060, 3450, 3450)	(7980)+(6060, 3450, 3450)+(6060, 3450, 3450)
	Motor Output×Number of Units		kW	(4.5×1)+((2.5+4.5)×1)+((4.3+4.5+4.5)×1)	(4.5×1)+((2.7+4.5+4.5)×1)+((2.7+4.5+4.5)×1)
	Starting Method			Soft Start	Soft Start
Fan	Type			Propeller Fan	Propeller Fan
	Motor Output		kW	(0.75×1)+(0.35×2)+(0.75×2)	(0.75×1)+(0.35×2)+(0.35×2)
	Air Flow Rate		m³/min	180+233+239	180+233+233
	Drive			Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ19.1 (Brazing Connection)	ϕ19.1 (Brazing Connection)
	Gas Pipe		mm	ϕ41.3 (Brazing Connection)	ϕ41.3 (Brazing Connection)
Product Mass (Machine Weight)			kg	205+285+341	205+329+329
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer	Deicer
Capacity Control			%	4~100	4~100
Refrigerant	Refrigerant Name			R-410A	R-410A
	Charge		kg	7.2+9.5+11.7	7.2+11.5+11.5
	Control			Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.					

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix "E" as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Model Name (Combination Unit)			Y1(E)	RXYQ42PAY1(E)	RXYQ44PAY1(E)
Model Name (Independent Unit)				RXYQ8PAY1(E)+RXYQ16PAY1(E)+RXYQ18PAY1(E)	RXYQ8PAY1(E)+RXYQ18PAY1(E)+RXYQ18PAY1(E)
Model Name (Combination Unit)			YL(E)	RXYQ42PAYL(E)	RXYQ44PAYL(E)
Model Name (Independent Unit)				RXYQ8PAYL(E)+RXYQ16PAYL(E)+RXYQ18PAYL(E)	RXYQ8PAYL(E)+RXYQ18PAYL(E)+RXYQ18PAYL(E)
Model Name (Combination Unit)			TL(E)	RXYQ42PTL(E)	RXYQ44PTL(E)
Model Name (Independent Unit)				RXYQ8PTL(E)+RXYQ16PTL(E)+RXYQ18PTL(E)	RXYQ8PTL(E)+RXYQ18PTL(E)+RXYQ18PTL(E)
★1 Cooling Capacity (19.5°CWB)			kcal / h	101,000	104,000
			Btu / h	399,000	413,000
			kW	117	121
★2 Cooling Capacity (19.0°CWB)			kW	116	120
★3 Heating Capacity			kcal / h	114,000	119,000
			Btu / h	450,000	471,000
			kW	132	138
Casing Color			Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	(1680×930×765)+(1680×1240×765)+(1680×1240×765)	(1680×930×765)+(1680×1240×765)+(1680×1240×765)
Heat Exchanger				Cross Fin Coil	Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m³/h	Y1(E)	(16.90)+(13.34+10.53+10.53)+(16.90+10.53+10.53)	(16.90)+(16.90+10.53+10.53)+(16.90+10.53+10.53)
			YL(E)	(16.90)+(12.84+12.52+12.52)+(12.84+12.52+12.52)	(16.90)+(12.84+12.52+12.52)+(12.84+12.52+12.52)
			TL(E)	(16.90)+(12.84+12.52+12.52)+(12.84+12.52+12.52)	(16.90)+(12.84+12.52+12.52)+(12.84+12.52+12.52)
	Number of Revolutions	r.p.m	Y1(E)	(7980)+(6300, 2900, 2900)+(7980, 2900, 2900)	(7980)+(7980, 2900, 2900)+(7980, 2900, 2900)
			YL(E)	(7980)+(6060, 3450, 3450)+(6060, 3450, 3450)	(7980)+(6060, 3450, 3450)+(6060, 3450, 3450)
			TL(E)	(7980)+(6060, 3450, 3450)+(6060, 3450, 3450)	(7980)+(6060, 3450, 3450)+(6060, 3450, 3450)
	Motor Output×Number of Units		kW	(4.5×1)+((2.7+4.5+4.5)×1)+((4.3+4.5+4.5)×1)	(4.5×1)+((4.3+4.5+4.5)×1)+((4.3+4.5+4.5)×1)
	Starting Method			Soft Start	Soft Start
Fan	Type			Propeller Fan	Propeller Fan
	Motor Output		kW	(0.75×1)+(0.35×2)+(0.75×2)	(0.75×1)+(0.75×2)+(0.75×2)
	Air Flow Rate		m³/min	180+233+239	180+239+239
	Drive			Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ19.1 (Brazing Connection)	ϕ19.1 (Brazing Connection)
	Gas Pipe		mm	ϕ41.3 (Brazing Connection)	ϕ41.3 (Brazing Connection)
Product Mass (Machine Weight)			kg	205+329+341	205+341+341
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer	Deicer
Capacity Control			%	4~100	4~100
Refrigerant	Refrigerant Name			R-410A	R-410A
	Charge		kg	7.2+11.5+11.7	7.2+11.7+11.7
	Control			Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.					

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix "E" as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

14

Model Name (Combination Unit)			**Y1(E)**	**RXYQ46PAY1(E)**	**RXYQ48PAY1(E)**
Model Name (Independent Unit)				**RXYQ10PAY1(E)+RXYQ18PAY1(E)+RXYQ18PAY1(E)**	**RXYQ12PAY1(E)+RXYQ18PAY1(E)+RXYQ18PAY1(E)**
Model Name (Combination Unit)			**YL(E)**	**RXYQ46PAYL(E)**	**RXYQ48PAYL(E)**
Model Name (Independent Unit)				**RXYQ10PAYL(E)+RXYQ18PAYL(E)+RXYQ18PAYL(E)**	**RXYQ12PAYL(E)+RXYQ18PAYL(E)+RXYQ18PAYL(E)**
Model Name (Combination Unit)			**TL(E)**	**RXYQ46PTL(E)**	**RXYQ48PTL(E)**
Model Name (Independent Unit)				**RXYQ10PTL(E)+RXYQ18PTL(E)+RXYQ18PTL(E)**	**RXYQ12PTL(E)+RXYQ18PTL(E)+RXYQ18PTL(E)**
★1 Cooling Capacity (19.5°CWB)			kcal / h	109,000	114,000
			Btu / h	433,000	454,000
			kW	127	133
★2 Cooling Capacity (19.0°CWB)			kW	126	132
★3 Heating Capacity			kcal / h	125,000	130,000
			Btu / h	495,000	515,000
			kW	145	151
Casing Color			Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	(1680×930×765)+(1680×1240×765)+(1680×1240×765)	(1680×1240×765)+(1680×1240×765)+(1680×1240×765)
Heat Exchanger				Cross Fin Coil	Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m³/h	Y1(E)	(13.34+10.53)+(16.90+10.53+10.53)+(16.90+10.53+10.53)	(13.34+10.53)+(16.90+10.53+10.53)+(16.90+10.53+10.53)
			YL(E)	(13.34+12.52)+(12.84+12.52+12.52)+(12.84+12.52+12.52)	(13.34+12.52)+(12.84+12.52+12.52)+(12.84+12.52+12.52)
			TL(E)	(13.34+12.52)+(12.84+12.52+12.52)+(12.84+12.52+12.52)	(13.34+12.52)+(12.84+12.52+12.52)+(12.84+12.52+12.52)
	Number of Revolutions	r.p.m	Y1(E)	(6300, 2900)+(7980, 2900, 2900)+(7980, 2900, 2900)	(6300, 2900)+(7980, 2900, 2900)+(7980, 2900, 2900)
			YL(E)	(6300, 3450)+(6060, 3450, 3450)+(6060, 3450, 3450)	(6300, 3450)+(6060, 3450, 3450)+(6060, 3450, 3450)
			TL(E)	(6300, 3450)+(6060, 3450, 3450)+(6060, 3450, 3450)	(6300, 3450)+(6060, 3450, 3450)+(6060, 3450, 3450)
	Motor Output×Number of Units		kW	((1.4+4.5)×1)+((4.3+4.5+4.5)×1)+((4.3+4.5+4.5)×1)	((2.5+4.5)×1)+((4.3+4.5+4.5)×1)+((4.3+4.5+4.5)×1)
	Starting Method			Soft Start	Soft Start
Fan	Type			Propeller Fan	Propeller Fan
	Motor Output		kW	(0.75×1)+(0.75×2)+(0.75×2)	(0.35×2)+(0.75×2)+(0.75×2)
	Air Flow Rate		m³/min	185+239+239	233+239+239
	Drive			Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ19.1 (Brazing Connection)	ϕ19.1 (Brazing Connection)
	Gas Pipe		mm	ϕ41.3 (Brazing Connection)	ϕ41.3 (Brazing Connection)
Product Mass (Machine Weight)			kg	249+341+341	285+341+341
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer	Deicer
Capacity Control			%	3~100	3~100
Refrigerant	Refrigerant Name			R-410A	R-410A
	Charge		kg	7.9+11.7+11.7	9.5+11.7+11.7
	Control			Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.					

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix "E" as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

Model Name (Combination Unit)			Y1(E)	RXYQ50PAY1(E)	RXYQ52PAY1(E)
Model Name (Independent Unit)				RXYQ14PAY1(E)+RXYQ18PAY1(E)+RXYQ18PAY1(E)	RXYQ16PAY1(E)+RXYQ18PAY1(E)+RXYQ18PAY1(E)
Model Name (Combination Unit)			YL(E)	RXYQ50PAYL(E)	RXYQ52PAYL(E)
Model Name (Independent Unit)				RXYQ14PAYL(E)+RXYQ18PAYL(E)+RXYQ18PAYL(E)	RXYQ16PAYL(E)+RXYQ18PAYL(E)+RXYQ18PAYL(E)
Model Name (Combination Unit)			TL(E)	RXYQ50PTL(E)	RXYQ52PTL(E)
Model Name (Independent Unit)				RXYQ14PTL(E)+RXYQ18PTL(E)+RXYQ18PTL(E)	RXYQ16PTL(E)+RXYQ18PTL(E)+RXYQ18PTL(E)
★1 Cooling Capacity (19.5°CWB)			kcal / h	120,000	124,000
			Btu / h	474,000	491,000
			kW	139	144
★2 Cooling Capacity (19.0°CWB)			kW	138	143
★3 Heating Capacity			kcal / h	136,000	140,000
			Btu / h	539,000	556,000
			kW	158	163
Casing Color			Without(E)	Ivory White (5Y7.5/1)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	(1680×1240×765)+(1680×1240×765)+(1680×1240×765)	(1680×1240×765)+(1680×1240×765)+(1680×1240×765)
Heat Exchanger				Cross Fin Coil	Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type	Hermetically Sealed Scroll Type
	Piston Displacement	m³/h	Y1(E)	(13.34+10.53+10.53)+(16.90+10.53+10.53)+(16.90+10.53+10.53)	(13.34+10.53+10.53)+(16.90+10.53+10.53)+(16.90+10.53+10.53)
			YL(E)	(12.84+12.52+12.52)+(12.84+12.52+12.52)+(12.84+12.52+12.52)	(12.84+12.52+12.52)+(12.84+12.52+12.52)+(12.84+12.52+12.52)
			TL(E)	(12.84+12.52+12.52)+(12.84+12.52+12.52)+(12.84+12.52+12.52)	(12.84+12.52+12.52)+(12.84+12.52+12.52)+(12.84+12.52+12.52)
	Number of Revolutions	r.p.m	Y1(E)	(6300, 2900, 2900)+(7980, 2900, 2900)+(7980, 2900, 2900)	(6300, 2900, 2900)+(7980, 2900, 2900)+(7980, 2900, 2900)
			YL(E)	(6060, 3450, 3450)+(6060, 3450, 3450)+(6060, 3450, 3450)	(6060, 3450, 3450)+(6060, 3450, 3450)+(6060, 3450, 3450)
			TL(E)	(6060, 3450, 3450)+(6060, 3450, 3450)+(6060, 3450, 3450)	(6060, 3450, 3450)+(6060, 3450, 3450)+(6060, 3450, 3450)
	Motor Output×Number of Units		kW	((1.6+4.5+4.5)×1)+((4.3+4.5+4.5)×1)+((4.3+4.5+4.5)×1)	((2.7+4.5+4.5)×1)+((4.3+4.5+4.5)×1)+((4.3+4.5+4.5)×1)
	Starting Method			Soft Start	Soft Start
Fan	Type			Propeller Fan	Propeller Fan
	Motor Output		kW	(0.35×2)+(0.75×2)+(0.75×2)	(0.35×2)+(0.75×2)+(0.75×2)
	Air Flow Rate		m³/min	233+239+239	233+239+239
	Drive			Direct Drive	Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ19.1 (Brazing Connection)	ϕ19.1 (Brazing Connection)
	Gas Pipe		mm	ϕ41.3 (Brazing Connection)	ϕ41.3 (Brazing Connection)
Product Mass (Machine Weight)			kg	329+341+341	329+341+341
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector	High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer	Deicer
Capacity Control			%	3~100	3~100
Refrigerant	Refrigerant Name			R-410A	R-410A
	Charge		kg	11.3+11.7+11.7	11.5+11.7+11.7
	Control			Electronic Expansion Valve	Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor	Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Connection Pipes, Clamps	Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.					

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix “E” as RXYQ5PAY1E.

Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m³/min×35.3

14

Model Name (Combination Unit)			**Y1(E)**	**RXYQ54PAY1(E)**
Model Name (Independent Unit)				**RXYQ18PAY1(E)+RXYQ18PAY1(E)+RXYQ18PAY1(E)**
Model Name (Combination Unit)			**YL(E)**	**RXYQ54PAYL(E)**
Model Name (Independent Unit)				**RXYQ18PAYL(E)+RXYQ18PAYL(E)+RXYQ18PAYL(E)**
Model Name (Combination Unit)			**TL(E)**	**RXYQ54PTL(E)**
Model Name (Independent Unit)				**RXYQ18PTL(E)+RXYQ18PTL(E)+RXYQ18PTL(E)**
★1 Cooling Capacity (19.5°CWB)			kcal / h	127,000
			Btu / h	505,000
			kW	148
★2 Cooling Capacity (19.0°CWB)			kW	147
★3 Heating Capacity			kcal / h	146,000
			Btu / h	580,000
			kW	170
Casing Color			Without(E)	Ivory White (5Y7.5/1)
			With(E)	Light Camel (2.5Y6.5/1.5)
Dimensions: (H×W×D)			mm	(1680×1240×765)+(1680×1240×765)+(1680×1240×765)
Heat Exchanger				Cross Fin Coil
Comp.	Type			Hermetically Sealed Scroll Type
	Piston Displacement	m^3/h	Y1(E)	(16.90+10.53+10.53)+(16.90+10.53+10.53)+(16.90+10.53+10.53)
			YL(E)	(12.84+12.52+12.52)+(12.84+12.52+12.52)+(12.84+12.52+12.52)
			TL(E)	(12.84+12.52+12.52)+(12.84+12.52+12.52)+(12.84+12.52+12.52)
	Number of Revolutions	r.p.m	Y1(E)	(7980, 2900, 2900)+(7980, 2900, 2900)+(7980, 2900, 2900)
			YL(E)	(6060, 3450, 3450)+(6060, 3450, 3450)+(6060, 3450, 3450)
			TL(E)	(6060, 3450, 3450)+(6060, 3450, 3450)+(6060, 3450, 3450)
	Motor Output×Number of Units		kW	((4.3+4.5+4.5)×1)+((4.3+4.5+4.5)×1)+((4.3+4.5+4.5)×1)
	Starting Method			Soft Start
Fan	Type			Propeller Fan
	Motor Output		kW	(0.75×2)+(0.75×2)+(0.75×2)
	Air Flow Rate		m^3/min	239+239+239
	Drive			Direct Drive
Connecting Pipes	Liquid Pipe		mm	ϕ19.1 (Brazing Connection)
	Gas Pipe		mm	ϕ41.3 (Brazing Connection)
Product Mass (Machine Weight)			kg	341+341+341
Safety Devices				High Pressure Switch, Fan Driver Overload Protector, Over Current Relay, Inverter Overload Protector
Defrost Method				Deicer
Capacity Control			%	3~100
Refrigerant	Refrigerant Name			R-410A
	Charge		kg	11.7+11.7+11.7
	Control			Electronic Expansion Valve
Refrigerator Oil				Refer to the nameplate of compressor
Standard Accessories				Installation Manual, Operation Manual, Connection Pipes, Clamps
Drawing No.				

Notes:

★1 Indoor temp. : 27°CDB, 19.5°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★2 Indoor temp. : 27°CDB, 19.0°CWB / outdoor temp. : 35°CDB / Equivalent piping length : 7.5m, level difference : 0m.
★3 Indoor temp. : 20°CDB / outdoor temp. : 7°CDB, 6°CWB / Equivalent piping length : 7.5m, level difference : 0m.
4 The power input (PI) (Comp. + Outdoor Fan Motor) : Refer to P.523~597.
5 The units with anti-corrosion treatment will be available as standard. Please specify the suffix “E” as RXYQ5PAY1E.


Conversion Formulae
kcal/h=kW×860 Btu/h=kW×3412 cfm=m^3/min×35.3

2. Dimensions

2.1 Independent Unit

RXYQ5P(A)

Unit (mm)




No.	Parts name	Remarks
10	Pipe routing hole (bottom)	
9	Pipe routing hole (front)	
8	Wire routing hole (front)	φ27
7	Power cord routing hole (bottom)	φ50
6	Power cord routing hole (front)	φ27
5	Power cord routing hole (front)	φ45
4	Power cord routing hole (side)	φ62
3	Grounding terminal	Inside of switch box (M8)
2	Gas pipe connection port	φ15.9 Brazing connection
1	Liquid pipe connection port	φ9.5 Brazing connection

14


RXYQ8P(A), RXYQ10P(A)

Unit (mm)



No.	Parts name	Remarks
10	Pipe routing hole (bottom)	
9	Pipe routing hole (front)	
8	Wire routing hole (front)	φ27
7	Power cord routing hole (bottom)	φ65.5
6	Power cord routing hole (front)	φ27
5	Power cord routing hole (front)	φ45
4	Power cord routing hole (side)	φ62
3	Grounding terminal	Inside of switch box (M8)
2	Gas pipe connection port	See note 2.
1	Liquid pipe connection port	See note 2.


RXYQ12P(A), RXYQ14P(A), RXYQ16P(A), RXYQ18P(A)



2.2 Combination Unit

RXYQ20P(A), RXYQ22P(A), RXYQ24P(A), RXYQ26P(A), RXYQ28P(A)

Unit (mm)




Notes :
1. Heights of walls
   Front : 1500mm
   Suction side : 500mm
   Side : Height unrestricted
   The installation space shown in this figure is based on the condition of cooling operation at the outdoor air temperature of 35°C.
   The installation space of suction side shown above must be expanded in the following case.
   • Design outdoor temperature becomes over 35°C.
   • Operating load (In case of causing a heavy heating load at indoor unit side)
2. If the above wall heights are exceeded then h1/2 and h2/2 should be added to the front and suction side service spaces respectively as shown in the following figure.
3. When installing the units the most appropriate pattern should be selected from those shown above in order to obtain the best fit in the space available always bearing in mind the need to leave enough room for a person to pass between units and wall and for the air to circulate freely. (If more units are to be installed than are catered for in the above patterns your layout should take account of the possibility of short circuits.)
4. The units should be installed to leave sufficient space at the front for the on site refrigerant piping work to be carried out comfortably.

Model Name	Outdoor Unit 1	Drawing No.	Outdoor Unit 2	Drawing No.
RXYQ20P(A)	RXYQ12P(A)	3D051450H	RXYQ8P(A)	3D051449H
RXYQ22P(A)	RXYQ12P(A)	3D051450H	RXYQ10P(A)	3D051449H
RXYQ24P(A)	RXYQ16P(A)	3D051450H	RXYQ8P(A)	3D051449H
RXYQ26P(A)	RXYQ18P(A)	3D051450H	RXYQ8P(A)	3D051449H
RXYQ28P(A)	RXYQ18P(A)	3D051450H	RXYQ10P(A)	3D051449H

C : 3D052930A

RXYQ30P(A), RXYQ32P(A), RXYQ34P(A), RXYQ36P(A)

Unit (mm)




Model Name	Outdoor Unit 1	Drawing No.	Outdoor Unit 2	Drawing No.
RXYQ30P(A)	RXYQ18P(A)	3D051450H	RXYQ12P(A)	3D051450H
RXYQ32P(A)	RXYQ16P(A)	3D051450H	RXYQ16P(A)	3D051450H
RXYQ34P(A)	RXYQ18P(A)	3D051450H	RXYQ16P(A)	3D051450H
RXYQ36P(A)	RXYQ18P(A)	3D051450H	RXYQ18P(A)	3D051450H

14

RXYQ38P(A), RXYQ40P(A), RXYQ42P(A), RXYQ44P(A), RXYQ46P(A)

Unit (mm)




Notes :
1. Heights of walls
   Front : 1500mm
   Suction side : 500mm
   Side : Height unrestricted
   The installation space shown in this figure is based on the condition of cooling operation at the outdoor air temperature of 35°C.
   The installation space of suction side shown above must be expanded in the following case.
   • Design outdoor temperature becomes over 35°C.
   • Operating over Max. operating load (In case of causing a heavy heating load at indoor unit side)
2. If the above wall heights are exceeded then h1/2 and h2/2 should be added to the front and suction side service spaces respectively as shown in the following figure.
3. When installing the units the most appropriate pattern should be selected from those shown above in order to obtain the best fit in the space available always bearing in mind the need to leave enough room for a person to pass between units and wall and for the air to circulate freely. (If more units are to be installed than are catered for in the above patterns your layout should take account of the possibility of short circuits.)
4. The units should be installed to leave sufficient space at the front for the on site refrigerant piping work to be carried out comfortably.

Model Name	Outdoor Unit 1	Drawing No.	Outdoor Unit 2	Drawing No.	Outdoor Unit 3	Drawing No.
RXYQ38P(A)	RXYQ18P(A)	3D051450H	RXYQ12P(A)	3D051450H	RXYQ8P(A)	3D051449H
RXYQ40P(A)	RXYQ16P(A)	3D051450H	RXYQ16P(A)	3D051450H	RXYQ8P(A)	3D051449H
RXYQ42P(A)	RXYQ18P(A)	3D051450H	RXYQ16P(A)	3D051450H	RXYQ8P(A)	3D051449H
RXYQ44P(A)	RXYQ18P(A)	3D051450H	RXYQ18P(A)	3D051450H	RXYQ8P(A)	3D051449H
RXYQ46P(A)	RXYQ18P(A)	3D051450H	RXYQ18P(A)	3D051450H	RXYQ10P(A)	3D051449H

C : 3D052932A

RXYQ48P(A), RXYQ50P(A), RXYQ52P(A), RXYQ54P(A)

Unit (mm)




Model Name	Outdoor Unit 1	Drawing No.	Outdoor Unit 2	Drawing No.	Outdoor Unit 3	Drawing No.
RXYQ48P(A)	RXYQ18P(A)	3D051450H	RXYQ18P(A)	3D051450H	RXYQ12P(A)	3D051450H
RXYQ50P(A)	RXYQ18P(A)	3D051450H	RXYQ18P(A)	3D051450H	RXYQ14P(A)	3D051450H
RXYQ52P(A)	RXYQ18P(A)	3D051450H	RXYQ18P(A)	3D051450H	RXYQ16P(A)	3D051450H
RXYQ54P(A)	RXYQ18P(A)	3D051450H	RXYQ18P(A)	3D051450H	RXYQ18P(A)	3D051450H

C : 3D052933A

14


3. Service Space



Notes : 1. Heights of walls in case of Patterns 1 and 2 :
Front : 1500mm
Suction side : 500mm
Side : Height unrestricted.
Installation space to be shown in this drawing is based on the cooling operation at 35 degrees outdoor air temperature.
When the design outdoor air temperature exceeds 35 degrees or the load exceeds maximum ability because of much generation load of heat in all outdoor unit, take the suction side space more broadly than the space to be shown in this drawing.
2. If the above wall heights are exceeded then h2/2 and h1/2 should be added to the front and suction side service spaces respectively as shown in the figure on the right.
3. When installing the units most appropriate pattern should be selected from those shown above in order to obtain the best fit in the space available always bearing in mind the need to leave enough space for a person to pass between units and wall and for the air to circulate freely.
(If more units are to be installed than are catered for in the above patterns your layout should take account of the possibility of short circuits.)
4. The units should be installed to leave sufficient space at the front for the on site refrigerant piping work to be carried out comfortably.


4. Piping Diagrams

RXYQ5PAY1



3D050782B


RXYQ5PAYL
RXYQ5PTL



3D055764D


14

RXYQ8PAY1




3D050783C

RXYQ8PAYL
RXYQ8PTL




3D055765D

RXYQ10PAY1, RXYQ12PAY1




3D050784C

RXYQ10PAYL, RXYQ12PAYL
RXYQ10PTL, RXYQ12PTL



3D055766E


RXYQ14PAY1, RXYQ16PAY1, RXYQ18PAY1
RXYQ14PAYL, RXYQ16PAYL, RXYQ18PAYL
RXYQ14PTL, RXYQ16PTL, RXYQ18PTL



3D050785C

5. Wiring Diagrams

RXYQ5PAY1
RXYQ5PAYL




NOTES)
1. THIS WIRING DIAGRAM IS APPLIED ONLY TO THE OUTDOOR UNIT.
2. : FIELD WIRING.
3. : TERMINAL STRIP : CONNECTOR : TERMINAL : PROTECTIVE EARTH (SCREW)
4. WHEN USING THE OPTIONAL ADAPTOR, REFER TO THE INSTALLATION MANUAL OF THE OPTIONAL ADAPTOR.
5. FOR CONNECTION WIRING TO INDOOR-OUTDOOR TRANSMISSION F1 · F2, OUTDOOR-OUTDOOR TRANSMISSION F1 · F2, REFER TO THE INSTALLATION MANUAL.
6. HOW TO USE BS1~5 AND DS1 SWITCH, REFER TO "SERVICE PRECAUTION" LABEL ON EL. COMPO. BOX COVER.
7. WHEN OPERATING, DON' T SHORTCIRCUIT THE PROTECTION DEVICE (S1PH).
8. COLORS BLK : BLACK RED : RED BLU : BLUE WHT : WHITE PNK : PINK YLW : YELLOW BRN : BROWN
GRY : GRAY GRN : GREEN ORG : ORANGE.

A1P	PRINTED CIRCUIT BOARD (MAIN)	K4M	MAGNETIC CONTACTOR (M1C) (A2P)	S1NPH	PRESSURE SENSOR (HIGH)
A2P	PRINTED CIRCUIT BOARD (NOISE FILTER)	K3R	MAGNETIC RELAY (Y1S)	S1NPL	PRESSURE SENSOR (LOW)
A3P	PRINTED CIRCUIT BOARD (INV)	K4R	MAGNETIC RELAY (Y2S)	S1PH	PRESSURE SWITCH (HIGH)
A4P	PRINTED CIRCUIT BOARD (FAN)	K5R	MAGNETIC RELAY (Y3S)	V1CP	SAFETY DEVICES INPUT
A5P	PRINTED CIRCUIT BOARD (ABC I/P)	K7R	MAGNETIC RELAY (E1HC)	V1R	POWER MODULE (A3P, A4P)
BS1~5	PUSH BUTTON SWITCH (MODE, SET, RETURN, TEST, RESET)	K11R	MAGNETIC RELAY (Y4S)	V2R	DIODE BRIDGE (A3P)
		L1R	REACTOR	X1A, X2A	CONNECTOR (M1F)
C1	CAPACITOR	M1C	MOTOR (COMPRESSOR)	X1M	TERMINAL STRIP (POWER SUPPLY)
C63, C66	CAPACITOR	M1F	MOTOR (FAN)	X1M	TERMINAL STRIP (CONTROL) (A1P)
DS1	DIP SWITCH	PS	SWITCHING POWER SUPPLY (A1P, A3P)	X1M	TERMINAL STRIP (ABC I/P) (A5P)
E1HC	CRANKCASE HEATER	Q1RP	PHASE REVERSAL DETECT CIRCUIT	Y1E	ELECTRONIC EXPANSION VALVE (MAIN)
F1U	FUSE (8A, DC650V) (A4P)	R10	RESISTOR (CURRENT SENSOR) (A4P)	Y1S	SOLENOID VALVE (HOT GAS)
F1U, F2U	FUSE (T, 3.15A, 250V) (A1P)	R50, R59	RESISTOR	Y2S	SOLENOID VALVE (OIL)
F400U	FUSE (T, 6.3A, 250V) (A2P)	R95	RESISTOR (CURRENT LIMITING)	Y3S	SOLENOID VALVE (4 WAY VALVE)
H1P~8P	PILOTLAMP (SERVICE MONITOR-ORANGE) [H2P] PREPARE, TEST----------FLICKERING MALFUNCTION DETECTION---LIGHT UP	R1T	THERMISTOR (AIR) (A1P)	Y4S	SOLENOID VALVE (INJECTION)
		R1T	THERMISTOR (FIN) (A3P)	Z1C~5C	NOISE FILTER (FERRITE CORE)
		R2T	THERMISTOR (SUCTION)	Z1F	NOISE FILTER (WITH SURGE ABSORBER)
HAP	PILOTLAMP (SERVICE MONITOR-GREEN)	R3T	THERMISTOR (M1C DISCHARGE)		
K1R	MAGNETIC RELAY (A3P)	R4T	THERMISTOR (HEAT EXC. DEICER)	COOL/HEAT SELECTOR	
K3R	MAGNETIC RELAY (A2P)	R5T	THERMISTOR (LIQ. PIPE)	S1S	SELECTOR SWITCH (FAN/COOL · HEAT)
K2M	MAGNETIC CONTACTOR (M1C) (A3P)	R6T	THERMISTOR (ACCUMULATOR)	S2S	SELECTOR SWITCH (COOL/HEAT)

3D060907A


14

RXYQ5PTL



L1-RED	L2-WHT	L3-BLU			
A1P	PRINTED CIRCUIT BOARD (MAIN)		K84R	MAGNETIC RELAY (CURRENT LIMITING)	Y1R	DIODE BRIDGE (A2P)
A2P	PRINTED CIRCUIT BOARD (INV)		L1R	REACTOR	Y2R, Y3R	POWER MODULE (A2P)
A3P	PRINTED CIRCUIT BOARD (ABC I/P)		M1C	MOTOR (COMPRESSOR)	X1A, X2A	CONNECTOR (M1F)
BS1~5	PUSH BUTTON SWITCH		M1F	MOTOR (FAN)	X1M	TERMINAL STRIP (POWER SUPPLY)
	(MODE, SET, RETURN, TEST, RESET)		PS	SWITCHING POWER SUPPLY (A1P, A2P)	X1M	TERMINAL STRIP (CONTROL) (A1P)
C1	CAPACITOR		Q1RP	PHASE REVERSAL DETECT CIRCUIT	X1M	TERMINAL STRIP (ABC I/P) (A3P)
DS1	DIP SWITCH		R1	RESISTOR (CURRENT LIMITING)	Y1E	ELECTRONIC EXPANSION VALVE (MAIN)
E1HC	CRANKCASE HEATER		R112	RESISTOR (CURRENT SENSOR) (A2P)	Y1S	SOLENOID VALVE (HOT GAS)
F1U	FUSE (16A, DC450V) (A2P)		R502	RESISTOR (CURRENT SENSOR) (A2P)	Y2S	SOLENOID VALVE (OIL)
F1U, F2U	FUSE (T, 3.15A, 250V) (A1P)		R1T	THERMISTOR (AIR) (A1P)	Y3S	SOLENOID VALVE (4 WAY VALVE)
H1P~8P	PILOTLAMP (SERVICE MONITOR-ORANGE)		R1T	THERMISTOR (FIN) (A2P)	Y4S	SOLENOID VALVE (INJECTION)
	[H2P] PREPARE, TEST----------FLICKERING		R2T	THERMISTOR (SUCTION)	Z1C~3C	NOISE FILTER (FERRITE CORE)
	MALFUNCTION DETECTION---LIGHT UP		R3T	THERMISTOR (M1C DISCHARGE)	Z1F	NOISE FILTER (WITH SURGE ABSORBER)
HAP	PILOTLAMP (SERVICE MONITOR-GREEN)		R4T	THERMISTOR (HEAT EXC. DEICER)		
K1M, K2M	MAGNETIC CONTACTOR (M1C) (A2P)		R5T	THERMISTOR (LIQ. PIPE)		
K3R	MAGNETIC RELAY (Y1S)		R6T	THERMISTOR (ACCUMULATOR)		
K4R	MAGNETIC RELAY (Y2S)		S1NPH	PRESSURE SENSOR (HIGH)		
K5R	MAGNETIC RELAY (Y3S)		S1NPL	PRESSURE SENSOR (LOW)	COOL/HEAT SELECTOR	
K7R	MAGNETIC RELAY (E1HC)		S1PH	PRESSURE SWITCH (HIGH)	S1S	SELECTOR SWITCH (FAN/COOL · HEAT)
K11R	MAGNETIC RELAY (Y4S)		V1CP	SAFETY DEVICES INPUT	S2S	SELECTOR SWITCH (COOL/HEAT)


RXYQ8PAY1
RXYQ8PAYL



A1P	PRINTED CIRCUIT BOARD (MAIN)	K4M	MAGNETIC CONTACTOR (M1C) (A2P)	S1NPH	PRESSURE SENSOR (HIGH)
A2P	PRINTED CIRCUIT BOARD (NOISE FILTER)	K3R	MAGNETIC RELAY (Y1S)	S1NPL	PRESSURE SENSOR (LOW)
A3P	PRINTED CIRCUIT BOARD (INV)	K4R	MAGNETIC RELAY (Y2S)	S1PH	PRESSURE SWITCH (HIGH)
A4P	PRINTED CIRCUIT BOARD (FAN)	K5R	MAGNETIC RELAY (Y3S)	V1CP	SAFETY DEVICES INPUT
A5P	PRINTED CIRCUIT BOARD (ABC I/P)	K7R	MAGNETIC RELAY (E1HC)	V1R	POWER MODULE (A3P, A4P)
BS1~5	PUSH BUTTON SWITCH (MODE, SET, RETURN, TEST, RESET)	L1R	REACTOR	V2R	DIODE BRIDGE (A3P)
		M1C	MOTOR (COMPRESSOR)	X1A, X2A	CONNECTOR (M1F)
C1	CAPACITOR	M1F	MOTOR (FAN)	X1M	TERMINAL STRIP (POWER SUPPLY)
C63, C66	CAPACITOR	PS	SWITCHING POWER SUPPLY (A1P, A3P)	X1M	TERMINAL STRIP (CONTROL) (A1P)
DS1	DIP SWITCH	Q1RP	PHASE REVERSAL DETECT CIRCUIT	X1M	TERMINAL STRIP (ABC I/P) (A5P)
E1HC	CRANKCASE HEATER	R10	RESISTOR (CURRENT SENSOR) (A4P)	Y1E	ELECTRONIC EXPANSION VALVE (MAIN)
F1U	FUSE (8A, DC650V) (A4P)	R50, R59	RESISTOR	Y2E	ELECTRONIC EXPANSION VALVE (SUBCOOL)
F1U, F2U	FUSE (T, 3.15A, 250V) (A1P)	R95	RESISTOR (CURRENT LIMITING)	Y1S	SOLENOID VALVE (HOT GAS)
F400U	FUSE (T, 6.3A, 250V) (A2P)	R1T	THERMISTOR (AIR) (A1P)	Y2S	SOLENOID VALVE (OIL)
H1P~8P	PILOTLAMP (SERVICE MONITOR-ORANGE) [H2P] PREPARE, TEST----------FLICKERING MALFUNCTION DETECTION--LIGHT UP	R1T	THERMISTOR (FIN) (A3P)	Y3S	SOLENOID VALVE (4 WAY VALVE)
		R2T	THERMISTOR (SUCTION)	Z1C~5C	NOISE FILTER (FERRITE CORE)
		R3T	THERMISTOR (M1C DISCHARGE)	Z1F	NOISE FILTER (WITH SURGE ABSORBER)
HAP	PILOTLAMP (SERVICE MONITOR-GREEN)	R4T	THERMISTOR (HEAT EXC. DEICER)		
K1R	MAGNETIC RELAY (A3P)	R5T	THERMISTOR (HEAT EXC. OUTLET)	COOL/HEAT SELECTOR	
K3R	MAGNETIC RELAY (A2P)	R6T	THERMISTOR (LIQ. PIPE)	S1S	SELECTOR SWITCH (FAN/COOL · HEAT)
K2M	MAGNETIC CONTACTOR (M1C) (A3P)	R7T	THERMISTOR (ACCUMULATOR)	S2S	SELECTOR SWITCH (COOL/HEAT)

14

RXYQ8PTL




NOTES)
1. THIS WIRING DIAGRAM IS APPLIED ONLY TO THE OUTDOOR UNIT.
2. : FIELD WIRING.
3. : TERMINAL STRIP : CONNECTOR : TERMINAL : PROTECTIVE EARTH (SCREW)
4. WHEN USING THE OPTIONAL ADAPTOR, REFER TO THE INSTALLATION MANUAL OF THE OPTIONAL ADAPTOR.
5. FOR CONNECTION WIRING TO INDOOR-OUTDOOR TRANSMISSION F1 · F2, OUTDOOR-OUTDOOR TRANSMISSION F1 · F2, OUTDOOR-MULTI TRANSMISSION Q1 · Q2, REFER TO THE INSTALLATION MANUAL.
6. HOW TO USE BS1~5 AND DS1 SWITCH, REFER TO "SERVICE PRECAUTION" LABEL ON EL. COMPO. BOX COVER.
7. WHEN OPERATING, DON'T SHORTCIRCUIT THE PROTECTION DEVICE (S1PH).
8. COLORS BLK : BLACK RED : RED BLU : BLUE WHT : WHITE PNK : PINK YLW : YELLOW BRN : BROWN GRY : GRAY GRN : GREEN ORG : ORANGE.

L1-RED	L2-WHT	L3-BLU				
A1P	PRINTED CIRCUIT BOARD (MAIN)		L1R	REACTOR	V1R	DIODE BRIDGE (A2P)
A2P	PRINTED CIRCUIT BOARD (INV)		M1C	MOTOR (COMPRESSOR)	V2R, V3R	POWER MODULE (A2P)
A3P	PRINTED CIRCUIT BOARD (ABC I/P)		M1F	MOTOR (FAN)	X1A, X2A	CONNECTOR (M1F)
BS1~5	PUSH BUTTON SWITCH		PS	SWITCHING POWER SUPPLY (A1P,A2P)	X1M	TERMINAL STRIP (POWER SUPPLY)
	(MODE, SET, RETURN, TEST, RESET)		Q1RP	PHASE REVERSAL DETECT CIRCUIT	X1M	TERMINAL STRIP (CONTROL) (A1P)
C1	CAPACITOR		R1	RESISTOR (CURRENT LIMITING)	X1M	TERMINAL STRIP (ABC I/P) (A3P)
DS1	DIP SWITCH		R112	RESISTOR (CURRENT SENSOR) (A2P)	Y1E	ELECTRONIC EXPANSION VALVE (MAIN)
E1HC	CRANKCASE HEATER		R502	RESISTOR (CURRENT SENSOR) (A2P)	Y2E	ELECTRONIC EXPANSION VALVE (SUBCOOL)
F1U	FUSE (16A, DC450V) (A2P)		R1T	THERMISTOR (AIR) (A1P)	Y1S	SOLENOID VALVE (HOT GAS)
F1U, F2U	FUSE (T, 3.15A, 250V) (A1P)		R1T	THERMISTOR (FIN) (A2P)	Y2S	SOLENOID VALVE (OIL)
H1P~8P	PILOTLAMP (SERVICE MONITOR-ORANGE)		R2T	THERMISTOR (SUCTION)	Y3S	SOLENOID VALVE (4 WAY VALVE)
	[H2P] PREPARE TEST----------FLICKERING		R3T	THERMISTOR (M1C DISCHARGE)	Z1C~3C	NOISE FILTER (FERRITE CORE)
	MALFUNCTION DETECTION---LIGHT UP		R4T	THERMISTOR (HEAT EXC. DEICER)	Z1F	NOISE FILTER (WITH SURGE ABSORBER)
HAP	PILOTLAMP (SERVICE MONITOR-GREEN)		R5T	THERMISTOR (HEAT EXC. OUTLET)		
K1M, K2M	MAGNETIC CONTACTOR (M1C) (A2P)		R6T	THERMISTOR (LIQ. PIPE)		
K3R	MAGNETIC RELAY (Y1S)		R7T	THERMISTOR (ACCUMULATOR)		
K4R	MAGNETIC RELAY (Y2S)		S1NPH	PRESSURE SENSOR (HIGH)		
K5R	MAGNETIC RELAY (Y3S)		S1NPL	PRESSURE SENSOR (LOW)	COOL/HEAT SELECTOR	
K7R	MAGNETIC RELAY (E1HC)		S1PH	PRESSURE SWITCH (HIGH)	S1S	SELECTOR SWITCH (FAN/COOL · HEAT)
K84R	MAGNETIC RELAY (CURRENT LIMITING)		V1CP	SAFETY DEVICES INPUT	S2S	SELECTOR SWITCH (COOL/HEAT)


3D060627B

RXYQ10PAY1
RXYQ10PAYL



A1P	PRINTED CIRCUIT BOARD (MAIN)	K2M	MAGNETIC CONTACTOR (M2C)	S1NPH	PRESSURE SENSOR (HIGH)
A2P	PRINTED CIRCUIT BOARD (NOISE FILTER)	K1R	MAGNETIC RELAY (K2M)	S1NPL	PRESSURE SENSOR (LOW)
A3P	PRINTED CIRCUIT BOARD (INV)	K3R	MAGNETIC RELAY (Y1S)	S1PH, S2PH	PRESSURE SWITCH (HIGH)
A4P	PRINTED CIRCUIT BOARD (FAN)	K4R	MAGNETIC RELAY (Y2S)	T1A	CURRENT SENSOR (A6P)
A5P	PRINTED CIRCUIT BOARD (ABC I/P)	K5R	MAGNETIC RELAY (Y3S)	V1CP	SAFETY DEVICES INPUT
A6P	PRINTED CIRCUIT BOARD (CURRENT SENSOR)	K7R	MAGNETIC RELAY (E1HC)	V1R	POWER MODULE (A3P, A4P)
BS1~5	PUSH BUTTON SWITCH (MODE, SET, RETURN, TEST, RESET)	K8R	MAGNETIC RELAY (E2HC)	V2R	DIODE BRIDGE (A3P)
C1	CAPACITOR	L1R	REACTOR	X1A, X2A	CONNECTOR (M1F)
C63, C66	CAPACITOR	M1C, M2C	MOTOR (COMPRESSOR)	X1M	TERMINAL STRIP (POWER SUPPLY)
DS1	DIP SWITCH	M1F	MOTOR (FAN)	X1M	TERMINAL STRIP (CONTROL) (A1P)
E1HC, E2HC	CRANKCASE HEATER	PS	SWITCHING POWER SUPPLY (A1P, A3P)	X1M	TERMINAL STRIP (ABC I/P) (A5P)
F1U	FUSE (8A, DC650V) (A4P)	Q1RP	PHASE REVERSAL DETECT CIRCUIT	Y1E	ELECTRONIC EXPANSION VALVE (MAIN)
F1U, F2U	FUSE (T, 3.15A, 250V) (A1P)	R10	RESISTOR (CURRENT SENSOR) (A4P, A5P)	Y2E	ELECTRONIC EXPANSION VALVE (SUBCOOL)
F400U	FUSE (T, 6.3A, 250V) (A2P)	R50, R59	RESISTOR	Y1S	SOLENOID VALVE (HOT GAS)
H1P~8P	PILOTLAMP (SERVICE MONITOR-ORANGE)	R95	RESISTOR (CURRENT LIMITING)	Y2S	SOLENOID VALVE (OIL)
	[H2P] PREPARE, TEST----------FLICKERING	R1T	THERMISTOR (AIR) (A1P)	Y3S	SOLENOID VALVE (4 WAY VALVE)
	MALFUNCTION DETECTION---LIGHT UP	R1T	THERMISTOR (FIN) (A3P)	Z1C~7C	NOISE FILTER (FERRITE CORE)
HAP	PILOTLAMP (SERVICE MONITOR-GREEN)	R2T	THERMISTOR (SUCTION)	Z1F	NOISE FILTER (WITH SURGE ABSORBER)
K1R	MAGNETIC RELAY (A3P)	R31T, R32T	THERMISTOR (M1C, M2C DISCHARGE)		
K3R	MAGNETIC RELAY (A2P)	R4T	THERMISTOR (HEAT EXC. DEICER)		
K2M	MAGNETIC CONTACTOR (M1C) (A3P)	R5T	THERMISTOR (HEAT EXC. OUTLET)	COOL/HEAT	SELECTOR
K4M	MAGNETIC CONTACTOR (M1C) (A2P)	R6T	THERMISTOR (LIQ. PIPE)	S1S	SELECTOR SWITCH (FAN/COOL · HEAT)
		R7T	THERMISTOR (ACCUMULATOR)	S2S	SELECTOR SWITCH (COOL/HEAT)

RXYQ10PTL




NOTES)
1. THIS WIRING DIAGRAM IS APPLIED ONLY TO THE OUTDOOR UNIT.
2. : FIELD WIRING.
3. : TERMINAL STRIP : CONNECTOR : TERMINAL : PROTECTIVE EARTH (SCREW)
4. WHEN USING THE OPTIONAL ADAPTOR, REFER TO THE INSTALLATION MANUAL OF THE OPTIONAL ADAPTOR.
5. FOR CONNECTION WIRING TO INDOOR-OUTDOOR TRANSMISSION F1 · F2, OUTDOOR-OUTDOOR TRANSMISSION F1 · F2, OUTDOOR-MULTI TRANSMISSION Q1 · Q2, REFER TO THE INSTALLATION MANUAL.
6. HOW TO USE BS1~5 AND DS1 SWITCH, REFER TO "SERVICE PRECAUTION" LABEL ON EL. COMPO. BOX COVER.
7. WHEN OPERATING, DON' T SHORTCIRCUIT THE PROTECTION DEVICE (S1PH).
8. COLORS BLK : BLACK RED : RED BLU : BLUE WHT : WHITE PNK : PINK YLW : YELLOW BRN : BROWN GRY : GRAY GRN : GREEN ORG : ORANGE.

L1-RED	L2-WHT	L3-BLU			
A1P	PRINTED CIRCUIT BOARD (MAIN)		K8R	MAGNETIC RELAY (E2HC)	V1CP	SAFETY DEVICES INPUT
A2P	PRINTED CIRCUIT BOARD (INV)		K84R	MAGNETIC RELAY (CURRENT LIMITING)	V1R	DIODE BRIDGE (A2P)
A3P	PRINTED CIRCUIT BOARD (ABC I/P)		L1R	REACTOR	V2R, V3R	POWER MODULE (A2P)
A4P	PRINTED CIRCUIT BOARD (CURRENT SENSOR)		M1C, M2C	MOTOR (COMPRESSOR)	X1A, X2A	CONNECTOR (M1F)
BS1~5	PUSH BUTTON SWITCH (MODE, SET, RETURN, TEST, RESET)		M1F	MOTOR (FAN)	X1M	TERMINAL STRIP (POWER SUPPLY)
			PS	SWITCHING POWER SUPPLY (A1P, A2P)	X1M	TERMINAL STRIP (CONTROL) (A1P)
C1	CAPACITOR		Q1RP	PHASE REVERSAL DETECT CIRCUIT	X1M	TERMINAL STRIP (ABC I/P) (A3P)
DS1	DIP SWITCH		R1	RESISTOR (CURRENT LIMITING)	Y1E	ELECTRONIC EXPANSION VALVE (MAIN)
E1HC, E2HC	CRANKCASE HEATER		R112	RESISTOR (CURRENT SENSOR) (A2P)	Y2E	ELECTRONIC EXPANSION VALVE (SUBCOOL)
F1U	FUSE (16A, DC450V) (A2P)		R502	RESISTOR (CURRENT SENSOR) (A2P)	Y1S	SOLENOID VALVE (HOT GAS)
F1U, F2U	FUSE (T, 3.15A, 250V) (A1P)		R1T	THERMISTOR (AIR) (A1P)	Y2S	SOLENOID VALVE (OIL)
H1P~8P	PILOTLAMP (SERVICE MONITOR-ORANGE) [H2P] PREPARE TEST----------FLICKERING MALFUNCTION DETECTION--LIGHT UP		R1T	THERMISTOR (FIN) (A2P)	Y3S	SOLENOID VALVE (4 WAY VALVE)
			R2T	THERMISTOR (SUCTION)	Z1C~4C	NOISE FILTER (FERRITE CORE)
			R31T, R32T	THERMISTOR (M1C, DISCHARGE)	Z1F	NOISE FILTER (WITH SURGE ABSORBER)
HAP	PILOTLAMP (SERVICE MONITOR-GREEN)		R4T	THERMISTOR (HEAT EXC. DEICER)		
K1M, K2M	MAGNETIC CONTACTOR (M1C) (A2P)		R5T	THERMISTOR (HEAT EXC. OUTLET)		
K2M	MAGNETIC CONTACTOR (M2C)		R6T	THERMISTOR (LIQ. PIPE)		
K1R	MAGNETIC RELAY (K2M)		R7T	THERMISTOR (ACCUMULATOR)		
K3R	MAGNETIC RELAY (Y1S)		S1NPH	PRESSURE SENSOR (HIGH)		
K4R	MAGNETIC RELAY (Y2S)		S1NPL	PRESSURE SENSOR (LOW)	COOL/HEAT SELECTOR	
K5R	MAGNETIC RELAY (Y3S)		S1PH, S2PH	PRESSURE SWITCH (HIGH)	S1S	SELECTOR SWITCH (FAN/COOL · HEAT)
K7R	MAGNETIC RELAY (E1HC)		T1A	CURRENT SENSOR (A4P)	S2S	SELECTOR SWITCH (COOL/HEAT)

3D060629B


RXYQ12PAY1
RXYQ12PAYL



A1P	PRINTED CIRCUIT BOARD (MAIN)	K2M	MAGNETIC CONTACTOR (M2C)	S1NPH	PRESSURE SENSOR (HIGH)
A2P	PRINTED CIRCUIT BOARD (NOISE FILTER)	K1R	MAGNETIC RELAY (K2M)	S1NPL	PRESSURE SENSOR (LOW)
A3P	PRINTED CIRCUIT BOARD (INV)	K3R	MAGNETIC RELAY (Y1S)	S1PH, S2PH	PRESSURE SWITCH (HIGH)
A4P, A8P	PRINTED CIRCUIT BOARD (FAN)	K4R	MAGNETIC RELAY (Y2S)	T1A	CURRENT SENSOR (A6P)
A5P	PRINTED CIRCUIT BOARD (ABC I/P)	K5R	MAGNETIC RELAY (Y3S)	V1CP	SAFETY DEVICES INPUT
A6P	PRINTED CIRCUIT BOARD (CURRENT SENSOR)	K7R	MAGNETIC RELAY (E1HC)	V1R	POWER MODULE (A3P, A4P, A8P)
BS1~5	PUSH BUTTON SWITCH (MODE, SET, RETURN, TEST, RESET)	K8R	MAGNETIC RELAY (E2HC)	V2R	DIODE BRIDGE (A3P)
		L1R	REACTOR	X1A~4A	CONNECTOR (M1F, M2F)
C1	CAPACITOR	M1C, M2C	MOTOR (COMPRESSOR)	X1M	TERMINAL STRIP (POWER SUPPLY)
C63, C66	CAPACITOR	M1F, M2F	MOTOR (FAN)	X1M	TERMINAL STRIP (CONTROL) (A1P)
DS1	DIP SWITCH	PS	SWITCHING POWER SUPPLY (A1P, A3P)	X1M	TERMINAL STRIP (ABC I/P) (A5P)
E1HC E2HC	CRANKCASE HEATER	Q1RP	PHASE REVERSAL DETECT CIRCUIT	Y1E	ELECTRONIC EXPANSION VALVE (MAIN)
F1U	FUSE (8A, DC650V) (A4P) (A8P)	R10	RESISTOR (CURRENT SENSOR) (A4P, A8P)	Y2E	ELECTRONIC EXPANSION VALVE (SUBCOOL)
F1U, F2U	FUSE (T, 3.15A, 250V) (A1P)	R50, R59	RESISTOR	Y1S	SOLENOID VALVE (HOT GAS)
F400U	FUSE (T, 6.3A, 250V) (A2P)	R95	RESISTOR (CURRENT LIMITING)	Y2S	SOLENOID VALVE (OIL)
H1P~8P	PILOTLAMP (SERVICE MONITOR-ORANGE) [H2P] PREPARE TEST----------FLICKERING MALFUNCTION DETECTION--LIGHT UP	R1T	THERMISTOR (AIR) (A1P)	Y3S	SOLENOID VALVE (4 WAY VALVE)
		R1T	THERMISTOR (FIN) (A3P)	Z1C~7C, Z9C	NOISE FILTER (FERRITE CORE)
		R2T	THERMISTOR (SUCTION)	Z1F	NOISE FILTER (WITH SURGE ABSORBER)
HAP	PILOTLAMP (SERVICE MONITOR-GREEN)	R31T, R32T	THERMISTOR (M1C, M2C DISCHARGE)		
K1R	MAGNETIC RELAY (A3P)	R4T	THERMISTOR (HEAT EXC. DEICER)		
K3R	MAGNETIC RELAY (A2P)	R5T	THERMISTOR (HEAT EXC. OUTLET)	COOL/HEAT SELECTOR	
K2M	MAGNETIC CONTACTOR (M1C) (A3P)	R6T	THERMISTOR (LIQ. PIPE)	S1S	SELECTOR SWITCH (FAN/COOL · HEAT)
K4M	MAGNETIC CONTACTOR (M1C) (A2P)	R7T	THERMISTOR (ACCUMULATOR)	S2S	SELECTOR SWITCH (COOL/HEAT)

14

RXYQ12PTL




NOTES)
1. THIS WIRING DIAGRAM IS APPLIED ONLY TO THE OUTDOOR UNIT.
2. : FIELD WIRING.
3. : TERMINAL STRIP : CONNECTOR : TERMINAL : PROTECTIVE EARTH (SCREW)
4. WHEN USING THE OPTIONAL ADAPTOR, REFER TO THE INSTALLATION MANUAL OF THE OPTIONAL ADAPTOR.
5. FOR CONNECTION WIRING TO INDOOR-OUTDOOR TRANSMISSION F1 · F2, OUTDOOR-OUTDOOR TRANSMISSION F1 · F2, OUTDOOR-MULTI TRANSMISSION Q1 · Q2, REFER TO THE INSTALLATION MANUAL.
6. HOW TO USE BS1~5 AND DS1 SWITCH, REFER TO "SERVICE PRECAUTION" LABEL ON EL. COMPO. BOX COVER.
7. WHEN OPERATING, DON' T SHORTCIRCUIT THE PROTECTION DEVICE (S1PH).
8. COLORS BLK : BLACK RED : RED BLU : BLUE WHT : WHITE PNK : PINK YLW : YELLOW BRN : BROWN
GRY : GRAY GRN : GREEN ORG : ORANGE.

L1-RED	L2-WHT	L3-BLU			
A1P	PRINTED CIRCUIT BOARD (MAIN)		K8R	MAGNETIC RELAY (E2HC)	V1CP	SAFETY DEVICES INPUT
A2P	PRINTED CIRCUIT BOARD (INV)		K84R	MAGNETIC RELAY (CURRENT LIMITING)	V1R	DIODE BRIDGE (A2P)
A3P	PRINTED CIRCUIT BOARD (ABC I/P)		L1R	REACTOR	V1R	POWER MODULE (A5P)
A4P	PRINTED CIRCUIT BOARD (CURRENT SENSOR)		M1C, M2C	MOTOR (COMPRESSOR)	V2R, V3R	POWER MODULE (A2P)
A5P	PRINTED CIRCUIT BOARD (INV)		M1F, M2F	MOTOR (FAN)	X1A~4A	CONNECTOR (M1F, M2F)
BS1~5	PUSH BUTTON SWITCH (MODE, SET, RETURN, TEST, RESET)		PS	SWITCHING POWER SUPPLY (A1P,A2P)	X1M	TERMINAL STRIP (POWER SUPPLY)
			Q1RP	PHASE REVERSAL DETECT CIRCUIT	X1M	TERMINAL STRIP (CONTROL) (A1P)
C1	CAPACITOR		R1	RESISTOR (CURRENT LIMITING)	X1M	TERMINAL STRIP (ABC I/P) (A3P)
DS1	DIP SWITCH		R2	RESISTOR (CURRENT SENSOR) (A5P)	Y1E	ELECTRONIC EXPANSION VALVE (MAIN)
E1HC, E2HC	CRANKCASE HEATER		R112	RESISTOR (CURRENT SENSOR) (A2P)	Y2E	ELECTRONIC EXPANSION VALVE (SUBCOOL)
F1U	FUSE (16A, DC450V) (A2P, A5P)		R502	RESISTOR (CURRENT SENSOR) (A2P)	Y1S	SOLENOID VALVE (HOT GAS)
F1U, F2U	FUSE (T, 3.15A, 250V) (A1P)		R1T	THERMISTOR (AIR) (A1P)	Y2S	SOLENOID VALVE (OIL)
H1P~8P	PILOTLAMP (SERVICE MONITOR-ORANGE)		R1T	THERMISTOR (FIN) (A2P)	Y3S	SOLENOID VALVE (4 WAY VALVE)
	[H2P] PREPARE, TEST----------FLICKERING		R2T	THERMISTOR (SUCTION)	Z1C~6C	NOISE FILTER (FERRITE CORE)
	MALFUNCTION DETECTION--LIGHT UP		R31T, R32T	THERMISTOR (M1C, M2C DISCHARGE)	Z1F	NOISE FILTER (WITH SURGE ABSORBER)
HAP	PILOTLAMP (SERVICE MONITOR-GREEN)		R4T	THERMISTOR (HEAT EXC. DEICER)		
K1M, K2M	MAGNETIC CONTACTOR (M1C) (A2P)		R5T	THERMISTOR (HEAT EXC. OUTLET)		
K2M	MAGNETIC CONTACTOR (M2C)		R6T	THERMISTOR (LIQ. PIPE)		
K1R	MAGNETIC RELAY (K2M)		R7T	THERMISTOR (ACCUMULATOR)		
K3R	MAGNETIC RELAY (Y1S)		S1NPH	PRESSURE SENSOR (HIGH)		
K4R	MAGNETIC RELAY (Y2S)		S1NPL	PRESSURE SENSOR (LOW)	COOL/HEAT SELECTOR	
K5R	MAGNETIC RELAY (Y3S)		S1PH, S2PH	PRESSURE SWITCH (HIGH)	S1S	SELECTOR SWITCH (FAN/COOL · HEAT)
K7R	MAGNETIC RELAY (E1HC)		T1A	CURRENT SENSOR (A4P)	S2S	SELECTOR SWITCH (COOL/HEAT)

3D060630B


RXYQ14PAY1, RXYQ16PAY1, RXYQ18PAY1
RXYQ14PAYL, RXYQ16PAYL, RXYQ18PAYL



NOTES)
1. THIS WIRING DIAGRAM IS APPLIED ONLY TO THE OUTDOOR UNIT.
2. : FIELD WIRING.
3. : TERMINAL STRIP : CONNECTOR : TERMINAL : PROTECTIVE EARTH (SCREW)
4. WHEN USING THE OPTIONAL ADAPTOR, REFER TO THE INSTALLATION MANUAL OF THE OPTIONAL ADAPTOR.
5. FOR CONNECTION WIRING TO INDOOR-OUTDOOR TRANSMISSION F1 · F2, OUTDOOR-OUTDOOR TRANSMISSION F1 · F2 OUTDOOR-MULTI TRANSMISSION Q1 · Q2, REFER TO THE INSTALLATION MANUAL.
6. HOW TO USE BS1~5 AND DS1 SWITCH, REFER TO "SERVICE PRECAUTION" LABEL ON EL. COMPO. BOX COVER.
7. WHEN OPERATING, DON'T SHORTCIRCUIT THE PROTECTION DEVICE (S1PH~S3PH).
8. COLORS BLK : BLACK RED : RED BLU : BLUE WHT : WHITE PNK : PINK YLW : YELLOW BRN : BROWN GRY : GRAY GRN : GREEN ORG : ORANGE.

A1P	PRINTED CIRCUIT BOARD (MAIN)	K2M, K3M	MAGNETIC CONTACTOR (M2C, M3C)	R7T	THERMISTOR (ACCUMULATOR)
A2P	PRINTED CIRCUIT BOARD (NOISE FILTER)	K1R, K2R	MAGNETIC RELAY (K2M, K3M)	S1NPH	PRESSURE SENSOR (HIGH)
A3P	PRINTED CIRCUIT BOARD (INV)	K3R	MAGNETIC RELAY (Y1S)	S1NPL	PRESSURE SENSOR (LOW)
A4P, A8P	PRINTED CIRCUIT BOARD (FAN)	K4R	MAGNETIC RELAY (Y2S)	S1PH~3PH	PRESSURE SWITCH (HIGH)
A5P	PRINTED CIRCUIT BOARD (ABC I/P)	K5R	MAGNETIC RELAY (Y3S)	T1A	CURRENT SENSOR (A6P, A7P)
A6P, A7P	PRINTED CIRCUIT BOARD (CURRENT SENSOR)	K7R	MAGNETIC RELAY (E1HC)	V1CP	SAFETY DEVICES INPUT
BS1~5	PUSH BUTTON SWITCH (MODE, SET, RETURN, TEST, RESET)	K8R	MAGNETIC RELAY (E2HC)	V1R	POWER MODULE (A3P, A4P, A8P)
C1	CAPACITOR	K9R	MAGNETIC RELAY (E3HC)	V2R	DIODE BRIDGE (A3P)
C63, C66	CAPACITOR	L1R	REACTOR	X1A~4A	CONNECTOR (M1F, M2F)
DS1	DIP SWITCH	M1C~3C	MOTOR (COMPRESSOR)	X1M	TERMINAL STRIP (POWER SUPPLY)
E1HC~3HC	CRANKCASE HEATER	M1F, M2F	MOTOR (FAN)	X1M	TERMINAL STRIP (CONTROL) (A1P)
F1U	FUSE (8A, DC650V) (A4P, A8P)	PS	SWITCHING POWER SUPPLY (A1P, A3P)	X1M	TERMINAL STRIP (ABC I/P) (A5P)
F1U, F2U	FUSE (T, 3.15A, 250V) (A1P)	Q1RP	PHASE REVERSAL DETECT CIRCUIT	Y1E	ELECTRONIC EXPANSION VALVE (MAIN)
F400U	FUSE (T, 6.3A, 250V) (A2P)	R10	RESISTOR (CURRENT SENSOR) (A4P, A8P)	Y2E	ELECTRONIC EXPANSION VALVE (SUBCOOL)
H1P~8P	PILOTLAMP (SERVICE MONITOR-ORANGE)	R50, R59	RESISTOR	Y1S	SOLENOID VALVE (HOT GAS)
	[H2P] PREPARE, TEST----------FLICKERING	R95	RESISTOR (CURRENT LIMITING)	Y2S	SOLENOID VALVE (OIL)
	MALFUNCTION DETECTION--LIGHT UP	R1T	THERMISTOR (AIR) (A1P)	Y3S	SOLENOID VALVE (4 WAY VALVE)
		R1T	THERMISTOR (FIN) (A3P)	Z1C~9C	NOISE FILTER (FERRITE CORE)
HAP	PILOTLAMP (SERVICE MONITOR-GREEN)	R2T	THERMISTOR (SUCTION)	Z1F	NOISE FILTER (WITH SURGE ABSORBER)
K1R	MAGNETIC RELAY (A3P)	R31~33T	THERMISTOR (M1C~3C DISCHARGE)		
K3R	MAGNETIC RELAY (A2P)	R4T	THERMISTOR (HEAT EXC. DEICER)	COOL/HEAT	SELECTOR
K2M	MAGNETIC CONTACTOR (M1C) (A3P)	R5T	THERMISTOR (HEAT EXC. OUTLET)	S1S	SELECTOR SWITCH (FAN/COOL · HEAT)
K4M	MAGNETIC CONTACTOR (M1C) (A2P)	R6T	THERMISTOR (LIQ. PIPE)	S2S	SELECTOR SWITCH (COOL/HEAT)

RXYQ14PTL, RXYQ16PTL, RXYQ18PTL




NOTES)
1. THIS WIRING DIAGRAM IS APPLIED ONLY TO THE OUTDOOR UNIT.
2. ▮▮▮: FIELD WIRING.
3. ▭▭: TERMINAL STRIP ▭▭: CONNECTOR ⊸: TERMINAL ⏚: PROTECTIVE EARTH (SCREW)
4. WHEN USING THE OPTIONAL ADAPTOR, REFER TO THE INSTALLATION MANUAL OF THE OPTIONAL ADAPTOR.
5. FOR CONNECTION WIRING TO INDOOR-OUTDOOR TRANSMISSION F1 · F2, OUTDOOR-OUTDOOR TRANSMISSION F1 · F2, OUTDOOR-MULTI TRANSMISSION Q1 · Q2, REFER TO THE INSTALLATION MANUAL.
6. HOW TO USE BS1~5 AND DS1 SWITCH, REFER TO "SERVICE PRECAUTION" LABEL ON EL. COMPO. BOX COVER.
7. WHEN OPERATING, DON'T SHORTCIRCUIT THE PROTECTION DEVICE (S1PH).
8. COLORS BLK : BLACK RED : RED BLU : BLUE WHT : WHITE PNK : PINK YLW : YELLOW BRN : BROWN GRY : GRAY GRN : GREEN ORG : ORANGE.

A1P	PRINTED CIRCUIT BOARD (MAIN)	K8R	MAGNETIC RELAY (E2HC)	T1A	CURRENT SENSOR (A4P, A6P)
A2P	PRINTED CIRCUIT BOARD (INV)	K9R	MAGNETIC RELAY (E3HC)	V1CP	SAFETY DEVICES INPUT
A3P	PRINTED CIRCUIT BOARD (ABC I/P)	K84R	MAGNETIC RELAY (CURRENT LIMITING)	V1R	DIODE BRIDGE (A2P)
A4P, A6P	PRINTED CIRCUIT BOARD (CURRENT SENSOR)	L1R	REACTOR	V1R	POWER MODULE (A5P)
A5P	PRINTED CIRCUIT BOARD (INV)	M1C~3C	MOTOR (COMPRESSOR)	V2R,V3R	POWER MODULE (A2P)
BS1~5	PUSH BUTTON SWITCH (MODE, SET, RETURN, TEST, RESET)	M1F,M2F	MOTOR (FAN)	X1A~4A	CONNECTOR (M1F, M2F)
		PS	SWITCHING POWER SUPPLY (A1P, A2P)	X1M	TERMINAL STRIP (POWER SUPPLY)
C1	CAPACITOR	Q1RP	PHASE REVERSAL DETECT CIRCUIT	X1M	TERMINAL STRIP (CONTROL) (A1P)
DS1	DIP SWITCH	R1	RESISTOR (CURRENT LIMITING)	X1M	TERMINAL STRIP (ABC I/P) (A3P)
E1HC~3HC	CRANKCASE HEATER	R2	RESISTOR (CURRENT SENSOR) (A5P)	Y1E	ELECTRONIC EXPANSION VALVE (MAIN)
F1U	FUSE (16A, DC450V) (A2P, A5P)	R112	RESISTOR (CURRENT SENSOR) (A2P)	Y2E	ELECTRONIC EXPANSION VALVE (SUBCOOL)
F1U,F2U	FUSE (T, 3.15A, 250V) (A1P)	R502	RESISTOR (CURRENT SENSOR) (A2P)	Y1S	SOLENOID VALVE (HOT GAS)
H1P~8P	PILOTLAMP /SERVICE MONITOR-ORANGE) [H2P] PREPARE, TEST ---------- FLICKERING MALFUNCTION DETECTION --- LIGHT UP	R1T	THERMISTOR (AIR) (A1P)	Y2S	SOLENOID VALVE (OIL)
		R1T	THERMISTOR (FIN) (A2P)	Y3S	SOLENOID VALVE (4 WAY VALVE)
		R2T	THERMISTOR (SUCTION)	Z1C~7C	NOISE FILTER (FERRITE CORE)
HAP	PILOTLAMP (SERVICE MONITOR-GREEN)	R31T~33T	THERMISTOR (M1C~3C DISCHARGE)	Z1F	NOISE FILTER (WITH SURGE ABSORBER)
K1M,K2M	MAGNETIC CONTACTOR (M1C) (A2P)	R4T	THERMISTOR (HEAT EXC. DEICER)		
K2M,K3M	MAGNETIC CONTACTOR (M2C, M3C)	R5T	THERMISTOR (HEAT EXC. OUTLET)		
K1R,K2R	MAGNETIC RELAY (K2M, K3M)	R6T	THERMISTOR (LIQ. PIPE)		
K3R	MAGNETIC RELAY (Y1S)	R7T	THERMISTOR (ACCUMULATOR)		
K4R	MAGNETIC RELAY (Y2S)	S1NPH	PRESSURE SENSOR (HIGH)	COOL/HEAT SELECTOR	
K5R	MAGNETIC RELAY (Y3S)	S1NPL	PRESSURE SENSOR (LOW)	S1S	SELECTOR SWITCH (FAN/COOL · HEAT)
K7R	MAGNETIC RELAY (E1HC)	S1PH~3PH	PRESSURE SWITCH (HIGH)	S2S	SELECTOR SWITCH (COOL/HEAT)

3D060632B


6. Field Wiring

RXYQ5PA, 8PA, 10PA, 12PA, 14PA, 16PA, 18PAY1
RXYQ5PA, 8PA, 10PA, 12PA, 14PA, 16PA, 18PAYL




14

RXYQ5P, 8P, 10P, 12P, 14P, 16P, 18PTL




RXYQ20PA, 22PA, 24PA, 26PA, 28PA, 30PA, 32PA, 34PA, 36PAY1
RXYQ20PA, 22PA, 24PA, 26PA, 28PA, 30PA, 32PA, 34PA, 36PAYL




Notes:
1) All wiring, components and materials to be procured on the site must comply with the applicable local and national codes.
2) Use copper conductors only.
3) As for details, see wiring diagram.
4) Install circuit breaker for safety.
5) All field wiring and components must be provided by licensed electrician.
6) Unit shall be grounded in compliance with the applicable local and national codes.
7) Wiring shown are general points-of-connection guides only and are not intended for or to include all details for a specific installation.
8) Be sure to install the switch and the fuse to the power line of each equipment.
9) Install the main switch that can interrupt all the power sources in an integrated manner because this system consists of the equipment utilizing the multiple power sources.
10) The capacity of Unit1 must be larger than UNIT2 when the power source is connected in series between the units.
11) If there exists the possibility of reversed phase, lose phase, momentary blackout or the power goes on and off while the product is operating, attach a reversed phase protection circuit locally. Running the product in reversed phase may break the compressor and other parts.

14

RXYQ20P, 22P, 24P, 26P, 28P, 30P, 32P, 34P, 36PTL




RXYQ38PA, 40PA, 42PA, 44PA, 46PA, 48PA, 50PA, 52PA, 54PAY1
RXYQ38PA, 40PA, 42PA, 44PA, 46PA, 48PA, 50PA, 52PA, 54PAYL



Notes
1) All wiring, components and materials to be procured on the site must comply with the applicable local and national codes.
2) Use copper conductors only.
3) As for details, see wiring diagram.
4) Install circuit breaker for safety.
5) All field wiring and components must be provided by licensed electrician.
6) Unit shall be grounded in compliance with the applicable local and national codes.
7) Wiring shown are general points-of-connection guides only and are not intended for or to include all details for a specific installation.
8) Be sure to install the switch and the fuse to the power line of each equipment.
9) Install the main switch that can interrupt all the power sources in an integrated manner because this system consists of the equipment utilizing the multiple power sources.
10) The capacity of Unit1 must be larger than UNIT2 when the power source is connected in series between the units.
11) If there exists the possibility of reversed phase, lose phase, momentary blackout or the power goes on and off while the product is operating, attach a reversed phase protection circuit locally.
Running the product in reversed phase may break the compressor and other parts.

RXYQ38P, 40P, 42P, 44P, 46P, 48P, 50P, 52P, 54PTL




7. Electric Characteristics

7.1 50Hz 380-415V (RXYQ-PAY1)

RXYQ5, 8, 10, 12, 14, 16, 18PAY1

Model Name	Units			Power supply			Comp.		OFM	
	Hz	Volts	Min.	Max.	MCA	TOCA	MFA	MSC	RLA	KW	FLA
RX(Y)Q5PY1 RXYQ5PAY1 RXYQ5PAY6 RXQ5PAY1	50	380	342	456	11.9	15.6	15	—	6.1	0.35	0.4
		400						—	5.8		
		415						—	5.6		
RX(Y)Q8PY1 RZYQ7,8PY1 RQ200KY1 RXYQ8PAY1 RXYQ8PAY6 RXQ8PAY1(S)	50	380	342	456	18.5	16.5	25	—	8.6	0.75	0.7
		400						—	8.2		
		415						—	7.9		
RX(Y)Q10PY1 RZYQ10PY1 RXYQ10PAY1 RXYQ10PAY6 RXQ10PAY1(S)	50	380	342	456	21.6	31.5	25	78	4.7+7.2	0.75	0.9
		400						74	4.5+6.8		
		415						72	4.3+6.6		
RX(Y)Q12PY1 RQ250KY1 RXYQ12PAY1 RXYQ12PAY6 RXQ12PAY1(S)	50	380	342	456	22.7	31.5	25	79	6.5+7.0	0.35X2	0.6X2
		400						75	6.2+6.7		
		415						72	6.0+6.4		
RX(Y)Q14PY1 RXYQ14PAY1 RXYQ14PAY6 RXQ14PAY1(S)	50	380	342	456	31.5	46.4	35	89	3.6+7.9×2	0.35X2	0.6X2
		400						84	3.4+7.5×2		
		415						81	3.3+7.3×2		
RX(Y)Q16PY1 RXYQ16PAY1 RXYQ16PAY6 RXQ16PAY1(S)	50	380	342	456	31.5	46.4	35	90	6.4+8.0×2	0.35X2	0.6X2
		400						85	6.1+7.6×2		
		415						82	5.9+7.3×2		
RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	32.5	48.3	40	90	9.4+8.3×2	0.75X2	0.7X2
		400						85	9.0+7.8×2		
		415						82	8.6+7.6×2		

Symbols:
MCA :Min. Circuit Amps. (A)
TOCA :Total Over-current Amps. (A)
MFA :Max. Fuse Amps. (A)
MSC :Max. Starting current
RLA :Rated Load Amps. (A)
OFM :Outdoor Fan Motor
FLA :Full Load Amps. (A)
kW :Rated Motor Output(kW)



The relationship between the starting time and the starting current.


Notes:
1. RLA is based on the following conditions.
Indoor temp. 27°C DB/19.0°C WB
Outdoor temp. 35°C DB
2. TOCA means the total value of each OC set.
3. MSC means the Max. current during the starting of compressor.
4. Voltage range
Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
5. Maximum allowable voltage variation between phases is 2%.
6. Select wire size based on the larger value of MCA or TOCA.
7. MFA is used to select the circuit breaker and the ground fault circuit interrupter (earth leakage circuit breaker).

3D052399G

14

Model Name			Units			Power supply			Comp.		OFM	
Combination Unit	Independent Unit		Hz	Volts	Min.	Max.	MCA	TOCA	MFA	MSC	RLA	KW	FLA
RX(Y)Q20PY1 RXYQ20PAY1 RXYQ20PAY6 RXQ20PAY1(S)	RX(Y)Q8PY1 RXYQ8PAY1 RXYQ8PAY6 RXQ8PAY1(S)	RX(Y)Q12PY1 RXYQ12PAY1 RXYQ12PAY6 RXQ12PAY1(S)	50	380	342	456	41.2	48.0	50	83	8.6+6.5+7.0	0.75 +0.35X2	0.7 +0.6X2
				400						79	8.2+6.2+6.7		
				415						76	7.9+6.0+6.4		
RX(Y)Q22PY1 RXYQ22PAY1 RXYQ22PAY6 RXQ22PAY1(S)	RX(Y)Q10PY1 RXYQ10PAY1 RXYQ10PAY6 RXQ10PAY1(S)	RX(Y)Q12PY1 RXYQ12PAY1 RXYQ12PAY6 RXQ12PAY1(S)	50	380	342	456	44.3	63.0	50	92	4.7+7.2+6.5+7.0	0.75 +0.35X2	0.9 +0.6X2
				400						88	4.5+6.8+6.2+6.7		
				415						84	4.3+6.6+6.0+6.4		
RX(Y)Q24PY1 RXYQ24PAY1 RXYQ24PAY6 RXQ24PAY1(S)	RX(Y)Q8PY1 RXYQ8PAY1 RXYQ8PAY6 RXQ8PAY1(S)	RX(Y)Q16PY1 RXYQ16PAY1 RXYQ16PAY6 RXQ16PAY1(S)	50	380	342	456	50.0	63.0	60	93	8.6+6.4+8.0X2	0.75 +0.35X2	0.7 +0.6X2
				400						89	8.2+6.1+7.6X2		
				415						86	7.9+5.9+7.3X2		
RX(Y)Q26PY1 RXYQ26PAY1 RXYQ26PAY6 RXQ26PAY1(S)	RX(Y)Q8PY1 RXYQ8PAY1 RXYQ8PAY6 RXQ8PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	51.0	64.8	60	93	8.6+9.4+8.3X2	0.75 +0.75X2	0.7 +0.7X2
				400						89	8.2+9.0+7.8X2		
				415						86	7.9+8.6+7.6X2		
RX(Y)Q28PY1 RXYQ28PAY1 RXYQ28PAY6 RXQ28PAY1(S)	RX(Y)Q10PY1 RXYQ10PAY1 RXYQ10PAY6 RXQ10PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	54.1	79.8	60	103	4.7+7.2+9.4+8.3X2	0.75 +0.75X2	0.9 +0.7X2
				400						98	4.5+6.8+9.0+7.8X2		
				415						94	4.3+6.6+8.6+7.6X2		
RX(Y)Q30PY1 RXYQ30PAY1 RXYQ30PAY6 RXQ30PAY1(S)	RX(Y)Q12PY1 RXYQ12PAY1 RXYQ12PAY6 RXQ12PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	55.2	79.8	70	103	6.5+7.0+9.4+8.3X2	0.35X2 +0.75X2	0.6X2 +0.7X2
				400						98	6.2+6.7+9.0+7.8X2		
				415						95	6.0+6.4+8.6+7.6X2		
RX(Y)Q32PY1 RXYQ32PAY1 RXYQ32PAY6 RXQ32PAY1(S)	RX(Y)Q16PY1 RXYQ16PAY1 RXYQ16PAY6 RXQ16PAY1(S)	RX(Y)Q16PY1 RXYQ16PAY1 RXYQ16PAY6 RXQ16PAY1(S)	50	380	342	456	63.0	92.8	70	115	(6.4X8.0X2)X2	(0.35X2)X2	(0.6X2)X2
				400						109	(6.1X7.6X2)X2		
				415						105	(5.9X7.3X2)X2		

Symbols:
MCA :Min. Circuit Amps. (A)
TOCA :Total Over-current Amps. (A)
MFA :Max. Fuse Amps. (A)
MSC :Max. Starting current
RLA :Rated Load Amps. (A)
OFM :Outdoor Fan Motor
FLA :Full Load Amps. (A)
kW :Rated Motor Output(kW)



The relationship between the starting time and the starting current.


Notes:
1. RLA is based on the following conditions.
Indoor temp. 27℃ DB/19.0℃ WB
Outdoor temp. 35℃ DB
2. TOCA means the total value of each OC set.
3. MSC means the Max. current during the starting of compressor.
4. Voltage range
Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
5. Maximum allowable voltage variation between phases is 2%.
6. Select wire size based on the larger value of MCA or TOCA.
7. MFA is used to select the circuit breaker and the ground fault circuit interrupter (earth leakage circuit breaker).

3D052400E

RXYQ34, 36, 38, 40, 42, 44, 46PAY1

Model Name				Units			Power supply			Comp.		OFM	
Combination Unit	Independent Unit			Hz	Volts	Min.	Max.	MCA	TOCA	MFA	MSC	RLA	KW	FLA
RX(Y)Q34PY1 RXYQ34PAY1 RXYQ34PAY6 RXQ34PAY1(S)	RX(Y)Q16PY1 RXYQ16PAY1 RXYQ16PAY6 RXQ16PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)		50	380	342	456	64.0	94.7	80	115	6.4+8.0X2+9.4+8.3X2	0.35x2 +0.75x2	0.6x2 +0.7x2
					400						109	6.1+7.6X2+9.0+7.8X2		
					415						105	5.9+7.3X2+8.6+7.6X2		
RX(Y)Q36PY1 RXYQ36PAY1 RXYQ36PAY6 RXQ36PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)		50	380	342	456	65.0	96.6	80	115	(9.4+8.3X2)X2	(0.75x2)x2	(0.7x2)x2
					400						109	(9.0+7.8X2)X2		
					415						105	(8.6+7.6X2)X2		
RX(Y)Q38PY1 RXYQ38PAY1 RXYQ38PAY6 RXQ38PAY1(S)	RX(Y)Q8PY1 RXYQ8PAY1 RXYQ8PAY6 RXQ8PAY1(S)	RX(Y)Q12PY1 RXYQ12PAY1 RXYQ12PAY6 RXQ12PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	73.7	96.3	90	107	8.6+6.5+7.0+9.4+8.3X2	0.75 +0.35x2 +0.75x2	0.7 +0.6x2 +0.7x2
					400						102	8.2+6.2+6.7+9.0+7.8X2		
					415						98	7.9+6.0+6.4+8.6+7.6X2		
RX(Y)Q40PY1 RXYQ40PAY1 RXYQ40PAY6 RXQ40PAY1(S)	RX(Y)Q8PY1 RXYQ8PAY1 RXYQ8PAY6 RXQ8PAY1(S)	RX(Y)Q16PY1 RXYQ16PAY1 RXYQ16PAY6 RXQ16PAY1(S)	RX(Y)Q16PY1 RXYQ16PAY1 RXYQ16PAY6 RXQ16PAY1(S)	50	380	342	456	81.5	109.4	90	119	8.6+(6.4+8.0X2)X2	0.75 +(0.35x2)x2	0.7 +(0.6x2)x2
					400						113	8.2+(6.1+7.6X2)X2		
					415						109	7.9+(5.9+7.3X2)X2		
RX(Y)Q42PY1 RXYQ42PAY1 RXYQ42PAY6 RXQ42PAY1(S)	RX(Y)Q8PY1 RXYQ8PAY1 RXYQ8PAY6 RXQ8PAY1(S)	RX(Y)Q16PY1 RXYQ16PAY1 RXYQ16PAY6 RXQ16PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	82.5	111.2	100	119	8.6+6.4+8.0X2+9.4+8.3X2	0.75 +0.35x2 +0.75x2	0.7 +0.6x2 +0.7x2
					400						113	8.2+6.1+7.6X2+9.0+7.8X2		
					415						109	7.9+5.9+7.3X2+8.6+7.6X2		
RX(Y)Q44PY1 RXYQ44PAY1 RXYQ44PAY6 RXQ44PAY1(S)	RX(Y)Q8PY1 RXYQ8PAY1 RXYQ8PAY6 RXQ8PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	83.5	113.1	100	119	8.6+(9.4+8.3X2)X2	0.75 +(0.75x2)x2	0.7 +(0.7x2)x2
					400						113	8.2+(9.0+7.8X2)X2		
					415						109	7.9+(8.6+7.6X2)X2		
RX(Y)Q46PY1 RXYQ46PAY1 RXYQ46PAY6 RXQ46PAY1(S)	RX(Y)Q10PY1 RXYQ10PAY1 RXYQ10PAY6 RXQ10PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	86.6	128.1	100	128	4.7+7.2+(9.4+8.3X2)X2	0.75 +(0.75x2)x2	0.9 +(0.7x2)x2
					400						122	4.5+6.8+(9.0+7.8X2)X2		
					415						118	4.3+6.6+(8.6+7.6X2)X2		

Symbols:
MCA :Min. Circuit Amps. (A)
TOCA :Total Over-current Amps. (A)
MFA :Max. Fuse Amps. (A)
MSC :Max. Starting current
RLA :Rated Load Amps. (A)
OFM :Outdoor Fan Motor
FLA :Full Load Amps. (A)
kW :Rated Motor Output(kW)




The relationship between the starting time and the starting current.

Notes:
1. RLA is based on the following conditions.
   Indoor temp. 27°C DB/19.0°C WB
   Outdoor temp. 35°C DB
2. TOCA means the total value of each OC set.
3. MSC means the Max. current during the starting of compressor.
4. Voltage range
   Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
5. Maximum allowable voltage variation between phases is 2%.
6. Select wire size based on the larger value of MCA or TOCA.
7. MFA is used to select the circuit breaker and the ground fault circuit interrupter (earth leakage circuit breaker).

3D052401E

Model Name				Units				Power supply			Comp.		OFM	
Combination Unit	Independent Unit			Hz	Volts	Min.	Max.	MCA	TOCA	MFA	MSC	RLA	KW	FLA
RX(Y)Q48PY1 RXYQ48PAY1 RXYQ48PAY6 RXQ48PAY1(S)	RX(Y)Q12PY1 RXYQ12PAY1 RXYQ12PAY6 RXQ12PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	87.7	128.0	100	129	6.5+7.0+(9.4+8.3X2)X2	0.35x2 +(0.75x2)x2	0.6x2 +(0.7x2)x2
					400						122	6.2+6.7+(9.0+7.8X2)X2		
					415						118	6.0+6.4+(8.6+7.6X2)X2		
RX(Y)Q50PY1 RXYQ50PAY1 RXYQ50PAY6 RXQ50PAY1(S)	RX(Y)Q14PY1 RXYQ14PAY1 RXYQ14PAY6 RXQ14PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	96.5	143.0	110	139	3.6+7.9X2+(9.4+8.3X2)X2	0.35x2 +(0.75x2)x2	0.6x2 +(0.7x2)x2
					400						132	3.4+7.5X2+(9.0+7.8X2)X2		
					415						127	3.3+7.3X2+(8.6+7.6X2)X2		
RX(Y)Q52PY1 RXYQ52PAY1 RXYQ52PAY6 RXQ52PAY1(S)	RX(Y)Q16PY1 RXYQ16PAY1 RXYQ16PAY6 RXQ16PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	96.5	143.0	110	141	6.4+8.0X2+(9.4+8.3x2)x2	0.35x2 +(0.75x2)x2	0.6x2 +(0.7x2)x2
					400						134	6.1+7.6X2+(9.0+7.8x2)x2		
					415						129	5.9+7.3X2+(8.6+7.6x2)x2		
RX(Y)Q54PY1 RXYQ54PAY1 RXYQ54PAY6 RXQ54PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	RX(Y)Q18PY1 RXYQ18PAY1 RXYQ18PAY6 RXQ18PAY1(S)	50	380	342	456	97.5	144.8	110	141	(9.4+8.3X2)X3	(0.75x2)x3	(0.7x2)x3
					400						134	(9.0+7.8X2)X3		
					415						129	(8.6+7.6X2)X3		

Symbols:
MCA :Min. Circuit Amps. (A)
TOCA :Total Over-current Amps. (A)
MFA :Max. Fuse Amps. (A)
MSC :Max. Starting current
RLA :Rated Load Amps. (A)
OFM :Outdoor Fan Motor
FLA :Full Load Amps. (A)
kW :Rated Motor Output(kW)



The relationship between the starting time and the starting current.

Notes:
1. RLA is based on the following conditions.
Indoor temp. 27℃ DB/19.0℃ WB
Outdoor temp. 35℃ DB
2. TOCA means the total value of each OC set.
3. MSC means the Max. current during the starting of compressor.
4. Voltage range
Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
5. Maximum allowable voltage variation between phases is 2%.
6. Select wire size based on the larger value of MCA or TOCA.
7. MFA is used to select the circuit breaker and the ground fault circuit interrupter (earth leakage circuit breaker).

3D052402D


7.2 60Hz 380V (RXYQ-PAYL)

RXYQ5, 8, 10, 12, 14, 16, 18PAYL

Model Name	Units			Power supply			Comp.		OFM	
	Hz	Volts	Min.	Max.	MCA	TOCA	MFA	MSC	RLA	KW	FLA
RXYQ5PYL(E) RXYQ5PAYL(E) RXYQ5PAYLD	60	380	342	418	11.9	15.6	15	—	6.1	0.35	0.4
RXYQ8PYL(E) RXYQ8PAYL(E) RXYQ8PAYLD	60	380	342	418	18.5	16.5	25	—	8.6	0.75	0.7
RXYQ10PYL(E) RXYQ10PAYL(E) RXYQ10PAYLD	60	380	342	418	22.8	31.5	30	78	3.6+8.3	0.75	0.9
RXYQ12PYL(E) RXYQ12PAYL(E) RXYQ12PAYLD	60	380	342	418	23.9	31.5	30	79	5.4+8.9	0.35×2	0.6×2
RXYQ14PYL(E) RXYQ14PAYL(E) RXYQ14PAYLD	60	380	342	418	33.9	46.4	40	89	1.6+8.9×2	0.35×2	0.6×2
RXYQ16PYL(E) RXYQ16PAYL(E) RXYQ16PAYLD	60	380	342	418	33.9	46.4	40	90	4.4+9.0×2	0.35×2	0.6×2
RXYQ18PYL(E) RXYQ18PAYL(E) RXYQ18PAYLD	60	380	342	418	34.9	48.3	40	90	7.4+9.3×2	0.75×2	0.7×2

Symbols:
MCA :Min. Circuit Amps. (A)
TOCA :Total Over-current Amps. (A)
MFA :Max. Fuse Amps. (A)
MSC :Max. Starting current
RLA :Rated Load Amps. (A)
OFM :Outdoor Fan Motor
FLA :Full Load Amps. (A)
KW :Rated Motor Output(kW)

(Inverter comp.+ Non-inverter comp.)



The relationship between the starting time and the starting current.

Notes:
1. RLA is based on the following conditions.
Indoor temp. 27°C DB/19.0°C WB
Outdoor temp. 35°C DB
2. TOCA means the total value of each OC set.
3. MSC means the Max. current during the starting of compressor.
4. Voltage range
Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
5. Maximum allowable voltage variation between phases is 2%.
6. Select wire size based on the larger value of MCA or TOCA.
7. MFA is used to select the circuit breaker and the ground fault circuit interrupter (earth leakage circuit breaker).

3D055706A

14

RXYQ20, 22, 24, 26, 28, 30, 32, 34, 36, 38, 40, 42, 44, 46, 48, 50, 52, 54PAYL

Model Name		Units				Power supply			Comp.		OFM	
Combination unit	Independent unit	Hz	Volts	Min.	Max.	MCA	TOCA	MFA	MSC	RLA	KW	FLA
RXYQ20PYL(E) RXYQ20PAYL(E)	RXYQ12PYL(E) RXYQ12PAYL(E)	60	380	342	418	42.4	48.0	50	83	8.6+5.4+8.9	0.75+0.35×2	0.7+0.6×2
RXYQ22PYL(E) RXYQ22PAYL(E)	RXYQ10PYL(E) RXYQ12PAYL(E)	60	380	342	418	46.7	63.0	60	92	3.6+8.3+5.4+8.9	0.75+0.35×2	0.9+0.6×2
RXYQ24PYL(E) RXYQ24PAYL(E)	RXYQ8PYL(E) RXYQ16PAYL(E)	60	380	342	418	52.4	62.9	60	93	8.6+4.4+9.0×2	0.75+0.35×2	0.7+0.6×2
RXYQ26PYL(E) RXYQ26PAYL(E)	RXYQ8PYL(E) RXYQ18PAYL(E)	60	380	342	418	53.4	64.8	60	93	8.6+7.4+9.3×2	0.75+0.75×2	0.7+0.7×2
RXYQ28PYL(E) RXYQ28PAYL(E)	RXYQ10PYL(E) RXYQ18PAYL(E)	60	380	342	418	57.7	79.8	70	103	3.6+8.3+7.4+9.3×2	0.75+0.75×2	0.9+0.7×2
RXYQ30PYL(E) RXYQ30PAYL(E)	RXYQ12PYL(E) RXYQ18PAYL(E)	60	380	342	418	58.8	79.8	70	103	5.4+8.9+7.4+9.3×2	0.35×2+0.75×2	0.6×2+0.7×2
RXYQ32PYL(E) RXYQ32PAYL(E)	RXYQ16PYL(E) RXYQ16PAYL(E)	60	380	342	418	67.8	92.8	80	115	(4.4+9.0×2)×2	(0.35×2)×2	(0.6×2)×2
RXYQ34PYL(E) RXYQ34PAYL(E)	RXYQ16PYL(E) RXYQ18PAYL(E)	60	380	342	418	68.8	94.7	80	115	4.4+9.0×2+7.4+9.3×2	0.35×2+0.75×2	0.6×2+0.7×2
RXYQ36PYL(E) RXYQ36PAYL(E)	RXYQ18PYL(E) RXYQ18PAYL(E)	60	380	342	418	69.8	96.6	80	115	(7.4+9.3×2)×2	(0.75×2)×2	(0.7×2)×2
RXYQ38PYL(E) RXYQ38PAYL(E)	RXYQ8PYL(E) RXYQ8PAYL(E)	RXYQ12PYL(E) RXYQ12PAYL(E)	60	380	342	418	77.3	96.3	90	107	8.6+5.4+8.9+7.4+9.3×2	0.75+0.35×2+0.75×2	0.7+0.6×2+0.7×2
RXYQ40PYL(E) RXYQ40PAYL(E)	RXYQ8PYL(E) RXYQ8PAYL(E)	RXYQ16PYL(E) RXYQ16PAYL(E)	60	380	342	418	86.3	109.3	100	119	8.6+(4.4+9.0×2)×2	0.75+(0.35×2)×2	0.7+(0.6×2)×2
RXYQ42PYL(E) RXYQ42PAYL(E)	RXYQ8PYL(E) RXYQ8PAYL(E)	RXYQ16PYL(E) RXYQ16PAYL(E)	60	380	342	418	87.3	111.2	100	119	8.6+4.4+9.0×2+7.4+9.3×2	0.75+0.35×2+0.75×2	0.7+0.6×2+0.7×2
RXYQ44PYL(E) RXYQ44PAYL(E)	RXYQ8PYL(E) RXYQ8PAYL(E)	RXYQ18PYL(E) RXYQ18PAYL(E)	60	380	342	418	88.3	113.1	100	119	8.6+(7.4+9.3×2)×2	0.75+(0.75×2)×2	0.7+(0.7×2)×2
RXYQ46PYL(E) RXYQ46PAYL(E)	RXYQ10PYL(E) RXYQ10PAYL(E)	RXYQ18PYL(E) RXYQ18PAYL(E)	60	380	342	418	92.6	128.1	110	128	3.6+8.3+(7.4+9.3×2)×2	0.75+(0.75×2)×2	0.9+(0.7×2)×2
RXYQ48PYL(E) RXYQ48PAYL(E)	RXYQ12PYL(E) RXYQ12PAYL(E)	RXYQ18PYL(E) RXYQ18PAYL(E)	60	380	342	418	93.7	128.1	110	129	5.4+8.9+(7.4+9.3×2)×2	0.35×2+(0.75×2)×2	0.6×2+(0.7×2)×2
RXYQ50PYL(E) RXYQ50PAYL(E)	RXYQ14PYL(E) RXYQ14PAYL(E)	RXYQ18PYL(E) RXYQ18PAYL(E)	60	380	342	418	103.7	143.0	120	139	1.6+8.9×2+(7.4+9.3×2)×2	0.35×2+(0.75×2)×2	0.6×2+(0.7×2)×2
RXYQ52PYL(E) RXYQ52PAYL(E)	RXYQ16PYL(E) RXYQ16PAYL(E)	RXYQ18PYL(E) RXYQ18PAYL(E)	60	380	342	418	103.7	143.0	120	141	4.4+9.0×2+(7.4+9.3×2)×2	0.35×2+(0.75×2)×2	0.6×2+(0.7×2)×2
RXYQ54PYL(E) RXYQ54PAYL(E)	RXYQ18PYL(E) RXYQ18PAYL(E)	RXYQ18PYL(E) RXYQ18PAYL(E)	60	380	342	418	104.7	144.9	120	141	(7.4+9.3×2)×3	(0.75×2)×3	(0.7×2)×3

Symbols:
MCA :Min. Circuit Amps. (A)
TOCA :Total Over-current Amps. (A)
MFA :Max. Fuse Amps. (A)
MSC :Max. Starting current
RLA :Rated Load Amps. (A)
OFM :Outdoor Fan Motor
FLA :Full Load Amps. (A)
KW :Rated Motor Output(kW)

The relationship between the starting time and the starting current.

Notes:
1. RLA is based on the following conditions.
   Indoor temp. 27°C DB/19.0°C WB
   Outdoor temp. 35°C DB
2. TOCA means the total value of each OC set.
3. MSC means the Max. current during the starting of compressor.
4. Voltage range
   Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
5. Maximum allowable voltage variation between phases is 2%.
6. Select wire size based on the larger value of MCA or TOCA.
7. MFA is used to select the circuit breaker and the ground fault circuit interrupter (earth leakage circuit breaker).

3D056132A

7.3 60Hz 220V (RXYQ-PTL)

RXYQ5, 8, 10, 12, 14, 16, 18PTL

3D060861

Model Name	Units			Power supply			Comp.		OFM	
	Hz	Volts	Min.	Max.	MCA	TOCA	MFA	MSC	RLA	KW	FLA
RXYQ5PTL(E)	60	220	198	242	20.6	27.9	25	—	10.5	0.35	0.7
RXYQ8PTL(E)	60	220	198	242	32.0	29.5	40	—	14.9	0.75	1.2
RXYQ10PTL(E)	60	220	198	242	39.4	54.5	45	135	6.2+14.3	0.75	1.6
RXYQ12PTL(E)	60	220	198	242	41.3	54.5	50	136	9.3+15.4	0.35×2	1.0×2
RXYQ14PTL(E)	60	220	198	242	58.6	79.3	65	153	2.8+15.4×2	0.35×2	1.0×2
RXYQ16PTL(E)	60	220	198	242	58.6	79.3	65	155	7.6+15.5×2	0.35×2	1.0×2
RXYQ18PTL(E)	60	220	198	242	60.3	80.3	70	155	12.8+16.1×2	0.75×2	1.2×2

Symbols:
MCA :Min. Circuit Amps. (A)
TOCA :Total Over-current Amps. (A)
MFA :Max. Fuse Amps. (A)
MSC :Max. Starting current
RLA :Rated Load Amps. (A)
OFM :Outdoor Fan Motor
FLA :Full Load Amps. (A)
kW :Rated Motor Output(kW)


The relationship between the starting time and the starting current.

Notes:
1. RLA is based on the following conditions.
Indoor temp. 27°C DB/19.0°C WB
Outdoor temp. 35°C DB
2. TOCA means the total value of each OC set.
3. MSC means the Max. current during the starting of compressor.
4. Voltage range
Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
5. Maximum allowable voltage variation between phases is 2%.
6. Select wire size based on the larger value of MCA or TOCA.
7. MFA is used to select the circuit breaker and the ground fault circuit interrupter (earth leakage circuit breaker).

14

Model Name			Units				Power supply			Comp.		OFM	
Combination Unit	Independent Unit		Hz	Volts	Min.	Max.	MCA	TOCA	MFA	MSC	RLA	KW	FLA
RXYQ20PTL(E)	RXYQ8PTL(E)	RXYQ12PTL(E)	60	220	198	242	73.3	84.0	90	143	14.9+9.3+15.4	0.75 +0.35X2	1.2 +1.0×2
RXYQ22PTL(E)	RXYQ10PTL(E)	RXYQ12PTL(E)	60	220	198	242	80.7	109	90	159	6.2+14.3+9.3+15.4	0.75 +0.35X2	1.6 +1.0×2
RXYQ24PTL(E)	RXYQ8PTL(E)	RXYQ16PTL(E)	60	220	198	242	90.6	109	100	161	14.9+7.6+15.5×2	0.75 +0.35X2	1.2 +1.0×2
RXYQ26PTL(E)	RXYQ8PTL(E)	RXYQ18PTL(E)	60	220	198	242	92.3	110	110	161	14.9+12.8+16.1×2	0.75 +0.75X2	1.2 +1.2×2
RXYQ28PTL(E)	RXYQ10PTL(E)	RXYQ18PTL(E)	60	220	198	242	99.7	135	110	178	6.2+14.3+12.8+16.1×2	0.75 +0.75X2	1.6 +1.2×2
RXYQ30PTL(E)	RXYQ12PTL(E)	RXYQ18PTL(E)	60	220	198	242	102	135	125	179	9.3+15.4+12.8+16.1×2	0.35X2 +0.75X2	1.0×2 +1.2×2
RXYQ32PTL(E)	RXYQ16PTL(E)	RXYQ16PTL(E)	60	220	198	242	117	159	150	199	(7.6+15.5×2)×2	(0.35X2)X2	1.0×2 +1.0×2

Symbols:
MCA :Min. Circuit Amps. (A)
TOCA :Total Over-current Amps. (A)
MFA :Max. Fuse Amps. (A)
MSC :Max. Starting current
RLA :Rated Load Amps. (A)
OFM :Outdoor Fan Motor
FLA :Full Load Amps. (A)
kW :Rated Motor Output(kW)




The relationship between the starting time and the starting current.

Notes:
1. RLA is based on the following conditions.
Indoor temp. 27℃ DB/19.0℃ WB
Outdoor temp. 35℃ DB
2. TOCA means the total value of each OC set.
3. MSC means the Max. current during the starting of compressor.
4. Voltage range
Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
5. Maximum allowable voltage variation between phases is 2%.
6. Select wire size based on the larger value of MCA or TOCA.
7. MFA is used to select the circuit breaker and the ground fault circuit interrupter (earth leakage circuit breaker).

3D060863

Model Name				Units				Power supply			Comp.		OFM	
Combination Unit	Independent Unit			Hz	Volts	Min.	Max.	MCA	TOCA	MFA	MSC	RLA	KW	FLA
RXYQ34PTL(E)	RXYQ16PTL(E)	RXYQ18PTL(E)		60	220	198	242	119	160	150	199	7.6+15.5X2+12.8+16.1X2	0.35x2 +0.75x2	1.0x2 +1.2x2
RXYQ36PTL(E)	RXYQ18PTL(E)	RXYQ18PTL(E)		60	220	198	242	121	161	150	199	(12.8+16.1X2)X2	(0.75x2)x2	(1.2x2)x2
RXYQ38PTL(E)	RXYQ8PTL(E)	RXYQ12PTL(E)	RXYQ18PTL(E)	60	220	198	242	134	164	150	185	14.9+9.3+15.4+12.8+16.1X2	0.75 +0.35x2 +0.75x2	1.2 +1.0x2 +1.2x2
RXYQ40PTL(E)	RXYQ8PTL(E)	RXYQ16PTL(E)	RXYQ16PTL(E)	60	220	198	242	149	188	175	205	14.9+(7.6+15.5X2)X2	0.75 +(0.35x2)x2	1.2 +1.0x2 +1.0x2
RXYQ42PTL(E)	RXYQ8PTL(E)	RXYQ16PTL(E)	RXYQ18PTL(E)	60	220	198	242	151	189	175	205	14.9+7.6+15.5X2+12.8+16.1X2	0.75 +0.35x2 +0.75x2	1.2 +1.0x2 +1.2x2
RXYQ44PTL(E)	RXYQ8PTL(E)	RXYQ18PTL(E)	RXYQ18PTL(E)	60	220	198	242	153	190	175	205	14.9+(12.8+16.1X2)X2	0.75 +(0.75x2)x2	1.2 +1.2x2 +1.2x2
RXYQ46PTL(E)	RXYQ10PTL(E)	RXYQ18PTL(E)	RXYQ18PTL(E)	60	220	198	242	160	215	200	222	6.2+14.3+(12.8+16.1X2)X2	0.75 +(0.75x2)x2	1.6 +1.2x2 +1.2x2

Symbols:
MCA :Min. Circuit Amps. (A)
TOCA :Total Over-current Amps. (A)
MFA :Max. Fuse Amps. (A)
MSC :Max. Starting current
RLA :Rated Load Amps. (A)
OFM :Outdoor Fan Motor
FLA :Full Load Amps. (A)
kW :Rated Motor Output(kW)




The relationship between the starting time and the starting current.

Notes:
1. RLA is based on the following conditions.
Indoor temp. 27°C DB/19.0°C WB
Outdoor temp. 35°C DB
2. TOCA means the total value of each OC set.
3. MSC means the Max. current during the starting of compressor.
4. Voltage range
Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
5. Maximum allowable voltage variation between phases is 2%.
6. Select wire size based on the larger value of MCA or TOCA.
7. MFA is used to select the circuit breaker and the ground fault circuit interrupter (earth leakage circuit breaker).

3D060864

Model Name				Units				Power supply			Comp.		OFM	
Combination Unit	Independent Unit			Hz	Volts	Min.	Max.	MCA	TOCA	MFA	MSC	RLA	KW	FLA
RXYQ48PTL(E)	RXYQ12PTL(E)	RXYQ18PTL(E)	RXYQ18PTL(E)	60	220	198	242	162	215	200	223	9.3+15.4+(12.8+16.1X2)X2	0.35x2 +(0.75x2)x2	1.0x2 +1.2x2 +1.2x2
RXYQ50PTL(E)	RXYQ14PTL(E)	RXYQ18PTL(E)	RXYQ18PTL(E)	60	220	198	242	179	240	200	240	2.8+15.4X2+(12.8+16.1X2)X2	0.35x2 +(0.75x2)x2	1.0x2 +1.2x2 +1.2x2
RXYQ52PTL(E)	RXYQ16PTL(E)	RXYQ18PTL(E)	RXYQ18PTL(E)	60	220	198	242	179	240	200	243	7.6+15.5X2+(12.8+16.1X2)X2	0.35x2 +(0.75x2)x2	1.0x2 +1.2x2 +1.2x2
RXYQ54PTL(E)	RXYQ18PTL(E)	RXYQ18PTL(E)	RXYQ18PTL(E)	60	220	198	242	181	241	200	243	(12.8+16.1X2)X3	(0.75x2)x3	1.2x2 +1.2x2 +1.2x2

Symbols:
MCA :Min. Circuit Amps. (A)
TOCA :Total Over-current Amps. (A)
MFA :Max. Fuse Amps. (A)
MSC :Max. Starting current
RLA :Rated Load Amps. (A)
OFM :Outdoor Fan Motor
FLA :Full Load Amps. (A)
kW :Rated Motor Output(kW)



The relationship between the starting time and the starting current.

Notes:
1. RLA is based on the following conditions.
Indoor temp. 27℃ DB/19.0℃ WB
Outdoor temp. 35℃ DB
2. TOCA means the total value of each OC set.
3. MSC means the Max. current during the starting of compressor.
4. Voltage range
Units are suitable for use on electrical systems where voltage supplied to unit terminal is not below or above listed range limits.
5. Maximum allowable voltage variation between phases is 2%.
6. Select wire size based on the larger value of MCA or TOCA.
7. MFA is used to select the circuit breaker and the ground fault circuit interrupter (earth leakage circuit breaker).

3D060865

8. Capacity Tables (Heat Pump)

8.1 Cooling Capacity (RXYQ-P(A))

RXYQ5PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (162.5)	10	12.3	1.62	14.6	1.98	17.0	2.36	17.6	2.41	17.9	2.36	18.3	2.26	18.7	2.16
	12	12.3	1.65	14.6	2.02	17.0	2.40	17.4	2.40	17.6	2.35	18.1	2.25	18.5	2.21
	14	12.3	1.68	14.6	2.06	17.0	2.43	17.2	2.38	17.4	2.33	17.8	2.32	18.3	2.34
	16	12.3	1.71	14.6	2.10	16.7	2.42	16.9	2.41	17.2	2.42	17.6	2.44	18.1	2.46
	18	12.3	1.75	14.6	2.14	16.5	2.52	16.7	2.53	16.9	2.54	17.4	2.57	17.8	2.59
	20	12.3	1.78	14.6	2.28	16.3	2.64	16.5	2.65	16.7	2.66	17.2	2.69	17.6	2.72
	21	12.3	1.83	14.6	2.36	16.2	2.70	16.4	2.71	16.6	2.73	17.0	2.75	17.5	2.78
	23	12.3	1.96	14.6	2.53	15.9	2.82	16.2	2.84	16.4	2.85	16.8	2.88	17.3	2.91
	25	12.3	2.10	14.6	2.71	15.7	2.95	15.9	2.96	16.1	2.98	16.6	3.01	17.0	3.04
	27	12.3	2.24	14.6	2.90	15.5	3.07	15.7	3.09	15.9	3.10	16.4	3.14	16.8	3.17
	29	12.3	2.39	14.6	3.10	15.2	3.19	15.5	3.21	15.7	3.23	16.1	3.26	16.6	3.30
	31	12.3	2.55	14.6	3.28	15.0	3.32	15.2	3.34	15.5	3.36	15.9	3.39	16.3	3.43
	33	12.3	2.72	14.3	3.41	14.8	3.45	15.0	3.46	15.2	3.48	15.7	3.52	16.1	3.56
	35	12.3	2.90	14.1	3.53	14.6	3.57	14.8	3.59	15.0	3.61	15.5	3.65	15.9	3.69
	37	12.3	3.08	13.9	3.66	14.3	3.70	14.6	3.72	14.8	3.74	15.2	3.78	15.7	3.83
	39	12.3	3.28	13.7	3.78	14.1	3.83	14.3	3.85	14.6	3.87	15.0	3.92	15.4	3.96
120 (150)	10	11.3	1.48	13.5	1.81	15.7	2.15	16.8	2.33	17.6	2.42	18.0	2.33	18.4	2.24
	12	11.3	1.51	13.5	1.84	15.7	2.19	16.8	2.37	17.3	2.41	17.8	2.32	18.2	2.22
	14	11.3	1.54	13.5	1.88	15.7	2.23	16.8	2.41	17.1	2.40	17.5	2.30	17.9	2.32
	16	11.3	1.57	13.5	1.91	15.7	2.28	16.7	2.43	16.9	2.40	17.3	2.42	17.7	2.44
	18	11.3	1.60	13.5	1.95	15.7	2.36	16.5	2.51	16.7	2.52	17.1	2.55	17.5	2.57
	20	11.3	1.63	13.5	2.03	15.7	2.53	16.2	2.64	16.4	2.65	16.8	2.67	17.3	2.70
	21	11.3	1.64	13.5	2.10	15.7	2.62	16.1	2.70	16.3	2.71	16.7	2.73	17.1	2.76
	23	11.3	1.75	13.5	2.25	15.7	2.81	15.9	2.82	16.1	2.83	16.5	2.86	16.9	2.89
	25	11.3	1.88	13.5	2.41	15.5	2.93	15.7	2.94	15.9	2.96	16.3	2.99	16.7	3.01
	27	11.3	2.00	13.5	2.58	15.2	3.05	15.4	3.07	15.6	3.08	16.0	3.11	16.5	3.14
	29	11.3	2.14	13.5	2.75	15.0	3.18	15.2	3.19	15.4	3.21	15.8	3.24	16.2	3.27
	31	11.3	2.28	13.5	2.94	14.8	3.30	15.0	3.32	15.2	3.33	15.6	3.37	16.0	3.40
	33	11.3	2.42	13.5	3.13	14.5	3.42	14.8	3.44	15.0	3.46	15.4	3.49	15.8	3.53
	35	11.3	2.58	13.5	3.34	14.3	3.55	14.5	3.57	14.7	3.59	15.1	3.62	15.5	3.66
	37	11.3	2.75	13.5	3.56	14.1	3.67	14.3	3.69	14.5	3.71	14.9	3.75	15.3	3.79
	39	11.3	2.92	13.5	3.76	13.9	3.80	14.1	3.82	14.3	3.84	14.7	3.88	15.1	3.93
110 (137.5)	10	10.4	1.34	12.4	1.64	14.4	1.94	15.4	2.10	16.4	2.26	17.7	2.40	18.0	2.32
	12	10.4	1.37	12.4	1.67	14.4	1.98	15.4	2.14	16.4	2.30	17.4	2.39	17.8	2.30
	14	10.4	1.39	12.4	1.70	14.4	2.02	15.4	2.18	16.4	2.35	17.2	2.38	17.6	2.30
	16	10.4	1.42	12.4	1.73	14.4	2.06	15.4	2.23	16.4	2.39	17.0	2.41	17.4	2.43
	18	10.4	1.45	12.4	1.77	14.4	2.10	15.4	2.29	16.4	2.51	16.8	2.53	17.1	2.55
	20	10.4	1.47	12.4	1.80	14.4	2.22	15.4	2.46	16.2	2.63	16.5	2.65	16.9	2.68
	21	10.4	1.49	12.4	1.86	14.4	2.30	15.4	2.55	16.0	2.69	16.4	2.72	16.8	2.74
	23	10.4	1.56	12.4	1.99	14.4	2.47	15.4	2.73	15.8	2.82	16.2	2.84	16.6	2.86
	25	10.4	1.67	12.4	2.13	14.4	2.64	15.4	2.93	15.6	2.94	16.0	2.96	16.3	2.99
	27	10.4	1.78	12.4	2.27	14.4	2.83	15.2	3.05	15.4	3.06	15.7	3.09	16.1	3.12
	29	10.4	1.89	12.4	2.42	14.4	3.02	14.9	3.17	15.1	3.19	15.5	3.21	15.9	3.24
	31	10.4	2.02	12.4	2.59	14.4	3.23	14.7	3.30	14.9	3.31	15.3	3.34	15.7	3.37
	33	10.4	2.15	12.4	2.76	14.3	3.40	14.5	3.42	14.7	3.44	15.1	3.47	15.4	3.50
	35	10.4	2.28	12.4	2.94	14.1	3.53	14.3	3.54	14.4	3.56	14.8	3.60	15.2	3.63
	37	10.4	2.43	12.4	3.13	13.8	3.65	14.0	3.67	14.2	3.69	14.6	3.72	15.0	3.76
	39	10.4	2.58	12.4	3.33	13.6	3.78	13.8	3.80	14.0	3.81	14.4	3.85	14.7	3.89
100 (125)	10	9.45	1.21	11.3	1.47	13.1	1.74	14.0	1.88	14.9	2.02	16.7	2.31	17.7	2.39
	12	9.45	1.23	11.3	1.50	13.1	1.78	14.0	1.92	14.9	2.06	16.7	2.36	17.5	2.38
	14	9.45	1.26	11.3	1.53	13.1	1.81	14.0	1.95	14.9	2.10	16.7	2.40	17.2	2.37
	16	9.45	1.28	11.3	1.55	13.1	1.84	14.0	1.99	14.9	2.14	16.7	2.43	17.0	2.41
	18	9.45	1.30	11.3	1.58	13.1	1.88	14.0	2.03	14.9	2.19	16.4	2.51	16.8	2.53
	20	9.45	1.33	11.3	1.62	13.1	1.94	14.0	2.13	14.9	2.34	16.2	2.64	16.6	2.66
	21	9.45	1.34	11.3	1.63	13.1	2.01	14.0	2.21	14.9	2.43	16.1	2.70	16.4	2.72
	23	9.45	1.38	11.3	1.74	13.1	2.15	14.0	2.37	14.9	2.60	15.9	2.82	16.2	2.84
	25	9.45	1.47	11.3	1.86	13.1	2.30	14.0	2.54	14.9	2.79	15.6	2.94	16.0	2.97
	27	9.45	1.56	11.3	1.98	13.1	2.46	14.0	2.71	14.9	2.98	15.4	3.07	15.8	3.09
	29	9.45	1.67	11.3	2.12	13.1	2.62	14.0	2.90	14.9	3.16	15.2	3.19	15.5	3.22
	31	9.45	1.77	11.3	2.26	13.1	2.80	14.0	3.09	14.6	3.29	15.0	3.32	15.3	3.34
	33	9.45	1.89	11.3	2.40	13.1	2.99	14.0	3.30	14.4	3.41	14.7	3.44	15.1	3.47
	35	9.45	2.00	11.3	2.56	13.1	3.18	14.0	3.52	14.2	3.54	14.5	3.57	14.9	3.60
	37	9.45	2.13	11.3	2.72	13.1	3.39	13.8	3.64	13.9	3.66	14.3	3.69	14.6	3.73
	39	9.45	2.26	11.3	2.90	13.1	3.61	13.5	3.77	13.7	3.79	14.1	3.82	14.4	3.85

1. This table indicates the situation of 50~130% combination of indoor units.
2. If connecting the indoor units over 130% of outdoor unit capacity, capacity of indoor unit will decrease.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (112.5)	10	8.50	1.09	10.1	1.31	11.8	1.55	12.6	1.67	13.4	1.79	15.1	2.05	16.7	2.31
	12	8.50	1.10	10.1	1.33	11.8	1.57	12.6	1.70	13.4	1.83	15.1	2.09	16.7	2.35
	14	8.50	1.12	10.1	1.36	11.8	1.60	12.6	1.73	13.4	1.86	15.1	2.13	16.7	2.40
	16	8.50	1.14	10.1	1.38	11.8	1.63	12.6	1.76	13.4	1.90	15.1	2.17	16.7	2.44
	18	8.50	1.16	10.1	1.41	11.8	1.67	12.6	1.80	13.4	1.94	15.1	2.21	16.4	2.51
	20	8.50	1.18	10.1	1.44	11.8	1.70	12.6	1.84	13.4	2.01	15.1	2.38	16.2	2.63
	21	8.50	1.20	10.1	1.45	11.8	1.73	12.6	1.90	13.4	2.08	15.1	2.46	16.1	2.70
	23	8.50	1.22	10.1	1.51	11.8	1.85	12.6	2.03	13.4	2.23	15.1	2.64	15.9	2.82
	25	8.50	1.28	10.1	1.61	11.8	1.98	12.6	2.18	13.4	2.38	15.1	2.83	15.6	2.94
	27	8.50	1.37	10.1	1.72	11.8	2.11	12.6	2.32	13.4	2.55	15.1	3.03	15.4	3.07
	29	8.50	1.45	10.1	1.83	11.8	2.25	12.6	2.48	13.4	2.72	14.9	3.17	15.2	3.19
	31	8.50	1.55	10.1	1.95	11.8	2.40	12.6	2.65	13.4	2.90	14.7	3.29	15.0	3.31
	33	8.50	1.64	10.1	2.07	11.8	2.56	12.6	2.82	13.4	3.10	14.4	3.41	14.7	3.44
	35	8.50	1.74	10.1	2.21	11.8	2.73	12.6	3.01	13.4	3.30	14.2	3.54	14.5	3.57
	37	8.50	1.85	10.1	2.35	11.8	2.90	12.6	3.20	13.4	3.52	14.0	3.66	14.3	3.69
	39	8.50	1.96	10.1	2.49	11.8	3.09	12.6	3.41	13.4	3.75	13.7	3.79	14.0	3.82
80 (100)	10	7.56	0.96	9.02	1.15	10.5	1.36	11.2	1.46	11.9	1.57	13.4	1.79	14.8	2.01
	12	7.56	0.98	9.02	1.17	10.5	1.38	11.2	1.49	11.9	1.60	13.4	1.82	14.8	2.05
	14	7.56	1.00	9.02	1.19	10.5	1.41	11.2	1.51	11.9	1.63	13.4	1.86	14.8	2.09
	16	7.56	1.01	9.02	1.22	10.5	1.43	11.2	1.54	11.9	1.66	13.4	1.89	14.8	2.13
	18	7.56	1.03	9.02	1.24	10.5	1.46	11.2	1.57	11.9	1.69	13.4	1.93	14.8	2.17
	20	7.56	1.05	9.02	1.26	10.5	1.49	11.2	1.60	11.9	1.72	13.4	2.00	14.8	2.33
	21	7.56	1.06	9.02	1.27	10.5	1.50	11.2	1.62	11.9	1.76	13.4	2.07	14.8	2.41
	23	7.56	1.08	9.02	1.30	10.5	1.58	11.2	1.73	11.9	1.88	13.4	2.22	14.8	2.58
	25	7.56	1.11	9.02	1.38	10.5	1.68	11.2	1.84	11.9	2.01	13.4	2.37	14.8	2.77
	27	7.56	1.18	9.02	1.47	10.5	1.79	11.2	1.97	11.9	2.15	13.4	2.54	14.8	2.96
	29	7.56	1.26	9.02	1.57	10.5	1.91	11.2	2.10	11.9	2.29	13.4	2.71	14.8	3.16
	31	7.56	1.33	9.02	1.67	10.5	2.04	11.2	2.24	11.9	2.45	13.4	2.89	14.6	3.29
	33	7.56	1.42	9.02	1.77	10.5	2.17	11.2	2.38	11.9	2.61	13.4	3.09	14.4	3.41
	35	7.56	1.50	9.02	1.88	10.5	2.31	11.2	2.54	11.9	2.78	13.4	3.29	14.2	3.53
	37	7.56	1.59	9.02	2.00	10.5	2.45	11.2	2.70	11.9	2.96	13.4	3.51	13.9	3.66
	39	7.56	1.69	9.02	2.12	10.5	2.61	11.2	2.87	11.9	3.15	13.4	3.73	13.7	3.78
70 (87.5)	10	6.61	0.85	7.89	1.01	9.16	1.17	9.80	1.26	10.4	1.35	11.7	1.54	13.0	1.73
	12	6.61	0.86	7.89	1.02	9.16	1.19	9.80	1.28	10.4	1.38	11.7	1.56	13.0	1.76
	14	6.61	0.87	7.89	1.04	9.16	1.22	9.80	1.31	10.4	1.40	11.7	1.59	13.0	1.79
	16	6.61	0.89	7.89	1.06	9.16	1.24	9.80	1.33	10.4	1.43	11.7	1.62	13.0	1.83
	18	6.61	0.90	7.89	1.08	9.16	1.26	9.80	1.36	10.4	1.45	11.7	1.66	13.0	1.86
	20	6.61	0.92	7.89	1.10	9.16	1.28	9.80	1.38	10.4	1.48	11.7	1.69	13.0	1.92
	21	6.61	0.93	7.89	1.11	9.16	1.30	9.80	1.40	10.4	1.50	11.7	1.71	13.0	1.98
	23	6.61	0.94	7.89	1.13	9.16	1.32	9.80	1.44	10.4	1.57	11.7	1.84	13.0	2.12
	25	6.61	0.96	7.89	1.17	9.16	1.41	9.80	1.54	10.4	1.67	11.7	1.96	13.0	2.27
	27	6.61	1.01	7.89	1.25	9.16	1.50	9.80	1.64	10.4	1.79	11.7	2.09	13.0	2.43
	29	6.61	1.08	7.89	1.32	9.16	1.60	9.80	1.75	10.4	1.90	11.7	2.23	13.0	2.59
	31	6.61	1.14	7.89	1.41	9.16	1.70	9.80	1.86	10.4	2.03	11.7	2.38	13.0	2.77
	33	6.61	1.21	7.89	1.49	9.16	1.81	9.80	1.98	10.4	2.16	11.7	2.54	13.0	2.95
	35	6.61	1.28	7.89	1.58	9.16	1.92	9.80	2.11	10.4	2.30	11.7	2.70	13.0	3.14
	37	6.61	1.35	7.89	1.68	9.16	2.04	9.80	2.24	10.4	2.44	11.7	2.88	13.0	3.35
	39	6.61	1.43	7.89	1.78	9.16	2.17	9.80	2.38	10.4	2.60	11.7	3.06	13.0	3.57
60 (75)	10	5.67	0.74	6.76	0.87	7.85	1.00	8.40	1.07	8.95	1.14	10.0	1.29	11.1	1.45
	12	5.67	0.75	6.76	0.88	7.85	1.02	8.40	1.09	8.95	1.16	10.0	1.32	11.1	1.48
	14	5.67	0.76	6.76	0.89	7.85	1.03	8.40	1.11	8.95	1.18	10.0	1.34	11.1	1.50
	16	5.67	0.77	6.76	0.91	7.85	1.05	8.40	1.13	8.95	1.21	10.0	1.37	11.1	1.53
	18	5.67	0.78	6.76	0.92	7.85	1.07	8.40	1.15	8.95	1.23	10.0	1.39	11.1	1.56
	20	5.67	0.79	6.76	0.94	7.85	1.09	8.40	1.17	8.95	1.25	10.0	1.42	11.1	1.59
	21	5.67	0.80	6.76	0.95	7.85	1.10	8.40	1.18	8.95	1.26	10.0	1.43	11.1	1.61
	23	5.67	0.81	6.76	0.96	7.85	1.12	8.40	1.20	8.95	1.29	10.0	1.49	11.1	1.71
	25	5.67	0.83	6.76	0.98	7.85	1.16	8.40	1.26	8.95	1.37	10.0	1.59	11.1	1.83
	27	5.67	0.86	6.76	1.04	7.85	1.24	8.40	1.35	8.95	1.46	10.0	1.70	11.1	1.95
	29	5.67	0.91	6.76	1.10	7.85	1.32	8.40	1.43	8.95	1.55	10.0	1.81	11.1	2.08
	31	5.67	0.96	6.76	1.17	7.85	1.40	8.40	1.52	8.95	1.65	10.0	1.92	11.1	2.22
	33	5.67	1.02	6.76	1.24	7.85	1.48	8.40	1.62	8.95	1.75	10.0	2.05	11.1	2.36
	35	5.67	1.08	6.76	1.31	7.85	1.58	8.40	1.72	8.95	1.86	10.0	2.18	11.1	2.51
	37	5.67	1.14	6.76	1.39	7.85	1.67	8.40	1.82	8.95	1.98	10.0	2.31	11.1	2.67
	39	5.67	1.20	6.76	1.47	7.85	1.77	8.40	1.93	8.95	2.10	10.0	2.46	11.1	2.84
50 (62.5)	10	4.72	0.63	5.63	0.73	6.54	0.84	7.00	0.89	7.46	0.95	8.37	1.07	9.28	1.19
	12	4.72	0.64	5.63	0.74	6.54	0.85	7.00	0.91	7.46	0.97	8.37	1.09	9.28	1.21
	14	4.72	0.65	5.63	0.75	6.54	0.87	7.00	0.92	7.46	0.98	8.37	1.10	9.28	1.23
	16	4.72	0.66	5.63	0.77	6.54	0.88	7.00	0.94	7.46	1.00	8.37	1.12	9.28	1.25
	18	4.72	0.67	5.63	0.78	6.54	0.89	7.00	0.95	7.46	1.02	8.37	1.14	9.28	1.28
	20	4.72	0.68	5.63	0.79	6.54	0.91	7.00	0.97	7.46	1.03	8.37	1.16	9.28	1.30
	21	4.72	0.68	5.63	0.80	6.54	0.92	7.00	0.98	7.46	1.04	8.37	1.18	9.28	1.31
	23	4.72	0.69	5.63	0.81	6.54	0.93	7.00	1.00	7.46	1.06	8.37	1.20	9.28	1.34
	25	4.72	0.70	5.63	0.82	6.54	0.95	7.00	1.02	7.46	1.09	8.37	1.26	9.28	1.43
	27	4.72	0.71	5.63	0.85	6.54	1.00	7.00	1.08	7.46	1.16	8.37	1.34	9.28	1.53
	29	4.72	0.76	5.63	0.90	6.54	1.06	7.00	1.15	7.46	1.24	8.37	1.42	9.28	1.63
	31	4.72	0.80	5.63	0.96	6.54	1.13	7.00	1.22	7.46	1.31	8.37	1.51	9.28	1.73
	33	4.72	0.84	5.63	1.01	6.54	1.19	7.00	1.29	7.46	1.39	8.37	1.61	9.28	1.84
	35	4.72	0.89	5.63	1.07	6.54	1.26	7.00	1.37	7.46	1.48	8.37	1.71	9.28	1.95
	37	4.72	0.94	5.63	1.13	6.54	1.34	7.00	1.45	7.46	1.57	8.37	1.81	9.28	2.08
	39	4.72	0.99	5.63	1.19	6.54	1.42	7.00	1.53	7.46	1.66	8.37	1.92	9.28	2.20

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
130 (260)	10	19.7	2.41	23.4	2.95	27.2	3.51	28.2	3.59	28.6	3.51	29.3	3.37	30.0	3.21
	12	19.7	2.46	23.4	3.01	27.2	3.58	27.8	3.57	28.2	3.49	28.9	3.34	29.6	3.29
	14	19.7	2.50	23.4	3.07	27.1	3.62	27.5	3.55	27.8	3.47	28.5	3.45	29.3	3.48
	16	19.7	2.55	23.4	3.13	26.8	3.61	27.1	3.58	27.5	3.60	28.2	3.63	28.9	3.67
	18	19.7	2.60	23.4	3.19	26.4	3.75	26.8	3.76	27.1	3.78	27.8	3.82	28.5	3.86
	20	19.7	2.65	23.4	3.40	26.0	3.93	26.4	3.95	26.7	3.97	27.5	4.01	28.2	4.04
	21	19.7	2.73	23.4	3.52	25.9	4.02	26.2	4.04	26.6	4.06	27.3	4.10	28.0	4.14
	23	19.7	2.92	23.4	3.77	25.5	4.20	25.8	4.22	26.2	4.24	26.9	4.29	27.6	4.33
	25	19.7	3.12	23.4	4.04	25.1	4.39	25.5	4.41	25.8	4.43	26.5	4.48	27.3	4.52
	27	19.7	3.34	23.4	4.32	24.8	4.57	25.1	4.59	25.5	4.62	26.2	4.67	26.9	4.72
	29	19.7	3.56	23.4	4.62	24.4	4.76	24.8	4.78	25.1	4.81	25.8	4.86	26.5	4.91
	31	19.7	3.80	23.3	4.89	24.0	4.94	24.4	4.97	24.7	5.00	25.4	5.05	26.2	5.10
	33	19.7	4.05	23.0	5.07	23.7	5.13	24.0	5.16	24.4	5.19	25.1	5.24	25.8	5.30
	35	19.7	4.31	22.6	5.26	23.3	5.32	23.7	5.35	24.0	5.38	24.7	5.44	25.4	5.50
	37	19.7	4.59	22.2	5.44	22.9	5.51	23.3	5.54	23.6	5.57	24.4	5.63	25.1	5.70
	39	19.7	4.89	21.9	5.63	22.6	5.70	22.9	5.73	23.3	5.76	24.0	5.83	24.7	5.90
120 (240)	10	18.1	2.20	21.6	2.69	25.1	3.20	26.9	3.46	28.1	3.61	28.8	3.47	29.4	3.33
	12	18.1	2.24	21.6	2.74	25.1	3.26	26.9	3.53	27.8	3.59	28.4	3.45	29.1	3.31
	14	18.1	2.29	21.6	2.80	25.1	3.33	26.9	3.59	27.4	3.57	28.0	3.43	28.7	3.45
	16	18.1	2.33	21.6	2.85	25.1	3.39	26.7	3.62	27.0	3.58	27.7	3.61	28.3	3.64
	18	18.1	2.38	21.6	2.91	25.1	3.51	26.3	3.74	26.7	3.76	27.3	3.79	28.0	3.83
	20	18.1	2.42	21.6	3.02	25.1	3.77	26.0	3.92	26.3	3.94	27.0	3.98	27.6	4.01
	21	18.1	2.45	21.6	3.13	25.1	3.91	25.8	4.02	26.1	4.03	26.8	4.07	27.4	4.11
	23	18.1	2.61	21.6	3.35	25.1	4.18	25.4	4.20	25.8	4.22	26.4	4.26	27.1	4.30
	25	18.1	2.79	21.6	3.59	24.7	4.36	25.1	4.38	25.4	4.40	26.0	4.44	26.7	4.49
	27	18.1	2.98	21.6	3.84	24.4	4.54	24.7	4.57	25.0	4.59	25.7	4.63	26.3	4.68
	29	18.1	3.18	21.6	4.10	24.0	4.73	24.3	4.75	24.7	4.77	25.3	4.82	26.0	4.87
	31	18.1	3.39	21.6	4.37	23.6	4.91	24.0	4.94	24.3	4.96	24.9	5.01	25.6	5.06
	33	18.1	3.61	21.6	4.66	23.3	5.10	23.6	5.12	23.9	5.15	24.6	5.20	25.2	5.26
	35	18.1	3.84	21.6	4.97	22.9	5.28	23.2	5.31	23.6	5.34	24.2	5.39	24.9	5.45
	37	18.1	4.09	21.6	5.30	22.5	5.47	22.9	5.50	23.2	5.53	23.9	5.59	24.5	5.65
	39	18.1	4.35	21.5	5.60	22.2	5.66	22.5	5.69	22.8	5.72	23.5	5.78	24.1	5.84
110 (220)	10	16.6	2.00	19.8	2.44	23.0	2.90	24.6	3.13	26.2	3.37	28.3	3.57	28.9	3.45
	12	16.6	2.04	19.8	2.48	23.0	2.95	24.6	3.19	26.2	3.43	27.9	3.56	28.5	3.43
	14	16.6	2.07	19.8	2.53	23.0	3.01	24.6	3.25	26.2	3.50	27.5	3.54	28.1	3.43
	16	16.6	2.11	19.8	2.58	23.0	3.06	24.6	3.31	26.2	3.56	27.2	3.58	27.8	3.61
	18	16.6	2.15	19.8	2.63	23.0	3.13	24.6	3.40	26.2	3.74	26.8	3.77	27.4	3.80
	20	16.6	2.20	19.8	2.68	23.0	3.31	24.6	3.66	25.9	3.92	26.5	3.95	27.1	3.98
	21	16.6	2.22	19.8	2.76	23.0	3.43	24.6	3.79	25.7	4.01	26.3	4.04	26.9	4.08
	23	16.6	2.32	19.8	2.96	23.0	3.68	24.6	4.07	25.3	4.19	25.9	4.23	26.5	4.26
	25	16.6	2.48	19.8	3.16	23.0	3.94	24.6	4.35	24.9	4.37	25.5	4.41	26.1	4.45
	27	16.6	2.64	19.8	3.38	23.0	4.21	24.3	4.54	24.6	4.56	25.2	4.60	25.8	4.64
	29	16.6	2.82	19.8	3.61	23.0	4.50	23.9	4.72	24.2	4.74	24.8	4.79	25.4	4.83
	31	16.6	3.00	19.8	3.85	23.0	4.80	23.5	4.91	23.8	4.93	24.4	4.97	25.0	5.02
	33	16.6	3.19	19.8	4.10	22.9	5.07	23.2	5.09	23.5	5.11	24.1	5.16	24.7	5.21
	35	16.6	3.40	19.8	4.37	22.5	5.25	22.8	5.28	23.1	5.30	23.7	5.35	24.3	5.40
	37	16.6	3.61	19.8	4.65	22.2	5.44	22.5	5.46	22.8	5.49	23.4	5.54	24.0	5.60
	39	16.6	3.84	19.8	4.96	21.8	5.62	22.1	5.65	22.4	5.68	23.0	5.73	23.6	5.79
100 (200)	10	15.1	1.81	18.0	2.19	20.9	2.59	22.4	2.80	23.9	3.01	26.8	3.44	28.3	3.57
	12	15.1	1.84	18.0	2.23	20.9	2.64	22.4	2.86	23.9	3.07	26.8	3.51	28.0	3.55
	14	15.1	1.87	18.0	2.27	20.9	2.69	22.4	2.91	23.9	3.13	26.8	3.58	27.6	3.53
	16	15.1	1.90	18.0	2.31	20.9	2.75	22.4	2.97	23.9	3.19	26.7	3.62	27.2	3.59
	18	15.1	1.94	18.0	2.36	20.9	2.80	22.4	3.03	23.9	3.25	26.3	3.74	26.9	3.77
	20	15.1	1.98	18.0	2.41	20.9	2.88	22.4	3.18	23.9	3.49	26.0	3.92	26.5	3.95
	21	15.1	2.00	18.0	2.43	20.9	2.99	22.4	3.29	23.9	3.61	25.8	4.01	26.3	4.05
	23	15.1	2.05	18.0	2.59	20.9	3.20	22.4	3.53	23.9	3.87	25.4	4.20	25.9	4.23
	25	15.1	2.19	18.0	2.77	20.9	3.42	22.4	3.78	23.9	4.15	25.0	4.38	25.6	4.42
	27	15.1	2.33	18.0	2.95	20.9	3.66	22.4	4.04	23.9	4.44	24.7	4.56	25.2	4.60
	29	15.1	2.48	18.0	3.15	20.9	3.91	22.4	4.31	23.8	4.71	24.3	4.75	24.9	4.79
	31	15.1	2.64	18.0	3.36	20.9	4.17	22.4	4.61	23.4	4.89	23.9	4.94	24.5	4.98
	33	15.1	2.81	18.0	3.58	20.9	4.44	22.4	4.91	23.0	5.08	23.6	5.12	24.1	5.17
	35	15.1	2.98	18.0	3.81	20.9	4.74	22.4	5.24	22.7	5.26	23.2	5.31	23.8	5.36
	37	15.1	3.17	18.0	4.05	20.9	5.05	22.0	5.42	22.3	5.45	22.9	5.50	23.4	5.55
	39	15.1	3.37	18.0	4.31	20.9	5.38	21.7	5.61	21.9	5.64	22.5	5.69	23.0	5.74

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
90 (180)	10	13.6	1.62	16.2	1.95	18.8	2.30	20.2	2.48	21.5	2.67	24.1	3.05	26.7	3.44
	12	13.6	1.64	16.2	1.98	18.8	2.34	20.2	2.53	21.5	2.72	24.1	3.11	26.7	3.50
	14	13.6	1.67	16.2	2.02	18.8	2.39	20.2	2.58	21.5	2.77	24.1	3.17	26.7	3.57
	16	13.6	1.70	16.2	2.06	18.8	2.43	20.2	2.63	21.5	2.82	24.1	3.23	26.7	3.63
	18	13.6	1.73	16.2	2.10	18.8	2.48	20.2	2.68	21.5	2.88	24.1	3.29	26.3	3.74
	20	13.6	1.76	16.2	2.14	18.8	2.53	20.2	2.73	21.5	2.99	24.1	3.54	25.9	3.92
	21	13.6	1.78	16.2	2.16	18.8	2.57	20.2	2.83	21.5	3.09	24.1	3.67	25.8	4.01
	23	13.6	1.81	16.2	2.25	18.8	2.75	20.2	3.03	21.5	3.32	24.1	3.93	25.4	4.20
	25	13.6	1.91	16.2	2.40	18.8	2.94	20.2	3.24	21.5	3.55	24.1	4.21	25.0	4.38
	27	13.6	2.03	16.2	2.56	18.8	3.14	20.2	3.46	21.5	3.79	24.1	4.50	24.7	4.56
	29	13.6	2.16	16.2	2.73	18.8	3.35	20.2	3.69	21.5	4.05	23.8	4.71	24.3	4.75
	31	13.6	2.30	16.2	2.90	18.8	3.58	20.2	3.94	21.5	4.32	23.4	4.90	23.9	4.93
	33	13.6	2.44	16.2	3.09	18.8	3.81	20.2	4.20	21.5	4.61	23.1	5.08	23.6	5.12
	35	13.6	2.60	16.2	3.28	18.8	4.06	20.2	4.48	21.5	4.92	22.7	5.27	23.2	5.31
	37	13.6	2.75	16.2	3.49	18.8	4.32	20.2	4.77	21.5	5.24	22.4	5.45	22.8	5.50
	39	13.6	2.92	16.2	3.71	18.8	4.60	20.2	5.08	21.5	5.58	22.0	5.64	22.5	5.69
80 (160)	10	12.1	1.43	14.4	1.72	16.8	2.02	17.9	2.17	19.1	2.33	21.4	2.66	23.7	3.00
	12	12.1	1.46	14.4	1.75	16.8	2.05	17.9	2.21	19.1	2.38	21.4	2.71	23.7	3.05
	14	12.1	1.48	14.4	1.78	16.8	2.09	17.9	2.26	19.1	2.42	21.4	2.76	23.7	3.11
	16	12.1	1.51	14.4	1.81	16.8	2.13	17.9	2.30	19.1	2.47	21.4	2.82	23.7	3.17
	18	12.1	1.53	14.4	1.84	16.8	2.17	17.9	2.34	19.1	2.52	21.4	2.87	23.7	3.24
	20	12.1	1.56	14.4	1.88	16.8	2.21	17.9	2.39	19.1	2.57	21.4	2.98	23.7	3.46
	21	12.1	1.57	14.4	1.90	16.8	2.24	17.9	2.41	19.1	2.62	21.4	3.08	23.7	3.59
	23	12.1	1.60	14.4	1.93	16.8	2.34	17.9	2.57	19.1	2.80	21.4	3.30	23.7	3.85
	25	12.1	1.66	14.4	2.06	16.8	2.50	17.9	2.74	19.1	3.00	21.4	3.53	23.7	4.12
	27	12.1	1.76	14.4	2.19	16.8	2.67	17.9	2.93	19.1	3.20	21.4	3.78	23.7	4.41
	29	12.1	1.87	14.4	2.33	16.8	2.85	17.9	3.12	19.1	3.41	21.4	4.04	23.7	4.71
	31	12.1	1.99	14.4	2.48	16.8	3.03	17.9	3.33	19.1	3.64	21.4	4.31	23.4	4.89
	33	12.1	2.11	14.4	2.64	16.8	3.23	17.9	3.55	19.1	3.88	21.4	4.59	23.0	5.08
	35	12.1	2.24	14.4	2.80	16.8	3.43	17.9	3.77	19.1	4.13	21.4	4.90	22.7	5.26
	37	12.1	2.37	14.4	2.98	16.8	3.65	17.9	4.02	19.1	4.40	21.4	5.22	22.3	5.45
	39	12.1	2.51	14.4	3.16	16.8	3.88	17.9	4.27	19.1	4.68	21.4	5.56	21.9	5.63
70 (140)	10	10.6	1.26	12.6	1.50	14.7	1.75	15.7	1.88	16.7	2.01	18.7	2.29	20.8	2.57
	12	10.6	1.28	12.6	1.52	14.7	1.78	15.7	1.91	16.7	2.05	18.7	2.33	20.8	2.62
	14	10.6	1.30	12.6	1.55	14.7	1.81	15.7	1.95	16.7	2.08	18.7	2.37	20.8	2.67
	16	10.6	1.32	12.6	1.57	14.7	1.84	15.7	1.98	16.7	2.12	18.7	2.42	20.8	2.72
	18	10.6	1.34	12.6	1.60	14.7	1.88	15.7	2.02	16.7	2.16	18.7	2.46	20.8	2.77
	20	10.6	1.37	12.6	1.63	14.7	1.91	15.7	2.06	16.7	2.21	18.7	2.51	20.8	2.85
	21	10.6	1.38	12.6	1.65	14.7	1.93	15.7	2.08	16.7	2.23	18.7	2.55	20.8	2.95
	23	10.6	1.40	12.6	1.68	14.7	1.97	15.7	2.15	16.7	2.33	18.7	2.73	20.8	3.16
	25	10.6	1.43	12.6	1.74	14.7	2.10	15.7	2.29	16.7	2.49	18.7	2.92	20.8	3.38
	27	10.6	1.51	12.6	1.85	14.7	2.24	15.7	2.44	16.7	2.66	18.7	3.12	20.8	3.62
	29	10.6	1.60	12.6	1.97	14.7	2.38	15.7	2.60	16.7	2.83	18.7	3.33	20.8	3.86
	31	10.6	1.70	12.6	2.09	14.7	2.53	15.7	2.77	16.7	3.02	18.7	3.55	20.8	4.12
	33	10.6	1.80	12.6	2.22	14.7	2.69	15.7	2.95	16.7	3.21	18.7	3.78	20.8	4.39
	35	10.6	1.90	12.6	2.36	14.7	2.86	15.7	3.13	16.7	3.42	18.7	4.02	20.8	4.68
	37	10.6	2.02	12.6	2.50	14.7	3.04	15.7	3.33	16.7	3.63	18.7	4.28	20.8	4.99
	39	10.6	2.13	12.6	2.65	14.7	3.23	15.7	3.54	16.7	3.86	18.7	4.56	20.8	5.31
60 (120)	10	9.1	1.10	10.8	1.29	12.6	1.49	13.4	1.60	14.3	1.70	16.1	1.93	17.8	2.16
	12	9.1	1.11	10.8	1.31	12.6	1.51	13.4	1.62	14.3	1.73	16.1	1.96	17.8	2.20
	14	9.1	1.13	10.8	1.33	12.6	1.54	13.4	1.65	14.3	1.76	16.1	2.00	17.8	2.24
	16	9.1	1.15	10.8	1.35	12.6	1.57	13.4	1.68	14.3	1.80	16.1	2.03	17.8	2.28
	18	9.1	1.16	10.8	1.37	12.6	1.59	13.4	1.71	14.3	1.83	16.1	2.07	17.8	2.33
	20	9.1	1.18	10.8	1.40	12.6	1.62	13.4	1.74	14.3	1.86	16.1	2.11	17.8	2.37
	21	9.1	1.19	10.8	1.41	12.6	1.64	13.4	1.76	14.3	1.88	16.1	2.13	17.8	2.40
	23	9.1	1.21	10.8	1.43	12.6	1.67	13.4	1.79	14.3	1.92	16.1	2.22	17.8	2.55
	25	9.1	1.23	10.8	1.46	12.6	1.73	13.4	1.88	14.3	2.04	16.1	2.37	17.8	2.72
	27	9.1	1.28	10.8	1.55	12.6	1.84	13.4	2.00	14.3	2.17	16.1	2.52	17.8	2.90
	29	9.1	1.35	10.8	1.64	12.6	1.96	13.4	2.13	14.3	2.31	16.1	2.69	17.8	3.10
	31	9.1	1.43	10.8	1.74	12.6	2.08	13.4	2.27	14.3	2.46	16.1	2.86	17.8	3.30
	33	9.1	1.51	10.8	1.85	12.6	2.21	13.4	2.41	14.3	2.61	16.1	3.05	17.8	3.52
	35	9.1	1.60	10.8	1.95	12.6	2.35	13.4	2.55	14.3	2.77	16.1	3.24	17.8	3.74
	37	9.1	1.69	10.8	2.07	12.6	2.49	13.4	2.71	14.3	2.94	16.1	3.44	17.8	3.98
	39	9.1	1.79	10.8	2.19	12.6	2.64	13.4	2.88	14.3	3.13	16.1	3.66	17.8	4.23
50 (100)	10	7.56	0.94	9.0	1.09	10.5	1.25	11.2	1.33	11.9	1.42	13.4	1.59	14.8	1.77
	12	7.56	0.96	9.0	1.11	10.5	1.27	11.2	1.35	11.9	1.44	13.4	1.62	14.8	1.80
	14	7.56	0.97	9.0	1.12	10.5	1.29	11.2	1.37	11.9	1.46	13.4	1.64	14.8	1.83
	16	7.56	0.98	9.0	1.14	10.5	1.31	11.2	1.40	11.9	1.49	13.4	1.67	14.8	1.87
	18	7.56	0.99	9.0	1.16	10.5	1.33	11.2	1.42	11.9	1.51	13.4	1.70	14.8	1.90
	20	7.56	1.01	9.0	1.18	10.5	1.35	11.2	1.44	11.9	1.54	13.4	1.73	14.8	1.94
	21	7.56	1.02	9.0	1.18	10.5	1.36	11.2	1.46	11.9	1.55	13.4	1.75	14.8	1.96
	23	7.56	1.03	9.0	1.20	10.5	1.39	11.2	1.48	11.9	1.58	13.4	1.78	14.8	2.00
	25	7.56	1.05	9.0	1.22	10.5	1.41	11.2	1.51	11.9	1.63	13.4	1.87	14.8	2.13
	27	7.56	1.06	9.0	1.27	10.5	1.49	11.2	1.61	11.9	1.73	13.4	1.99	14.8	2.27
	29	7.56	1.13	9.0	1.34	10.5	1.58	11.2	1.71	11.9	1.84	13.4	2.12	14.8	2.42
	31	7.56	1.19	9.0	1.42	10.5	1.68	11.2	1.81	11.9	1.95	13.4	2.25	14.8	2.58
	33	7.56	1.26	9.0	1.50	10.5	1.78	11.2	1.92	11.9	2.07	13.4	2.39	14.8	2.74
	35	7.56	1.33	9.0	1.59	10.5	1.88	11.2	2.04	11.9	2.20	13.4	2.54	14.8	2.91
	37	7.56	1.40	9.0	1.68	10.5	1.99	11.2	2.16	11.9	2.33	13.4	2.70	14.8	3.09
	39	7.56	1.47	9.0	1.78	10.5	2.11	11.2	2.28	11.9	2.47	13.4	2.86	14.8	3.28

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

RXYQ10PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (325)	10	24.6	3.64	29.3	4.45	34.0	5.30	35.3	5.41	35.7	5.30	36.6	5.07	37.5	4.85
	12	24.6	3.70	29.3	4.54	34.0	5.40	34.8	5.38	35.3	5.27	36.1	5.04	37.0	4.96
	14	24.6	3.77	29.3	4.62	33.9	5.46	34.4	5.35	34.8	5.24	35.7	5.20	36.6	5.24
	16	24.6	3.85	29.3	4.71	33.5	5.44	33.9	5.40	34.3	5.42	35.2	5.48	36.1	5.53
	18	24.6	3.92	29.3	4.81	33.0	5.65	33.4	5.67	33.9	5.70	34.8	5.76	35.7	5.81
	20	24.6	4.00	29.3	5.12	32.5	5.92	33.0	5.95	33.4	5.98	34.3	6.04	35.2	6.10
	21	24.6	4.11	29.3	5.30	32.3	6.06	32.8	6.09	33.2	6.12	34.1	6.18	35.0	6.24
	23	24.6	4.40	29.3	5.69	31.9	6.34	32.3	6.37	32.7	6.40	33.6	6.46	34.5	6.53
	25	24.6	4.71	29.3	6.09	31.4	6.61	31.8	6.65	32.3	6.68	33.2	6.75	34.1	6.82
	27	24.6	5.03	29.3	6.51	31.0	6.89	31.4	6.93	31.8	6.96	32.7	7.04	33.6	7.11
	29	24.6	5.37	29.3	6.96	30.5	7.17	30.9	7.21	31.4	7.25	32.3	7.32	33.2	7.40
	31	24.6	5.73	29.2	7.37	30.0	7.45	30.5	7.49	30.9	7.53	31.8	7.61	32.7	7.69
	33	24.6	6.10	28.7	7.65	29.6	7.73	30.0	7.78	30.5	7.82	31.4	7.90	32.2	7.99
	35	24.6	6.50	28.2	7.92	29.1	8.02	29.6	8.06	30.0	8.11	30.9	8.20	31.8	8.29
	37	24.6	6.92	27.8	8.20	28.7	8.30	29.1	8.35	29.6	8.40	30.4	8.49	31.3	8.59
	39	24.6	7.37	27.3	8.49	28.2	8.59	28.7	8.64	29.1	8.69	30.0	8.79	30.9	8.89
120 (300)	10	22.7	3.32	27.0	4.06	31.4	4.83	33.6	5.22	35.2	5.44	36.0	5.23	36.8	5.03
	12	22.7	3.38	27.0	4.14	31.4	4.92	33.6	5.32	34.7	5.41	35.5	5.20	36.3	4.99
	14	22.7	3.45	27.0	4.21	31.4	5.01	33.6	5.42	34.2	5.38	35.1	5.17	35.9	5.21
	16	22.7	3.51	27.0	4.30	31.4	5.11	33.4	5.46	33.8	5.39	34.6	5.44	35.4	5.49
	18	22.7	3.58	27.0	4.38	31.4	5.29	32.9	5.64	33.3	5.67	34.1	5.72	35.0	5.77
	20	22.7	3.65	27.0	4.56	31.4	5.68	32.5	5.92	32.9	5.94	33.7	6.00	34.5	6.05
	21	22.7	3.69	27.0	4.72	31.4	5.89	32.2	6.05	32.6	6.08	33.5	6.14	34.3	6.19
	23	22.7	3.94	27.0	5.05	31.4	6.30	31.8	6.33	32.2	6.36	33.0	6.42	33.8	6.48
	25	22.7	4.21	27.0	5.41	30.9	6.57	31.3	6.61	31.7	6.64	32.6	6.70	33.4	6.76
	27	22.7	4.49	27.0	5.78	30.5	6.85	30.9	6.88	31.3	6.92	32.1	6.98	32.9	7.05
	29	22.7	4.79	27.0	6.18	30.0	7.13	30.4	7.16	30.8	7.20	31.6	7.27	32.5	7.34
	31	22.7	5.11	27.0	6.59	29.5	7.41	30.0	7.44	30.4	7.48	31.2	7.56	32.0	7.63
	33	22.7	5.44	27.0	7.03	29.1	7.68	29.5	7.72	29.9	7.76	30.7	7.84	31.5	7.92
	35	22.7	5.79	27.0	7.50	28.6	7.97	29.0	8.01	29.5	8.05	30.3	8.13	31.1	8.22
	37	22.7	6.16	26.9	7.99	28.2	8.25	28.6	8.29	29.0	8.34	29.8	8.42	30.6	8.51
	39	22.7	6.56	26.9	8.44	27.7	8.53	28.1	8.58	28.5	8.62	29.4	8.72	30.2	8.81
110 (275)	10	20.8	3.02	24.8	3.68	28.8	4.36	30.8	4.72	32.8	5.08	33.5	5.39	34.1	5.20
	12	20.8	3.07	24.8	3.74	28.8	4.45	30.8	4.81	32.8	5.17	34.9	5.36	35.6	5.17
	14	20.8	3.13	24.8	3.81	28.8	4.53	30.8	4.90	32.8	5.27	34.4	5.33	35.2	5.17
	16	20.8	3.19	24.8	3.89	28.8	4.62	30.8	4.99	32.8	5.37	34.0	5.40	34.7	5.45
	18	20.8	3.25	24.8	3.96	28.8	4.71	30.8	5.13	32.8	5.63	33.5	5.88	34.3	5.73
	20	20.8	3.31	24.8	4.04	28.8	4.99	30.8	5.52	32.3	5.91	33.1	5.96	33.8	6.01
	21	20.8	3.34	24.8	4.17	28.8	5.17	30.8	5.71	32.1	6.04	32.8	6.09	33.6	6.15
	23	20.8	3.50	24.8	4.46	28.8	5.54	30.8	6.13	31.6	6.32	32.4	6.37	33.1	6.43
	25	20.8	3.74	24.8	4.77	28.8	5.93	30.8	6.57	31.2	6.59	31.9	6.65	32.7	6.71
	27	20.8	3.99	24.8	5.10	28.8	6.35	30.3	6.84	30.7	6.87	31.5	6.93	32.2	6.99
	29	20.8	4.25	24.8	5.44	28.8	6.78	29.9	7.12	30.3	7.15	31.0	7.22	31.8	7.28
	31	20.8	4.52	24.8	5.80	28.8	7.24	29.4	7.40	29.8	7.43	30.6	7.50	31.3	7.57
	33	20.8	4.82	24.8	6.18	28.6	7.64	29.0	7.67	29.4	7.71	30.1	7.78	30.9	7.86
	35	20.8	5.12	24.8	6.59	28.1	7.92	28.5	7.95	28.9	7.99	29.6	8.07	30.4	8.15
	37	20.8	5.45	24.8	7.02	27.7	8.19	28.1	8.23	28.4	8.28	29.2	8.36	29.9	8.44
	39	20.8	5.79	24.8	7.47	27.2	8.47	27.6	8.52	28.0	8.56	28.7	8.65	29.5	8.73
100 (250)	10	18.9	2.72	22.5	3.30	26.2	3.91	28.0	4.23	29.8	4.54	33.5	5.19	35.4	5.37
	12	18.9	2.77	22.5	3.36	26.2	3.98	28.0	4.30	29.8	4.63	33.5	5.29	34.9	5.35
	14	18.9	2.82	22.5	3.42	26.2	4.06	28.0	4.39	29.8	4.72	33.5	5.39	34.5	5.32
	16	18.9	2.87	22.5	3.49	26.2	4.14	28.0	4.47	29.8	4.81	33.3	5.46	34.0	5.41
	18	18.9	2.92	22.5	3.56	26.2	4.22	28.0	4.56	29.8	4.91	32.9	5.64	33.6	5.68
	20	18.9	2.98	22.5	3.63	26.2	4.35	28.0	4.79	29.8	5.26	32.4	5.91	33.1	5.96
	21	18.9	3.01	22.5	3.66	26.2	4.50	28.0	4.96	29.8	5.45	32.2	6.05	32.9	6.10
	23	18.9	3.09	22.5	3.91	26.2	4.82	28.0	5.32	29.8	5.84	31.8	6.33	32.4	6.38
	25	18.9	3.29	22.5	4.17	26.2	5.16	28.0	5.69	29.8	6.25	31.3	6.60	32.0	6.66
	27	18.9	3.51	22.5	4.45	26.2	5.51	28.0	6.09	29.8	6.69	30.8	6.88	31.5	6.94
	29	18.9	3.74	22.5	4.75	26.2	5.89	28.0	6.50	29.7	7.10	30.4	7.16	31.1	7.22
	31	18.9	3.98	22.5	5.06	26.2	6.28	28.0	6.94	29.3	7.38	29.9	7.44	30.6	7.50
	33	18.9	4.23	22.5	5.39	26.2	6.70	28.0	7.41	28.8	7.66	29.5	7.72	30.2	7.79
	35	18.9	4.50	22.5	5.74	26.2	7.14	28.0	7.90	28.3	7.93	29.0	8.00	29.7	8.07
	37	18.9	4.78	22.5	6.11	26.2	7.61	27.5	8.18	27.9	8.22	28.6	8.29	29.2	8.36
	39	18.9	5.07	22.5	6.50	26.2	8.10	27.1	8.46	27.4	8.50	28.1	8.57	28.8	8.65

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (225)	10	17.0	2.44	20.3	2.94	23.6	3.47	25.2	3.74	26.8	4.02	30.1	4.60	33.4	5.18
	12	17.0	2.48	20.3	2.99	23.6	3.53	25.2	3.81	26.8	4.10	30.1	4.68	33.4	5.28
	14	17.0	2.52	20.3	3.05	23.6	3.60	25.2	3.89	26.8	4.18	30.1	4.77	33.4	5.38
	16	17.0	2.57	20.3	3.10	23.6	3.67	25.2	3.96	26.8	4.26	30.1	4.87	33.3	5.47
	18	17.0	2.61	20.3	3.16	23.6	3.74	25.2	4.04	26.8	4.34	30.1	4.96	32.9	5.64
	20	17.0	2.66	20.3	3.22	23.6	3.81	25.2	4.12	26.8	4.51	30.1	5.33	32.4	5.91
	21	17.0	2.68	20.3	3.25	23.6	3.88	25.2	4.26	26.8	4.67	30.1	5.53	32.2	6.05
	23	17.0	2.74	20.3	3.39	23.6	4.15	25.2	4.57	26.8	5.00	30.1	5.93	31.7	6.33
	25	17.0	2.88	20.3	3.62	23.6	4.44	25.2	4.88	26.8	5.35	30.1	6.35	31.3	6.60
	27	17.0	3.07	20.3	3.86	23.6	4.74	25.2	5.22	26.8	5.72	30.1	6.79	30.8	6.88
	29	17.0	3.26	20.3	4.11	23.6	5.06	25.2	5.57	26.8	6.11	29.8	7.11	30.4	7.16
	31	17.0	3.47	20.3	4.38	23.6	5.39	25.2	5.94	26.8	6.52	29.3	7.38	29.9	7.44
	33	17.0	3.69	20.3	4.66	23.6	5.75	25.2	6.33	26.8	6.95	28.9	7.66	29.5	7.72
	35	17.0	3.91	20.3	4.95	23.6	6.12	25.2	6.75	26.8	7.41	28.4	7.94	29.0	8.00
	37	17.0	4.15	20.3	5.26	23.6	6.51	25.2	7.19	26.8	7.90	27.9	8.22	28.6	8.29
	39	17.0	4.41	20.3	5.60	23.6	6.93	25.2	7.65	26.8	8.41	27.5	8.50	28.1	8.57
80 (200)	10	15.1	2.16	18.0	2.59	20.9	3.04	22.4	3.28	23.9	3.52	26.8	4.01	29.7	4.52
	12	15.1	2.20	18.0	2.63	20.9	3.10	22.4	3.34	23.9	3.58	26.8	4.09	29.7	4.61
	14	15.1	2.23	18.0	2.68	20.9	3.15	22.4	3.40	23.9	3.65	26.8	4.17	29.7	4.69
	16	15.1	2.27	18.0	2.73	20.9	3.21	22.4	3.53	23.9	3.72	26.8	4.25	29.7	4.79
	18	15.1	2.31	18.0	2.78	20.9	3.27	22.4	3.60	23.9	3.79	26.8	4.33	29.7	4.88
	20	15.1	2.35	18.0	2.83	20.9	3.34	22.4	3.64	23.9	3.87	26.8	4.49	29.7	5.22
	21	15.1	2.37	18.0	2.86	20.9	3.37	22.4	3.64	23.9	3.95	26.8	4.65	29.7	5.41
	23	15.1	2.42	18.0	2.91	20.9	3.53	22.4	3.87	23.9	4.23	26.8	4.98	29.7	5.80
	25	15.1	2.50	18.0	3.10	20.9	3.78	22.4	4.14	23.9	4.52	26.8	5.33	29.7	6.21
	27	15.1	2.65	18.0	3.30	20.9	4.03	22.4	4.42	23.9	4.82	26.8	5.70	29.7	6.64
	29	15.1	2.82	18.0	3.52	20.9	4.29	22.4	4.71	23.9	5.15	26.8	6.08	29.7	7.10
	31	15.1	3.00	18.0	3.74	20.9	4.57	22.4	5.02	23.9	5.49	26.8	6.49	29.2	7.38
	33	15.1	3.18	18.0	3.98	20.9	4.87	22.4	5.35	23.9	5.85	26.8	6.93	28.8	7.65
	35	15.1	3.37	18.0	4.22	20.9	5.18	22.4	5.69	23.9	6.23	26.8	7.38	28.3	7.93
	37	15.1	3.57	18.0	4.49	20.9	5.50	22.4	6.06	23.9	6.63	26.8	7.87	27.9	8.21
	39	15.1	3.79	18.0	4.76	20.9	5.85	22.4	6.44	23.9	7.06	26.8	8.36	27.4	8.48
70 (175)	10	13.2	1.90	15.8	2.26	18.3	2.63	19.6	2.83	20.9	3.03	23.4	3.45	26.0	3.88
	12	13.2	1.93	15.8	2.29	18.3	2.68	19.6	2.88	20.9	3.09	23.4	3.51	26.0	3.95
	14	13.2	1.96	15.8	2.33	18.3	2.73	19.6	2.93	20.9	3.14	23.4	3.58	26.0	4.02
	16	13.2	1.99	15.8	2.37	18.3	2.78	19.6	2.99	20.9	3.20	23.4	3.64	26.0	4.10
	18	13.2	2.03	15.8	2.41	18.3	2.83	19.6	3.04	20.9	3.26	23.4	3.71	26.0	4.18
	20	13.2	2.06	15.8	2.46	18.3	2.88	19.6	3.10	20.9	3.33	23.4	3.79	26.0	4.30
	21	13.2	2.08	15.8	2.48	18.3	2.91	19.6	3.13	20.9	3.36	23.4	3.85	26.0	4.45
	23	13.2	2.11	15.8	2.53	18.3	2.97	19.6	3.24	20.9	3.52	23.4	4.12	26.0	4.77
	25	13.2	2.15	15.8	2.63	18.3	3.17	19.6	3.46	20.9	3.76	23.4	4.40	26.0	5.10
	27	13.2	2.27	15.8	2.80	18.3	3.37	19.6	3.68	20.9	4.01	23.4	4.70	26.0	5.45
	29	13.2	2.41	15.8	2.97	18.3	3.59	19.6	3.92	20.9	4.27	23.4	5.02	26.0	5.82
	31	13.2	2.56	15.8	3.16	18.3	3.82	19.6	4.18	20.9	4.55	23.4	5.35	26.0	6.21
	33	13.2	2.71	15.8	3.35	18.3	4.06	19.6	4.44	20.9	4.84	23.4	5.70	26.0	6.62
	35	13.2	2.87	15.8	3.56	18.3	4.32	19.6	4.72	20.9	5.15	23.4	6.07	26.0	7.06
	37	13.2	3.04	15.8	3.77	18.3	4.58	19.6	5.02	20.9	5.48	23.4	6.46	26.0	7.52
	39	13.2	3.22	15.8	4.00	18.3	4.87	19.6	5.33	20.9	5.83	23.4	6.87	26.0	8.01
60 (150)	10	11.3	1.65	13.5	1.94	15.7	2.25	16.8	2.41	17.9	2.57	20.1	2.91	22.3	3.26
	12	11.3	1.68	13.5	1.97	15.7	2.28	16.8	2.45	17.9	2.61	20.1	2.96	22.3	3.32
	14	11.3	1.70	13.5	2.00	15.7	2.32	16.8	2.49	17.9	2.66	20.1	3.01	22.3	3.38
	16	11.3	1.73	13.5	2.04	15.7	2.36	16.8	2.53	17.9	2.71	20.1	3.07	22.3	3.44
	18	11.3	1.75	13.5	2.07	15.7	2.40	16.8	2.58	17.9	2.76	20.1	3.12	22.3	3.51
	20	11.3	1.78	13.5	2.10	15.7	2.45	16.8	2.63	17.9	2.81	20.1	3.18	22.3	3.58
	21	11.3	1.80	13.5	2.12	15.7	2.47	16.8	2.65	17.9	2.83	20.1	3.22	22.3	3.61
	23	11.3	1.83	13.5	2.16	15.7	2.51	16.8	2.70	17.9	2.89	20.1	3.34	22.3	3.84
	25	11.3	1.86	13.5	2.20	15.7	2.61	16.8	2.84	17.9	3.07	20.1	3.57	22.3	4.10
	27	11.3	1.92	13.5	2.33	15.7	2.78	16.8	3.02	17.9	3.27	20.1	3.80	22.3	4.38
	29	11.3	2.04	13.5	2.47	15.7	2.96	16.8	3.21	17.9	3.48	20.1	4.05	22.3	4.67
	31	11.3	2.16	13.5	2.62	15.7	3.14	16.8	3.42	17.9	3.70	20.1	4.32	22.3	4.98
	33	11.3	2.28	13.5	2.78	15.7	3.33	16.8	3.63	17.9	3.94	20.1	4.59	22.3	5.30
	35	11.3	2.41	13.5	2.95	15.7	3.54	16.8	3.85	17.9	4.18	20.1	4.88	22.3	5.64
	37	11.3	2.55	13.5	3.12	15.7	3.75	16.8	4.09	17.9	4.44	20.1	5.19	22.3	6.00
	39	11.3	2.69	13.5	3.30	15.7	3.97	16.8	4.34	17.9	4.71	20.1	5.52	22.3	6.38
50 (125)	10	9.45	1.42	11.3	1.65	13.1	1.88	14.0	2.01	14.9	2.13	16.7	2.40	18.6	2.67
	12	9.45	1.44	11.3	1.67	13.1	1.91	14.0	2.04	14.9	2.17	16.7	2.44	18.6	2.72
	14	9.45	1.46	11.3	1.69	13.1	1.94	14.0	2.07	14.9	2.20	16.7	2.48	18.6	2.76
	16	9.45	1.48	11.3	1.72	13.1	1.97	14.0	2.11	14.9	2.24	16.7	2.52	18.6	2.81
	18	9.45	1.50	11.3	1.74	13.1	2.00	14.0	2.14	14.9	2.28	16.7	2.57	18.6	2.87
	20	9.45	1.52	11.3	1.77	13.1	2.04	14.0	2.18	14.9	2.32	16.7	2.61	18.6	2.92
	21	9.45	1.53	11.3	1.79	13.1	2.06	14.0	2.20	14.9	2.34	16.7	2.64	18.6	2.95
	23	9.45	1.56	11.3	1.82	13.1	2.09	14.0	2.24	14.9	2.38	16.7	2.69	18.6	3.02
	25	9.45	1.58	11.3	1.85	13.1	2.13	14.0	2.28	14.9	2.46	16.7	2.82	18.6	3.22
	27	9.45	1.60	11.3	1.91	13.1	2.25	14.0	2.43	14.9	2.61	16.7	3.01	18.6	3.43
	29	9.45	1.70	11.3	2.02	13.1	2.38	14.0	2.58	14.9	2.77	16.7	3.20	18.6	3.65
	31	9.45	1.79	11.3	2.14	13.1	2.53	14.0	2.73	14.9	2.95	16.7	3.40	18.6	3.88
	33	9.45	1.89	11.3	2.27	13.1	2.68	14.0	2.90	14.9	3.13	16.7	3.61	18.6	4.13
	35	9.45	2.00	11.3	2.40	13.1	2.84	14.0	3.07	14.9	3.31	16.7	3.83	18.6	4.39
	37	9.45	2.11	11.3	2.53	13.1	3.00	14.0	3.25	14.9	3.51	16.7	4.07	18.6	4.66
	39	9.45	2.22	11.3	2.68	13.1	3.18	14.0	3.44	14.9	3.72	16.7	4.31	18.6	4.95

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

14

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (390)	10	29.4	4.11	35.1	5.03	40.7	5.99	42.2	6.11	42.7	5.99	43.8	5.74	44.8	5.48
	12	29.4	4.19	35.1	5.13	40.7	6.10	41.6	6.08	42.2	5.95	43.2	5.70	44.3	5.61
	14	29.4	4.27	35.1	5.23	40.6	6.18	41.1	6.05	41.6	5.92	42.7	5.87	43.8	5.93
	16	29.4	4.35	35.1	5.33	40.0	6.15	40.6	6.10	41.1	6.13	42.1	6.19	43.2	6.25
	18	29.4	4.43	35.1	5.43	39.5	6.38	40.0	6.41	40.5	6.45	41.6	6.51	42.7	6.57
	20	29.4	4.52	35.1	5.79	38.9	6.69	39.5	6.73	40.0	6.76	41.1	6.83	42.1	6.89
	21	29.4	4.65	35.1	6.00	38.7	6.85	39.2	6.88	39.7	6.92	40.8	6.99	41.8	7.06
	23	29.4	4.98	35.1	6.43	38.1	7.16	38.7	7.20	39.2	7.23	40.2	7.31	41.3	7.38
	25	29.4	5.32	35.1	6.88	37.6	7.47	38.1	7.51	38.6	7.55	39.7	7.63	40.8	7.71
	27	29.4	5.69	35.1	7.36	37.0	7.79	37.6	7.83	38.1	7.87	39.2	7.95	40.2	8.04
	29	29.4	6.07	35.1	7.87	36.5	8.10	37.0	8.15	37.5	8.19	38.6	8.28	39.7	8.37
	31	29.4	6.47	34.9	8.33	35.9	8.42	36.5	8.47	37.0	8.51	38.1	8.61	39.1	8.70
	33	29.4	6.90	34.3	8.64	35.4	8.74	35.9	8.79	36.5	8.84	37.5	8.94	38.6	9.03
	35	29.4	7.35	33.8	8.96	34.9	9.06	35.4	9.11	35.9	9.16	37.0	9.27	38.0	9.37
	37	29.4	7.83	33.2	9.27	34.3	9.38	34.8	9.44	35.4	9.49	36.4	9.6	37.5	9.7
	39	29.4	8.33	32.7	9.6	33.8	9.7	34.3	9.8	34.8	9.8	35.9	9.9	36.9	10.0
120 (360)	10	27.1	3.76	32.4	4.59	37.6	5.46	40.2	5.90	42.1	6.14	43.0	5.91	44.0	5.68
	12	27.1	3.83	32.4	4.68	37.6	5.56	40.2	6.01	41.5	6.11	42.5	5.88	43.5	5.64
	14	27.1	3.90	32.4	4.76	37.6	5.67	40.2	6.13	41.0	6.08	41.9	5.84	42.9	5.89
	16	27.1	3.97	32.4	4.86	37.6	5.78	39.9	6.17	40.4	6.09	41.4	6.15	42.4	6.20
	18	27.1	4.05	32.4	4.95	37.6	5.98	39.4	6.38	39.9	6.41	40.9	6.46	41.8	6.52
	20	27.1	4.13	32.4	5.15	37.6	6.42	38.8	6.69	39.3	6.72	40.3	6.78	41.3	6.84
	21	27.1	4.17	32.4	5.33	37.6	6.66	38.6	6.84	39.1	6.87	40.0	6.94	41.0	7.00
	23	27.1	4.45	32.4	5.71	37.5	7.12	38.0	7.15	38.5	7.19	39.5	7.26	40.5	7.32
	25	27.1	4.76	32.4	6.11	37.0	7.43	37.5	7.47	38.0	7.50	38.9	7.57	39.9	7.65
	27	27.1	5.08	32.4	6.54	36.4	7.74	36.9	7.78	37.4	7.82	38.4	7.90	39.4	7.97
	29	27.1	5.42	32.4	6.98	35.9	8.06	36.4	8.10	36.9	8.14	37.9	8.22	38.8	8.30
	31	27.1	5.77	32.4	7.45	35.4	8.37	35.8	8.41	36.3	8.46	37.3	8.54	38.3	8.63
	33	27.1	6.15	32.4	7.95	34.8	8.69	35.3	8.73	35.8	8.78	36.8	8.87	37.7	8.96
	35	27.1	6.55	32.4	8.47	34.3	9.00	34.8	9.05	35.2	9.10	36.2	9.19	37.2	9.29
	37	27.1	6.97	32.4	9.03	33.7	9.32	34.2	9.37	34.7	9.42	35.7	9.52	36.7	9.6
	39	27.1	7.41	32.2	9.54	33.2	9.6	33.7	9.7	34.2	9.7	35.1	9.9	36.1	10.0
110 (330)	10	24.9	3.41	29.7	4.15	34.5	4.93	36.9	5.33	39.2	5.74	42.3	6.09	43.2	5.88
	12	24.9	3.47	29.7	4.23	34.5	5.03	36.9	5.43	39.2	5.85	41.7	6.06	42.6	5.84
	14	24.9	3.54	29.7	4.31	34.5	5.12	36.9	5.54	39.2	5.96	41.2	6.03	42.1	5.84
	16	24.9	3.60	29.7	4.39	34.5	5.22	36.9	5.65	39.2	6.07	40.6	6.11	41.5	6.16
	18	24.9	3.67	29.7	4.48	34.5	5.33	36.9	5.80	39.2	6.37	40.1	6.42	41.0	6.47
	20	24.9	3.74	29.7	4.57	34.5	5.64	36.9	6.23	38.7	6.68	39.6	6.73	40.5	6.79
	21	24.9	3.78	29.7	4.71	34.5	5.85	36.9	6.46	38.4	6.83	39.3	6.89	40.2	6.95
	23	24.9	3.96	29.7	5.04	34.5	6.27	36.9	6.93	37.8	7.14	38.7	7.20	39.6	7.27
	25	24.9	4.22	29.7	5.39	34.5	6.71	36.9	7.42	37.3	7.45	38.2	7.52	39.1	7.59
	27	24.9	4.51	29.7	5.76	34.5	7.17	36.3	7.73	36.8	7.77	37.7	7.84	38.5	7.91
	29	24.9	4.80	29.7	6.15	34.5	7.67	35.8	8.05	36.2	8.08	37.1	8.16	38.0	8.23
	31	24.9	5.11	29.7	6.56	34.5	8.19	35.2	8.36	35.7	8.40	36.6	8.48	37.5	8.55
	33	24.9	5.44	29.7	6.99	34.2	8.63	34.7	8.67	35.1	8.72	36.0	8.80	36.9	8.88
	35	24.9	5.79	29.7	7.45	33.7	8.95	34.1	8.99	34.6	9.03	35.5	9.12	36.4	9.21
	37	24.9	6.16	29.7	7.93	33.1	9.26	33.6	9.31	34.0	9.35	34.9	9.45	35.8	9.54
	39	24.9	6.55	29.7	8.45	32.6	9.6	33.0	9.6	33.5	9.7	34.4	9.8	35.3	9.9
100 (300)	10	22.6	3.08	27.0	3.73	31.3	4.42	33.5	4.78	35.7	5.14	40.0	5.87	42.3	6.08
	12	22.6	3.13	27.0	3.80	31.3	4.50	33.5	4.87	35.7	5.23	40.0	5.98	41.8	6.04
	14	22.6	3.19	27.0	3.87	31.3	4.59	33.5	4.96	35.7	5.33	40.0	6.10	41.3	6.01
	16	22.6	3.24	27.0	3.94	31.3	4.68	33.5	5.06	35.7	5.44	39.9	6.18	40.7	6.11
	18	22.6	3.30	27.0	4.02	31.3	4.77	33.5	5.16	35.7	5.55	39.4	6.38	40.2	6.42
	20	22.6	3.37	27.0	4.10	31.3	4.91	33.5	5.42	35.7	5.94	38.8	6.69	39.6	6.74
	21	22.6	3.40	27.0	4.14	31.3	5.09	33.5	5.61	35.7	6.16	38.5	6.84	39.4	6.89
	23	22.6	3.49	27.0	4.41	31.3	5.45	33.5	6.01	35.7	6.60	38.0	7.15	38.8	7.21
	25	22.6	3.72	27.0	4.72	31.3	5.83	33.5	6.43	35.7	7.07	37.4	7.47	38.3	7.52
	27	22.6	3.97	27.0	5.04	31.3	6.23	33.5	6.88	35.7	7.56	36.9	7.78	37.7	7.84
	29	22.6	4.23	27.0	5.37	31.3	6.66	33.5	7.35	35.5	8.03	36.4	8.09	37.2	8.16
	31	22.6	4.50	27.0	5.72	31.3	7.10	33.5	7.85	35.0	8.34	35.8	8.41	36.6	8.48
	33	22.6	4.78	27.0	6.10	31.3	7.57	33.5	8.37	34.5	8.65	35.3	8.73	36.1	8.80
	35	22.6	5.08	27.0	6.49	31.3	8.07	33.5	8.93	33.9	8.97	34.7	9.05	35.5	9.13
	37	22.6	5.40	27.0	6.91	31.3	8.60	33.0	9.24	33.4	9.29	34.2	9.37	35.0	9.45
	39	22.6	5.74	27.0	7.35	31.3	9.16	32.4	9.56	32.8	9.6	33.6	9.7	34.4	9.8

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (270)	10	20.3	2.75	24.3	3.32	28.2	3.92	30.2	4.23	32.1	4.55	36.0	5.20	40.0	5.86
	12	20.3	2.80	24.3	3.38	28.2	3.99	30.2	4.31	32.1	4.63	36.0	5.29	40.0	5.97
	14	20.3	2.85	24.3	3.44	28.2	4.07	30.2	4.39	32.1	4.72	36.0	5.40	40.0	6.08
	16	20.3	2.90	24.3	3.51	28.2	4.15	30.2	4.48	32.1	4.81	36.0	5.50	39.9	6.18
	18	20.3	2.95	24.3	3.57	28.2	4.23	30.2	4.57	32.1	4.91	36.0	5.61	39.3	6.37
	20	20.3	3.01	24.3	3.64	28.2	4.31	30.2	4.66	32.1	5.09	36.0	6.03	38.8	6.68
	21	20.3	3.03	24.3	3.68	28.2	4.39	30.2	4.82	32.1	5.27	36.0	6.25	38.5	6.84
	23	20.3	3.09	24.3	3.83	28.2	4.69	30.2	5.16	32.1	5.65	36.0	6.70	38.0	7.15
	25	20.3	3.26	24.3	4.09	28.2	5.02	30.2	5.52	32.1	6.05	36.0	7.17	37.4	7.46
	27	20.3	3.47	24.3	4.36	28.2	5.36	30.2	5.90	32.1	6.46	36.0	7.67	36.9	7.78
	29	20.3	3.69	24.3	4.65	28.2	5.72	30.2	6.30	32.1	6.90	35.6	8.03	36.3	8.09
	31	20.3	3.92	24.3	4.95	28.2	6.10	30.2	6.72	32.1	7.37	35.1	8.35	35.8	8.41
	33	20.3	4.17	24.3	5.26	28.2	6.49	30.2	7.16	32.1	7.86	34.5	8.66	35.3	8.73
	35	20.3	4.42	24.3	5.60	28.2	6.92	30.2	7.63	32.1	8.38	34.0	8.98	34.7	9.05
	37	20.3	4.69	24.3	5.95	28.2	7.36	30.2	8.13	32.1	8.93	33.4	9.29	34.2	9.37
	39	20.3	4.98	24.3	6.32	28.2	7.84	30.2	8.65	32.1	9.51	32.9	9.6	33.6	9.7
80 (240)	10	18.1	2.44	21.6	2.93	25.1	3.44	26.8	3.71	28.5	3.98	32.0	4.54	35.5	5.11
	12	18.1	2.48	21.6	2.98	25.1	3.50	26.8	3.77	28.5	4.05	32.0	4.62	35.5	5.21
	14	18.1	2.53	21.6	3.03	25.1	3.57	26.8	3.84	28.5	4.13	32.0	4.71	35.5	5.31
	16	18.1	2.57	21.6	3.08	25.1	3.63	26.8	3.92	28.5	4.21	32.0	4.80	35.5	5.41
	18	18.1	2.61	21.6	3.14	25.1	3.70	26.8	3.99	28.5	4.29	32.0	4.89	35.5	5.52
	20	18.1	2.66	21.6	3.20	25.1	3.77	26.8	4.07	28.5	4.37	32.0	5.07	35.5	5.90
	21	18.1	2.68	21.6	3.23	25.1	3.81	26.8	4.11	28.5	4.46	32.0	5.25	35.5	6.11
	23	18.1	2.73	21.6	3.29	25.1	4.00	26.8	4.38	28.5	4.78	32.0	5.63	35.5	6.55
	25	18.1	2.82	21.6	3.51	25.1	4.27	26.8	4.68	28.5	5.11	32.0	6.02	35.5	7.02
	27	18.1	3.00	21.6	3.73	25.1	4.55	26.8	4.99	28.5	5.45	32.0	6.44	35.5	7.51
	29	18.1	3.19	21.6	3.98	25.1	4.85	26.8	5.32	28.5	5.82	32.0	6.88	35.5	8.03
	31	18.1	3.39	21.6	4.23	25.1	5.17	26.8	5.67	28.5	6.21	32.0	7.34	35.0	8.34
	33	18.1	3.59	21.6	4.49	25.1	5.50	26.8	6.04	28.5	6.61	32.0	7.83	34.4	8.65
	35	18.1	3.81	21.6	4.77	25.1	5.85	26.8	6.43	28.5	7.04	32.0	8.35	33.9	8.97
	37	18.1	4.04	21.6	5.07	25.1	6.22	26.8	6.84	28.5	7.50	32.0	8.89	33.3	9.28
	39	18.1	4.28	21.6	5.38	25.1	6.62	26.8	7.28	28.5	7.98	32.0	9.47	32.8	9.6
70 (210)	10	15.8	2.15	18.9	2.55	21.9	2.98	23.5	3.20	25.0	3.43	28.0	3.90	31.1	4.38
	12	15.8	2.18	18.9	2.59	21.9	3.03	23.5	3.26	25.0	3.49	28.0	3.97	31.1	4.46
	14	15.8	2.22	18.9	2.64	21.9	3.08	23.5	3.32	25.0	3.55	28.0	4.04	31.1	4.55
	16	15.8	2.25	18.9	2.68	21.9	3.14	23.5	3.38	25.0	3.62	28.0	4.12	31.1	4.64
	18	15.8	2.29	18.9	2.73	21.9	3.20	23.5	3.44	25.0	3.69	28.0	4.20	31.1	4.73
	20	15.8	2.33	18.9	2.78	21.9	3.26	23.5	3.51	25.0	3.76	28.0	4.28	31.1	4.86
	21	15.8	2.35	18.9	2.80	21.9	3.29	23.5	3.54	25.0	3.80	28.0	4.35	31.1	5.03
	23	15.8	2.39	18.9	2.86	21.9	3.36	23.5	3.66	25.0	3.98	28.0	4.66	31.1	5.39
	25	15.8	2.43	18.9	2.97	21.9	3.58	23.5	3.91	25.0	4.25	28.0	4.98	31.1	5.77
	27	15.8	2.57	18.9	3.16	21.9	3.81	23.5	4.16	25.0	4.53	28.0	5.31	31.1	6.16
	29	15.8	2.73	18.9	3.36	21.9	4.06	23.5	4.44	25.0	4.83	28.0	5.67	31.1	6.58
	31	15.8	2.89	18.9	3.57	21.9	4.32	23.5	4.72	25.0	5.14	28.0	6.04	31.1	7.02
	33	15.8	3.06	18.9	3.79	21.9	4.59	23.5	5.02	25.0	5.48	28.0	6.44	31.1	7.49
	35	15.8	3.25	18.9	4.02	21.9	4.88	23.5	5.34	25.0	5.82	28.0	6.86	31.1	7.98
	37	15.8	3.44	18.9	4.26	21.9	5.18	23.5	5.68	25.0	6.19	28.0	7.30	31.1	8.50
	39	15.8	3.64	18.9	4.52	21.9	5.50	23.5	6.03	25.0	6.58	28.0	7.77	31.1	9.05
60 (180)	10	13.6	1.87	16.2	2.19	18.8	2.54	20.1	2.72	21.4	2.90	24.0	3.28	26.6	3.68
	12	13.6	1.90	16.2	2.23	18.8	2.58	20.1	2.77	21.4	2.95	24.0	3.34	26.6	3.75
	14	13.6	1.92	16.2	2.26	18.8	2.63	20.1	2.81	21.4	3.01	24.0	3.40	26.6	3.82
	16	13.6	1.95	16.2	2.30	18.8	2.67	20.1	2.86	21.4	3.06	24.0	3.47	26.6	3.89
	18	13.6	1.98	16.2	2.34	18.8	2.72	20.1	2.91	21.4	3.12	24.0	3.53	26.6	3.96
	20	13.6	2.01	16.2	2.38	18.8	2.77	20.1	2.97	21.4	3.17	24.0	3.60	26.6	4.04
	21	13.6	2.03	16.2	2.40	18.8	2.79	20.1	2.99	21.4	3.20	24.0	3.64	26.6	4.08
	23	13.6	2.06	16.2	2.44	18.8	2.84	20.1	3.05	21.4	3.27	24.0	3.78	26.6	4.34
	25	13.6	2.10	16.2	2.49	18.8	2.95	20.1	3.21	21.4	3.47	24.0	4.03	26.6	4.64
	27	13.6	2.17	16.2	2.63	18.8	3.14	20.1	3.41	21.4	3.70	24.0	4.30	26.6	4.95
	29	13.6	2.30	16.2	2.80	18.8	3.34	20.1	3.63	21.4	3.94	24.0	4.58	26.6	5.28
	31	13.6	2.44	16.2	2.97	18.8	3.55	20.1	3.86	21.4	4.19	24.0	4.88	26.6	5.63
	33	13.6	2.58	16.2	3.14	18.8	3.77	20.1	4.10	21.4	4.45	24.0	5.19	26.6	5.99
	35	13.6	2.73	16.2	3.33	18.8	4.00	20.1	4.35	21.4	4.73	24.0	5.52	26.6	6.38
	37	13.6	2.88	16.2	3.53	18.8	4.24	20.1	4.62	21.4	5.02	24.0	5.87	26.6	6.78
	39	13.6	3.05	16.2	3.73	18.8	4.49	20.1	4.90	21.4	5.33	24.0	6.23	26.6	7.22
50 (150)	10	11.3	1.61	13.5	1.86	15.7	2.13	16.8	2.27	17.8	2.41	20.0	2.71	22.2	3.02
	12	11.3	1.63	13.5	1.89	15.7	2.16	16.8	2.30	17.8	2.45	20.0	2.75	22.2	3.07
	14	11.3	1.65	13.5	1.91	15.7	2.19	16.8	2.34	17.8	2.49	20.0	2.80	22.2	3.12
	16	11.3	1.67	13.5	1.94	15.7	2.23	16.8	2.38	17.8	2.53	20.0	2.85	22.2	3.18
	18	11.3	1.70	13.5	1.97	15.7	2.27	16.8	2.42	17.8	2.58	20.0	2.90	22.2	3.24
	20	11.3	1.72	13.5	2.00	15.7	2.30	16.8	2.46	17.8	2.62	20.0	2.95	22.2	3.30
	21	11.3	1.73	13.5	2.02	15.7	2.32	16.8	2.48	17.8	2.65	20.0	2.98	22.2	3.33
	23	11.3	1.76	13.5	2.05	15.7	2.36	16.8	2.53	17.8	2.69	20.0	3.04	22.2	3.41
	25	11.3	1.78	13.5	2.09	15.7	2.41	16.8	2.58	17.8	2.78	20.0	3.19	22.2	3.64
	27	11.3	1.81	13.5	2.16	15.7	2.54	16.8	2.74	17.8	2.95	20.0	3.40	22.2	3.87
	29	11.3	1.92	13.5	2.29	15.7	2.70	16.8	2.91	17.8	3.14	20.0	3.61	22.2	4.13
	31	11.3	2.03	13.5	2.42	15.7	2.86	16.8	3.09	17.8	3.33	20.0	3.84	22.2	4.39
	33	11.3	2.14	13.5	2.56	15.7	3.03	16.8	3.28	17.8	3.53	20.0	4.08	22.2	4.67
	35	11.3	2.26	13.5	2.71	15.7	3.21	16.8	3.47	17.8	3.75	20.0	4.33	22.2	4.96
	37	11.3	2.38	13.5	2.86	15.7	3.39	16.8	3.68	17.8	3.97	20.0	4.60	22.2	5.27
	39	11.3	2.51	13.5	3.03	15.7	3.59	16.8	3.89	17.8	4.21	20.0	4.87	22.2	5.59

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (455)	10	35.1	5.71	41.9	6.99	48.6	8.31	50.4	8.49	51.0	8.32	52.3	7.96	53.5	7.61
	12	35.1	5.81	41.9	7.12	48.6	8.47	49.7	8.44	50.4	8.27	51.6	7.91	52.9	7.79
	14	35.1	5.92	41.9	7.26	48.4	8.58	49.1	8.40	49.7	8.22	51.0	8.16	52.2	8.23
	16	35.1	6.04	41.9	7.40	47.8	8.53	48.4	8.47	49.1	8.51	50.3	8.60	51.6	8.68
	18	35.1	6.16	41.9	7.55	47.1	8.86	47.8	8.91	48.4	8.95	49.7	9.04	50.9	9.12
	20	35.1	6.28	41.9	8.04	46.5	9.3	47.1	9.3	47.8	9.4	49.0	9.5	50.3	9.6
	21	35.1	6.46	41.9	8.33	46.2	9.5	46.8	9.6	47.4	9.6	48.7	9.7	50.0	9.8
	23	35.1	6.91	41.9	8.93	45.5	9.9	46.1	10.0	46.8	10.0	48.0	10.1	49.3	10.2
	25	35.1	7.39	41.9	9.6	44.9	10.4	45.5	10.4	46.1	10.5	47.4	10.6	48.7	10.7
	27	35.1	7.90	41.9	10.2	44.2	10.8	44.8	10.9	45.5	10.9	46.7	11.0	48.0	11.2
	29	35.1	8.43	41.9	10.9	43.6	11.3	44.2	11.3	44.8	11.4	46.1	11.5	47.4	11.6
	31	35.1	8.99	41.6	11.6	42.9	11.7	43.5	11.8	44.2	11.8	45.4	12.0	46.7	12.1
	33	35.1	9.6	41.0	12.0	42.3	12.1	42.9	12.2	43.5	12.3	44.8	12.4	46.1	12.5
	35	35.1	10.2	40.3	12.4	41.6	12.6	42.2	12.7	42.9	12.7	44.1	12.9	45.4	13.0
	37	35.1	10.9	39.7	12.9	41.0	13.0	41.6	13.1	42.2	13.2	43.5	13.3	44.8	13.5
	39	35.1	11.6	39.0	13.3	40.3	13.5	40.9	13.6	41.6	13.6	42.8	13.8	44.1	14.0
120 (420)	10	32.4	5.22	38.6	6.37	44.9	7.58	48.0	8.19	50.2	8.53	51.4	8.21	52.6	7.89
	12	32.4	5.31	38.6	6.49	44.9	7.72	48.0	8.35	49.6	8.49	50.7	8.16	51.9	7.83
	14	32.4	5.41	38.6	6.62	44.9	7.87	48.0	8.51	48.9	8.45	50.1	8.11	51.2	8.17
	16	32.4	5.51	38.6	6.74	44.9	8.02	47.7	8.57	48.3	8.46	49.4	8.54	50.6	8.61
	18	32.4	5.62	38.6	6.88	44.9	8.30	47.0	8.85	47.6	8.89	48.8	8.97	49.9	9.06
	20	32.4	5.73	38.6	7.15	44.9	8.92	46.4	9.3	47.0	9.3	48.1	9.4	49.3	9.5
	21	32.4	5.79	38.6	7.41	44.9	9.24	46.1	9.5	46.6	9.5	47.8	9.6	49.0	9.7
	23	32.4	6.18	38.6	7.93	44.8	9.9	45.4	9.9	46.0	10.0	47.2	10.1	48.3	10.2
	25	32.4	6.61	38.6	8.49	44.2	10.3	44.8	10.4	45.3	10.4	46.5	10.5	47.7	10.6
	27	32.4	7.05	38.6	9.08	43.5	10.8	44.1	10.8	44.7	10.9	45.9	11.0	47.0	11.1
	29	32.4	7.52	38.6	9.7	42.9	11.2	43.4	11.2	44.0	11.3	45.2	11.4	46.4	11.5
	31	32.4	8.02	38.6	10.3	42.2	11.6	42.8	11.7	43.4	11.7	44.6	11.9	45.7	12.0
	33	32.4	8.54	38.6	11.0	41.6	12.1	42.1	12.1	42.7	12.2	43.9	12.3	45.1	12.4
	35	32.4	9.09	38.6	11.8	40.9	12.5	41.5	12.6	42.1	12.6	43.2	12.8	44.4	12.9
	37	32.4	9.7	38.6	12.5	40.3	12.9	40.8	13.0	41.4	13.1	42.6	13.2	43.8	13.4
	39	32.4	10.3	38.4	13.2	39.6	13.4	40.2	13.5	40.8	13.5	41.9	13.7	43.1	13.8
110 (385)	10	29.7	4.74	35.4	5.77	41.1	6.85	44.0	7.41	46.9	7.97	50.5	8.46	51.6	8.16
	12	29.7	4.82	35.4	5.88	41.1	6.98	44.0	7.55	46.9	8.12	49.8	8.41	50.9	8.12
	14	29.7	4.91	35.4	5.99	41.1	7.11	44.0	7.69	46.9	8.27	49.2	8.37	50.3	8.11
	16	29.7	5.00	35.4	6.10	41.1	7.25	44.0	7.84	46.9	8.43	48.5	8.48	49.6	8.55
	18	29.7	5.10	35.4	6.22	41.1	7.40	44.0	8.06	46.8	8.84	47.9	8.91	49.0	8.99
	20	29.7	5.20	35.4	6.35	41.1	7.84	44.0	8.66	46.2	9.3	47.2	9.3	48.3	9.4
	21	29.7	5.25	35.4	6.54	41.1	8.12	44.0	8.97	45.8	9.5	46.9	9.6	48.0	9.6
	23	29.7	5.49	35.4	7.00	41.1	8.70	44.0	9.6	45.2	9.9	46.3	10.0	47.3	10.1
	25	29.7	5.87	35.4	7.49	41.1	9.3	44.0	10.3	44.5	10.4	45.6	10.4	46.7	10.5
	27	29.7	6.26	35.4	8.00	41.1	10.0	43.4	10.7	43.9	10.8	45.0	10.9	46.0	11.0
	29	29.7	6.67	35.4	8.54	41.1	10.6	42.7	11.2	43.2	11.2	44.3	11.3	45.4	11.4
	31	29.7	7.10	35.4	9.11	41.1	11.4	42.0	11.6	42.6	11.7	43.7	11.8	44.7	11.9
	33	29.7	7.56	35.4	9.7	40.9	12.0	41.4	12.0	41.9	12.1	43.0	12.2	44.1	12.3
	35	29.7	8.04	35.4	10.3	40.2	12.4	40.7	12.5	41.3	12.5	42.4	12.7	43.4	12.8
	37	29.7	8.55	35.4	11.0	39.6	12.9	40.1	12.9	40.6	13.0	41.7	13.1	42.8	13.2
	39	29.7	9.09	35.4	11.7	38.9	13.3	39.4	13.4	40.0	13.4	41.1	13.6	42.1	13.7
100 (350)	10	27.0	4.27	32.2	5.18	37.4	6.14	40.0	6.63	42.6	7.13	47.8	8.15	50.6	8.44
	12	27.0	4.35	32.2	5.28	37.4	6.25	40.0	6.76	42.6	7.27	47.8	8.31	49.9	8.39
	14	27.0	4.42	32.2	5.37	37.4	6.37	40.0	6.89	42.6	7.41	47.8	8.46	49.3	8.35
	16	27.0	4.51	32.2	5.48	37.4	6.50	40.0	7.02	42.6	7.55	47.6	8.58	48.6	8.49
	18	27.0	4.59	32.2	5.58	37.4	6.62	40.0	7.16	42.6	7.70	47.0	8.85	48.0	8.92
	20	27.0	4.68	32.2	5.69	37.4	6.82	40.0	7.52	42.6	8.25	46.3	9.3	47.3	9.4
	21	27.0	4.72	32.2	5.75	37.4	7.07	40.0	7.79	42.6	8.55	46.0	9.5	47.0	9.6
	23	27.0	4.85	32.2	6.13	37.4	7.57	40.0	8.35	42.6	9.16	45.4	9.9	46.3	10.0
	25	27.0	5.17	32.2	6.55	37.4	8.10	40.0	8.94	42.6	9.8	44.7	10.4	45.7	10.4
	27	27.0	5.51	32.2	6.99	37.4	8.65	40.0	9.6	42.6	10.5	44.1	10.8	45.0	10.9
	29	27.0	5.87	32.2	7.46	37.4	9.24	40.0	10.2	42.4	11.1	43.4	11.2	44.4	11.3
	31	27.0	6.25	32.2	7.95	37.4	9.9	40.0	10.9	41.8	11.6	42.8	11.7	43.7	11.8
	33	27.0	6.64	32.2	8.46	37.4	10.5	40.0	11.6	41.1	12.0	42.1	12.1	43.1	12.2
	35	27.0	7.06	32.2	9.01	37.4	11.2	40.0	12.4	40.5	12.5	41.5	12.6	42.4	12.7
	37	27.0	7.50	32.2	9.6	37.4	11.9	39.3	12.8	39.8	12.9	40.8	13.0	41.8	13.1
	39	27.0	7.96	32.2	10.2	37.4	12.7	38.7	13.3	39.2	13.3	40.2	13.5	41.1	13.6

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (315)	10	24.3	3.82	29.0	4.61	33.7	5.45	36.0	5.88	38.3	6.32	43.0	7.22	47.7	8.13
	12	24.3	3.89	29.0	4.69	33.7	5.55	36.0	5.99	38.3	6.43	43.0	7.35	47.7	8.29
	14	24.3	3.96	29.0	4.78	33.7	5.65	36.0	6.10	38.3	6.56	43.0	7.49	47.7	8.44
	16	24.3	4.03	29.0	4.87	33.7	5.76	36.0	6.22	38.3	6.68	43.0	7.64	47.6	8.58
	18	24.3	4.10	29.0	4.96	33.7	5.87	36.0	6.34	38.3	6.82	43.0	7.79	47.0	8.85
	20	24.3	4.17	29.0	5.06	33.7	5.99	36.0	6.47	38.3	7.07	43.0	8.37	46.3	9.3
	21	24.3	4.21	29.0	5.11	33.7	6.09	36.0	6.69	38.3	7.32	43.0	8.67	46.0	9.5
	23	24.3	4.29	29.0	5.32	33.7	6.52	36.0	7.17	38.3	7.85	43.0	9.3	45.3	9.9
	25	24.3	4.52	29.0	5.68	33.7	6.97	36.0	7.67	38.3	8.40	43.0	10.0	44.7	10.4
	27	24.3	4.81	29.0	6.05	33.7	7.44	36.0	8.19	38.3	8.98	43.0	10.7	44.0	10.8
	29	24.3	5.12	29.0	6.45	33.7	7.94	36.0	8.74	38.3	9.6	42.5	11.2	43.4	11.2
	31	24.3	5.45	29.0	6.87	33.7	8.46	36.0	9.3	38.3	10.2	41.9	11.6	42.7	11.7
	33	24.3	5.78	29.0	7.31	33.7	9.02	36.0	9.9	38.3	10.9	41.2	12.0	42.1	12.1
	35	24.3	6.14	29.0	7.77	33.7	9.6	36.0	10.6	38.3	11.6	40.6	12.5	41.4	12.6
	37	24.3	6.52	29.0	8.26	33.7	10.2	36.0	11.3	38.3	12.4	39.9	12.9	40.8	13.0
	39	24.3	6.92	29.0	8.78	33.7	10.9	36.0	12.0	38.3	13.2	39.3	13.3	40.1	13.5
80 (280)	10	21.6	3.40	25.8	4.07	29.9	4.78	32.0	5.15	34.1	5.52	38.2	6.30	42.4	7.10
	12	21.6	3.45	25.8	4.14	29.9	4.86	32.0	5.24	34.1	5.62	38.2	6.42	42.4	7.23
	14	21.6	3.51	25.8	4.21	29.9	4.95	32.0	5.34	34.1	5.73	38.2	6.54	42.4	7.37
	16	21.6	3.57	25.8	4.28	29.9	5.04	32.0	5.44	34.1	5.84	38.2	6.67	42.4	7.51
	18	21.6	3.63	25.8	4.36	29.9	5.14	32.0	5.54	34.1	5.95	38.2	6.80	42.4	7.66
	20	21.6	3.69	25.8	4.44	29.9	5.24	32.0	5.65	34.1	6.07	38.2	7.05	42.4	8.19
	21	21.6	3.73	25.8	4.49	29.9	5.29	32.0	5.71	34.1	6.20	38.2	7.30	42.4	8.49
	23	21.6	3.79	25.8	4.57	29.9	5.55	32.0	6.08	34.1	6.63	38.2	7.82	42.4	9.10
	25	21.6	3.92	25.8	4.87	29.9	5.93	32.0	6.49	34.1	7.09	38.2	8.36	42.4	9.7
	27	21.6	4.17	25.8	5.19	29.9	6.32	32.0	6.93	34.1	7.57	38.2	8.94	42.4	10.4
	29	21.6	4.43	25.8	5.52	29.9	6.74	32.0	7.39	34.1	8.08	38.2	9.5	42.4	11.1
	31	21.6	4.70	25.8	5.87	29.9	7.18	32.0	7.88	34.1	8.62	38.2	10.2	41.8	11.6
	33	21.6	4.99	25.8	6.24	29.9	7.64	32.0	8.39	34.1	9.18	38.2	10.9	41.1	12.0
	35	21.6	5.29	25.8	6.63	29.9	8.13	32.0	8.93	34.1	9.8	38.2	11.6	40.4	12.5
	37	21.6	5.61	25.8	7.04	29.9	8.64	32.0	9.50	34.1	10.4	38.2	12.3	39.8	12.9
	39	21.6	5.94	25.8	7.47	29.9	9.19	32.0	10.11	34.1	11.1	38.2	13.2	39.1	13.3
70 (245)	10	18.9	2.99	22.5	3.54	26.2	4.14	28.0	4.44	29.8	4.76	33.5	5.41	37.1	6.08
	12	18.9	3.03	22.5	3.60	26.2	4.21	28.0	4.52	29.8	4.84	33.5	5.51	37.1	6.20
	14	18.9	3.08	22.5	3.66	26.2	4.28	28.0	4.60	29.8	4.93	33.5	5.61	37.1	6.31
	16	18.9	3.13	22.5	3.72	26.2	4.36	28.0	4.69	29.8	5.03	33.5	5.72	37.1	6.44
	18	18.9	3.18	22.5	3.79	26.2	4.44	28.0	4.78	29.8	5.12	33.5	5.83	37.1	6.56
	20	18.9	3.23	22.5	3.86	26.2	4.52	28.0	4.87	29.8	5.22	33.5	5.95	37.1	6.75
	21	18.9	3.26	22.5	3.89	26.2	4.57	28.0	4.91	29.8	5.27	33.5	6.04	37.1	6.99
	23	18.9	3.32	22.5	3.97	26.2	4.66	28.0	5.08	29.8	5.52	33.5	6.47	37.1	7.48
	25	18.9	3.38	22.5	4.12	26.2	4.97	28.0	5.42	29.8	5.90	33.5	6.91	37.1	8.01
	27	18.9	3.57	22.5	4.39	26.2	5.30	28.0	5.78	29.8	6.29	33.5	7.38	37.1	8.56
	29	18.9	3.79	22.5	4.66	26.2	5.64	28.0	6.16	29.8	6.71	33.5	7.87	37.1	9.14
	31	18.9	4.02	22.5	4.95	26.2	6.00	28.0	6.56	29.8	7.14	33.5	8.39	37.1	9.7
	33	18.9	4.26	22.5	5.26	26.2	6.38	28.0	6.98	29.8	7.60	33.5	8.94	37.1	10.4
	35	18.9	4.51	22.5	5.58	26.2	6.77	28.0	7.42	29.8	8.09	33.5	9.5	37.1	11.1
	37	18.9	4.77	22.5	5.92	26.2	7.19	28.0	7.88	29.8	8.60	33.5	10.1	37.1	11.8
	39	18.9	5.05	22.5	6.27	26.2	7.64	28.0	8.37	29.8	9.14	33.5	10.8	37.1	12.6
60 (210)	10	16.2	2.60	19.3	3.05	22.4	3.53	24.0	3.78	25.6	4.03	28.7	4.56	31.8	5.11
	12	16.2	2.63	19.3	3.09	22.4	3.59	24.0	3.84	25.6	4.10	28.7	4.64	31.8	5.20
	14	16.2	2.67	19.3	3.14	22.4	3.65	24.0	3.91	25.6	4.17	28.7	4.73	31.8	5.30
	16	16.2	2.71	19.3	3.19	22.4	3.71	24.0	3.97	25.6	4.25	28.7	4.81	31.8	5.40
	18	16.2	2.75	19.3	3.25	22.4	3.77	24.0	4.05	25.6	4.33	28.7	4.90	31.8	5.50
	20	16.2	2.80	19.3	3.30	22.4	3.84	24.0	4.12	25.6	4.41	28.7	5.00	31.8	5.61
	21	16.2	2.82	19.3	3.33	22.4	3.88	24.0	4.16	25.6	4.45	28.7	5.05	31.8	5.67
	23	16.2	2.87	19.3	3.39	22.4	3.95	24.0	4.24	25.6	4.53	28.7	5.25	31.8	6.03
	25	16.2	2.91	19.3	3.45	22.4	4.10	24.0	4.45	25.6	4.82	28.7	5.60	31.8	6.44
	27	16.2	3.02	19.3	3.66	22.4	4.36	24.0	4.74	25.6	5.14	28.7	5.97	31.8	6.87
	29	16.2	3.20	19.3	3.88	22.4	4.64	24.0	5.04	25.6	5.47	28.7	6.36	31.8	7.33
	31	16.2	3.39	19.3	4.12	22.4	4.93	24.0	5.36	25.6	5.81	28.7	6.77	31.8	7.81
	33	16.2	3.58	19.3	4.37	22.4	5.23	24.0	5.69	25.6	6.18	28.7	7.21	31.8	8.32
	35	16.2	3.79	19.3	4.63	22.4	5.55	24.0	6.05	25.6	6.56	28.7	7.66	31.8	8.85
	37	16.2	4.00	19.3	4.90	22.4	5.89	24.0	6.42	25.6	6.97	28.7	8.15	31.8	9.4
	39	16.2	4.23	19.3	5.18	22.4	6.24	24.0	6.81	25.6	7.40	28.7	8.66	31.8	10.0
50 (175)	10	13.5	2.23	16.1	2.58	18.7	2.96	20.0	3.15	21.3	3.35	23.9	3.76	26.5	4.19
	12	13.5	2.26	16.1	2.62	18.7	3.00	20.0	3.20	21.3	3.40	23.9	3.82	26.5	4.26
	14	13.5	2.29	16.1	2.66	18.7	3.05	20.0	3.25	21.3	3.46	23.9	3.89	26.5	4.34
	16	13.5	2.32	16.1	2.70	18.7	3.10	20.0	3.30	21.3	3.52	23.9	3.96	26.5	4.42
	18	13.5	2.35	16.1	2.74	18.7	3.15	20.0	3.36	21.3	3.58	23.9	4.03	26.5	4.50
	20	13.5	2.39	16.1	2.78	18.7	3.20	20.0	3.42	21.3	3.64	23.9	4.10	26.5	4.58
	21	13.5	2.41	16.1	2.80	18.7	3.23	20.0	3.45	21.3	3.67	23.9	4.14	26.5	4.63
	23	13.5	2.44	16.1	2.85	18.7	3.28	20.0	3.51	21.3	3.74	23.9	4.22	26.5	4.73
	25	13.5	2.48	16.1	2.90	18.7	3.34	20.0	3.58	21.3	3.85	23.9	4.43	26.5	5.05
	27	13.5	2.52	16.1	3.00	18.7	3.53	20.0	3.81	21.3	4.10	23.9	4.72	26.5	5.38
	29	13.5	2.66	16.1	3.18	18.7	3.74	20.0	4.04	21.3	4.36	23.9	5.02	26.5	5.73
	31	13.5	2.81	16.1	3.36	18.7	3.97	20.0	4.29	21.3	4.62	23.9	5.33	26.5	6.09
	33	13.5	2.97	16.1	3.56	18.7	4.20	20.0	4.55	21.3	4.91	23.9	5.66	26.5	6.48
	35	13.5	3.14	16.1	3.76	18.7	4.45	20.0	4.82	21.3	5.20	23.9	6.01	26.5	6.89
	37	13.5	3.31	16.1	3.98	18.7	4.71	20.0	5.10	21.3	5.51	23.9	6.38	26.5	7.31
	39	13.5	3.49	16.1	4.20	18.7	4.99	20.0	5.41	21.3	5.84	23.9	6.77	26.5	7.77

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
130 (520)	10	39.5	6.54	47.1	8.00	54.7	9.5	56.7	9.7	57.4	9.5	58.8	9.1	60.2	8.71
	12	39.5	6.66	47.1	8.15	54.7	9.7	55.9	9.7	56.7	9.5	58.1	9.1	59.5	8.9
	14	39.5	6.78	47.1	8.31	54.5	9.8	55.2	9.6	55.9	9.4	57.3	9.3	58.8	9.4
	16	39.5	6.92	47.1	8.47	53.8	9.8	54.5	9.7	55.2	9.7	56.6	9.8	58.0	9.9
	18	39.5	7.05	47.1	8.64	53.0	10.1	53.7	10.2	54.5	10.2	55.9	10.3	57.3	10.4
	20	39.5	7.19	47.1	9.2	52.3	10.6	53.0	10.7	53.7	10.7	55.2	10.9	56.6	11.0
	21	39.5	7.39	47.1	9.5	51.9	10.9	52.7	10.9	53.4	11.0	54.8	11.1	56.2	11.2
	23	39.5	7.92	47.1	10.2	51.2	11.4	51.9	11.4	52.6	11.5	54.1	11.6	55.5	11.7
	25	39.5	8.46	47.1	10.9	50.5	11.9	51.2	11.9	51.9	12.0	53.3	12.1	54.7	12.3
	27	39.5	9.0	47.1	11.7	49.7	12.4	50.5	12.5	51.2	12.5	52.6	12.6	54.0	12.8
	29	39.5	9.7	47.1	12.5	49.0	12.9	49.7	13.0	50.4	13.0	51.9	13.2	53.3	13.3
	31	39.5	10.3	46.9	13.2	48.3	13.4	49.0	13.5	49.7	13.5	51.1	13.7	52.5	13.8
	33	39.5	11.0	46.1	13.7	47.5	13.9	48.3	14.0	49.0	14.1	50.4	14.2	51.8	14.4
	35	39.5	11.7	45.4	14.2	46.8	14.4	47.5	14.5	48.2	14.6	49.7	14.7	51.1	14.9
	37	39.5	12.4	44.7	14.7	46.1	14.9	46.8	15.0	47.5	15.1	48.9	15.3	50.4	15.4
	39	39.5	13.2	43.9	15.3	45.4	15.4	46.1	15.5	46.8	15.6	48.2	15.8	49.6	16.0
120 (480)	10	36.4	5.97	43.5	7.30	50.5	8.68	54.0	9.4	56.5	9.8	57.8	9.4	59.1	9.0
	12	36.4	6.08	43.5	7.43	50.5	8.84	54.0	9.6	55.8	9.7	57.1	9.4	58.4	9.0
	14	36.4	6.20	43.5	7.58	50.5	9.0	54.0	9.7	55.0	9.7	56.3	9.3	57.7	9.4
	16	36.4	6.31	43.5	7.72	50.5	9.2	53.6	9.8	54.3	9.7	55.6	9.8	56.9	9.9
	18	36.4	6.44	43.5	7.88	50.5	9.5	52.9	10.1	53.6	10.2	54.9	10.3	56.2	10.4
	20	36.4	6.56	43.5	8.19	50.5	10.2	52.2	10.6	52.8	10.7	54.1	10.8	55.5	10.9
	21	36.4	6.63	43.5	8.48	50.5	10.6	51.8	10.9	52.5	10.9	53.8	11.0	55.1	11.1
	23	36.4	7.08	43.5	9.1	50.4	11.3	51.1	11.4	51.7	11.4	53.0	11.5	54.4	11.6
	25	36.4	7.56	43.5	9.7	49.7	11.8	50.3	11.9	51.0	11.9	52.3	12.0	53.6	12.2
	27	36.4	8.08	43.5	10.4	49.0	12.3	49.6	12.4	50.3	12.4	51.6	12.6	52.9	12.7
	29	36.4	8.61	43.5	11.1	48.2	12.8	48.9	12.9	49.5	12.9	50.9	13.1	52.2	13.2
	31	36.4	9.2	43.5	11.9	47.5	13.3	48.1	13.4	48.8	13.4	50.1	13.6	51.4	13.7
	33	36.4	9.8	43.5	12.6	46.8	13.8	47.4	13.9	48.1	14.0	49.4	14.1	50.7	14.2
	35	36.4	10.4	43.5	13.5	46.0	14.3	46.7	14.4	47.3	14.5	48.7	14.6	50.0	14.8
	37	36.4	11.1	43.5	14.4	45.3	14.8	46.0	14.9	46.6	15.0	47.9	15.1	49.2	15.3
	39	36.4	11.8	43.2	15.2	44.6	15.3	45.2	15.4	45.9	15.5	47.2	15.7	48.5	15.8
110 (440)	10	33.4	5.43	39.8	6.61	46.3	7.85	49.5	8.48	52.7	9.1	56.8	9.7	58.0	9.3
	12	33.4	5.52	39.8	6.73	46.3	7.99	49.5	8.64	52.7	9.3	56.1	9.6	57.3	9.3
	14	33.4	5.62	39.8	6.86	46.3	8.15	49.5	8.81	52.7	9.5	55.3	9.6	56.5	9.3
	16	33.4	5.73	39.8	6.99	46.3	8.31	49.5	9.0	52.7	9.7	54.6	9.7	55.8	9.8
	18	33.4	5.84	39.8	7.13	46.3	8.47	49.5	9.2	52.7	10.1	53.9	10.2	55.1	10.3
	20	33.4	5.95	39.8	7.27	46.3	9.0	49.5	9.9	51.9	10.6	53.1	10.7	54.3	10.8
	21	33.4	6.01	39.8	7.49	46.3	9.3	49.5	10.3	51.6	10.9	52.8	11.0	54.0	11.0
	23	33.4	6.29	39.8	8.02	46.3	10.0	49.5	11.0	50.8	11.4	52.0	11.5	53.2	11.6
	25	33.4	6.72	39.8	8.58	46.3	10.7	49.5	11.8	50.1	11.9	51.3	12.0	52.5	12.1
	27	33.4	7.17	39.8	9.2	46.3	11.4	48.8	12.3	49.4	12.4	50.6	12.5	51.8	12.6
	29	33.4	7.64	39.8	9.8	46.3	12.2	48.0	12.8	48.6	12.9	49.8	13.0	51.0	13.1
	31	33.4	8.13	39.8	10.4	46.3	13.0	47.3	13.3	47.9	13.4	49.1	13.5	50.3	13.6
	33	33.4	8.66	39.8	11.1	46.0	13.7	46.6	13.8	47.2	13.9	48.4	14.0	49.6	14.1
	35	33.4	9.2	39.8	11.8	45.2	14.2	45.8	14.3	46.4	14.4	47.6	14.5	48.9	14.6
	37	33.4	9.8	39.8	12.6	44.5	14.7	45.1	14.8	45.7	14.9	46.9	15.0	48.1	15.2
	39	33.4	10.4	39.8	13.4	43.8	15.2	44.4	15.3	45.0	15.4	46.2	15.5	47.4	15.7
100 (400)	10	30.4	4.89	36.2	5.93	42.1	7.03	45.0	7.60	47.9	8.17	53.8	9.3	56.9	9.7
	12	30.4	4.98	36.2	6.04	42.1	7.16	45.0	7.74	47.9	8.32	53.8	9.5	56.2	9.6
	14	30.4	5.07	36.2	6.15	42.1	7.30	45.0	7.89	47.9	8.48	53.8	9.7	55.4	9.6
	16	30.4	5.16	36.2	6.27	42.1	7.44	45.0	8.04	47.9	8.65	53.6	9.8	54.7	9.7
	18	30.4	5.26	36.2	6.39	42.1	7.59	45.0	8.20	47.9	8.82	52.9	10.1	54.0	10.2
	20	30.4	5.36	36.2	6.52	42.1	7.81	45.0	8.61	47.9	9.4	52.1	10.6	53.2	10.7
	21	30.4	5.41	36.2	6.58	42.1	8.09	45.0	8.9	47.9	9.8	51.8	10.9	52.9	11.0
	23	30.4	5.55	36.2	7.02	42.1	8.67	45.0	9.6	47.9	10.5	51.0	11.4	52.1	11.5
	25	30.4	5.92	36.2	7.50	42.1	9.3	45.0	10.2	47.9	11.2	50.3	11.9	51.4	12.0
	27	30.4	6.31	36.2	8.01	42.1	9.9	45.0	10.9	47.9	12.0	49.6	12.4	50.7	12.5
	29	30.4	6.72	36.2	8.54	42.1	10.6	45.0	11.7	47.7	12.8	48.8	12.9	49.9	13.0
	31	30.4	7.15	36.2	9.1	42.1	11.3	45.0	12.5	47.0	13.3	48.1	13.4	49.2	13.5
	33	30.4	7.60	36.2	9.7	42.1	12.0	45.0	13.3	46.3	13.8	47.4	13.9	48.5	14.0
	35	30.4	8.08	36.2	10.3	42.1	12.8	45.0	14.2	45.5	14.3	46.6	14.4	47.7	14.5
	37	30.4	8.59	36.2	11.0	42.1	13.7	44.3	14.7	44.8	14.8	45.9	14.9	47.0	15.0
	39	30.4	9.1	36.2	11.7	42.1	14.6	43.5	15.2	44.1	15.3	45.2	15.4	46.3	15.6

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
90 (360)	10	27.3	4.38	32.6	5.28	37.9	6.24	40.5	6.73	43.1	7.23	48.4	8.26	53.7	9.3
	12	27.3	4.45	32.6	5.38	37.9	6.35	40.5	6.86	43.1	7.37	48.4	8.42	53.7	9.5
	14	27.3	4.53	32.6	5.47	37.9	6.47	40.5	6.99	43.1	7.51	48.4	8.58	53.7	9.7
	16	27.3	4.61	32.6	5.57	37.9	6.59	40.5	7.12	43.1	7.66	48.4	8.75	53.6	9.8
	18	27.3	4.69	32.6	5.68	37.9	6.72	40.5	7.26	43.1	7.81	48.4	8.9	52.8	10.1
	20	27.3	4.78	32.6	5.79	37.9	6.86	40.5	7.41	43.1	8.10	48.4	9.6	52.1	10.6
	21	27.3	4.82	32.6	5.85	37.9	6.97	40.5	7.66	43.1	8.39	48.4	9.9	51.7	10.9
	23	27.3	4.92	32.6	6.09	37.9	7.46	40.5	8.21	43.1	9.0	48.4	10.7	51.0	11.4
	25	27.3	5.18	32.6	6.50	37.9	7.98	40.5	8.78	43.1	9.6	48.4	11.4	50.3	11.9
	27	27.3	5.51	32.6	6.93	37.9	8.52	40.5	9.4	43.1	10.3	48.4	12.2	49.5	12.4
	29	27.3	5.87	32.6	7.39	37.9	9.1	40.5	10.0	43.1	11.0	47.8	12.8	48.8	12.9
	31	27.3	6.24	32.6	7.87	37.9	9.7	40.5	10.7	43.1	11.7	47.1	13.3	48.1	13.4
	33	27.3	6.62	32.6	8.37	37.9	10.3	40.5	11.4	43.1	12.5	46.4	13.8	47.4	13.9
	35	27.3	7.03	32.6	8.9	37.9	11.0	40.5	12.1	43.1	13.3	45.6	14.3	46.6	14.4
	37	27.3	7.46	32.6	9.5	37.9	11.7	40.5	12.9	43.1	14.2	44.9	14.8	45.9	14.9
	39	27.3	7.92	32.6	10.1	37.9	12.5	40.5	13.8	43.1	15.1	44.2	15.3	45.2	15.4
80 (320)	10	24.3	3.89	29.0	4.66	33.7	5.47	36.0	5.89	38.3	6.32	43.0	7.21	47.7	8.13
	12	24.3	3.95	29.0	4.74	33.7	5.57	36.0	6.00	38.3	6.44	43.0	7.35	47.7	8.28
	14	24.3	4.02	29.0	4.82	33.7	5.67	36.0	6.11	38.3	6.56	43.0	7.49	47.7	8.44
	16	24.3	4.08	29.0	4.91	33.7	5.78	36.0	6.23	38.3	6.69	43.0	7.63	47.7	8.60
	18	24.3	4.15	29.0	5.00	33.7	5.89	36.0	6.35	38.3	6.82	43.0	7.78	47.7	8.77
	20	24.3	4.23	29.0	5.09	33.7	6.00	36.0	6.47	38.3	6.95	43.0	8.07	47.7	9.4
	21	24.3	4.27	29.0	5.14	33.7	6.06	36.0	6.54	38.3	7.10	43.0	8.36	47.7	9.7
	23	24.3	4.34	29.0	5.24	33.7	6.35	36.0	6.96	38.3	7.60	43.0	9.0	47.7	10.4
	25	24.3	4.49	29.0	5.57	33.7	6.79	36.0	7.44	38.3	8.12	43.0	9.6	47.7	11.2
	27	24.3	4.77	29.0	5.94	33.7	7.24	36.0	7.94	38.3	8.67	43.0	10.2	47.7	11.9
	29	24.3	5.07	29.0	6.32	33.7	7.72	36.0	8.47	38.3	9.3	43.0	10.9	47.7	12.8
	31	24.3	5.38	29.0	6.72	33.7	8.22	36.0	9.0	38.3	9.9	43.0	11.7	47.0	13.3
	33	24.3	5.71	29.0	7.15	33.7	8.75	36.0	9.6	38.3	10.5	43.0	12.4	46.2	13.8
	35	24.3	6.06	29.0	7.59	33.7	9.3	36.0	10.2	38.3	11.2	43.0	13.3	45.5	14.3
	37	24.3	6.42	29.0	8.06	33.7	9.9	36.0	10.9	38.3	11.9	43.0	14.1	44.8	14.8
	39	24.3	6.81	29.0	8.56	33.7	10.5	36.0	11.6	38.3	12.7	43.0	15.1	44.0	15.3
70 (280)	10	21.3	3.42	25.4	4.06	29.5	4.74	31.5	5.09	33.5	5.45	37.6	6.20	41.7	6.97
	12	21.3	3.47	25.4	4.12	29.5	4.82	31.5	5.18	33.5	5.55	37.6	6.31	41.7	7.10
	14	21.3	3.53	25.4	4.19	29.5	4.90	31.5	5.27	33.5	5.65	37.6	6.43	41.7	7.23
	16	21.3	3.58	25.4	4.26	29.5	4.99	31.5	5.37	33.5	5.75	37.6	6.55	41.7	7.37
	18	21.3	3.64	25.4	4.34	29.5	5.08	31.5	5.47	33.5	5.86	37.6	6.68	41.7	7.52
	20	21.3	3.70	25.4	4.42	29.5	5.18	31.5	5.57	33.5	5.98	37.6	6.81	41.7	7.73
	21	21.3	3.73	25.4	4.46	29.5	5.23	31.5	5.63	33.5	6.04	37.6	6.92	41.7	8.00
	23	21.3	3.80	25.4	4.54	29.5	5.34	31.5	5.82	33.5	6.33	37.6	7.40	41.7	8.57
	25	21.3	3.87	25.4	4.72	29.5	5.69	31.5	6.21	33.5	6.76	37.6	7.91	41.7	9.2
	27	21.3	4.09	25.4	5.02	29.5	6.06	31.5	6.62	33.5	7.21	37.6	8.45	41.7	9.8
	29	21.3	4.34	25.4	5.34	29.5	6.46	31.5	7.05	33.5	7.68	37.6	9.0	41.7	10.5
	31	21.3	4.60	25.4	5.67	29.5	6.87	31.5	7.51	33.5	8.18	37.6	9.6	41.7	11.2
	33	21.3	4.87	25.4	6.02	29.5	7.30	31.5	7.99	33.5	8.71	37.6	10.2	41.7	11.9
	35	21.3	5.16	25.4	6.39	29.5	7.76	31.5	8.49	33.5	9.3	37.6	10.9	41.7	12.7
	37	21.3	5.46	25.4	6.78	29.5	8.24	31.5	9.0	33.5	9.8	37.6	11.6	41.7	13.5
	39	21.3	5.78	25.4	7.18	29.5	8.75	31.5	9.6	33.5	10.5	37.6	12.4	41.7	14.4
60 (240)	10	18.2	2.97	21.7	3.49	25.2	4.04	27.0	4.33	28.8	4.62	32.3	5.22	35.8	5.85
	12	18.2	3.02	21.7	3.54	25.2	4.11	27.0	4.40	28.8	4.70	32.3	5.32	35.8	5.96
	14	18.2	3.06	21.7	3.60	25.2	4.17	27.0	4.47	28.8	4.78	32.3	5.41	35.8	6.07
	16	18.2	3.11	21.7	3.66	25.2	4.25	27.0	4.55	28.8	4.87	32.3	5.51	35.8	6.18
	18	18.2	3.15	21.7	3.72	25.2	4.32	27.0	4.63	28.8	4.95	32.3	5.62	35.8	6.30
	20	18.2	3.20	21.7	3.78	25.2	4.40	27.0	4.72	28.8	5.05	32.3	5.72	35.8	6.43
	21	18.2	3.23	21.7	3.81	25.2	4.44	27.0	4.76	28.8	5.09	32.3	5.78	35.8	6.49
	23	18.2	3.28	21.7	3.88	25.2	4.52	27.0	4.85	28.8	5.19	32.3	6.01	35.8	6.90
	25	18.2	3.34	21.7	3.95	25.2	4.70	27.0	5.10	28.8	5.52	32.3	6.41	35.8	7.37
	27	18.2	3.46	21.7	4.19	25.2	5.00	27.0	5.43	28.8	5.88	32.3	6.84	35.8	7.87
	29	18.2	3.66	21.7	4.45	25.2	5.31	27.0	5.78	28.8	6.26	32.3	7.29	35.8	8.39
	31	18.2	3.88	21.7	4.72	25.2	5.64	27.0	6.14	28.8	6.66	32.3	7.76	35.8	8.9
	33	18.2	4.10	21.7	5.00	25.2	5.99	27.0	6.52	28.8	7.07	32.3	8.25	35.8	9.5
	35	18.2	4.34	21.7	5.30	25.2	6.36	27.0	6.92	28.8	7.52	32.3	8.78	35.8	10.1
	37	18.2	4.59	21.7	5.61	25.2	6.74	27.0	7.35	28.8	7.98	32.3	9.3	35.8	10.8
	39	18.2	4.84	21.7	5.94	25.2	7.14	27.0	7.79	28.8	8.47	32.3	9.9	35.8	11.5
50 (200)	10	15.2	2.56	18.1	2.96	21.0	3.39	22.5	3.61	24.0	3.84	26.9	4.31	29.8	4.80
	12	15.2	2.59	18.1	3.00	21.0	3.44	22.5	3.66	24.0	3.90	26.9	4.38	29.8	4.88
	14	15.2	2.62	18.1	3.04	21.0	3.49	22.5	3.72	24.0	3.96	26.9	4.45	29.8	4.97
	16	15.2	2.66	18.1	3.09	21.0	3.55	22.5	3.78	24.0	4.03	26.9	4.53	29.8	5.06
	18	15.2	2.70	18.1	3.14	21.0	3.60	22.5	3.85	24.0	4.10	26.9	4.61	29.8	5.15
	20	15.2	2.73	18.1	3.19	21.0	3.66	22.5	3.91	24.0	4.17	26.9	4.70	29.8	5.25
	21	15.2	2.75	18.1	3.21	21.0	3.70	22.5	3.95	24.0	4.21	26.9	4.74	29.8	5.30
	23	15.2	2.80	18.1	3.26	21.0	3.76	22.5	4.02	24.0	4.28	26.9	4.83	29.8	5.42
	25	15.2	2.84	18.1	3.32	21.0	3.83	22.5	4.10	24.0	4.41	26.9	5.07	29.8	5.78
	27	15.2	2.88	18.1	3.44	21.0	4.04	22.5	4.36	24.0	4.69	26.9	5.40	29.8	6.16
	29	15.2	3.05	18.1	3.64	21.0	4.29	22.5	4.63	24.0	4.99	26.9	5.75	29.8	6.56
	31	15.2	3.22	18.1	3.85	21.0	4.54	22.5	4.91	24.0	5.30	26.9	6.11	29.8	6.98
	33	15.2	3.40	18.1	4.08	21.0	4.81	22.5	5.21	24.0	5.62	26.9	6.49	29.8	7.42
	35	15.2	3.59	18.1	4.31	21.0	5.10	22.5	5.52	24.0	5.96	26.9	6.89	29.8	7.89
	37	15.2	3.79	18.1	4.55	21.0	5.40	22.5	5.85	24.0	6.31	26.9	7.31	29.8	8.38
	39	15.2	3.99	18.1	4.81	21.0	5.71	22.5	6.19	24.0	6.69	26.9	7.75	29.8	8.9

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (585)	10	43.0	7.55	51.3	9.24	59.6	11.0	61.7	11.2	62.5	11.0	64.0	10.53	65.6	10.06
	12	43.0	7.69	51.3	9.42	59.6	11.2	60.9	11.2	61.7	10.9	63.2	10.46	64.8	10.30
	14	43.0	7.84	51.3	9.60	59.3	11.3	60.1	11.1	60.9	10.9	62.4	10.8	64.0	10.9
	16	43.0	7.99	51.3	9.79	58.5	11.3	59.3	11.2	60.1	11.3	61.6	11.4	63.2	11.5
	18	43.0	8.14	51.3	9.98	57.8	11.7	58.5	11.8	59.3	11.8	60.9	12.0	62.4	12.1
	20	43.0	8.31	51.3	10.63	57.0	12.3	57.7	12.4	58.5	12.4	60.1	12.5	61.6	12.7
	21	43.0	8.54	51.3	11.0	56.6	12.6	57.3	12.6	58.1	12.7	59.7	12.8	61.2	13.0
	23	43.0	9.14	51.3	11.8	55.8	13.2	56.5	13.2	57.3	13.3	58.9	13.4	60.4	13.6
	25	43.0	9.78	51.3	12.6	55.0	13.7	55.7	13.8	56.5	13.9	58.1	14.0	59.6	14.2
	27	43.0	10.44	51.3	13.5	54.2	14.3	54.9	14.4	55.7	14.5	57.3	14.6	58.8	14.8
	29	43.0	11.1	51.3	14.5	53.4	14.9	54.1	15.0	54.9	15.0	56.5	15.2	58.0	15.4
	31	43.0	11.9	51.0	15.3	52.6	15.5	53.3	15.6	54.1	15.6	55.7	15.8	57.2	16.0
	33	43.0	12.7	50.2	15.9	51.8	16.1	52.5	16.1	53.3	16.2	54.9	16.4	56.4	16.6
	35	43.0	13.5	49.4	16.5	51.0	16.6	51.8	16.7	52.5	16.8	54.1	17.0	55.6	17.2
	37	43.0	14.4	48.6	17.0	50.2	17.2	51.0	17.3	51.7	17.4	53.3	17.6	54.8	17.8
	39	43.0	15.3	47.8	17.6	49.4	17.8	50.2	17.9	50.9	18.0	52.5	18.2	54.0	18.5
120 (540)	10	39.7	6.90	47.3	8.43	55.0	10.02	58.8	10.8	61.5	11.3	62.9	10.9	64.4	10.43
	12	39.7	7.03	47.3	8.59	55.0	10.21	58.8	11.0	60.7	11.2	62.1	10.8	63.6	10.36
	14	39.7	7.16	47.3	8.75	55.0	10.41	58.8	11.2	59.9	11.2	61.3	10.7	62.8	10.8
	16	39.7	7.29	47.3	8.92	55.0	10.61	58.4	11.3	59.1	11.2	60.6	11.3	62.0	11.4
	18	39.7	7.43	47.3	9.10	55.0	11.0	57.6	11.7	58.3	11.8	59.8	11.9	61.2	12.0
	20	39.7	7.58	47.3	9.46	55.0	11.8	56.8	12.3	57.5	12.3	59.0	12.5	60.4	12.6
	21	39.7	7.66	47.3	9.79	55.0	12.2	56.4	12.6	57.1	12.6	58.6	12.7	60.0	12.9
	23	39.7	8.18	47.3	10.49	54.9	13.1	55.6	13.1	56.3	13.2	57.8	13.3	59.2	13.4
	25	39.7	8.74	47.3	11.2	54.1	13.6	54.8	13.7	55.5	13.8	57.0	13.9	58.4	14.0
	27	39.7	9.33	47.3	12.0	53.3	14.2	54.0	14.3	54.7	14.4	56.2	14.5	57.6	14.6
	29	39.7	9.95	47.3	12.8	52.5	14.8	53.2	14.9	53.9	14.9	55.4	15.1	56.8	15.2
	31	39.7	10.60	47.3	13.7	51.7	15.4	52.4	15.5	53.1	15.5	54.6	15.7	56.0	15.8
	33	39.7	11.3	47.3	14.6	50.9	16.0	51.6	16.0	52.3	16.1	53.8	16.3	55.2	16.4
	35	39.7	12.0	47.3	15.6	50.1	16.5	50.8	16.6	51.5	16.7	53.0	16.9	54.4	17.1
	37	39.7	12.8	47.3	16.6	49.3	17.1	50.0	17.2	50.8	17.3	52.2	17.5	53.6	17.7
	39	39.7	13.6	47.1	17.5	48.5	17.7	49.2	17.8	50.0	17.9	51.4	18.1	52.8	18.3
110 (495)	10	36.4	6.27	43.4	7.63	50.4	9.06	53.9	9.79	57.4	10.54	61.8	11.2	63.2	10.8
	12	36.4	6.38	43.4	7.77	50.4	9.23	53.9	9.98	57.4	10.7	61.1	11.1	62.4	10.7
	14	36.4	6.49	43.4	7.92	50.4	9.41	53.9	10.17	57.4	10.9	60.3	11.1	61.6	10.7
	16	36.4	6.62	43.4	8.07	50.4	9.59	53.9	10.37	57.4	11.2	59.5	11.2	60.8	11.3
	18	36.4	6.74	43.4	8.23	50.4	9.78	53.9	10.65	57.3	11.7	58.7	11.8	60.0	11.9
	20	36.4	6.87	43.4	8.39	50.4	10.36	53.9	11.5	56.6	12.3	57.9	12.4	59.2	12.5
	21	36.4	6.94	43.4	8.65	50.4	10.7	53.9	11.9	56.2	12.5	57.5	12.7	58.8	12.8
	23	36.4	7.26	43.4	9.26	50.4	11.5	53.9	12.7	55.4	13.1	56.7	13.2	58.0	13.3
	25	36.4	7.76	43.4	9.90	50.4	12.3	53.9	13.6	54.6	13.7	55.9	13.8	57.2	13.9
	27	36.4	8.28	43.4	10.58	50.4	13.2	53.1	14.2	53.8	14.3	55.1	14.4	56.4	14.5
	29	36.4	8.82	43.4	11.3	50.4	14.1	52.3	14.8	53.0	14.8	54.3	15.0	55.6	15.1
	31	36.4	9.39	43.4	12.0	50.4	15.0	51.5	15.4	52.2	15.4	53.5	15.6	54.8	15.7
	33	36.4	10.00	43.4	12.8	50.1	15.9	50.7	15.9	51.4	16.0	52.7	16.2	54.0	16.3
	35	36.4	10.63	43.4	13.7	49.3	16.4	49.9	16.5	50.6	16.6	51.9	16.8	53.2	16.9
	37	36.4	11.3	43.4	14.6	48.5	17.0	49.1	17.1	49.8	17.2	51.1	17.3	52.4	17.5
	39	36.4	12.0	43.4	15.5	47.7	17.6	48.3	17.7	49.0	17.8	50.3	17.9	51.6	18.1
100 (450)	10	33.1	5.65	39.4	6.85	45.8	8.12	49.0	8.77	52.2	9.43	58.6	10.8	61.9	11.2
	12	33.1	5.75	39.4	6.98	45.8	8.27	49.0	8.94	52.2	9.61	58.6	11.0	61.1	11.1
	14	33.1	5.85	39.4	7.11	45.8	8.43	49.0	9.11	52.2	9.80	58.6	11.2	60.4	11.0
	16	33.1	5.96	39.4	7.24	45.8	8.59	49.0	9.29	52.2	9.99	58.4	11.3	59.6	11.2
	18	33.1	6.07	39.4	7.38	45.8	8.76	49.0	9.47	52.2	10.19	57.6	11.7	58.8	11.8
	20	33.1	6.18	39.4	7.53	45.8	9.03	49.0	9.95	52.2	10.9	56.8	12.3	58.0	12.4
	21	33.1	6.24	39.4	7.60	45.8	9.35	49.0	10.30	52.2	11.3	56.4	12.6	57.6	12.7
	23	33.1	6.41	39.4	8.11	45.8	10.01	49.0	11.0	52.2	12.1	55.6	13.1	56.8	13.2
	25	33.1	6.84	39.4	8.66	45.8	10.71	49.0	11.8	52.2	13.0	54.8	13.7	56.0	13.8
	27	33.1	7.29	39.4	9.25	45.8	11.4	49.0	12.6	52.2	13.9	54.0	14.3	55.2	14.4
	29	33.1	7.76	39.4	9.86	45.8	12.2	49.0	13.5	52.0	14.7	53.2	14.9	54.4	15.0
	31	33.1	8.26	39.4	10.51	45.8	13.0	49.0	14.4	51.2	15.3	52.4	15.4	53.6	15.6
	33	33.1	8.78	39.4	11.2	45.8	13.9	49.0	15.4	50.4	15.9	51.6	16.0	52.8	16.2
	35	33.1	9.33	39.4	11.9	45.8	14.8	49.0	16.4	49.6	16.5	50.8	16.6	52.0	16.8
	37	33.1	9.92	39.4	12.7	45.8	15.8	48.2	17.0	48.8	17.1	50.0	17.2	51.2	17.4
	39	33.1	10.53	39.4	13.5	45.8	16.8	47.4	17.6	48.0	17.6	49.2	17.8	50.4	18.0

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (405)	10	29.8	5.06	35.5	6.10	41.2	7.20	44.1	7.77	47.0	8.35	52.7	9.54	58.4	10.8
	12	29.8	5.14	35.5	6.21	41.2	7.34	44.1	7.92	47.0	8.51	52.7	9.72	58.4	11.0
	14	29.8	5.23	35.5	6.32	41.2	7.47	44.1	8.07	47.0	8.67	52.7	9.91	58.4	11.2
	16	29.8	5.32	35.5	6.44	41.2	7.62	44.1	8.22	47.0	8.84	52.7	10.10	58.3	11.4
	18	29.8	5.42	35.5	6.56	41.2	7.76	44.1	8.38	47.0	9.02	52.7	10.30	57.5	11.7
	20	29.8	5.52	35.5	6.69	41.2	7.92	44.1	8.55	47.0	9.35	52.7	11.1	56.7	12.3
	21	29.8	5.57	35.5	6.75	41.2	8.05	44.1	8.85	47.0	9.69	52.7	11.5	56.3	12.6
	23	29.8	5.68	35.5	7.03	41.2	8.62	44.1	9.48	47.0	10.38	52.7	12.3	55.5	13.1
	25	29.8	5.98	35.5	7.51	41.2	9.22	44.1	10.14	47.0	11.1	52.7	13.2	54.8	13.7
	27	29.8	6.37	35.5	8.01	41.2	9.84	44.1	10.8	47.0	11.9	52.7	14.1	54.0	14.3
	29	29.8	6.77	35.5	8.53	41.2	10.50	44.1	11.6	47.0	12.7	52.1	14.8	53.2	14.9
	31	29.8	7.20	35.5	9.08	41.2	11.2	44.1	12.3	47.0	13.5	51.3	15.3	52.4	15.4
	33	29.8	7.65	35.5	9.67	41.2	11.9	44.1	13.1	47.0	14.4	50.5	15.9	51.6	16.0
	35	29.8	8.12	35.5	10.28	41.2	12.7	44.1	14.0	47.0	15.4	49.7	16.5	50.8	16.6
	37	29.8	8.62	35.5	10.9	41.2	13.5	44.1	14.9	47.0	16.4	48.9	17.1	50.0	17.2
	39	29.8	9.15	35.5	11.6	41.2	14.4	44.1	15.9	47.0	17.5	48.1	17.7	49.2	17.8
80 (360)	10	26.5	4.49	31.6	5.38	36.7	6.32	39.2	6.81	41.7	7.30	46.8	8.33	51.9	9.38
	12	26.5	4.56	31.6	5.47	36.7	6.43	39.2	6.93	41.7	7.44	46.8	8.49	51.9	9.56
	14	26.5	4.64	31.6	5.57	36.7	6.55	39.2	7.06	41.7	7.58	46.8	8.65	51.9	9.74
	16	26.5	4.72	31.6	5.67	36.7	6.67	39.2	7.19	41.7	7.72	46.8	8.82	51.9	9.93
	18	26.5	4.80	31.6	5.77	36.7	6.80	39.2	7.33	41.7	7.87	46.8	8.99	51.9	10.13
	20	26.5	4.88	31.6	5.88	36.7	6.93	39.2	7.48	41.7	8.03	46.8	9.32	51.9	10.8
	21	26.5	4.93	31.6	5.93	36.7	7.00	39.2	7.55	41.7	8.20	46.8	9.65	51.9	11.2
	23	26.5	5.02	31.6	6.05	36.7	7.34	39.2	8.04	41.7	8.77	46.8	10.34	51.9	12.0
	25	26.5	5.18	31.6	6.44	36.7	7.84	39.2	8.59	41.7	9.38	46.8	11.1	51.9	12.9
	27	26.5	5.51	31.6	6.86	36.7	8.36	39.2	9.17	41.7	10.02	46.8	11.8	51.9	13.8
	29	26.5	5.86	31.6	7.30	36.7	8.91	39.2	9.78	41.7	10.69	46.8	12.6	51.9	14.7
	31	26.5	6.22	31.6	7.77	36.7	9.49	39.2	10.42	41.7	11.4	46.8	13.5	51.1	15.3
	33	26.5	6.60	31.6	8.25	36.7	10.10	39.2	11.1	41.7	12.1	46.8	14.4	50.3	15.9
	35	26.5	7.00	31.6	8.77	36.7	10.7	39.2	11.8	41.7	12.9	46.8	15.3	49.6	16.5
	37	26.5	7.42	31.6	9.31	36.7	11.4	39.2	12.6	41.7	13.8	46.8	16.3	48.8	17.0
	39	26.5	7.86	31.6	9.88	36.7	12.1	39.2	13.4	41.7	14.7	46.8	17.4	48.0	17.6
70 (315)	10	23.1	3.95	27.6	4.69	32.1	5.47	34.3	5.88	36.5	6.29	41.0	7.16	45.5	8.05
	12	23.1	4.01	27.6	4.76	32.1	5.56	34.3	5.98	36.5	6.41	41.0	7.29	45.5	8.20
	14	23.1	4.07	27.6	4.84	32.1	5.66	34.3	6.09	36.5	6.52	41.0	7.42	45.5	8.35
	16	23.1	4.14	27.6	4.93	32.1	5.76	34.3	6.20	36.5	6.65	41.0	7.56	45.5	8.51
	18	23.1	4.20	27.6	5.01	32.1	5.87	34.3	6.32	36.5	6.77	41.0	7.71	45.5	8.68
	20	23.1	4.27	27.6	5.10	32.1	5.98	34.3	6.44	36.5	6.90	41.0	7.87	45.5	8.92
	21	23.1	4.31	27.6	5.15	32.1	6.04	34.3	6.50	36.5	6.97	41.0	7.99	45.5	9.24
	23	23.1	4.39	27.6	5.24	32.1	6.16	34.3	6.72	36.5	7.31	41.0	8.55	45.5	9.90
	25	23.1	4.47	27.6	5.45	32.1	6.57	34.3	7.17	36.5	7.80	41.0	9.14	45.5	10.59
	27	23.1	4.72	27.6	5.80	32.1	7.00	34.3	7.65	36.5	8.32	41.0	9.76	45.5	11.3
	29	23.1	5.01	27.6	6.17	32.1	7.46	34.3	8.15	36.5	8.87	41.0	10.41	45.5	12.1
	31	23.1	5.31	27.6	6.55	32.1	7.93	34.3	8.67	36.5	9.45	41.0	11.1	45.5	12.9
	33	23.1	5.63	27.6	6.96	32.1	8.43	34.3	9.23	36.5	10.06	41.0	11.8	45.5	13.7
	35	23.1	5.96	27.6	7.38	32.1	8.96	34.3	9.81	36.5	10.70	41.0	12.6	45.5	14.7
	37	23.1	6.31	27.6	7.83	32.1	9.52	34.3	10.42	36.5	11.4	41.0	13.4	45.5	15.6
	39	23.1	6.68	27.6	8.30	32.1	10.10	34.3	11.1	36.5	12.1	41.0	14.3	45.5	16.6
60 (270)	10	19.8	3.43	23.7	4.03	27.5	4.67	29.4	5.00	31.3	5.33	35.1	6.03	39.0	6.76
	12	19.8	3.48	23.7	4.09	27.5	4.74	29.4	5.08	31.3	5.42	35.1	6.14	39.0	6.88
	14	19.8	3.53	23.7	4.16	27.5	4.82	29.4	5.17	31.3	5.52	35.1	6.25	39.0	7.01
	16	19.8	3.59	23.7	4.23	27.5	4.90	29.4	5.26	31.3	5.62	35.1	6.37	39.0	7.14
	18	19.8	3.64	23.7	4.30	27.5	4.99	29.4	5.35	31.3	5.72	35.1	6.49	39.0	7.28
	20	19.8	3.70	23.7	4.37	27.5	5.08	29.4	5.45	31.3	5.83	35.1	6.61	39.0	7.42
	21	19.8	3.73	23.7	4.41	27.5	5.13	29.4	5.50	31.3	5.88	35.1	6.68	39.0	7.50
	23	19.8	3.79	23.7	4.48	27.5	5.22	29.4	5.60	31.3	6.00	35.1	6.94	39.0	7.97
	25	19.8	3.85	23.7	4.56	27.5	5.42	29.4	5.89	31.3	6.38	35.1	7.41	39.0	8.52
	27	19.8	3.99	23.7	4.84	27.5	5.77	29.4	6.27	31.3	6.79	35.1	7.90	39.0	9.09
	29	19.8	4.23	23.7	5.14	27.5	6.14	29.4	6.67	31.3	7.23	35.1	8.41	39.0	9.69
	31	19.8	4.48	23.7	5.45	27.5	6.52	29.4	7.09	31.3	7.69	35.1	8.96	39.0	10.33
	33	19.8	4.74	23.7	5.77	27.5	6.92	29.4	7.53	31.3	8.17	35.1	9.53	39.0	11.0
	35	19.8	5.01	23.7	6.12	27.5	7.34	29.4	8.00	31.3	8.68	35.1	10.14	39.0	11.7
	37	19.8	5.30	23.7	6.48	27.5	7.78	29.4	8.48	31.3	9.22	35.1	10.8	39.0	12.5
	39	19.8	5.59	23.7	6.86	27.5	8.25	29.4	9.00	31.3	9.78	35.1	11.5	39.0	13.3
50 (225)	10	16.5	2.95	19.7	3.42	22.9	3.91	24.5	4.17	26.1	4.43	29.3	4.97	32.5	5.54
	12	16.5	2.99	19.7	3.46	22.9	3.97	24.5	4.23	26.1	4.50	29.3	5.06	32.5	5.64
	14	16.5	3.03	19.7	3.52	22.9	4.03	24.5	4.30	26.1	4.57	29.3	5.14	32.5	5.74
	16	16.5	3.07	19.7	3.57	22.9	4.10	24.5	4.37	26.1	4.65	29.3	5.23	32.5	5.84
	18	16.5	3.11	19.7	3.62	22.9	4.16	24.5	4.44	26.1	4.73	29.3	5.33	32.5	5.95
	20	16.5	3.16	19.7	3.68	22.9	4.23	24.5	4.52	26.1	4.82	29.3	5.43	32.5	6.06
	21	16.5	3.18	19.7	3.71	22.9	4.27	24.5	4.56	26.1	4.86	29.3	5.48	32.5	6.12
	23	16.5	3.23	19.7	3.77	22.9	4.34	24.5	4.64	26.1	4.95	29.3	5.58	32.5	6.26
	25	16.5	3.28	19.7	3.83	22.9	4.42	24.5	4.74	26.1	5.10	29.3	5.86	32.5	6.68
	27	16.5	3.33	19.7	3.97	22.9	4.66	24.5	5.04	26.1	5.42	29.3	6.24	32.5	7.12
	29	16.5	3.52	19.7	4.20	22.9	4.95	24.5	5.35	26.1	5.76	29.3	6.64	32.5	7.58
	31	16.5	3.72	19.7	4.45	22.9	5.25	24.5	5.67	26.1	6.12	29.3	7.05	32.5	8.06
	33	16.5	3.93	19.7	4.71	22.9	5.56	24.5	6.02	26.1	6.49	29.3	7.49	32.5	8.57
	35	16.5	4.15	19.7	4.98	22.9	5.89	24.5	6.37	26.1	6.88	29.3	7.95	32.5	9.11
	37	16.5	4.38	19.7	5.26	22.9	6.23	24.5	6.75	26.1	7.29	29.3	8.44	32.5	9.67
	39	16.5	4.61	19.7	5.56	22.9	6.59	24.5	7.15	26.1	7.73	29.3	8.95	32.5	10.27

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

RXYQ20PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp.																					
		14.0°CWB		16.0°CWB		18.0°CWB		19.0°CWB		20.0°CWB		22.0°CWB		24.0°CWB									
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI								
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW								
130 (650)	10	49.0	6.54	58.5	8.00	67.9	9.5	70.4	9.7	71.3	9.5	73.1	9.1	74.8	8.71								
	12	49.0	6.66	58.5	8.15	67.9	9.7	69.5	9.7	70.4	9.5	72.1	9.1	73.9	8.9								
	14	49.0	6.78	58.5	8.31	67.7	9.8	68.6	9.6	69.5	9.4	71.2	9.3	73.0	9.4								
	16	49.0	6.92	58.5	8.47	66.8	9.8	67.7	9.7	68.6	9.7	70.3	9.8	72.1	9.9								
	18	49.0	7.05	58.5	8.64	65.9	10.1	66.8	10.2	67.7	10.2	69.4	10.3	71.2	10.4								
	20	49.0	7.19	58.5	9.2	65.0	10.6	65.9	10.7	66.7	10.7	68.5	10.9	70.3	11.0								
	21	49.0	7.39	58.5	9.5	64.5	10.9	65.4	10.9	66.3	11.0	68.1	11.1	69.8	11.2								
	23	49.0	7.92	58.5	10.2	63.6	11.4	64.5	11.4	65.4	11.5	67.1	11.6	68.9	11.7								
	25	49.0	8.46	58.5	10.9	62.7	11.9	63.6	11.9	64.5	12.0	66.2	12.1	68.0	12.3								
	27	49.0	9.0	58.5	11.7	61.8	12.4	62.7	12.5	63.6	12.5	65.3	12.6	67.1	12.8								
	29	49.0	9.7	58.5	12.5	60.9	12.9	61.8	13.0	62.7	13.0	64.4	13.2	66.2	13.3								
	31	49.0	10.3	58.2	13.2	60.0	13.4	60.9	13.5	61.7	13.5	63.5	13.7	65.3	13.8								
	33	49.0	11.0	57.3	13.7	59.1	13.9	59.9	14.0	60.8	14.1	62.6	14.2	64.4	14.4								
	35	49.0	11.7	56.4	14.2	58.2	14.3	59.0	14.5	59.9	14.6	61.7	14.7	63.5	14.9								
	37	49.0	12.4	55.5	14.7	57.2	14.9	58.1	15.0	59.0	15.1	60.8	15.3	62.5	15.4								
	39	49.0	13.2	54.6	15.3	56.3	15.4	57.2	15.5	58.1	15.6	59.9	15.8	61.6	16.0								
120 (600)	10	45.3	5.97	54.0	7.30	62.7	8.68	67.1	9.4	70.2	9.8	71.8	9.4	73.4	9.0								
	12	45.3	6.08	54.0	7.43	62.7	8.84	67.1	9.6	69.3	9.7	70.9	9.4	72.5	9.0								
	14	45.3	6.20	54.0	7.58	62.7	9.0	67.1	9.7	68.4	9.7	70.0	9.3	71.6	9.4								
	16	45.3	6.31	54.0	7.72	62.7	9.2	66.6	9.8	67.4	9.7	69.1	9.8	70.7	9.9								
	18	45.3	6.44	54.0	7.88	62.7	9.5	65.7	10.1	66.5	10.2	68.2	10.3	69.8	10.4								
	20	45.3	6.56	54.0	8.19	62.7	10.2	64.8	10.6	65.6	10.7	67.3	10.8	68.9	10.9								
	21	45.3	6.63	54.0	8.48	62.7	10.6	64.4	10.9	65.2	10.9	66.8	11.0	68.4	11.1								
	23	45.3	7.08	54.0	9.1	62.6	11.3	63.4	11.4	64.3	11.4	65.9	11.5	67.5	11.6								
	25	45.3	7.56	54.0	9.7	61.7	11.8	62.5	11.9	63.4	11.9	65.0	12.0	66.6	12.2								
	27	45.3	8.08	54.0	10.4	60.8	12.3	61.6	12.4	62.4	12.4	64.1	12.6	65.7	12.7								
	29	45.3	8.61	54.0	11.1	59.9	12.8	60.7	12.9	61.5	12.9	63.2	13.1	64.8	13.2								
	31	45.3	9.2	54.0	11.9	59.0	13.3	59.8	13.4	60.6	13.4	62.3	13.6	63.9	13.7								
	33	45.3	9.8	54.0	12.6	58.1	13.8	58.9	13.9	59.7	14.0	61.3	14.1	63.0	14.2								
	35	45.3	10.4	54.0	13.5	57.2	14.3	58.0	14.4	58.8	14.5	60.4	14.6	62.1	14.8								
	37	45.3	11.1	54.0	14.4	56.4	14.8	57.1	14.9	57.9	15.0	59.5	15.1	61.2	15.3								
	39	45.3	11.8	53.7	15.2	55.4	15.3	56.2	15.4	57.0	15.5	58.6	15.7	60.3	15.8								
110 (550)	10	41.5	5.43	49.5	6.61	57.5	7.85	61.5	8.48	65.5	9.1	70.6	9.7	72.1	9.3								
	12	41.5	5.52	49.5	6.73	57.5	7.99	61.5	8.64	65.5	9.3	69.6	9.6	71.1	9.3								
	14	41.5	5.62	49.5	6.86	57.5	8.15	61.5	8.81	65.5	9.5	68.7	9.6	70.2	9.3								
	16	41.5	5.73	49.5	6.99	57.5	8.31	61.5	9.0	65.5	9.7	67.8	9.7	69.3	9.8								
	18	41.5	5.84	49.5	7.13	57.5	8.47	61.5	9.2	65.4	10.1	66.9	10.2	68.4	10.3								
	20	41.5	5.95	49.5	7.27	57.5	9.0	61.5	9.9	64.5	10.6	66.0	10.7	67.5	10.8								
	21	41.5	6.01	49.5	7.49	57.5	9.3	61.5	10.3	64.1	10.9	65.6	11.0	67.1	11.0								
	23	41.5	6.29	49.5	8.02	57.5	10.0	61.5	11.0	63.2	11.4	64.6	11.5	66.1	11.6								
	25	41.5	6.72	49.5	8.58	57.5	10.7	61.5	11.8	62.2	11.9	63.7	12.0	65.2	12.1								
	27	41.5	7.17	49.5	9.2	57.5	11.4	60.6	12.3	61.3	12.4	62.8	12.5	64.3	12.6								
	29	41.5	7.64	49.5	9.8	57.5	12.2	59.7	12.8	60.4	12.9	61.9	13.0	63.4	13.1								
	31	41.5	8.13	49.5	10.4	57.5	13.0	58.8	13.3	59.5	13.4	61.0	13.5	62.5	13.6								
	33	41.5	8.66	49.5	11.1	57.1	13.7	57.9	13.8	58.6	13.9	60.1	14.0	61.6	14.1								
	35	41.5	9.2	49.5	11.8	56.2	14.2	56.9	14.3	57.7	14.4	59.2	14.5	60.7	14.6								
	37	41.5	9.8	49.5	12.6	55.3	14.7	56.0	14.8	56.8	14.9	58.3	15.0	59.8	15.2								
	39	41.5	10.4	49.5	13.4	54.4	15.2	55.1	15.3	55.9	15.4	57.4	15.5	58.9	15.7								
100 (500)	10	37.7	4.89	45.0	5.93	52.3	7.03	55.9	7.60	59.5	8.17	66.8	9.3	70.7	9.7								
	12	37.7	4.98	45.0	6.04	52.3	7.16	55.9	7.74	59.5	8.32	66.8	9.5	69.8	9.6								
	14	37.7	5.07	45.0	6.15	52.3	7.30	55.9	7.89	59.5	8.48	66.8	9.7	68.8	9.6								
	16	37.7	5.16	45.0	6.27	52.3	7.44	55.9	8.04	59.5	8.65	66.6	9.8	67.9	9.7								
	18	37.7	5.26	45.0	6.39	52.3	7.59	55.9	8.20	59.5	8.82	66.7	10.1	67.0	10.2								
	20	37.7	5.36	45.0	6.52	52.3	7.81	55.9	8.61	59.5	9.4	64.8	10.6	66.1	10.7								
	21	37.7	5.41	45.0	6.58	52.3	8.09	55.9	8.9	59.5	9.8	64.3	10.9	65.7	11.0								
	23	37.7	5.55	45.0	7.02	52.3	8.67	55.9	9.6	59.5	10.5	63.4	11.4	64.8	11.5								
	25	37.7	5.92	45.0	7.50	52.3	9.3	55.9	10.2	59.5	11.2	62.5	11.9	63.8	12.0								
	27	37.7	6.31	45.0	8.01	52.3	9.9	55.9	10.9	59.5	12.0	61.6	12.4	62.9	12.5								
	29	37.7	6.72	45.0	8.54	52.3	10.6	55.9	11.7	59.3	12.8	60.7	12.9	62.0	13.0								
	31	37.7	7.15	45.0	9.1	52.3	11.3	55.9	12.5	58.4	13.3	59.8	13.4	61.1	13.5								
	33	37.7	7.60	45.0	9.7	52.3	12.0	55.9	13.3	57.5	13.8	58.8	13.9	60.2	14.0								
	35	37.7	8.08	45.0	10.3	52.3	12.8	55.9	14.2	56.6	14.3	57.9	14.4	59.3	14.5								
	37	37.7	8.59	45.0	11.0	52.3	13.7	55.0	14.7	55.7	14.8	57.0	14.9	58.4	15.0								
	39	37.7	9.1	45.0	11.7	52.3	14.6	54.1	15.2	54.8	15.3	56.1	15.4	57.5	15.6								

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp.																					
		14.0°CWB		16.0°CWB		18.0°CWB		19.0°CWB		20.0°CWB		22.0°CWB		24.0°CWB									
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI								
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW								
90 (450)	10	34.0	4.38	40.5	5.28	47.0	6.24	50.3	6.73	53.6	7.23	60.1	8.26	66.7	9.3								
	12	34.0	4.45	40.5	5.38	47.0	6.35	50.3	6.86	53.6	7.37	60.1	8.42	66.7	9.5								
	14	34.0	4.53	40.5	5.47	47.0	6.47	50.3	6.99	53.6	7.51	60.1	8.58	66.7	9.7								
	16	34.0	4.61	40.5	5.57	47.0	6.59	50.3	7.12	53.6	7.66	60.1	8.75	66.6	9.8								
	18	34.0	4.69	40.5	5.68	47.0	6.72	50.3	7.26	53.6	7.81	60.1	8.9	65.6	10.1								
	21	34.0	4.82	40.5	5.85	47.0	6.97	50.3	7.66	53.6	8.39	60.1	9.9	64.3	10.9								
	23	34.0	4.92	40.5	6.09	47.0	7.46	50.3	8.21	53.6	9.0	60.1	10.7	63.4	11.4								
	25	34.0	5.18	40.5	6.50	47.0	7.98	50.3	8.78	53.6	9.6	60.1	11.4	62.5	11.9								
	27	34.0	5.51	40.5	6.93	47.0	8.52	50.3	9.4	53.6	10.3	60.1	12.2	61.6	12.4								
	29	34.0	5.87	40.5	7.39	47.0	9.1	50.3	10.0	53.6	11.0	59.4	12.8	60.6	12.9								
	31	34.0	6.24	40.5	7.87	47.0	9.7	50.3	10.7	53.6	11.7	58.5	13.3	59.7	13.4								
	33	34.0	6.62	40.5	8.37	47.0	10.3	50.3	11.4	53.6	12.5	57.6	13.8	58.8	13.9								
	35	34.0	7.03	40.5	8.9	47.0	11.0	50.3	12.1	53.6	13.3	56.7	14.3	57.9	14.4								
	37	34.0	7.46	40.5	9.5	47.0	11.7	50.3	12.9	53.6	14.2	55.8	14.8	57.0	14.9								
	39	34.0	7.92	40.5	10.1	47.0	12.5	50.3	13.8	53.6	15.1	54.9	15.3	56.1	15.4								
80 (400)	10	30.2	3.89	36.0	4.66	41.8	5.47	44.7	5.89	47.6	6.32	53.4	7.21	59.3	8.13								
	12	30.2	3.95	36.0	4.74	41.8	5.57	44.7	6.00	47.6	6.44	53.4	7.35	59.3	8.28								
	14	30.2	4.02	36.0	4.82	41.8	5.67	44.7	6.11	47.6	6.56	53.4	7.49	59.3	8.44								
	16	30.2	4.08	36.0	4.91	41.8	5.78	44.7	6.23	47.6	6.69	53.4	7.63	59.3	8.60								
	18	30.2	4.15	36.0	5.00	41.8	5.89	44.7	6.35	47.6	6.82	53.4	7.78	59.3	8.77								
	20	30.2	4.23	36.0	5.09	41.8	6.00	44.7	6.47	47.6	6.95	53.4	8.07	59.3	9.4								
	21	30.2	4.27	36.0	5.14	41.8	6.06	44.7	6.54	47.6	7.10	53.4	8.36	59.3	9.7								
	23	30.2	4.34	36.0	5.24	41.8	6.35	44.7	6.96	47.6	7.60	53.4	9.0	59.3	10.4								
	25	30.2	4.49	36.0	5.57	41.8	6.79	44.7	7.44	47.6	8.12	53.4	9.6	59.3	11.2								
	27	30.2	4.77	36.0	5.94	41.8	7.24	44.7	7.94	47.6	8.67	53.4	10.2	59.3	11.9								
	29	30.2	5.07	36.0	6.32	41.8	7.72	44.7	8.47	47.6	9.3	53.4	10.9	59.3	12.8								
	31	30.2	5.38	36.0	6.72	41.8	8.22	44.7	9.0	47.6	9.9	53.4	11.7	58.3	13.3								
	33	30.2	5.71	36.0	7.15	41.8	8.75	44.7	9.6	47.6	10.5	53.4	12.4	57.4	13.8								
	35	30.2	6.06	36.0	7.59	41.8	9.3	44.7	10.2	47.6	11.2	53.4	13.3	56.5	14.3								
	37	30.2	6.42	36.0	8.06	41.8	9.9	44.7	10.9	47.6	11.9	53.4	14.1	55.6	14.8								
	39	30.2	6.81	36.0	8.56	41.8	10.5	44.7	11.6	47.6	12.7	53.4	15.1	54.7	15.3								
70 (350)	10	26.4	3.42	31.5	4.06	36.6	4.74	39.1	5.09	41.7	5.45	46.8	6.20	51.9	6.97								
	12	26.4	3.47	31.5	4.12	36.6	4.82	39.1	5.18	41.7	5.55	46.8	6.31	51.9	7.10								
	14	26.4	3.53	31.5	4.19	36.6	4.90	39.1	5.27	41.7	5.65	46.8	6.43	51.9	7.23								
	16	26.4	3.58	31.5	4.26	36.6	4.99	39.1	5.37	41.7	5.75	46.8	6.55	51.9	7.37								
	18	26.4	3.64	31.5	4.34	36.6	5.08	39.1	5.47	41.7	5.86	46.8	6.68	51.9	7.52								
	20	26.4	3.70	31.5	4.42	36.6	5.18	39.1	5.57	41.7	5.98	46.8	6.81	51.9	7.73								
	21	26.4	3.73	31.5	4.46	36.6	5.23	39.1	5.63	41.7	6.04	46.8	6.92	51.9	8.00								
	23	26.4	3.80	31.5	4.54	36.6	5.34	39.1	5.82	41.7	6.33	46.8	7.40	51.9	8.57								
	25	26.4	3.87	31.5	4.72	36.6	5.69	39.1	6.21	41.7	6.76	46.8	7.91	51.9	9.2								
	27	26.4	4.09	31.5	5.02	36.6	6.06	39.1	6.62	41.7	7.21	46.8	8.45	51.9	9.8								
	29	26.4	4.34	31.5	5.34	36.6	6.46	39.1	7.05	41.7	7.68	46.8	9.0	51.9	10.5								
	31	26.4	4.60	31.5	5.67	36.6	6.87	39.1	7.51	41.7	8.18	46.8	9.6	51.9	11.2								
	33	26.4	4.87	31.5	6.02	36.6	7.30	39.1	7.99	41.7	8.71	46.8	10.2	51.9	11.9								
	35	26.4	5.16	31.5	6.39	36.6	7.76	39.1	8.49	41.7	9.3	46.8	10.9	51.9	12.7								
	37	26.4	5.46	31.5	6.78	36.6	8.24	39.1	9.0	41.7	9.8	46.8	11.6	51.9	13.5								
	39	26.4	5.78	31.5	7.18	36.6	8.75	39.1	9.6	41.7	10.5	46.8	12.4	51.9	14.4								
60 (300)	10	22.6	2.97	27.0	3.49	31.4	4.04	33.5	4.33	35.7	4.62	40.1	5.22	44.4	5.85								
	12	22.6	3.02	27.0	3.54	31.4	4.11	33.5	4.40	35.7	4.70	40.1	5.32	44.4	5.96								
	14	22.6	3.06	27.0	3.60	31.4	4.17	33.5	4.47	35.7	4.78	40.1	5.41	44.4	6.07								
	16	22.6	3.11	27.0	3.66	31.4	4.25	33.5	4.55	35.7	4.87	40.1	5.51	44.4	6.18								
	18	22.6	3.15	27.0	3.72	31.4	4.32	33.5	4.63	35.7	4.95	40.1	5.62	44.4	6.30								
	20	22.6	3.20	27.0	3.78	31.4	4.40	33.5	4.72	35.7	5.05	40.1	5.72	44.4	6.43								
	21	22.6	3.23	27.0	3.81	31.4	4.44	33.5	4.76	35.7	5.09	40.1	5.78	44.4	6.49								
	23	22.6	3.28	27.0	3.88	31.4	4.52	33.5	4.85	35.7	5.19	40.1	6.01	44.4	6.90								
	25	22.6	3.34	27.0	3.95	31.4	4.70	33.5	5.10	35.7	5.52	40.1	6.41	44.4	7.37								
	27	22.6	3.46	27.0	4.19	31.4	5.00	33.5	5.43	35.7	5.88	40.1	6.84	44.4	7.87								
	29	22.6	3.88	27.0	4.45	31.4	5.31	33.5	5.78	35.7	6.26	40.1	7.29	44.4	8.39								
	31	22.6	4.10	27.0	4.72	31.4	5.64	33.5	6.14	35.7	6.66	40.1	7.76	44.4	8.9								
	33	22.6	4.34	27.0	5.00	31.4	5.99	33.5	6.52	35.7	7.07	40.1	8.25	44.4	9.5								
	35	22.6	4.59	27.0	5.30	31.4	6.36	33.5	6.92	35.7	7.52	40.1	8.78	44.4	10.1								
	37	22.6	4.84	27.0	5.61	31.4	6.74	33.5	7.35	35.7	7.98	40.1	9.3	44.4	10.8								
	39	22.6	4.84	27.0	5.94	31.4	7.14	33.5	7.79	35.7	8.47	40.1	9.9	44.4	11.5								
50 (250)	10	18.9	2.56	22.5	2.96	26.1	3.39	28.0	3.61	29.8	3.84	33.4	4.31	37.0	4.80								
	12	18.9	2.59	22.5	3.00	26.1	3.44	28.0	3.66	29.8	3.90	33.4	4.38	37.0	4.88								
	14	18.9	2.62	22.5	3.04	26.1	3.49	28.0	3.72	29.8	3.96	33.4	4.45	37.0	4.97								
	16	18.9	2.66	22.5	3.09	26.1	3.55	28.0	3.78	29.8	4.03	33.4	4.53	37.0	5.06								
	18	18.9	2.70	22.5	3.14	26.1	3.60	28.0	3.85	29.8	4.10	33.4	4.61	37.0	5.15								
	20	18.9	2.73	22.5	3.19	26.1	3.66	28.0	3.91	29.8	4.17	33.4	4.70	37.0	5.25								
	21	18.9	2.75	22.5	3.21	26.1	3.70	28.0	3.95	29.8	4.21	33.4	4.74	37.0	5.30								
	23	18.9	2.80	22.5	3.26	26.1	3.76	28.0	4.02	29.8	4.28	33.4	4.83	37.0	5.42								
	25	18.9	2.84	22.5	3.32	26.1	3.83	28.0	4.10	29.8	4.41	33.4	5.07	37.0	5.78								
	27	18.9	2.88	22.5	3.44	26.1	4.04	28.0	4.36	29.8	4.69	33.4	5.40	37.0	6.16								
	29	18.9	3.05	22.5	3.64	26.1	4.29	28.0	4.63	29.8	4.99	33.4	5.75	37.0	6.56								
	31	18.9	3.22	22.5	3.85	26.1	4.54	28.0	4.91	29.8	5.30	33.4	6.11	37.0	6.98								
	33	18.9	3.40	22.5	4.08	26.1	4.81	28.0	5.21	29.8	5.62	33.4	6.49	37.0	7.42								
	35	18.9	3.59	22.5	4.31	26.1	5.10	28.0	5.52	29.8	5.96	33.4	6.89	37.0	7.89								
	37	18.9	3.79	22.5	4.55	26.1	5.40	28.0	5.85	29.8	6.31	33.4	7.31	37.0	8.38								
	39	18.9	3.99	22.5	4.81	26.1	5.71	28.0	6.19	29.8	6.69	33.4	7.75	37.0	8.9								

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (715)	10	54.0	7.74	64.4	9.47	74.8	11.3	77.5	11.5	78.4	11.3	80.4	10.8	82.3	10.3
	12	54.0	7.88	64.4	9.65	74.8	11.5	76.5	11.4	77.4	11.2	79.4	10.7	81.3	10.6
	14	54.0	8.03	64.4	9.8	74.5	11.6	75.5	11.4	76.4	11.1	78.4	11.1	80.3	11.2
	16	54.0	8.18	64.4	10.0	73.5	11.6	74.5	11.5	75.4	11.5	77.4	11.6	79.3	11.8
	18	54.0	8.34	64.4	10.2	72.5	12.0	73.5	12.1	74.4	12.1	76.4	12.2	78.3	12.4
	20	54.0	8.51	64.4	10.9	71.5	12.6	72.5	12.7	73.4	12.7	75.4	12.8	77.3	13.0
	21	54.0	8.75	64.4	11.3	71.0	12.9	72.0	12.9	72.9	13.0	74.9	13.1	76.8	13.3
	23	54.0	9.36	64.4	12.1	70.0	13.5	71.0	13.5	71.9	13.6	73.9	13.7	75.8	13.9
	25	54.0	10.0	64.4	12.9	69.0	14.1	70.0	14.1	70.9	14.2	72.9	14.4	74.8	14.5
	27	54.0	10.7	64.4	13.9	68.0	14.7	69.0	14.7	69.9	14.8	71.9	15.0	73.8	15.1
	29	54.0	11.4	64.4	14.8	67.0	15.2	68.0	15.3	68.9	15.4	70.9	15.6	72.8	15.7
	31	54.0	12.2	64.0	15.7	66.0	15.8	67.0	15.9	67.9	16.0	69.9	16.2	71.8	16.4
	33	54.0	13.0	63.0	16.3	65.0	16.4	66.0	16.5	66.9	16.6	68.9	16.8	70.8	17.0
	35	54.0	13.8	62.0	16.9	64.0	17.0	65.0	17.1	65.9	17.2	67.9	17.4	69.8	17.6
	37	54.0	14.7	61.0	17.4	63.0	17.7	64.0	17.8	64.9	17.9	66.9	18.1	68.8	18.3
	39	54.0	15.7	60.0	18.0	62.0	18.3	63.0	18.4	63.9	18.5	65.9	18.7	67.8	18.9
120 (660)	10	49.8	7.07	59.4	8.63	69.0	10.3	73.8	11.1	77.2	11.6	79.0	11.1	80.8	10.7
	12	49.8	7.20	59.4	8.80	69.0	10.5	73.8	11.3	76.2	11.5	78.0	11.1	79.8	10.6
	14	49.8	7.33	59.4	8.96	69.0	10.7	73.8	11.5	75.2	11.4	77.0	11.0	78.8	11.1
	16	49.8	7.47	59.4	9.14	69.0	10.9	73.3	11.6	74.2	11.5	76.0	11.6	77.8	11.7
	18	49.8	7.61	59.4	9.32	69.0	11.2	72.3	12.0	73.2	12.1	75.0	12.2	76.8	12.3
	20	49.8	7.76	59.4	9.69	69.0	12.1	71.3	12.6	72.2	12.6	74.0	12.8	75.8	12.9
	21	49.8	7.84	59.4	10.0	69.0	12.5	70.8	12.9	71.7	12.9	73.5	13.1	75.3	13.2
	23	49.8	8.37	59.4	10.7	68.9	13.4	69.8	13.5	70.7	13.5	72.5	13.7	74.3	13.8
	25	49.8	8.95	59.4	11.5	67.9	14.0	68.8	14.0	69.7	14.1	71.5	14.3	73.3	14.4
	27	49.8	9.55	59.4	12.3	66.9	14.6	67.8	14.6	68.7	14.7	70.5	14.9	72.3	15.0
	29	49.8	10.2	59.4	13.1	65.9	15.2	66.8	15.2	67.7	15.3	69.5	15.5	71.3	15.6
	31	49.8	10.9	59.4	14.0	64.9	15.7	65.8	15.8	66.7	15.9	68.5	16.1	70.3	16.2
	33	49.8	11.6	59.4	15.0	63.9	16.3	64.8	16.4	65.7	16.5	67.5	16.7	69.3	16.8
	35	49.8	12.3	59.4	15.9	62.9	16.9	63.8	17.0	64.7	17.1	66.5	17.3	68.3	17.5
	37	49.8	13.1	59.4	17.0	61.9	17.5	62.8	17.6	63.7	17.7	65.5	17.9	67.3	18.1
	39	49.8	13.9	59.1	17.9	60.9	18.1	61.8	18.2	62.7	18.3	64.5	18.5	66.3	18.7
110 (605)	10	45.7	6.42	54.5	7.82	63.3	9.28	67.7	10.0	72.0	10.8	77.6	11.5	79.3	11.1
	12	45.7	6.53	54.5	7.96	63.3	9.46	67.7	10.2	72.0	11.0	76.6	11.4	78.3	11.0
	14	45.7	6.65	54.5	8.11	63.3	9.64	67.7	10.4	72.0	11.2	75.6	11.3	77.3	11.0
	16	45.7	6.78	54.5	8.27	63.3	9.8	67.7	10.6	72.0	11.4	74.6	11.5	76.3	11.6
	18	45.7	6.91	54.5	8.43	63.3	10.0	67.7	10.9	72.0	12.0	73.6	12.1	75.3	12.2
	20	45.7	7.04	54.5	8.60	63.3	10.6	67.7	11.7	71.0	12.6	72.6	12.7	74.3	12.8
	21	45.7	7.11	54.5	8.86	63.3	11.0	67.7	12.2	70.5	12.9	72.1	13.0	73.8	13.1
	23	45.7	7.44	54.5	9.49	63.3	11.8	67.7	13.0	69.5	13.4	71.1	13.6	72.8	13.7
	25	45.7	7.95	54.5	10.1	63.3	12.6	67.7	14.0	68.5	14.0	70.1	14.1	71.8	14.3
	27	45.7	8.48	54.5	10.8	63.3	13.5	66.7	14.5	67.5	14.6	69.1	14.7	70.8	14.9
	29	45.7	9.04	54.5	11.6	63.3	14.4	65.7	15.1	66.5	15.2	68.1	15.3	69.8	15.5
	31	45.7	9.62	54.5	12.3	63.3	15.4	64.7	15.7	65.5	15.8	67.1	15.9	68.8	16.1
	33	45.7	10.2	54.5	13.2	62.8	16.2	63.7	16.3	64.5	16.4	66.1	16.6	67.8	16.7
	35	45.7	10.9	54.5	14.0	61.8	16.8	62.7	16.9	63.5	17.0	65.1	17.2	66.8	17.3
	37	45.7	11.6	54.5	14.9	60.8	17.4	61.7	17.5	62.5	17.6	64.1	17.8	65.8	17.9
	39	45.7	12.3	54.5	15.9	59.8	18.0	60.6	18.1	61.5	18.2	63.1	18.4	64.8	18.6
100 (550)	10	41.5	5.79	49.5	7.02	57.5	8.32	61.5	8.99	65.5	9.66	73.5	11.0	77.7	11.4
	12	41.5	5.89	49.5	7.15	57.5	8.47	61.5	9.15	65.5	9.8	73.5	11.3	76.7	11.4
	14	41.5	5.99	49.5	7.28	57.5	8.63	61.5	9.33	65.5	10.0	73.5	11.5	75.7	11.3
	16	41.5	6.10	49.5	7.42	57.5	8.80	61.5	9.51	65.5	10.2	73.2	11.6	74.7	11.5
	18	41.5	6.22	49.5	7.56	57.5	8.97	61.5	9.70	65.5	10.4	72.2	12.0	73.7	12.1
	20	41.5	6.34	49.5	7.71	57.5	9.25	61.5	10.2	65.5	11.2	71.2	12.6	72.7	12.7
	21	41.5	6.40	49.5	7.79	57.5	9.57	61.5	10.6	65.5	11.6	70.7	12.9	72.2	13.0
	23	41.5	6.57	49.5	8.30	57.5	10.3	61.5	11.3	65.5	12.4	69.7	13.5	71.2	13.6
	25	41.5	7.01	49.5	8.87	57.5	11.0	61.5	12.1	65.5	13.3	68.7	14.0	70.2	14.2
	27	41.5	7.47	49.5	9.47	57.5	11.7	61.5	12.9	65.5	14.2	67.7	14.6	69.2	14.8
	29	41.5	7.95	49.5	10.1	57.5	12.5	61.5	13.8	65.2	15.1	66.7	15.2	68.2	15.4
	31	41.5	8.46	49.5	10.8	57.5	13.4	61.5	14.8	64.2	15.7	65.7	15.8	67.2	16.0
	33	41.5	9.00	49.5	11.5	57.5	14.2	61.5	15.8	63.2	16.3	64.7	16.4	66.2	16.6
	35	41.5	9.56	49.5	12.2	57.5	15.2	61.5	16.8	62.2	16.9	63.7	17.0	65.2	17.2
	37	41.5	10.2	49.5	13.0	57.5	16.2	60.5	17.4	61.2	17.5	62.7	17.6	64.2	17.8
	39	41.5	10.8	49.5	13.8	57.5	17.2	59.5	18.0	60.2	18.1	61.7	18.2	63.2	18.4

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (495)	10	37.4	5.18	44.6	6.25	51.8	7.38	55.4	7.96	58.9	8.56	66.1	9.8	73.3	11.0
	12	37.4	5.27	44.6	6.36	51.8	7.51	55.4	8.11	58.9	8.72	66.1	10.0	73.3	11.2
	14	37.4	5.36	44.6	6.48	51.8	7.65	55.4	8.26	58.9	8.88	66.1	10.2	73.3	11.4
	16	37.4	5.45	44.6	6.60	51.8	7.80	55.4	8.42	58.9	9.06	66.1	10.3	73.2	11.6
	18	37.4	5.55	44.6	6.72	51.8	7.95	55.4	8.59	58.9	9.24	66.1	10.6	72.2	12.0
	20	37.4	5.66	44.6	6.85	51.8	8.11	55.4	8.76	58.9	9.58	66.1	11.3	71.2	12.6
	21	37.4	5.71	44.6	6.92	51.8	8.25	55.4	9.07	58.9	9.9	66.1	11.8	70.7	12.9
	23	37.4	5.82	44.6	7.20	51.8	8.83	55.4	9.71	58.9	10.6	66.1	12.6	69.7	13.5
	25	37.4	6.13	44.6	7.69	51.8	9.44	55.4	10.4	58.9	11.4	66.1	13.5	68.7	14.0
	27	37.4	6.52	44.6	8.20	51.8	10.1	55.4	11.1	58.9	12.2	66.1	14.4	67.7	14.6
	29	37.4	6.94	44.6	8.74	51.8	10.8	55.4	11.8	58.9	13.0	65.4	15.1	66.7	15.2
	31	37.4	7.38	44.6	9.31	51.8	11.5	55.4	12.6	58.9	13.9	64.4	15.7	65.7	15.8
	33	37.4	7.84	44.6	9.9	51.8	12.2	55.4	13.5	58.9	14.8	63.4	16.3	64.7	16.4
	35	37.4	8.32	44.6	10.5	51.8	13.0	55.4	14.4	58.9	15.8	62.4	16.9	63.7	17.0
	37	37.4	8.83	44.6	11.2	51.8	13.9	55.4	15.3	58.9	16.8	61.4	17.5	62.7	17.6
	39	37.4	9.37	44.6	11.9	51.8	14.7	55.4	16.3	58.9	17.9	60.4	18.1	61.7	18.2
80 (440)	10	33.2	4.60	39.6	5.51	46.0	6.47	49.2	6.97	52.4	7.48	58.8	8.53	65.2	9.61
	12	33.2	4.67	39.6	5.60	46.0	6.59	49.2	7.10	52.4	7.62	58.8	8.69	65.2	9.8
	14	33.2	4.75	39.6	5.70	46.0	6.71	49.2	7.23	52.4	7.76	58.8	8.86	65.2	10.0
	16	33.2	4.83	39.6	5.80	46.0	6.83	49.2	7.37	52.4	7.91	58.8	9.03	65.2	10.2
	18	33.2	4.92	39.6	5.91	46.0	6.96	49.2	7.51	52.4	8.07	58.8	9.21	65.2	10.4
	20	33.2	5.00	39.6	6.02	46.0	7.10	49.2	7.66	52.4	8.23	58.8	9.55	65.2	11.1
	21	33.2	5.05	39.6	6.08	46.0	7.17	49.2	7.73	52.4	8.40	58.8	9.9	65.2	11.5
	23	33.2	5.14	39.6	6.20	46.0	7.52	49.2	8.23	52.4	8.99	58.8	10.6	65.2	12.3
	25	33.2	5.31	39.6	6.59	46.0	8.03	49.2	8.80	52.4	9.61	58.8	11.3	65.2	13.2
	27	33.2	5.65	39.6	7.03	46.0	8.56	49.2	9.39	52.4	10.3	58.8	12.1	65.2	14.1
	29	33.2	6.00	39.6	7.48	46.0	9.13	49.2	10.0	52.4	10.9	58.8	12.9	65.2	15.1
	31	33.2	6.37	39.6	7.95	46.0	9.72	49.2	10.7	52.4	11.7	58.8	13.8	64.2	15.7
	33	33.2	6.76	39.6	8.46	46.0	10.3	49.2	11.4	52.4	12.4	58.8	14.7	63.2	16.3
	35	33.2	7.17	39.6	8.98	46.0	11.0	49.2	12.1	52.4	13.2	58.8	15.7	62.2	16.9
	37	33.2	7.60	39.6	9.54	46.0	11.7	49.2	12.9	52.4	14.1	58.8	16.7	61.2	17.5
	39	33.2	8.05	39.6	10.1	46.0	12.4	49.2	13.7	52.4	15.0	58.8	17.8	60.2	18.1
70 (385)	10	29.1	4.04	34.7	4.80	40.3	5.60	43.1	6.02	45.8	6.45	51.4	7.33	57.0	8.24
	12	29.1	4.11	34.7	4.88	40.3	5.70	43.1	6.13	45.8	6.56	51.4	7.46	57.0	8.40
	14	29.1	4.17	34.7	4.96	40.3	5.80	43.1	6.24	45.8	6.68	51.4	7.60	57.0	8.56
	16	29.1	4.24	34.7	5.05	40.3	5.91	43.1	6.35	45.8	6.81	51.4	7.75	57.0	8.72
	18	29.1	4.31	34.7	5.13	40.3	6.01	43.1	6.47	45.8	6.94	51.4	7.90	57.0	8.89
	20	29.1	4.38	34.7	5.23	40.3	6.13	43.1	6.59	45.8	7.07	51.4	8.06	57.0	9.14
	21	29.1	4.42	34.7	5.27	40.3	6.19	43.1	6.66	45.8	7.14	51.4	8.18	57.0	9.47
	23	29.1	4.49	34.7	5.37	40.3	6.31	43.1	6.89	45.8	7.48	51.4	8.76	57.0	10.1
	25	29.1	4.57	34.7	5.59	40.3	6.73	43.1	7.35	45.8	7.99	51.4	9.36	57.0	10.8
	27	29.1	4.83	34.7	5.94	40.3	7.17	43.1	7.84	45.8	8.53	51.4	10.0	57.0	11.6
	29	29.1	5.13	34.7	6.32	40.3	7.64	43.1	8.35	45.8	9.09	51.4	10.7	57.0	12.4
	31	29.1	5.44	34.7	6.71	40.3	8.13	43.1	8.88	45.8	9.68	51.4	11.4	57.0	13.2
	33	29.1	5.77	34.7	7.13	40.3	8.64	43.1	9.45	45.8	10.3	51.4	12.1	57.0	14.1
	35	29.1	6.11	34.7	7.56	40.3	9.18	43.1	10.0	45.8	11.0	51.4	12.9	57.0	15.0
	37	29.1	6.46	34.7	8.02	40.3	9.75	43.1	10.7	45.8	11.7	51.4	13.7	57.0	16.0
	39	29.1	6.84	34.7	8.50	40.3	10.3	43.1	11.3	45.8	12.4	51.4	14.6	57.0	17.0
60 (330)	10	24.9	3.52	29.7	4.13	34.5	4.78	36.9	5.12	39.3	5.46	44.1	6.18	48.9	6.92
	12	24.9	3.57	29.7	4.19	34.5	4.86	36.9	5.20	39.3	5.56	44.1	6.29	48.9	7.05
	14	24.9	3.62	29.7	4.26	34.5	4.94	36.9	5.29	39.3	5.65	44.1	6.40	48.9	7.18
	16	24.9	3.67	29.7	4.33	34.5	5.02	36.9	5.39	39.3	5.76	44.1	6.52	48.9	7.32
	18	24.9	3.73	29.7	4.40	34.5	5.11	36.9	5.48	39.3	5.86	44.1	6.64	48.9	7.46
	20	24.9	3.79	29.7	4.47	34.5	5.20	36.9	5.58	39.3	5.97	44.1	6.77	48.9	7.60
	21	24.9	3.82	29.7	4.51	34.5	5.25	36.9	5.63	39.3	6.03	44.1	6.84	48.9	7.68
	23	24.9	3.88	29.7	4.59	34.5	5.35	36.9	5.74	39.3	6.14	44.1	7.11	48.9	8.17
	25	24.9	3.95	29.7	4.68	34.5	5.56	36.9	6.03	39.3	6.53	44.1	7.59	48.9	8.72
	27	24.9	4.09	29.7	4.96	34.5	5.91	36.9	6.42	39.3	6.96	44.1	8.09	48.9	9.31
	29	24.9	4.33	29.7	5.26	34.5	6.29	36.9	6.83	39.3	7.40	44.1	8.62	48.9	9.9
	31	24.9	4.59	29.7	5.58	34.5	6.68	36.9	7.26	39.3	7.88	44.1	9.18	48.9	10.6
	33	24.9	4.85	29.7	5.92	34.5	7.09	36.9	7.71	39.3	8.37	44.1	9.8	48.9	11.3
	35	24.9	5.13	29.7	6.27	34.5	7.52	36.9	8.19	39.3	8.89	44.1	10.4	48.9	12.0
	37	24.9	5.42	29.7	6.63	34.5	7.97	36.9	8.69	39.3	9.44	44.1	11.0	48.9	12.8
	39	24.9	5.73	29.7	7.02	34.5	8.45	36.9	9.22	39.3	10.0	44.1	11.7	48.9	13.6
50 (275)	10	20.8	3.02	24.8	3.50	28.8	4.00	30.8	4.27	32.7	4.54	36.7	5.10	40.7	5.68
	12	20.8	3.06	24.8	3.55	28.8	4.07	30.8	4.33	32.7	4.61	36.7	5.18	40.7	5.77
	14	20.8	3.10	24.8	3.60	28.8	4.13	30.8	4.40	32.7	4.69	36.7	5.27	40.7	5.88
	16	20.8	3.15	24.8	3.65	28.8	4.20	30.8	4.48	32.7	4.77	36.7	5.36	40.7	5.98
	18	20.8	3.19	24.8	3.71	28.8	4.26	30.8	4.55	32.7	4.85	36.7	5.46	40.7	6.09
	20	20.8	3.24	24.8	3.77	28.8	4.34	30.8	4.63	32.7	4.93	36.7	5.56	40.7	6.21
	21	20.8	3.26	24.8	3.80	28.8	4.37	30.8	4.67	32.7	4.98	36.7	5.61	40.7	6.27
	23	20.8	3.31	24.8	3.86	28.8	4.45	30.8	4.75	32.7	5.07	36.7	5.72	40.7	6.41
	25	20.8	3.36	24.8	3.92	28.8	4.53	30.8	4.85	32.7	5.22	36.7	6.00	40.7	6.84
	27	20.8	3.41	24.8	4.06	28.8	4.78	30.8	5.16	32.7	5.55	36.7	6.39	40.7	7.29
	29	20.8	3.61	24.8	4.31	28.8	5.07	30.8	5.48	32.7	5.90	36.7	6.80	40.7	7.76
	31	20.8	3.81	24.8	4.56	28.8	5.38	30.8	5.81	32.7	6.26	36.7	7.23	40.7	8.26
	33	20.8	4.03	24.8	4.82	28.8	5.70	30.8	6.16	32.7	6.65	36.7	7.67	40.7	8.78
	35	20.8	4.25	24.8	5.10	28.8	6.03	30.8	6.53	32.7	7.05	36.7	8.15	40.7	9.33
	37	20.8	4.48	24.8	5.39	28.8	6.38	30.8	6.92	32.7	7.47	36.7	8.65	40.7	9.9
	39	20.8	4.73	24.8	5.69	28.8	6.76	30.8	7.32	32.7	7.91	36.7	9.17	40.7	10.5

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

RXYQ24PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (780)	10	59.1	8.93	70.5	10.9	81.9	13.0	84.9	13.3	88.0	13.0	88.1	12.5	90.2	11.9
	12	59.1	9.1	70.5	11.1	81.9	13.3	83.8	13.2	84.9	12.9	87.0	12.4	89.1	12.2
	14	59.1	9.3	70.5	11.4	81.6	13.4	82.7	13.1	83.8	12.9	85.9	12.8	88.0	12.9
	16	59.1	9.4	70.5	11.6	80.5	13.4	81.6	13.3	82.7	13.3	84.8	13.4	86.9	13.6
	18	59.1	9.6	70.5	11.8	79.4	13.9	80.5	13.9	81.6	14.0	83.7	14.1	85.8	14.3
	20	59.1	9.8	70.5	12.6	78.3	14.5	79.4	14.6	80.5	14.7	82.6	14.8	84.7	15.0
	21	59.1	10.1	70.5	13.0	77.8	14.9	78.9	15.0	79.9	15.0	82.1	15.2	84.2	15.3
	23	59.1	10.8	70.5	14.0	76.7	15.6	77.8	15.6	78.8	15.7	81.0	15.9	83.1	16.0
	25	59.1	11.6	70.5	15.0	75.6	16.2	76.7	16.3	77.7	16.4	79.9	16.6	82.0	16.7
	27	59.1	12.4	70.5	16.0	74.5	16.9	75.6	17.0	76.6	17.1	78.8	17.3	80.9	17.5
	29	59.1	13.2	70.5	17.1	73.4	17.6	74.5	17.7	75.5	17.8	77.7	18.0	79.8	18.2
	31	59.1	14.1	70.2	18.1	72.3	18.3	73.4	18.4	74.4	18.5	76.6	18.7	78.7	18.9
	33	59.1	15.0	69.1	18.8	71.2	19.0	72.3	19.1	73.3	19.2	75.5	19.4	77.6	19.6
	35	59.1	16.0	68.0	19.5	70.1	19.7	71.2	19.8	72.2	19.9	74.4	20.1	76.5	20.4
	37	59.1	17.0	66.9	20.1	69.0	20.4	70.1	20.5	71.2	20.6	73.3	20.9	75.4	21.1
	39	59.1	18.1	65.8	20.8	67.9	21.1	69.0	21.2	70.1	21.2	72.2	21.6	74.3	21.8
120 (720)	10	54.6	8.16	65.1	10.0	75.6	11.9	80.9	12.8	84.6	13.3	86.6	12.8	88.5	12.3
	12	54.6	8.31	65.1	10.2	75.6	12.1	80.9	13.1	83.5	13.3	85.5	12.8	87.5	12.3
	14	54.6	8.47	65.1	10.4	75.6	12.3	80.9	13.3	82.4	13.2	84.4	12.7	86.4	12.8
	16	54.6	8.63	65.1	10.6	75.6	12.6	80.3	13.4	81.3	13.2	83.3	13.4	85.3	13.5
	18	54.6	8.79	65.1	10.8	75.6	13.0	79.2	13.9	80.2	13.9	82.2	14.0	84.2	14.2
	20	54.6	8.97	65.1	11.2	75.6	14.0	78.1	14.5	79.1	14.6	81.1	14.7	83.1	14.9
	21	54.6	9.06	65.1	11.6	75.6	14.5	77.6	14.9	78.6	14.9	80.5	15.1	82.5	15.2
	23	54.6	9.7	65.1	12.4	75.5	15.5	76.5	15.6	77.5	15.6	79.5	15.8	81.4	15.9
	25	54.6	10.3	65.1	13.3	74.4	16.1	75.4	16.2	76.4	16.3	78.4	16.5	80.3	16.6
	27	54.6	11.0	65.1	14.2	73.3	16.8	74.3	16.9	75.3	17.0	77.3	17.2	79.2	17.3
	29	54.6	11.8	65.1	15.2	72.2	17.5	73.2	17.6	74.2	17.7	76.2	17.9	78.1	18.0
	31	54.6	12.5	65.1	16.2	71.1	18.2	72.1	18.3	73.1	18.4	75.1	18.6	77.0	18.7
	33	54.6	13.4	65.1	17.3	70.0	18.9	71.0	19.0	72.0	19.1	74.0	19.3	75.9	19.5
	35	54.6	14.2	65.1	18.4	68.9	19.6	69.9	19.7	70.9	19.8	72.9	20.0	74.8	20.2
	37	54.6	15.1	65.1	19.6	67.8	20.3	68.8	20.4	69.8	20.5	71.8	20.7	73.7	20.8
	39	54.6	16.1	64.8	20.7	66.7	20.9	67.7	21.1	68.7	21.2	70.7	21.4	72.7	21.6
110 (660)	10	50.0	7.41	59.7	9.03	69.3	10.7	74.1	11.6	79.0	12.5	85.1	13.2	86.9	12.8
	12	50.0	7.54	59.7	9.2	69.3	10.9	74.1	11.8	79.0	12.7	84.0	13.2	85.8	12.7
	14	50.0	7.68	59.7	9.4	69.3	11.1	74.1	12.0	79.0	12.9	82.9	13.1	84.7	12.7
	16	50.0	7.83	59.7	9.5	69.3	11.3	74.1	12.3	79.0	13.2	81.8	13.3	83.6	13.4
	18	50.0	7.97	59.7	9.7	69.3	11.6	74.1	12.6	78.9	13.8	80.7	13.9	82.5	14.1
	20	50.0	8.13	59.7	9.9	69.3	12.3	74.1	13.5	77.8	14.5	79.6	14.6	81.4	14.7
	21	50.0	8.21	59.7	10.2	69.3	12.7	74.1	14.0	77.2	14.8	79.0	15.0	80.8	15.1
	23	50.0	8.59	59.7	11.0	69.3	13.6	74.1	15.1	76.1	15.5	77.9	15.7	78.7	15.8
	25	50.0	9.2	59.7	11.7	69.3	14.6	74.1	16.1	75.0	16.2	76.8	16.3	78.7	16.5
	27	50.0	9.8	59.7	12.5	69.3	15.6	73.0	16.8	73.9	16.9	75.8	17.0	77.6	17.2
	29	50.0	10.4	59.7	13.4	69.3	16.7	72.0	17.5	72.9	17.6	74.7	17.7	76.5	17.9
	31	50.0	11.1	59.7	14.2	69.3	17.8	70.9	18.2	71.8	18.2	73.6	18.4	75.4	18.6
	33	50.0	11.8	59.7	15.2	68.9	18.8	69.8	18.9	70.7	18.9	72.5	19.1	74.3	19.3
	35	50.0	12.6	59.7	16.2	67.8	19.4	68.7	19.5	69.6	19.6	71.4	19.8	73.2	20.0
	37	50.0	13.4	59.7	17.2	66.7	20.1	67.6	20.2	68.5	20.3	70.3	20.5	72.1	20.7
	39	50.0	14.2	59.7	18.3	65.6	20.8	66.5	20.9	67.4	21.0	69.2	21.2	71.0	21.4
100 (600)	10	45.5	6.69	54.3	8.11	63.0	9.6	67.4	10.4	71.8	11.2	80.5	12.8	85.2	13.2
	12	45.5	6.80	54.3	8.25	63.0	9.8	67.4	10.6	71.8	11.4	80.5	13.0	84.1	13.1
	14	45.5	6.92	54.3	8.41	63.0	10.0	67.4	10.8	71.8	11.6	80.5	13.2	83.0	13.1
	16	45.5	7.05	54.3	8.57	63.0	10.2	67.4	11.0	71.8	11.8	80.3	13.4	81.9	13.3
	18	45.5	7.18	54.3	8.73	63.0	10.4	67.4	11.2	71.8	12.0	79.2	13.8	80.8	14.0
	20	45.5	7.32	54.3	8.90	63.0	10.7	67.4	11.8	71.8	12.9	78.1	14.5	79.7	14.6
	21	45.5	7.39	54.3	8.99	63.0	11.1	67.4	12.2	71.8	13.4	77.5	14.9	79.2	14.9
	23	45.5	7.58	54.3	9.6	63.0	11.8	67.4	13.1	71.8	14.3	76.4	15.5	78.1	15.7
	25	45.5	8.09	54.3	10.2	63.0	12.7	67.4	14.0	71.8	15.4	75.3	16.2	77.0	16.3
	27	45.5	8.62	54.3	10.9	63.0	13.5	67.4	14.9	71.8	16.4	74.2	16.9	75.9	17.0
	29	45.5	9.2	54.3	11.7	63.0	14.5	67.4	16.0	71.5	17.4	73.1	17.6	74.8	17.7
	31	45.5	9.8	54.3	12.4	63.0	15.4	67.4	17.1	70.4	18.1	72.1	18.3	73.7	18.4
	33	45.5	10.4	54.3	13.2	63.0	16.5	67.4	18.2	69.3	18.8	71.0	19.0	72.6	19.1
	35	45.5	11.0	54.3	14.1	63.0	17.5	67.4	19.4	68.2	19.5	69.9	19.7	71.5	19.8
	37	45.5	11.7	54.3	15.0	63.0	18.7	66.3	20.1	67.1	20.2	68.8	20.4	70.4	20.5
	39	45.5	12.5	54.3	16.0	63.0	19.9	65.2	20.8	66.0	20.9	67.7	21.1	69.3	21.2

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (540)	10	40.9	5.98	48.8	7.22	56.7	8.52	60.7	9.2	64.6	9.9	72.5	11.3	80.4	12.7
	12	40.9	6.08	48.8	7.34	56.7	8.68	60.7	9.4	64.6	10.1	72.5	11.5	80.4	13.0
	14	40.9	6.19	48.8	7.48	56.7	8.84	60.7	9.5	64.6	10.3	72.5	11.7	80.4	13.2
	16	40.9	6.30	48.8	7.62	56.7	9.01	60.7	9.7	64.6	10.5	72.5	12.0	80.2	13.4
	18	40.9	6.41	48.8	7.76	56.7	9.2	60.7	9.9	64.6	10.7	72.5	12.2	79.1	13.8
	20	40.9	6.53	48.8	7.91	56.7	9.4	60.7	10.1	64.6	11.1	72.5	13.1	78.1	14.5
	21	40.9	6.59	48.8	7.99	56.7	9.5	60.7	10.5	64.6	11.5	72.5	13.6	77.5	14.9
	23	40.9	6.72	48.8	8.32	56.7	10.2	60.7	11.2	64.6	12.3	72.5	14.6	76.4	15.5
	25	40.9	7.07	48.8	8.88	56.7	10.9	60.7	12.0	64.6	13.1	72.5	15.6	75.3	16.2
	27	40.9	7.53	48.8	9.5	56.7	11.6	60.7	12.8	64.6	14.0	72.5	16.7	74.2	16.9
	29	40.9	8.01	48.8	10.1	56.7	12.4	60.7	13.7	64.6	15.0	71.6	17.5	73.1	17.6
	31	40.9	8.52	48.8	10.7	56.7	13.2	60.7	14.6	64.6	16.0	70.5	18.1	72.0	18.3
	33	40.9	9.05	48.8	11.4	56.7	14.1	60.7	15.6	64.6	17.1	69.4	18.8	70.9	19.0
	35	40.9	9.6	48.8	12.2	56.7	15.0	60.7	16.6	64.6	18.2	68.4	19.5	69.8	19.7
	37	40.9	10.2	48.8	12.9	56.7	16.0	60.7	17.7	64.6	19.4	67.3	20.2	68.7	20.4
	39	40.9	10.8	48.8	13.7	56.7	17.0	60.7	18.8	64.6	20.7	66.2	20.9	67.6	21.1
80 (480)	10	36.4	5.31	43.4	6.36	50.4	7.47	53.9	8.05	57.4	8.64	64.4	9.9	71.5	11.1
	12	36.4	5.40	43.4	6.47	50.4	7.61	53.9	8.20	57.4	8.80	64.4	10.0	71.5	11.3
	14	36.4	5.49	43.4	6.58	50.4	7.75	53.9	8.35	57.4	8.97	64.4	10.2	71.5	11.5
	16	36.4	5.58	43.4	6.70	50.4	7.89	53.9	8.51	57.4	9.1	64.4	10.4	71.5	11.8
	18	36.4	5.68	43.4	6.82	50.4	8.04	53.9	8.67	57.4	9.3	64.4	10.6	71.5	12.0
	20	36.4	5.78	43.4	6.95	50.4	8.20	53.9	8.84	57.4	9.5	64.4	11.0	71.5	12.8
	21	36.4	5.83	43.4	7.02	50.4	8.28	53.9	8.93	57.4	9.7	64.4	11.4	71.5	13.3
	23	36.4	5.94	43.4	7.15	50.4	8.68	53.9	9.5	57.4	10.4	64.4	12.2	71.5	14.2
	25	36.4	6.13	43.4	7.62	50.4	9.3	53.9	10.2	57.4	11.1	64.4	13.1	71.5	15.2
	27	36.4	6.52	43.4	8.11	50.4	9.9	53.9	10.8	57.4	11.8	64.4	14.0	71.5	16.3
	29	36.4	6.93	43.4	8.64	50.4	10.5	53.9	11.6	57.4	12.6	64.4	14.9	71.4	17.4
	31	36.4	7.36	43.4	9.2	50.4	11.2	53.9	12.3	57.4	13.5	64.4	15.9	70.4	18.1
	33	36.4	7.81	43.4	9.8	50.4	11.9	53.9	13.1	57.4	14.4	64.4	17.0	69.3	18.8
	35	36.4	8.28	43.4	10.4	50.4	12.7	53.9	14.0	57.4	15.3	64.4	18.1	68.2	19.5
	37	36.4	8.78	43.4	11.0	50.4	13.5	53.9	14.9	57.4	16.3	64.4	19.3	67.1	20.2
	39	36.4	9.3	43.4	11.7	50.4	14.4	53.9	15.8	57.4	17.3	64.4	20.6	66.0	20.9
70 (420)	10	31.8	4.67	38.0	5.54	44.1	6.47	47.2	6.95	50.2	7.45	56.4	8.46	62.5	9.5
	12	31.8	4.74	38.0	5.63	44.1	6.58	47.2	7.08	50.2	7.58	56.4	8.62	62.5	9.7
	14	31.8	4.82	38.0	5.73	44.1	6.70	47.2	7.20	50.2	7.72	56.4	8.78	62.5	9.9
	16	31.8	4.89	38.0	5.83	44.1	6.82	47.2	7.33	50.2	7.86	56.4	8.95	62.5	10.1
	18	31.8	4.97	38.0	5.93	44.1	6.94	47.2	7.47	50.2	8.01	56.4	9.1	62.5	10.3
	20	31.8	5.06	38.0	6.04	44.1	7.08	47.2	7.62	50.2	8.17	56.4	9.3	62.5	10.6
	21	31.8	5.10	38.0	6.09	44.1	7.14	47.2	7.69	50.2	8.25	56.4	9.5	62.5	10.9
	23	31.8	5.19	38.0	6.20	44.1	7.29	47.2	7.95	50.2	8.64	56.4	10.1	62.5	11.7
	25	31.8	5.28	38.0	6.45	44.1	7.78	47.2	8.49	50.2	9.2	56.4	10.8	62.5	12.5
	27	31.8	5.58	38.0	6.86	44.1	8.29	47.2	9.05	50.2	9.8	56.4	11.5	62.5	13.4
	29	31.8	5.93	38.0	7.30	44.1	8.82	47.2	9.6	50.2	10.5	56.4	12.3	62.5	14.3
	31	31.8	6.28	38.0	7.75	44.1	9.4	47.2	10.3	50.2	11.2	56.4	13.1	62.5	15.2
	33	31.8	6.66	38.0	8.23	44.1	10.0	47.2	10.9	50.2	11.9	56.4	14.0	62.5	16.3
	35	31.8	7.05	38.0	8.73	44.1	10.6	47.2	11.6	50.2	12.7	56.4	14.9	62.5	17.3
	37	31.8	7.46	38.0	9.3	44.1	11.3	47.2	12.3	50.2	13.5	56.4	15.9	62.5	18.5
	39	31.8	7.90	38.0	9.8	44.1	12.0	47.2	13.1	50.2	14.3	56.4	16.9	62.5	19.7
60 (360)	10	27.3	4.06	32.6	4.77	37.8	5.52	40.4	5.91	43.1	6.31	48.3	7.14	53.6	8.00
	12	27.3	4.12	32.6	4.84	37.8	5.61	40.4	6.01	43.1	6.42	48.3	7.26	53.6	8.14
	14	27.3	4.18	32.6	4.92	37.8	5.70	40.4	6.11	43.1	6.53	48.3	7.39	53.6	8.29
	16	27.3	4.24	32.6	5.00	37.8	5.80	40.4	6.22	43.1	6.65	48.3	7.53	53.6	8.45
	18	27.3	4.31	32.6	5.08	37.8	5.90	40.4	6.33	43.1	6.77	48.3	7.67	53.6	8.61
	20	27.3	4.38	32.6	5.17	37.8	6.01	40.4	6.45	43.1	6.89	48.3	7.82	53.6	8.78
	21	27.3	4.41	32.6	5.21	37.8	6.06	40.4	6.51	43.1	6.96	48.3	7.90	53.6	8.87
	23	27.3	4.48	32.6	5.30	37.8	6.18	40.4	6.63	43.1	7.10	48.3	8.21	53.6	9.4
	25	27.3	4.56	32.6	5.40	37.8	6.42	40.4	6.97	43.1	7.54	48.3	8.76	53.6	10.1
	27	27.3	4.72	32.6	5.72	37.8	6.83	40.4	7.42	43.1	8.03	48.3	9.3	53.6	10.8
	29	27.3	5.00	32.6	6.08	37.8	7.26	40.4	7.89	43.1	8.55	48.3	10.0	53.6	11.5
	31	27.3	5.30	32.6	6.44	37.8	7.71	40.4	8.39	43.1	9.1	48.3	10.6	53.6	12.2
	33	27.3	5.61	32.6	6.83	37.8	8.18	40.4	8.91	43.1	9.7	48.3	11.3	53.6	13.0
	35	27.3	5.93	32.6	7.24	37.8	8.68	40.4	9.5	43.1	10.3	48.3	12.0	53.6	13.9
	37	27.3	6.26	32.6	7.66	37.8	9.2	40.4	10.0	43.1	10.9	48.3	12.7	53.6	14.7
	39	27.3	6.62	32.6	8.11	37.8	9.8	40.4	10.6	43.1	11.6	48.3	13.5	53.6	15.7
50 (300)	10	22.7	3.49	27.1	4.04	31.5	4.62	33.7	4.93	35.9	5.24	40.3	5.88	44.7	6.56
	12	22.7	3.54	27.1	4.10	31.5	4.70	33.7	5.01	35.9	5.32	40.3	5.98	44.7	6.67
	14	22.7	3.58	27.1	4.16	31.5	4.77	33.7	5.09	35.9	5.41	40.3	6.09	44.7	6.79
	16	22.7	3.63	27.1	4.22	31.5	4.84	33.7	5.17	35.9	5.50	40.3	6.19	44.7	6.91
	18	22.7	3.68	27.1	4.28	31.5	4.92	33.7	5.26	35.9	5.60	40.3	6.30	44.7	7.04
	20	22.7	3.74	27.1	4.35	31.5	5.01	33.7	5.35	35.9	5.70	40.3	6.42	44.7	7.17
	21	22.7	3.76	27.1	4.39	31.5	5.05	33.7	5.39	35.9	5.75	40.3	6.48	44.7	7.24
	23	22.7	3.82	27.1	4.46	31.5	5.14	33.7	5.49	35.9	5.85	40.3	6.60	44.7	7.40
	25	22.7	3.88	27.1	4.53	31.5	5.23	33.7	5.60	35.9	6.03	40.3	6.93	44.7	7.90
	27	22.7	3.94	27.1	4.69	31.5	5.52	33.7	5.96	35.9	6.41	40.3	7.38	44.7	8.42
	29	22.7	4.17	27.1	4.97	31.5	5.86	33.7	6.33	35.9	6.81	40.3	7.85	44.7	8.96
	31	22.7	4.40	27.1	5.26	31.5	6.21	33.7	6.71	35.9	7.23	40.3	8.34	44.7	9.5
	33	22.7	4.65	27.1	5.57	31.5	6.58	33.7	7.12	35.9	7.68	40.3	8.86	44.7	10.1
	35	22.7	4.91	27.1	5.89	31.5	6.97	33.7	7.54	35.9	8.14	40.3	9.4	44.7	10.8
	37	22.7	5.18	27.1	6.22	31.5	7.37	33.7	7.99	35.9	8.63	40.3	10.0	44.7	11.4
	39	22.7	5.46	27.1	6.57	31.5	7.80	33.7	8.46	35.9	9.1	40.3	10.6	44.7	12.2

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
130 (845)	10	62.6	9.9	74.7	12.2	86.8	14.5	89.9	14.8	91.1	14.5	93.3	13.9	95.6	13.3
	12	62.6	10.1	74.7	12.4	86.8	14.8	88.8	14.7	89.9	14.4	92.2	13.8	94.4	13.6
	14	62.6	10.3	74.7	12.6	86.5	14.9	87.6	14.6	88.7	14.3	91.0	14.2	93.3	14.3
	16	62.6	10.5	74.7	12.9	85.3	14.9	86.4	14.8	87.6	14.8	89.8	15.0	92.1	15.1
	18	62.6	10.7	74.7	13.1	84.2	15.4	85.3	15.5	86.4	15.6	88.7	15.7	90.9	15.9
	20	62.6	10.9	74.7	14.0	83.0	16.2	84.1	16.3	85.2	16.4	87.5	16.5	89.8	16.7
	21	62.6	11.2	74.7	14.5	82.4	16.6	83.5	16.6	84.7	16.7	86.9	16.9	89.2	17.1
	23	62.6	12.0	74.7	15.5	81.2	17.3	82.4	17.4	83.5	17.5	85.8	17.7	88.0	17.9
	25	62.6	12.9	74.7	16.6	80.1	18.1	81.2	18.2	82.3	18.3	84.6	18.5	86.9	18.6
	27	62.6	13.8	74.7	17.8	78.9	18.8	80.1	18.9	81.2	19.0	83.4	19.2	85.7	19.4
	29	62.6	14.7	74.7	19.0	77.8	19.6	78.9	19.7	80.0	19.8	82.3	20.0	84.5	20.2
	31	62.6	15.7	74.3	20.1	76.6	20.4	77.7	20.5	78.9	20.6	81.1	20.8	83.4	21.0
	33	62.6	16.7	73.2	20.9	75.4	21.1	76.6	21.3	77.7	21.4	80.0	21.6	82.2	21.8
	35	62.6	17.8	72.0	21.7	74.3	21.9	75.4	22.0	76.5	22.2	78.8	22.4	81.1	22.7
	37	62.6	18.9	70.9	22.4	73.1	22.7	74.2	22.8	75.4	23.0	77.6	23.2	79.9	23.5
	39	62.6	20.2	69.7	23.2	72.0	23.5	73.1	23.6	74.2	23.8	76.5	24.0	78.7	24.3
120 (780)	10	57.8	9.1	69.0	11.1	80.1	13.2	85.7	14.3	89.6	14.9	91.7	14.3	93.8	13.7
	12	57.8	9.3	69.0	11.3	80.1	13.4	85.7	14.5	88.5	14.8	90.6	14.2	92.6	13.6
	14	57.8	9.4	69.0	11.5	80.1	13.7	85.7	14.8	87.3	14.7	89.4	14.1	91.5	14.2
	16	57.8	9.6	69.0	11.7	80.1	14.0	85.1	14.9	86.1	14.7	88.2	14.9	90.3	15.0
	18	57.8	9.8	69.0	12.0	80.1	14.5	83.9	15.4	85.0	15.5	87.1	15.6	89.2	15.8
	20	57.8	10.0	69.0	12.5	80.1	15.5	82.8	16.2	83.8	16.2	85.9	16.4	88.0	16.5
	21	57.8	10.1	69.0	12.9	80.1	16.1	82.2	16.6	83.2	16.6	85.3	16.8	87.4	16.9
	23	57.8	10.8	69.0	13.8	80.0	17.2	81.0	17.3	82.1	17.4	84.2	17.6	86.3	17.7
	25	57.8	11.5	69.0	14.8	78.8	18.0	79.9	18.1	80.9	18.1	83.0	18.3	85.1	18.5
	27	57.8	12.3	69.0	15.8	77.7	18.7	78.7	18.8	79.8	18.9	81.8	19.1	83.9	19.3
	29	57.8	13.1	69.0	16.9	76.5	19.5	77.6	19.6	78.6	19.7	80.7	19.9	82.8	20.1
	31	57.8	14.0	69.0	18.0	75.4	20.2	76.4	20.4	77.4	20.5	79.5	20.7	81.6	20.9
	33	57.8	14.9	69.0	19.2	74.2	21.0	75.2	21.1	76.3	21.2	78.4	21.4	80.4	21.7
	35	57.8	15.8	69.0	20.5	73.0	21.8	74.1	21.9	75.1	22.0	77.2	22.2	79.3	22.5
	37	57.8	16.8	69.0	21.8	71.9	22.5	72.9	22.7	74.0	22.8	76.0	23.0	78.1	23.3
	39	57.8	17.9	68.6	23.1	70.7	23.3	71.7	23.5	72.8	23.6	74.9	23.8	77.0	24.1
110 (715)	10	53.0	8.25	63.2	10.0	73.4	11.9	78.5	12.9	83.6	13.9	90.1	14.7	92.0	14.2
	12	53.0	8.40	63.2	10.2	73.4	12.2	78.5	13.1	83.6	14.1	89.0	14.7	90.9	14.1
	14	53.0	8.55	63.2	10.4	73.4	12.4	78.5	13.4	83.6	14.4	87.8	14.6	89.7	14.1
	16	53.0	8.71	63.2	10.6	73.4	12.6	78.5	13.7	83.6	14.7	86.6	14.8	88.5	14.9
	18	53.0	8.88	63.2	10.8	73.4	12.9	78.5	14.0	83.6	15.4	85.5	15.5	87.4	15.7
	20	53.0	9.1	63.2	11.1	73.4	13.6	78.5	15.1	82.4	16.1	84.3	16.3	86.2	16.4
	21	53.0	9.1	63.2	11.4	73.4	14.1	78.5	15.6	81.8	16.5	83.7	16.7	85.6	16.8
	23	53.0	9.6	63.2	12.2	73.4	15.2	78.5	16.8	80.7	17.3	82.6	17.4	84.5	17.6
	25	53.0	10.2	63.2	13.0	73.4	16.2	78.5	18.0	79.5	18.0	81.4	18.2	83.3	18.3
	27	53.0	10.9	63.2	13.9	73.4	17.4	77.4	18.7	78.3	18.8	80.2	19.0	82.2	19.1
	29	53.0	11.6	63.2	14.9	73.4	18.5	76.2	19.5	77.2	19.5	79.1	19.7	81.0	19.9
	31	53.0	12.4	63.2	15.9	73.4	19.8	75.1	20.2	76.0	20.3	77.9	20.5	79.8	20.7
	33	53.0	13.2	63.2	16.9	72.9	20.9	73.9	21.0	74.9	21.1	76.8	21.3	78.7	21.5
	35	53.0	14.0	63.2	18.0	71.8	21.6	72.7	21.7	73.7	21.9	75.6	22.1	77.5	22.3
	37	53.0	14.9	63.2	19.2	70.6	22.4	71.6	22.5	72.5	22.6	74.4	22.8	76.4	23.1
	39	53.0	15.8	63.2	20.4	69.5	23.2	70.4	23.3	71.4	23.4	73.3	23.6	75.2	23.9
100 (650)	10	48.2	7.44	57.5	9.0	66.8	10.7	71.4	11.6	76.0	12.4	85.3	14.2	90.3	14.7
	12	48.2	7.57	57.5	9.2	66.8	10.9	71.4	11.8	76.0	12.7	85.3	14.5	89.1	14.6
	14	48.2	7.71	57.5	9.4	66.8	11.1	71.4	12.0	76.0	12.9	85.3	14.7	87.9	14.5
	16	48.2	7.85	57.5	9.5	66.8	11.3	71.4	12.2	76.0	13.2	85.0	14.9	86.8	14.8
	18	48.2	7.99	57.5	9.7	66.8	11.5	71.4	12.5	76.0	13.4	83.9	15.4	85.6	15.5
	20	48.2	8.15	57.5	9.9	66.8	11.9	71.4	13.1	76.0	14.4	82.7	16.2	84.5	16.3
	21	48.2	8.22	57.5	10.0	66.8	12.3	71.4	13.6	76.0	14.9	82.1	16.5	83.9	16.7
	23	48.2	8.44	57.5	10.7	66.8	13.2	71.4	14.5	76.0	16.0	81.0	17.3	82.7	17.4
	25	48.2	9.0	57.5	11.4	66.8	14.1	71.4	15.6	76.0	17.1	79.8	18.1	81.6	18.2
	27	48.2	9.6	57.5	12.2	66.8	15.1	71.4	16.6	76.0	18.3	78.7	18.8	80.4	19.0
	29	48.2	10.2	57.5	13.0	66.8	16.1	71.4	17.8	75.8	19.4	77.5	19.6	79.2	19.7
	31	48.2	10.9	57.5	13.8	66.8	17.2	71.4	19.0	74.6	20.2	76.3	20.3	78.1	20.5
	33	48.2	11.6	57.5	14.7	66.8	18.3	71.4	20.3	73.4	20.9	75.2	21.1	76.9	21.3
	35	48.2	12.3	57.5	15.7	66.8	19.5	71.4	21.6	72.3	21.7	74.0	21.9	75.7	22.1
	37	48.2	13.1	57.5	16.7	66.8	20.8	70.2	22.4	71.1	22.5	72.8	22.7	74.6	22.9
	39	48.2	13.9	57.5	17.8	66.8	22.2	69.1	23.1	69.9	23.2	71.7	23.4	73.4	23.7

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
90 (585)	10	43.4	6.66	51.7	8.03	60.1	9.5	64.3	10.2	68.4	11.0	76.8	12.6	85.2	14.2
	12	43.4	6.78	51.7	8.18	60.1	9.7	64.3	10.4	68.4	11.2	76.8	12.8	85.2	14.4
	14	43.4	6.89	51.7	8.33	60.1	9.8	64.3	10.6	68.4	11.4	76.8	13.1	85.2	14.7
	16	43.4	7.01	51.7	8.48	60.1	10.0	64.3	10.8	68.4	11.6	76.8	13.3	85.0	15.0
	18	43.4	7.14	51.7	8.64	60.1	10.2	64.3	11.0	68.4	11.9	76.8	13.6	83.8	15.4
	20	43.4	7.27	51.7	8.81	60.1	10.4	64.3	11.3	68.4	12.3	76.8	14.6	82.7	16.2
	21	43.4	7.34	51.7	8.89	60.1	10.6	64.3	11.7	68.4	12.8	76.8	15.1	82.1	16.5
	23	43.4	7.48	51.7	9.3	60.1	11.4	64.3	12.5	68.4	13.7	76.8	16.2	80.9	17.3
	25	43.4	7.88	51.7	9.9	60.1	12.1	64.3	13.4	68.4	14.6	76.8	17.4	79.8	18.1
	27	43.4	8.39	51.7	10.5	60.1	13.0	64.3	14.3	68.4	15.6	76.8	18.6	78.6	18.8
	29	43.4	8.92	51.7	11.2	60.1	13.8	64.3	15.2	68.4	16.7	75.9	19.4	77.5	19.6
	31	43.4	9.5	51.7	12.0	60.1	14.7	64.3	16.2	68.4	17.8	74.7	20.2	76.3	20.3
	33	43.4	10.1	51.7	12.7	60.1	15.7	64.3	17.3	68.4	19.0	73.6	20.9	75.1	21.1
	35	43.4	10.7	51.7	13.5	60.1	16.7	64.3	18.5	68.4	20.3	72.4	21.7	74.0	21.9
	37	43.4	11.4	51.7	14.4	60.1	17.8	64.3	19.7	68.4	21.6	71.2	22.5	72.8	22.7
	39	43.4	12.0	51.7	15.3	60.1	19.0	64.3	20.9	68.4	23.0	70.1	23.2	71.7	23.4
80 (520)	10	38.5	5.91	46.0	7.08	53.4	8.32	57.1	8.96	60.8	9.6	68.3	11.0	75.7	12.4
	12	38.5	6.01	46.0	7.20	53.4	8.47	57.1	9.1	60.8	9.8	68.3	11.2	75.7	12.6
	14	38.5	6.11	46.0	7.33	53.4	8.62	57.1	9.3	60.8	10.0	68.3	11.4	75.7	12.8
	16	38.5	6.21	46.0	7.46	53.4	8.79	57.1	9.5	60.8	10.2	68.3	11.6	75.7	13.1
	18	38.5	6.32	46.0	7.60	53.4	8.95	57.1	9.7	60.8	10.4	68.3	11.8	75.7	13.3
	20	38.5	6.43	46.0	7.74	53.4	9.1	57.1	9.8	60.8	10.6	68.3	12.3	75.7	14.3
	21	38.5	6.49	46.0	7.81	53.4	9.2	57.1	9.9	60.8	10.8	68.3	12.7	75.7	14.8
	23	38.5	6.61	46.0	7.97	53.4	9.7	57.1	10.6	60.8	11.6	68.3	13.6	75.7	15.9
	25	38.5	6.82	46.0	8.48	53.4	10.3	57.1	11.3	60.8	12.4	68.3	14.6	75.7	17.0
	27	38.5	7.26	46.0	9.0	53.4	11.0	57.1	12.1	60.8	13.2	68.3	15.6	75.7	18.2
	29	38.5	7.71	46.0	9.6	53.4	11.7	57.1	12.9	60.8	14.1	68.3	16.6	75.7	19.4
	31	38.5	8.19	46.0	10.2	53.4	12.5	57.1	13.7	60.8	15.0	68.3	17.8	74.5	20.2
	33	38.5	8.69	46.0	10.9	53.4	13.3	57.1	14.6	60.8	16.0	68.3	18.9	73.4	20.9
	35	38.5	9.2	46.0	11.5	53.4	14.2	57.1	15.6	60.8	17.0	68.3	20.2	72.2	21.7
	37	38.5	9.8	46.0	12.3	53.4	15.1	57.1	16.6	60.8	18.1	68.3	21.5	71.0	22.5
	39	38.5	10.4	46.0	13.0	53.4	16.0	57.1	17.6	60.8	19.3	68.3	22.9	69.9	23.2
70 (455)	10	33.7	5.20	40.2	6.17	46.7	7.20	50.0	7.74	53.2	8.29	59.7	9.4	66.2	10.6
	12	33.7	5.28	40.2	6.27	46.7	7.33	50.0	7.88	53.2	8.44	59.7	9.6	66.2	10.8
	14	33.7	5.36	40.2	6.38	46.7	7.46	50.0	8.02	53.2	8.59	59.7	9.8	66.2	11.0
	16	33.7	5.45	40.2	6.49	46.7	7.59	50.0	8.17	53.2	8.75	59.7	10.0	66.2	11.2
	18	33.7	5.54	40.2	6.60	46.7	7.73	50.0	8.32	53.2	8.92	59.7	10.2	66.2	11.4
	20	33.7	5.63	40.2	6.72	46.7	7.88	50.0	8.48	53.2	9.1	59.7	10.4	66.2	11.8
	21	33.7	5.68	40.2	6.78	46.7	7.95	50.0	8.56	53.2	9.2	59.7	10.5	66.2	12.2
	23	33.7	5.78	40.2	6.91	46.7	8.12	50.0	8.85	53.2	9.6	59.7	11.3	66.2	13.0
	25	33.7	5.88	40.2	7.18	46.7	8.66	50.0	9.4	53.2	10.3	59.7	12.0	66.2	13.9
	27	33.7	6.22	40.2	7.64	46.7	9.2	50.0	10.1	53.2	11.0	59.7	12.9	66.2	14.9
	29	33.7	6.60	40.2	8.13	46.7	9.8	50.0	10.7	53.2	11.7	59.7	13.7	66.2	15.9
	31	33.7	7.00	40.2	8.63	46.7	10.4	50.0	11.4	53.2	12.4	59.7	14.6	66.2	17.0
	33	33.7	7.41	40.2	9.2	46.7	11.1	50.0	12.2	53.2	13.2	59.7	15.6	66.2	18.1
	35	33.7	7.85	40.2	9.7	46.7	11.8	50.0	12.9	53.2	14.1	59.7	16.6	66.2	19.3
	37	33.7	8.31	40.2	10.3	46.7	12.5	50.0	13.7	53.2	15.0	59.7	17.7	66.2	20.6
	39	33.7	8.79	40.2	10.9	46.7	13.3	50.0	14.6	53.2	15.9	59.7	18.8	66.2	21.9
60 (390)	10	28.9	4.52	34.5	5.31	40.1	6.14	42.8	6.58	45.6	7.02	51.2	7.95	56.8	8.90
	12	28.9	4.59	34.5	5.39	40.1	6.24	42.8	6.69	45.6	7.15	51.2	8.09	56.8	9.1
	14	28.9	4.65	34.5	5.48	40.1	6.35	42.8	6.80	45.6	7.27	51.2	8.23	56.8	9.2
	16	28.9	4.72	34.5	5.56	40.1	6.46	42.8	6.92	45.6	7.40	51.2	8.38	56.8	9.4
	18	28.9	4.80	34.5	5.66	40.1	6.57	42.8	7.05	45.6	7.54	51.2	8.54	56.8	9.6
	20	28.9	4.87	34.5	5.75	40.1	6.69	42.8	7.18	45.6	7.68	51.2	8.71	56.8	9.8
	21	28.9	4.91	34.5	5.80	40.1	6.75	42.8	7.24	45.6	7.75	51.2	8.79	56.8	9.9
	23	28.9	4.99	34.5	5.90	40.1	6.88	42.8	7.38	45.6	7.90	51.2	9.1	56.8	10.5
	25	28.9	5.07	34.5	6.01	40.1	7.14	42.8	7.76	45.6	8.40	51.2	9.8	56.8	11.2
	27	28.9	5.26	34.5	6.37	40.1	7.60	42.8	8.26	45.6	8.94	51.2	10.4	56.8	12.0
	29	28.9	5.57	34.5	6.77	40.1	8.08	42.8	8.79	45.6	9.5	51.2	11.1	56.8	12.8
	31	28.9	5.90	34.5	7.18	40.1	8.58	42.8	9.3	45.6	10.1	51.2	11.8	56.8	13.6
	33	28.9	6.24	34.5	7.61	40.1	9.1	42.8	9.9	45.6	10.8	51.2	12.6	56.8	14.5
	35	28.9	6.60	34.5	8.06	40.1	9.7	42.8	10.5	45.6	11.4	51.2	13.4	56.8	15.4
	37	28.9	6.97	34.5	8.53	40.1	10.3	42.8	11.2	45.6	12.1	51.2	14.2	56.8	16.4
	39	28.9	7.37	34.5	9.0	40.1	10.9	42.8	11.9	45.6	12.9	51.2	15.1	56.8	17.5
50 (325)	10	24.1	3.89	28.7	4.50	33.4	5.15	35.7	5.49	38.0	5.83	42.7	6.55	47.3	7.30
	12	24.1	3.94	28.7	4.56	33.4	5.23	35.7	5.57	38.0	5.93	42.7	6.66	47.3	7.42
	14	24.1	3.99	28.7	4.63	33.4	5.31	35.7	5.66	38.0	6.03	42.7	6.78	47.3	7.56
	16	24.1	4.04	28.7	4.70	33.4	5.39	35.7	5.76	38.0	6.13	42.7	6.89	47.3	7.69
	18	24.1	4.10	28.7	4.77	33.4	5.48	35.7	5.85	38.0	6.23	42.7	7.02	47.3	7.84
	20	24.1	4.16	28.7	4.84	33.4	5.57	35.7	5.95	38.0	6.34	42.7	7.15	47.3	7.98
	21	24.1	4.19	28.7	4.88	33.4	5.62	35.7	6.00	38.0	6.40	42.7	7.21	47.3	8.06
	23	24.1	4.25	28.7	4.96	33.4	5.72	35.7	6.11	38.0	6.52	42.7	7.35	47.3	8.24
	25	24.1	4.32	28.7	5.05	33.4	5.82	35.7	6.24	38.0	6.71	42.7	7.72	47.3	8.79
	27	24.1	4.39	28.7	5.23	33.4	6.14	35.7	6.63	38.0	7.14	42.7	8.22	47.3	9.4
	29	24.1	4.64	28.7	5.54	33.4	6.52	35.7	7.04	38.0	7.59	42.7	8.74	47.3	10.0
	31	24.1	4.90	28.7	5.86	33.4	6.91	35.7	7.47	38.0	8.05	42.7	9.3	47.3	10.6
	33	24.1	5.18	28.7	6.20	33.4	7.32	35.7	7.92	38.0	8.55	42.7	9.9	47.3	11.3
	35	24.1	5.46	28.7	6.56	33.4	7.76	35.7	8.40	38.0	9.1	42.7	10.5	47.3	12.0
	37	24.1	5.76	28.7	6.93	33.4	8.21	35.7	8.89	38.0	9.6	42.7	11.1	47.3	12.7
	39	24.1	6.08	28.7	7.32	33.4	8.69	35.7	9.4	38.0	10.2	42.7	11.8	47.3	13.5

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

RXYQ28PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
130 (910)	10	67.6	11.2	80.6	13.7	93.6	16.3	97.0	16.6	98	16.3	101	15.6	103	14.9
	12	67.6	11.4	80.6	14.0	93.6	16.6	95.7	16.5	96.9	16.2	99	15.5	102	15.3
	14	67.6	11.6	80.6	14.2	93.3	16.8	94.5	16.5	95.7	16.1	98	16.0	101	16.1
	16	67.6	11.8	80.6	14.5	92.0	16.7	93.2	16.6	94.4	16.7	96.9	16.8	99	17.0
	18	67.6	12.1	80.6	14.8	90.8	17.4	92.0	17.5	93.2	17.5	95.6	17.7	98	17.9
	20	67.6	12.3	80.6	15.8	89.5	18.2	90.7	18.3	91.9	18.4	94.4	18.6	96.8	18.8
	21	67.6	12.7	80.6	16.3	88.9	18.6	90.1	18.7	91.3	18.8	93.7	19.0	96.2	19.2
	23	67.6	13.5	80.6	17.5	87.6	19.5	88.8	19.6	90.1	19.7	92.5	19.9	94.9	20.1
	25	67.6	14.5	80.6	18.7	86.4	20.3	87.6	20.4	88.8	20.6	91.2	20.8	93.7	21.0
	27	67.6	15.5	80.6	20.0	85.1	21.2	86.3	21.3	87.6	21.4	90.0	21.6	92.4	21.9
	29	67.6	16.5	80.6	21.4	83.9	22.1	85.1	22.2	86.3	22.3	88.7	22.5	91.2	22.8
	31	67.6	17.6	80.2	22.7	82.6	22.9	83.8	23.0	85.0	23.2	87.5	23.4	89.9	23.7
	33	67.6	18.8	78.9	23.5	81.4	23.8	82.6	23.9	83.8	24.0	86.2	24.3	88.7	24.6
	35	67.6	20.0	77.7	24.4	80.1	24.7	81.3	24.8	82.5	24.9	85.0	25.2	87.4	25.5
	37	67.6	21.3	76.4	25.2	78.9	25.5	80.1	25.7	81.3	25.8	83.7	26.1	86.2	26.4
	39	67.6	22.7	75.2	26.1	77.6	26.4	78.8	26.6	80.0	26.7	82.5	27.0	84.9	27.3
120 (840)	10	62.4	10.2	74.4	12.5	86.4	14.8	92.4	16.1	96.7	16.7	99	16.1	101	15.5
	12	62.4	10.4	74.4	12.7	86.4	15.1	92.4	16.4	95.4	16.6	97.7	16.0	100	15.4
	14	62.4	10.6	74.4	13.0	86.4	15.4	92.4	16.7	94.2	16.6	96.4	15.9	99	16.0
	16	62.4	10.8	74.4	13.2	86.4	15.7	91.8	16.8	92.9	16.6	95.2	16.7	97.4	16.9
	18	62.4	11.0	74.4	13.5	86.4	16.3	90.5	17.4	91.7	17.4	93.9	17.6	96.1	17.7
	20	62.4	11.2	74.4	14.0	86.4	17.5	89.3	18.2	90.4	18.3	92.6	18.4	94.9	18.6
	21	62.4	11.3	74.4	14.5	86.4	18.1	88.6	18.6	89.8	18.7	92.0	18.9	94.3	19.1
	23	62.4	12.1	74.4	15.5	86.3	19.4	87.4	19.5	88.5	19.6	90.8	19.7	93.0	19.9
	25	62.4	12.9	74.4	16.6	85.0	20.2	86.1	20.3	87.3	20.4	89.5	20.6	91.8	20.8
	27	62.4	13.8	74.4	17.8	83.8	21.1	84.9	21.2	86.0	21.3	88.3	21.5	90.5	21.7
	29	62.4	14.7	74.4	19.0	82.5	21.9	83.6	22.0	84.8	22.1	87.0	22.4	89.3	22.6
	31	62.4	15.7	74.4	20.3	81.3	22.8	82.4	22.9	83.5	23.0	85.8	23.2	88.0	23.5
	33	62.4	16.7	74.4	21.6	80.0	23.6	81.1	23.8	82.3	23.9	84.5	24.1	86.8	24.4
	35	62.4	17.8	74.4	23.1	78.8	24.5	79.9	24.6	81.0	24.8	83.3	25.0	85.5	25.3
	37	62.4	19.0	74.4	24.6	77.5	25.4	78.6	25.5	79.8	25.6	82.0	25.9	84.3	26.2
	39	62.4	20.2	74.0	26.0	76.3	26.2	77.4	26.4	78.5	26.5	80.7	26.8	83.0	27.1
110 (770)	10	57.2	9.28	68.2	11.3	79.2	13.4	84.7	14.5	90.2	15.6	97.2	16.6	99	16.0
	12	57.2	9.45	68.2	11.5	79.2	13.7	84.7	14.8	90.2	15.9	95.9	16.5	98.0	15.9
	14	57.2	9.6	68.2	11.7	79.2	13.9	84.7	15.1	90.2	16.2	94.7	16.4	96.7	15.9
	16	57.2	9.8	68.2	12.0	79.2	14.2	84.7	15.4	90.2	16.5	93.4	16.6	95.5	16.8
	18	57.2	10.0	68.2	12.2	79.2	14.5	84.7	15.8	90.1	17.3	92.2	17.5	94.2	17.6
	20	57.2	10.2	68.2	12.4	79.2	15.4	84.7	17.0	88.9	18.2	90.9	18.3	93.0	18.5
	21	57.2	10.3	68.2	12.8	79.2	15.9	84.7	17.6	88.2	18.6	90.3	18.7	92.4	18.9
	23	57.2	10.8	68.2	13.7	79.2	17.0	84.7	18.9	87.0	19.4	89.0	19.6	91.1	19.8
	25	57.2	11.5	68.2	14.7	79.2	18.3	84.7	20.2	85.7	20.3	87.8	20.5	89.9	20.6
	27	57.2	12.3	68.2	15.7	79.2	19.5	83.5	21.0	84.5	21.1	86.5	21.3	88.6	21.5
	29	57.2	13.1	68.2	16.7	79.2	20.9	82.2	21.9	83.2	22.0	85.3	22.2	87.4	22.4
	31	57.2	13.9	68.2	17.8	79.2	22.3	80.9	22.7	82.0	22.9	84.0	23.1	86.1	23.3
	33	57.2	14.8	68.2	19.0	78.7	23.5	79.7	23.6	80.7	23.7	82.8	23.9	84.8	24.2
	35	57.2	15.8	68.2	20.3	77.4	24.3	78.4	24.5	79.5	24.6	81.5	24.8	83.6	25.1
	37	57.2	16.8	68.2	21.6	76.2	25.2	77.2	25.3	78.2	25.5	80.3	25.7	82.3	26.0
	39	57.2	17.8	68.2	23.0	74.9	26.1	75.9	26.2	77.0	26.3	79.0	26.6	81.1	26.9
100 (700)	10	52.0	8.37	62.0	10.2	72.0	12.0	77.0	13.0	82.0	14.0	92.0	16.0	97.3	16.5
	12	52.0	8.52	62.0	10.3	72.0	12.3	77.0	13.2	82.0	14.2	92.0	16.3	96.1	16.4
	14	52.0	8.67	62.0	10.5	72.0	12.5	77.0	13.5	82.0	14.5	92.0	16.6	94.8	16.4
	16	52.0	8.83	62.0	10.7	72.0	12.7	77.0	13.8	82.0	14.8	91.7	16.8	93.6	16.6
	18	52.0	8.99	62.0	10.9	72.0	13.0	77.0	14.0	82.0	15.1	90.5	17.3	92.3	17.5
	20	52.0	9.16	62.0	11.2	72.0	13.4	77.0	14.7	82.0	16.2	89.2	18.2	91.1	18.3
	21	52.0	9.25	62.0	11.3	72.0	13.8	77.0	15.3	82.0	16.7	88.6	18.6	90.5	18.8
	23	52.0	9.50	62.0	12.0	72.0	14.8	77.0	16.4	82.0	18.0	87.3	19.5	89.2	19.6
	25	52.0	10.1	62.0	12.8	72.0	15.9	77.0	17.5	82.0	19.2	86.1	20.3	87.9	20.5
	27	52.0	10.8	62.0	13.7	72.0	17.0	77.0	18.7	82.0	20.6	84.8	21.2	86.7	21.3
	29	52.0	11.5	62.0	14.6	72.0	18.1	77.0	20.0	81.7	21.8	83.6	22.0	85.4	22.2
	31	52.0	12.2	62.0	15.6	72.0	19.3	77.0	21.4	80.4	22.7	82.3	22.9	84.2	23.1
	33	52.0	13.0	62.0	16.6	72.0	20.6	77.0	22.8	79.2	23.5	81.1	23.8	82.9	24.0
	35	52.0	13.8	62.0	17.7	72.0	22.0	77.0	24.3	77.9	24.4	79.8	24.6	81.7	24.8
	37	52.0	14.7	62.0	18.8	72.0	23.4	75.7	25.2	76.7	25.3	78.6	25.5	80.4	25.7
	39	52.0	15.6	62.0	20.0	72.0	24.9	74.5	26.0	75.4	26.1	77.3	26.4	79.2	26.6

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
90 (630)	10	46.8	7.50	55.8	9.04	64.8	10.7	69.3	11.5	73.8	12.4	82.8	14.1	91.8	15.9
	12	46.8	7.62	55.8	9.20	64.8	10.9	69.3	11.7	73.8	12.6	82.8	14.4	91.8	16.2
	14	46.8	7.75	55.8	9.37	64.8	11.1	69.3	12.0	73.8	12.9	82.8	14.7	91.8	16.5
	16	46.8	7.89	55.8	9.54	64.8	11.3	69.3	12.2	73.8	13.1	82.8	15.0	91.7	16.8
	18	46.8	8.03	55.8	9.7	64.8	11.5	69.3	12.4	73.8	13.4	82.8	15.3	90.4	17.3
	20	46.8	8.18	55.8	9.9	64.8	11.7	69.3	12.7	73.8	13.9	82.8	16.4	89.2	18.2
	21	46.8	8.26	55.8	10.0	64.8	11.9	69.3	13.1	73.8	14.4	82.8	17.0	88.5	18.6
	23	46.8	8.41	55.8	10.4	64.8	12.8	69.3	14.0	73.8	15.4	82.8	18.2	87.3	19.5
	25	46.8	8.86	55.8	11.1	64.8	13.7	69.3	15.0	73.8	16.5	82.8	19.5	86.0	20.3
	27	46.8	9.44	55.8	11.9	64.8	14.6	69.3	16.0	73.8	17.6	82.8	20.9	84.8	21.2
	29	46.8	10.0	55.8	12.6	64.8	15.6	69.3	17.1	73.8	18.8	81.8	21.9	83.5	22.0
	31	46.8	10.7	55.8	13.5	64.8	16.6	69.3	18.3	73.8	20.0	80.6	22.7	82.3	22.9
	33	46.8	11.3	55.8	14.3	64.8	17.7	69.3	19.5	73.8	21.4	79.3	23.6	81.0	23.7
	35	46.8	12.0	55.8	15.2	64.8	18.8	69.3	20.8	73.8	22.8	78.1	24.4	79.8	24.6
	37	46.8	12.8	55.8	16.2	64.8	20.0	69.3	22.1	73.8	24.3	76.8	25.3	78.5	25.5
	39	46.8	13.6	55.8	17.2	64.8	21.3	69.3	23.5	73.8	25.9	75.6	26.2	77.3	26.4
80 (560)	10	41.6	6.65	49.6	7.97	57.6	9.36	61.6	10.1	65.6	10.8	73.6	12.3	81.6	13.9
	12	41.6	6.76	49.6	8.10	57.6	9.53	61.6	10.3	65.6	11.0	73.6	12.6	81.6	14.2
	14	41.6	6.87	49.6	8.25	57.6	9.7	61.6	10.5	65.6	11.2	73.6	12.8	81.6	14.4
	16	41.6	6.99	49.6	8.39	57.6	9.9	61.6	10.7	65.6	11.4	73.6	13.1	81.6	14.7
	18	41.6	7.11	49.6	8.55	57.6	10.1	61.6	10.9	65.6	11.7	73.6	13.3	81.6	15.0
	20	41.6	7.24	49.6	8.71	57.6	10.3	61.6	11.1	65.6	11.9	73.6	13.8	81.6	16.1
	21	41.6	7.30	49.6	8.79	57.6	10.4	61.6	11.2	65.6	12.1	73.6	14.3	81.6	16.6
	23	41.6	7.43	49.6	8.96	57.6	10.9	61.6	11.9	65.6	13.0	73.6	15.3	81.6	17.8
	25	41.6	7.68	49.6	9.54	57.6	11.6	61.6	12.7	65.6	13.9	73.6	16.4	81.6	19.1
	27	41.6	8.17	49.6	10.2	57.6	12.4	61.6	13.6	65.6	14.8	73.6	17.5	81.6	20.4
	29	41.6	8.68	49.6	10.8	57.6	13.2	61.6	14.5	65.6	15.8	73.6	18.7	81.6	21.8
	31	41.6	9.21	49.6	11.5	57.6	14.1	61.6	15.4	65.6	16.9	73.6	20.0	80.4	22.7
	33	41.6	9.8	49.6	12.2	57.6	15.0	61.6	16.4	65.6	18.0	73.6	21.3	79.1	23.5
	35	41.6	10.4	49.6	13.0	57.6	15.9	61.6	17.5	65.6	19.2	73.6	22.7	77.9	24.4
	37	41.6	11.0	49.6	13.8	57.6	16.9	61.6	18.6	65.6	20.4	73.6	24.2	76.6	25.3
	39	41.6	11.6	49.6	14.6	57.6	18.0	61.6	19.8	65.6	21.7	73.6	25.8	75.4	26.1
70 (490)	10	36.4	5.85	43.4	6.94	50.4	8.10	53.9	8.71	57.4	9.33	64.4	10.6	71.4	11.9
	12	36.4	5.94	43.4	7.06	50.4	8.24	53.9	8.86	57.4	9.49	64.4	10.8	71.4	12.1
	14	36.4	6.03	43.4	7.18	50.4	8.39	53.9	9.02	57.4	9.7	64.4	11.0	71.4	12.4
	16	36.4	6.13	43.4	7.30	50.4	8.54	53.9	9.19	57.4	9.8	64.4	11.2	71.4	12.6
	18	36.4	6.23	43.4	7.43	50.4	8.70	53.9	9.36	57.4	10.0	64.4	11.4	71.4	12.9
	20	36.4	6.33	43.4	7.56	50.4	8.86	53.9	9.54	57.4	10.2	64.4	11.7	71.4	13.2
	21	36.4	6.39	43.4	7.63	50.4	8.95	53.9	9.6	57.4	10.3	64.4	11.8	71.4	13.7
	23	36.4	6.50	43.4	7.77	50.4	9.13	53.9	10.0	57.4	10.8	64.4	12.7	71.4	14.7
	25	36.4	6.62	43.4	8.08	50.4	9.7	53.9	10.6	57.4	11.6	64.4	13.5	71.4	15.7
	27	36.4	6.99	43.4	8.60	50.4	10.4	53.9	11.3	57.4	12.3	64.4	14.5	71.4	16.8
	29	36.4	7.42	43.4	9.14	50.4	11.0	53.9	12.1	57.4	13.1	64.4	15.4	71.4	17.9
	31	36.4	7.87	43.4	9.7	50.4	11.8	53.9	12.9	57.4	14.0	64.4	16.4	71.4	19.1
	33	36.4	8.34	43.4	10.3	50.4	12.5	53.9	13.7	57.4	14.9	64.4	17.5	71.4	20.4
	35	36.4	8.83	43.4	10.9	50.4	13.3	53.9	14.5	57.4	15.9	64.4	18.7	71.4	21.7
	37	36.4	9.35	43.4	11.6	50.4	14.1	53.9	15.4	57.4	16.9	64.4	19.9	71.4	23.1
	39	36.4	9.9	43.4	12.3	50.4	15.0	53.9	16.4	57.4	17.9	64.4	21.1	71.4	24.6
60 (420)	10	31.2	5.09	37.2	5.97	43.2	6.91	46.2	7.40	49.2	7.90	55.2	8.94	61.2	10.0
	12	31.2	5.16	37.2	6.06	43.2	7.03	46.2	7.53	49.2	8.04	55.2	9.10	61.2	10.2
	14	31.2	5.24	37.2	6.16	43.2	7.14	46.2	7.65	49.2	8.18	55.2	9.26	61.2	10.4
	16	31.2	5.31	37.2	6.26	43.2	7.27	46.2	7.79	49.2	8.33	55.2	9.43	61.2	10.6
	18	31.2	5.40	37.2	6.36	43.2	7.39	46.2	7.93	49.2	8.48	55.2	9.6	61.2	10.8
	20	31.2	5.48	37.2	6.47	43.2	7.53	46.2	8.07	49.2	8.64	55.2	9.8	61.2	11.0
	21	31.2	5.52	37.2	6.53	43.2	7.59	46.2	8.15	49.2	8.72	55.2	9.9	61.2	11.1
	23	31.2	5.61	37.2	6.64	43.2	7.74	46.2	8.30	49.2	8.89	55.2	10.3	61.2	11.8
	25	31.2	5.71	37.2	6.76	43.2	8.04	46.2	8.73	49.2	9.45	55.2	11.0	61.2	12.6
	27	31.2	5.92	37.2	7.17	43.2	8.55	46.2	9.29	49.2	10.1	55.2	11.7	61.2	13.5
	29	31.2	6.27	37.2	7.61	43.2	9.09	46.2	9.9	49.2	10.7	55.2	12.5	61.2	14.4
	31	31.2	6.64	37.2	8.07	43.2	9.7	46.2	10.5	49.2	11.4	55.2	13.3	61.2	15.3
	33	31.2	7.02	37.2	8.56	43.2	10.3	46.2	11.2	49.2	12.1	55.2	14.1	61.2	16.3
	35	31.2	7.42	37.2	9.06	43.2	10.9	46.2	11.8	49.2	12.9	55.2	15.0	61.2	17.4
	37	31.2	7.85	37.2	9.6	43.2	11.5	46.2	12.6	49.2	13.7	55.2	16.0	61.2	18.5
	39	31.2	8.29	37.2	10.2	43.2	12.2	46.2	13.3	49.2	14.5	55.2	17.0	61.2	19.6
50 (350)	10	26.0	4.37	31.0	5.06	36.0	5.79	38.5	6.17	41.0	6.56	46.0	7.37	51.0	8.21
	12	26.0	4.43	31.0	5.13	36.0	5.88	38.5	6.27	41.0	6.67	46.0	7.49	51.0	8.35
	14	26.0	4.49	31.0	5.21	36.0	5.97	38.5	6.37	41.0	6.78	46.0	7.62	51.0	8.50
	16	26.0	4.55	31.0	5.29	36.0	6.07	38.5	6.48	41.0	6.89	46.0	7.76	51.0	8.65
	18	26.0	4.61	31.0	5.37	36.0	6.17	38.5	6.58	41.0	7.01	46.0	7.89	51.0	8.81
	20	26.0	4.68	31.0	5.45	36.0	6.27	38.5	6.70	41.0	7.13	46.0	8.04	51.0	8.98
	21	26.0	4.71	31.0	5.49	36.0	6.32	38.5	6.76	41.0	7.20	46.0	8.11	51.0	9.07
	23	26.0	4.78	31.0	5.58	36.0	6.43	38.5	6.88	41.0	7.33	46.0	8.27	51.0	9.27
	25	26.0	4.86	31.0	5.68	36.0	6.55	38.5	7.02	41.0	7.55	46.0	8.68	51.0	9.9
	27	26.0	4.94	31.0	5.88	36.0	6.91	38.5	7.46	41.0	8.03	46.0	9.24	51.0	10.5
	29	26.0	5.22	31.0	6.23	36.0	7.33	38.5	7.92	41.0	8.54	46.0	9.8	51.0	11.2
	31	26.0	5.52	31.0	6.59	36.0	7.78	38.5	8.41	41.0	9.06	46.0	10.5	51.0	11.9
	33	26.0	5.82	31.0	6.98	36.0	8.24	38.5	8.91	41.0	9.6	46.0	11.1	51.0	12.7
	35	26.0	6.15	31.0	7.38	36.0	8.72	38.5	9.44	41.0	10.2	46.0	11.8	51.0	13.5
	37	26.0	6.48	31.0	7.79	36.0	9.23	38.5	10.0	41.0	10.8	46.0	12.5	51.0	14.3
	39	26.0	6.84	31.0	8.23	36.0	9.8	38.5	10.6	41.0	11.4	46.0	13.3	51.0	15.2

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (975)	10	72.4	11.6	86.3	14.3	100	17.0	104	17.3	105	17.0	108	16.3	110	15.5
	12	72.4	11.9	86.3	14.5	100	17.3	103	17.2	104	16.9	106	16.1	109	15.9
	14	72.4	12.1	86.3	14.8	100	17.5	101	17.1	103	16.8	105	16.6	108	16.8
	16	72.4	12.3	86.3	15.1	99	17.4	100	17.3	101	17.4	104	17.5	106	17.7
	18	72.4	12.6	86.3	15.4	97	18.1	99	18.2	100	18.3	102	18.4	105	18.6
	20	72.4	12.8	86.3	16.4	95.9	19.0	97	19.1	99	19.2	101	19.3	104	19.5
	21	72.4	13.2	86.3	17.0	95.2	19.4	96.5	19.5	98	19.6	100	19.8	103	20.0
	23	72.4	14.1	86.3	18.2	93.9	20.3	95.2	20.4	96.5	20.5	99	20.7	102	20.9
	25	72.4	15.1	86.3	19.5	92.5	21.2	93.8	21.3	95.1	21.4	98	21.6	100	21.8
	27	72.4	16.1	86.3	20.9	91.2	22.1	92.5	22.2	93.8	22.3	96.4	22.5	99	22.8
	29	72.4	17.2	86.3	22.3	89.9	23.0	91.2	23.1	92.5	23.2	95.1	23.5	98	23.7
	31	72.4	18.3	85.9	23.6	88.5	23.9	89.8	24.0	91.1	24.1	93.7	24.4	96.3	24.6
	33	72.4	19.5	84.6	24.5	87.2	24.8	88.5	24.9	89.8	25.0	92.4	25.3	95.0	25.6
	35	72.4	20.8	83.2	25.4	85.8	25.7	87.1	25.8	88.4	26.0	91.0	26.3	93.7	26.5
	37	72.4	22.2	81.9	26.3	84.5	26.6	85.8	26.7	87.1	26.9	89.7	27.2	92.3	27.5
	39	72.4	23.6	80.5	27.2	83.1	27.5	84.4	27.7	85.8	27.8	88.4	28.1	91.0	28.5
120 (900)	10	66.8	10.6	79.7	13.0	92.6	15.5	99	16.7	104	17.4	106	16.8	108	16.1
	12	66.8	10.8	79.7	13.2	92.6	15.8	99	17.0	102	17.3	105	16.7	107	16.0
	14	66.8	11.0	79.7	13.5	92.6	16.1	99	17.4	101	17.2	103	16.6	106	16.7
	16	66.8	11.2	79.7	13.8	92.6	16.4	98	17.5	100	17.3	102	17.4	104	17.6
	18	66.8	11.5	79.7	14.0	92.6	16.9	97.0	18.1	98	18.1	101	18.3	103	18.5
	20	66.8	11.7	79.7	14.6	92.6	18.2	95.7	18.9	96.9	19.0	99	19.2	102	19.4
	21	66.8	11.8	79.7	15.1	92.6	18.9	95.0	19.4	96.2	19.5	99	19.7	101	19.8
	23	66.8	12.6	79.7	16.2	92.4	20.2	93.6	20.3	94.8	20.4	97	20.6	100	20.7
	25	66.8	13.5	79.7	17.3	91.1	21.1	92.3	21.2	93.5	21.3	95.9	21.5	98	21.7
	27	66.8	14.4	79.7	18.5	89.8	21.9	91.0	22.0	92.2	22.2	94.6	22.4	97.0	22.6
	29	66.8	15.3	79.7	19.8	88.4	22.8	89.6	22.9	90.8	23.1	93.2	23.3	95.6	23.5
	31	66.8	16.4	79.7	21.1	87.1	23.7	88.3	23.8	89.5	24.0	91.9	24.2	94.3	24.4
	33	66.8	17.4	79.7	22.5	85.7	24.6	86.9	24.7	88.1	24.9	90.5	25.1	93.0	25.4
	35	66.8	18.5	79.7	24.0	84.4	25.5	85.6	25.6	86.8	25.8	89.2	26.0	91.6	26.3
	37	66.8	19.7	79.7	25.6	83.0	26.4	84.2	26.6	85.5	26.7	87.9	27.0	90.3	27.3
	39	66.8	21.0	79.3	27.0	81.7	27.3	82.9	27.5	84.1	27.6	86.5	27.9	88.9	28.2
110 (825)	10	61.2	9.7	73.0	11.8	84.8	14.0	90.8	15.1	96.7	16.3	104	17.3	106	16.7
	12	61.2	9.8	73.0	12.0	84.8	14.2	90.8	15.4	96.7	16.6	103	17.2	105	16.6
	14	61.2	10.0	73.0	12.2	84.8	14.5	90.8	15.7	96.7	16.9	101	17.1	104	16.6
	16	61.2	10.2	73.0	12.5	84.8	14.8	90.8	16.0	96.7	17.2	100	17.3	102	17.4
	18	61.2	10.4	73.0	12.7	84.8	15.1	90.8	16.4	96.6	18.0	99	18.2	101	18.3
	20	61.2	10.6	73.0	12.9	84.8	16.0	90.8	17.7	95.2	18.9	97	19.1	100	19.2
	21	61.2	10.7	73.0	13.3	84.8	16.6	90.8	18.3	94.5	19.4	96.8	19.5	99	19.7
	23	61.2	11.2	73.0	14.3	84.8	17.8	90.8	19.6	93.2	20.2	95.4	20.4	98	20.6
	25	61.2	12.0	73.0	15.3	84.8	19.0	90.8	21.0	91.9	21.1	94.1	21.3	96.3	21.5
	27	61.2	12.8	73.0	16.3	84.8	20.3	89.4	21.9	90.5	22.0	92.7	22.2	94.9	22.4
	29	61.2	13.6	73.0	17.4	84.8	21.7	88.1	22.8	89.2	22.9	91.4	23.1	93.6	23.3
	31	61.2	14.5	73.0	18.6	84.8	23.2	86.7	23.7	87.8	23.8	90.0	24.0	92.2	24.2
	33	61.2	15.4	73.0	19.8	84.3	24.5	85.4	24.6	86.5	24.7	88.7	24.9	90.9	25.2
	35	61.2	16.4	73.0	21.1	82.9	25.3	84.0	25.5	85.1	25.6	87.4	25.8	89.6	26.1
	37	61.2	17.4	73.0	22.5	81.6	26.2	82.7	26.4	83.8	26.5	86.0	26.8	88.2	27.0
	39	61.2	18.5	73.0	23.9	80.3	27.1	81.4	27.3	82.5	27.4	84.7	27.7	86.9	28.0
100 (750)	10	55.7	8.7	66.4	10.6	77.1	12.5	82.5	13.5	87.9	14.6	99	16.6	104	17.2
	12	55.7	8.9	66.4	10.8	77.1	12.8	82.5	13.8	87.9	14.8	99	16.9	103	17.1
	14	55.7	9.0	66.4	11.0	77.1	13.0	82.5	14.1	87.9	15.1	99	17.3	102	17.0
	16	55.7	9.2	66.4	11.2	77.1	13.3	82.5	14.3	87.9	15.4	98	17.5	100	17.3
	18	55.7	9.4	66.4	11.4	77.1	13.5	82.5	14.6	87.9	15.7	96.9	18.1	99	18.2
	20	55.7	9.5	66.4	11.6	77.1	13.9	82.5	15.3	87.9	16.8	95.6	18.9	98	19.1
	21	55.7	9.6	66.4	11.7	77.1	14.4	82.5	15.9	87.9	17.4	94.9	19.4	96.9	19.5
	23	55.7	9.9	66.4	12.5	77.1	15.4	82.5	17.0	87.9	18.7	93.6	20.3	95.6	20.4
	25	55.7	10.6	66.4	13.4	77.1	16.5	82.5	18.2	87.9	20.0	92.2	21.2	94.2	21.3
	27	55.7	11.2	66.4	14.3	77.1	17.7	82.5	19.5	87.9	21.4	90.9	22.0	92.9	22.2
	29	55.7	12.0	66.4	15.2	77.1	18.9	82.5	20.8	87.5	22.7	89.5	22.9	91.5	23.1
	31	55.7	12.7	66.4	16.2	77.1	20.1	82.5	22.2	86.2	23.6	88.2	23.8	90.2	24.0
	33	55.7	13.5	66.4	17.3	77.1	21.5	82.5	23.7	84.8	24.5	86.9	24.7	88.9	24.9
	35	55.7	14.4	66.4	18.4	77.1	22.9	82.5	25.3	83.5	25.4	85.5	25.6	87.5	25.9
	37	55.7	15.3	66.4	19.6	77.1	24.4	81.2	26.2	82.2	26.3	84.2	26.5	86.2	26.8
	39	55.7	16.2	66.4	20.8	77.1	26.0	79.8	27.1	80.8	27.2	82.8	27.5	84.8	27.7

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (675)	10	50.1	7.80	59.8	9.4	69.4	11.1	74.3	12.0	79.1	12.9	88.7	14.7	98	16.6
	12	50.1	7.94	59.8	9.6	69.4	11.3	74.3	12.2	79.1	13.1	88.7	15.0	98	16.9
	14	50.1	8.07	59.8	9.8	69.4	11.5	74.3	12.4	79.1	13.4	88.7	15.3	98	17.2
	16	50.1	8.21	59.8	9.9	69.4	11.7	74.3	12.7	79.1	13.6	88.7	15.6	98	17.5
	18	50.1	8.36	59.8	10.1	69.4	12.0	74.3	12.9	79.1	13.9	88.7	15.9	96.9	18.1
	20	50.1	8.52	59.8	10.3	69.4	12.2	74.3	13.2	79.1	14.4	88.7	17.1	95.5	18.9
	21	50.1	8.60	59.8	10.4	69.4	12.4	74.3	13.7	79.1	14.9	88.7	17.7	94.9	19.4
	23	50.1	8.8	59.8	10.8	69.4	13.3	74.3	14.6	79.1	16.0	88.7	19.0	93.5	20.3
	25	50.1	9.2	59.8	11.6	69.4	14.2	74.3	15.6	79.1	17.1	88.7	20.3	92.2	21.1
	27	50.1	9.8	59.8	12.4	69.4	15.2	74.3	16.7	79.1	18.3	88.7	21.7	90.8	22.0
	29	50.1	10.5	59.8	13.2	69.4	16.2	74.3	17.8	79.1	19.6	87.7	22.8	89.5	22.9
	31	50.1	11.1	59.8	14.0	69.4	17.3	74.3	19.0	79.1	20.9	86.4	23.6	88.2	23.8
	33	50.1	11.8	59.8	14.9	69.4	18.4	74.3	20.3	79.1	22.3	85.0	24.5	86.8	24.7
	35	50.1	12.5	59.8	15.9	69.4	19.6	74.3	21.6	79.1	23.7	83.7	25.4	85.5	25.6
	37	50.1	13.3	59.8	16.9	69.4	20.9	74.3	23.0	79.1	25.3	82.3	26.3	84.1	26.5
	39	50.1	14.1	59.8	17.9	69.4	22.2	74.3	24.5	79.1	26.9	81.0	27.2	82.8	27.5
80 (600)	10	44.5	6.93	53.1	8.29	61.7	9.7	66.0	10.5	70.3	11.3	78.9	12.8	87.5	14.5
	12	44.5	7.04	53.1	8.44	61.7	9.9	66.0	10.7	70.3	11.5	78.9	13.1	87.5	14.7
	14	44.5	7.16	53.1	8.59	61.7	10.1	66.0	10.9	70.3	11.7	78.9	13.3	87.5	15.0
	16	44.5	7.28	53.1	8.7	61.7	10.3	66.0	11.1	70.3	11.9	78.9	13.6	87.5	15.3
	18	44.5	7.40	53.1	8.9	61.7	10.5	66.0	11.3	70.3	12.1	78.9	13.9	87.5	15.6
	20	44.5	7.53	53.1	9.1	61.7	10.7	66.0	11.5	70.3	12.4	78.9	14.4	87.5	16.7
	21	44.5	7.60	53.1	9.2	61.7	10.8	66.0	11.6	70.3	12.6	78.9	14.9	87.5	17.3
	23	44.5	7.74	53.1	9.3	61.7	11.3	66.0	12.4	70.3	13.5	78.9	15.9	87.5	18.6
	25	44.5	7.99	53.1	9.9	61.7	12.1	66.0	13.3	70.3	14.5	78.9	17.1	87.5	19.9
	27	44.5	8.50	53.1	10.6	61.7	12.9	66.0	14.1	70.3	15.5	78.9	18.2	87.5	21.3
	29	44.5	9.0	53.1	11.3	61.7	13.7	66.0	15.1	70.3	16.5	78.9	19.5	87.5	22.7
	31	44.5	9.6	53.1	12.0	61.7	14.6	66.0	16.1	70.3	17.6	78.9	20.8	86.1	23.6
	33	44.5	10.2	53.1	12.7	61.7	15.6	66.0	17.1	70.3	18.7	78.9	22.2	84.8	24.5
	35	44.5	10.8	53.1	13.5	61.7	16.6	66.0	18.2	70.3	20.0	78.9	23.6	83.4	25.4
	37	44.5	11.4	53.1	14.4	61.7	17.6	66.0	19.4	70.3	21.2	78.9	25.2	82.1	26.3
	39	44.5	12.1	53.1	15.2	61.7	18.7	66.0	20.6	70.3	22.6	78.9	26.8	80.7	27.2
70 (525)	10	39.0	6.09	46.5	7.23	54.0	8.44	57.8	9.1	61.5	9.7	69.0	11.0	76.5	12.4
	12	39.0	6.18	46.5	7.35	54.0	8.58	57.8	9.2	61.5	9.9	69.0	11.2	76.5	12.6
	14	39.0	6.28	46.5	7.47	54.0	8.7	57.8	9.4	61.5	10.1	69.0	11.5	76.5	12.9
	16	39.0	6.38	46.5	7.60	54.0	8.9	57.8	9.6	61.5	10.3	69.0	11.7	76.5	13.1
	18	39.0	6.49	46.5	7.73	54.0	9.1	57.8	9.7	61.5	10.4	69.0	11.9	76.5	13.4
	20	39.0	6.59	46.5	7.87	54.0	9.2	57.8	9.9	61.5	10.7	69.0	12.1	76.5	13.8
	21	39.0	6.65	46.5	7.94	54.0	9.3	57.8	10.0	61.5	10.8	69.0	12.3	76.5	14.3
	23	39.0	6.77	46.5	8.09	54.0	9.5	57.8	10.4	61.5	11.3	69.0	13.2	76.5	15.3
	25	39.0	6.89	46.5	8.41	54.0	10.1	57.8	11.1	61.5	12.0	69.0	14.1	76.5	16.3
	27	39.0	7.28	46.5	9.0	54.0	10.8	57.8	11.8	61.5	12.8	69.0	15.1	76.5	17.5
	29	39.0	7.73	46.5	9.5	54.0	11.5	57.8	12.6	61.5	13.7	69.0	16.1	76.5	18.6
	31	39.0	8.19	46.5	10.1	54.0	12.2	57.8	13.4	61.5	14.6	69.0	17.1	76.5	19.9
	33	39.0	8.7	46.5	10.7	54.0	13.0	57.8	14.2	61.5	15.5	69.0	18.2	76.5	21.2
	35	39.0	9.2	46.5	11.4	54.0	13.8	57.8	15.1	61.5	16.5	69.0	19.4	76.5	22.6
	37	39.0	9.7	46.5	12.1	54.0	14.7	57.8	16.1	61.5	17.5	69.0	20.7	76.5	24.1
	39	39.0	10.3	46.5	12.8	54.0	15.6	57.8	17.1	61.5	18.7	69.0	22.0	76.5	25.6
60 (450)	10	33.4	5.30	39.8	6.22	46.3	7.20	49.5	7.71	52.7	8.23	59.2	9.3	65.6	10.4
	12	33.4	5.37	39.8	6.31	46.3	7.31	49.5	7.84	52.7	8.37	59.2	9.5	65.6	10.6
	14	33.4	5.45	39.8	6.41	46.3	7.44	49.5	7.97	52.7	8.52	59.2	9.6	65.6	10.8
	16	33.4	5.53	39.8	6.52	46.3	7.56	49.5	8.11	52.7	8.7	59.2	9.8	65.6	11.0
	18	33.4	5.62	39.8	6.63	46.3	7.70	49.5	8.26	52.7	8.8	59.2	10.0	65.6	11.2
	20	33.4	5.71	39.8	6.74	46.3	7.84	49.5	8.41	52.7	9.0	59.2	10.2	65.6	11.5
	21	33.4	5.75	39.8	6.80	46.3	7.91	49.5	8.49	52.7	9.1	59.2	10.3	65.6	11.6
	23	33.4	5.85	39.8	6.92	46.3	8.05	49.5	8.6	52.7	9.3	59.2	10.7	65.6	12.3
	25	33.4	5.94	39.8	7.04	46.3	8.37	49.5	9.1	52.7	9.8	59.2	11.4	65.6	13.1
	27	33.4	6.16	39.8	7.47	46.3	8.9	49.5	9.7	52.7	10.5	59.2	12.2	65.6	14.0
	29	33.4	6.53	39.8	7.92	46.3	9.5	49.5	10.3	52.7	11.2	59.2	13.0	65.6	15.0
	31	33.4	6.91	39.8	8.40	46.3	10.1	49.5	10.9	52.7	11.9	59.2	13.8	65.6	15.9
	33	33.4	7.31	39.8	8.9	46.3	10.7	49.5	11.6	52.7	12.6	59.2	14.7	65.6	17.0
	35	33.4	7.73	39.8	9.4	46.3	11.3	49.5	12.3	52.7	13.4	59.2	15.6	65.6	18.1
	37	33.4	8.17	39.8	10.0	46.3	12.0	49.5	13.1	52.7	14.2	59.2	16.6	65.6	19.2
	39	33.4	8.6	39.8	10.6	46.3	12.7	49.5	13.9	52.7	15.1	59.2	17.7	65.6	20.4
50 (375)	10	27.8	4.55	33.2	5.27	38.6	6.03	41.3	6.43	43.9	6.83	49.3	7.67	54.7	8.55
	12	27.8	4.61	33.2	5.35	38.6	6.12	41.3	6.53	43.9	6.94	49.3	7.80	54.7	8.7
	14	27.8	4.67	33.2	5.42	38.6	6.22	41.3	6.63	43.9	7.06	49.3	7.94	54.7	8.9
	16	27.8	4.74	33.2	5.50	38.6	6.32	41.3	6.74	43.9	7.18	49.3	8.08	54.7	9.0
	18	27.8	4.80	33.2	5.59	38.6	6.42	41.3	6.85	43.9	7.30	49.3	8.22	54.7	9.2
	20	27.8	4.87	33.2	5.67	38.6	6.53	41.3	6.97	43.9	7.43	49.3	8.37	54.7	9.4
	21	27.8	4.91	33.2	5.72	38.6	6.58	41.3	7.03	43.9	7.49	49.3	8.45	54.7	9.4
	23	27.8	4.98	33.2	5.81	38.6	6.70	41.3	7.16	43.9	7.63	49.3	8.6	54.7	9.7
	25	27.8	5.06	33.2	5.91	38.6	6.82	41.3	7.31	43.9	7.86	49.3	9.0	54.7	10.3
	27	27.8	5.14	33.2	6.12	38.6	7.20	41.3	7.77	43.9	8.36	49.3	9.6	54.7	11.0
	29	27.8	5.43	33.2	6.49	38.6	7.64	41.3	8.25	43.9	8.9	49.3	10.2	54.7	11.7
	31	27.8	5.74	33.2	6.87	38.6	8.10	41.3	8.8	43.9	9.4	49.3	10.9	54.7	12.4
	33	27.8	6.06	33.2	7.26	38.6	8.58	41.3	9.3	43.9	10.0	49.3	11.6	54.7	13.2
	35	27.8	6.40	33.2	7.68	38.6	9.1	41.3	9.8	43.9	10.6	49.3	12.3	54.7	14.0
	37	27.8	6.75	33.2	8.12	38.6	9.6	41.3	10.4	43.9	11.2	49.3	13.0	54.7	14.9
	39	27.8	7.12	33.2	8.57	38.6	10.2	41.3	11.0	43.9	11.9	49.3	13.8	54.7	15.8

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
130 (1040)	10	79.0	13.1	94.2	16.0	109	19.0	113	19.4	115	19.0	118	18.2	120	17.4
	12	79.0	13.3	94.2	16.3	109	19.4	112	19.3	113	18.9	116	18.1	119	17.8
	14	79.0	13.6	94.2	16.6	109	19.6	110	19.2	112	18.8	115	18.7	118	18.9
	16	79.0	13.8	94.2	16.9	108	19.5	109	19.4	110	19.5	113	19.7	116	19.9
	18	79.0	14.1	94.2	17.3	106	20.3	107	20.4	109	20.5	112	20.7	115	20.9
	20	79.0	14.4	94.2	18.4	105	21.3	106	21.4	107	21.5	110	21.7	113	21.9
	21	79.0	14.8	94.2	19.1	104	21.8	105	21.9	107	22.0	110	22.2	112	22.4
	23	79.0	15.8	94.2	20.4	102	22.8	104	22.9	105	23.0	108	23.2	111	23.5
	25	79.0	16.9	94.2	21.9	101	23.8	102	23.9	104	24.0	107	24.3	109	24.5
	27	79.0	18.1	94.2	23.4	99.5	24.8	101	24.9	102	25.0	105	25.3	108	25.6
	29	79.0	19.3	94.2	25.0	98.0	25.8	99.4	25.9	101	26.1	104	26.3	107	26.6
	31	79.0	20.6	93.7	26.5	96.6	26.8	98.0	26.9	99.4	27.1	102	27.4	105	27.7
	33	79.0	21.9	92.2	27.5	95.1	27.8	96.5	28.0	97.9	28.1	101	28.4	104	28.7
	35	79.0	23.4	90.8	28.5	93.6	28.8	95.1	29.0	96.5	29.1	99.3	29.5	102	29.8
	37	79.0	24.9	89.3	29.5	92.2	29.8	93.6	30.0	95.0	30.2	97.9	30.5	101	30.9
	39	79.0	26.5	87.9	30.5	90.7	30.9	92.1	31.0	93.5	31.2	96.4	31.6	99.2	32.0
120 (960)	10	72.9	11.9	86.9	14.6	101	17.4	108	18.8	113	19.5	116	18.8	118	18.1
	12	72.9	12.2	86.9	14.9	101	17.7	108	19.1	112	19.4	114	18.7	117	17.9
	14	72.9	12.4	86.9	15.2	101	18.0	108	19.5	110	19.3	113	18.6	115	18.7
	16	72.9	12.6	86.9	15.4	101	18.4	107	19.6	109	19.4	111	19.6	114	19.7
	18	72.9	12.9	86.9	15.8	101	19.0	106	20.3	107	20.4	110	20.6	112	20.7
	20	72.9	13.1	86.9	16.4	101	20.4	104	21.3	106	21.4	108	21.6	111	21.8
	21	72.9	13.3	86.9	17.0	101	21.2	104	21.8	105	21.9	108	22.1	110	22.3
	23	72.9	14.2	86.9	18.2	101	22.6	102	22.8	103	22.9	106	23.1	109	23.3
	25	72.9	15.1	86.9	19.4	99.4	23.6	101	23.7	102	23.9	105	24.1	107	24.3
	27	72.9	16.2	86.9	20.8	97.9	24.6	99.2	24.7	101	24.9	103	25.1	106	25.4
	29	72.9	17.2	86.9	22.2	96.4	25.6	97.8	25.8	99.1	25.9	102	26.1	104	26.4
	31	72.9	18.4	86.9	23.7	95.0	26.6	96.3	26.8	97.6	26.9	100	27.2	103	27.4
	33	72.9	19.6	86.9	25.3	93.5	27.6	94.8	27.8	96.1	27.9	98.8	28.2	101	28.5
	35	72.9	20.8	86.9	27.0	92.1	28.6	93.4	28.8	94.7	28.9	97.3	29.2	99.9	29.5
	37	72.9	22.2	86.9	28.7	90.6	29.6	91.9	29.8	93.2	30.0	95.8	30.3	98.5	30.6
	39	72.9	23.6	86.5	30.3	89.1	30.7	90.4	30.8	91.8	31.0	94.4	31.3	97.0	31.7
110 (880)	10	66.8	10.9	79.7	13.2	92.6	15.7	99.0	17.0	105	18.2	114	19.4	116	18.7
	12	66.8	11.0	79.7	13.5	92.6	16.0	99.0	17.3	105	18.6	112	19.3	115	18.6
	14	66.8	11.2	79.7	13.7	92.6	16.3	99.0	17.6	105	18.9	111	19.2	113	18.6
	16	66.8	11.5	79.7	14.0	92.6	16.6	99.0	18.0	105	19.3	109	19.4	112	19.6
	18	66.8	11.7	79.7	14.3	92.6	16.9	99.0	18.4	105	20.2	108	20.4	110	20.6
	20	66.8	11.9	79.7	14.5	92.6	17.9	99.0	19.8	104	21.2	106	21.4	109	21.6
	21	66.8	12.0	79.7	15.0	92.6	18.6	99.0	20.5	103	21.7	106	21.9	108	22.1
	23	66.8	12.6	79.7	16.0	92.6	19.9	99.0	22.0	102	22.7	104	22.9	106	23.1
	25	66.8	13.4	79.7	17.2	92.6	21.3	99.0	23.6	100	23.7	103	23.9	105	24.1
	27	66.8	14.3	79.7	18.3	92.6	22.8	97.5	24.6	98.7	24.7	101	24.9	104	25.1
	29	66.8	15.3	79.7	19.6	92.6	24.4	96.1	25.6	97.3	25.7	99.7	25.9	102	26.2
	31	66.8	16.3	79.7	20.9	92.6	26.0	94.6	26.6	95.8	26.7	98.2	27.0	101	27.2
	33	66.8	17.3	79.7	22.2	91.9	27.5	93.1	27.6	94.4	27.7	96.8	28.0	99.2	28.2
	35	66.8	18.4	79.7	23.7	90.5	28.5	91.7	28.6	92.9	28.7	95.3	29.0	97.7	29.3
	37	66.8	19.6	79.7	25.2	89.0	29.5	90.2	29.6	91.4	29.7	93.8	30.0	96.2	30.3
	39	66.8	20.8	79.7	26.9	87.6	30.5	88.8	30.6	90.0	30.8	92.4	31.1	94.8	31.4
100 (800)	10	60.7	9.8	72.4	11.9	84.1	14.1	90.0	15.2	95.9	16.3	108	18.7	114	19.3
	12	60.7	10.0	72.4	12.1	84.1	14.3	90.0	15.5	95.9	16.6	108	19.0	112	19.2
	14	60.7	10.1	72.4	12.3	84.1	14.6	90.0	15.8	95.9	17.0	108	19.4	111	19.1
	16	60.7	10.3	72.4	12.5	84.1	14.9	90.0	16.1	95.9	17.3	107	19.6	109	19.4
	18	60.7	10.5	72.4	12.8	84.1	15.2	90.0	16.4	95.9	17.6	106	20.3	108	20.4
	20	60.7	10.7	72.4	13.0	84.1	15.6	90.0	17.2	95.9	18.9	104	21.3	106	21.4
	21	60.7	10.8	72.4	13.2	84.1	16.2	90.0	17.8	95.9	19.6	104	21.8	106	21.9
	23	60.7	11.1	72.4	14.0	84.1	17.3	90.0	19.1	95.9	21.0	102	22.7	104	22.9
	25	60.7	11.8	72.4	15.0	84.1	18.5	90.0	20.5	95.9	22.5	101	23.7	103	23.9
	27	60.7	12.6	72.4	16.0	84.1	19.8	90.0	21.9	95.9	24.0	99.1	24.7	101	24.9
	29	60.7	13.4	72.4	17.1	84.1	21.2	90.0	23.4	95.5	25.5	97.7	25.7	99.9	26.0
	31	60.7	14.3	72.4	18.2	84.1	22.6	90.0	25.0	94.0	26.5	96.2	26.7	98.4	27.0
	33	60.7	15.2	72.4	19.4	84.1	24.1	90.0	26.6	92.6	27.5	94.7	27.8	96.9	28.0
	35	60.7	16.2	72.4	20.6	84.1	25.7	90.0	28.4	91.1	28.5	93.3	28.8	95.5	29.0
	37	60.7	17.2	72.4	22.0	84.1	27.4	88.5	29.4	89.6	29.5	91.8	29.8	94.0	30.1
	39	60.7	18.2	72.4	23.4	84.1	29.1	87.1	30.4	88.2	30.5	90.4	30.8	92.5	31.1

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
90 (720)	10	54.7	8.76	65.2	10.6	75.7	12.5	81.0	13.5	86.3	14.5	96.8	16.5	107	18.6
	12	54.7	8.9	65.2	10.8	75.7	12.7	81.0	13.7	86.3	14.7	96.8	16.8	107	19.0
	14	54.7	9.1	65.2	10.9	75.7	12.9	81.0	14.0	86.3	15.0	96.8	17.2	107	19.3
	16	54.7	9.2	65.2	11.1	75.7	13.2	81.0	14.2	86.3	15.3	96.8	17.5	107	19.7
	18	54.7	9.4	65.2	11.4	75.7	13.4	81.0	14.5	86.3	15.6	96.8	17.8	106	20.3
	20	54.7	9.6	65.2	11.6	75.7	13.7	81.0	14.8	86.3	16.2	96.8	19.2	104	21.3
	21	54.7	9.6	65.2	11.7	75.7	13.9	81.0	15.3	86.3	16.8	96.8	19.9	103	21.8
	23	54.7	9.8	65.2	12.2	75.7	14.9	81.0	16.4	86.3	18.0	96.8	21.3	102	22.7
	25	54.7	10.4	65.2	13.0	75.7	16.0	81.0	17.6	86.3	19.2	96.8	22.8	101	23.7
	27	54.7	11.0	65.2	13.9	75.7	17.0	81.0	18.8	86.3	20.6	96.8	24.4	99.1	24.7
	29	54.7	11.7	65.2	14.8	75.7	18.2	81.0	20.0	86.3	22.0	95.7	25.5	97.6	25.7
	31	54.7	12.5	65.2	15.7	75.7	19.4	81.0	21.4	86.3	23.4	94.2	26.5	96.2	26.7
	33	54.7	13.2	65.2	16.7	75.7	20.7	81.0	22.8	86.3	25.0	92.7	27.5	94.7	27.8
	35	54.7	14.1	65.2	17.8	75.7	22.0	81.0	24.3	86.3	26.6	91.3	28.5	93.2	28.8
	37	54.7	14.9	65.2	18.9	75.7	23.4	81.0	25.8	86.3	28.4	89.8	29.6	91.8	29.8
	39	54.7	15.8	65.2	20.1	75.7	24.9	81.0	27.5	86.3	30.2	88.3	30.6	90.3	30.8
80 (640)	10	48.6	7.78	58.0	9.3	67.3	10.9	72.0	11.8	76.7	12.6	86.0	14.4	95.4	16.3
	12	48.6	7.90	58.0	9.5	67.3	11.1	72.0	12.0	76.7	12.9	86.0	14.7	95.4	16.6
	14	48.6	8.03	58.0	9.6	67.3	11.3	72.0	12.2	76.7	13.1	86.0	15.0	95.4	16.9
	16	48.6	8.17	58.0	9.8	67.3	11.6	72.0	12.5	76.7	13.4	86.0	15.3	95.4	17.2
	18	48.6	8.31	58.0	10.0	67.3	11.8	72.0	12.7	76.7	13.6	86.0	15.6	95.4	17.5
	20	48.6	8.46	58.0	10.2	67.3	12.0	72.0	12.9	76.7	13.9	86.0	16.1	95.4	18.8
	21	48.6	8.53	58.0	10.3	67.3	12.1	72.0	13.1	76.7	14.2	86.0	16.7	95.4	19.4
	23	48.6	8.69	58.0	10.5	67.3	12.7	72.0	13.9	76.7	15.2	86.0	17.9	95.4	20.8
	25	48.6	9.0	58.0	11.1	67.3	13.6	72.0	14.9	76.7	16.2	86.0	19.2	95.4	22.3
	27	48.6	9.5	58.0	11.9	67.3	14.5	72.0	15.9	76.7	17.3	86.0	20.5	95.4	23.9
	29	48.6	10.1	58.0	12.6	67.3	15.4	72.0	16.9	76.7	18.5	86.0	21.9	95.4	25.5
	31	48.6	10.8	58.0	13.4	67.3	16.4	72.0	18.0	76.7	19.7	86.0	23.3	93.9	26.5
	33	48.6	11.4	58.0	14.3	67.3	17.5	72.0	19.2	76.7	21.0	86.0	24.9	92.5	27.5
	35	48.6	12.1	58.0	15.2	67.3	18.6	72.0	20.5	76.7	22.4	86.0	26.5	91.0	28.5
	37	48.6	12.8	58.0	16.1	67.3	19.8	72.0	21.8	76.7	23.8	86.0	28.3	89.5	29.5
	39	48.6	13.6	58.0	17.1	67.3	21.0	72.0	23.2	76.7	25.4	86.0	30.1	88.1	30.5
70 (560)	10	42.5	6.84	50.7	8.11	58.9	9.5	63.0	10.2	67.1	10.9	75.3	12.4	83.5	13.9
	12	42.5	6.94	50.7	8.25	58.9	9.6	63.0	10.4	67.1	11.1	75.3	12.6	83.5	14.2
	14	42.5	7.05	50.7	8.39	58.9	9.8	63.0	10.5	67.1	11.3	75.3	12.9	83.5	14.5
	16	42.5	7.16	50.7	8.53	58.9	10.0	63.0	10.7	67.1	11.5	75.3	13.1	83.5	14.7
	18	42.5	7.28	50.7	8.68	58.9	10.2	63.0	10.9	67.1	11.7	75.3	13.4	83.5	15.0
	20	42.5	7.40	50.7	8.8	58.9	10.4	63.0	11.1	67.1	12.0	75.3	13.6	83.5	15.5
	21	42.5	7.47	50.7	8.9	58.9	10.5	63.0	11.3	67.1	12.1	75.3	13.8	83.5	16.0
	23	42.5	7.60	50.7	9.1	58.9	10.7	63.0	11.6	67.1	12.7	75.3	14.8	83.5	17.1
	25	42.5	7.73	50.7	9.4	58.9	11.4	63.0	12.4	67.1	13.5	75.3	15.8	83.5	18.3
	27	42.5	8.17	50.7	10.0	58.9	12.1	63.0	13.2	67.1	14.4	75.3	16.9	83.5	19.6
	29	42.5	8.67	50.7	10.7	58.9	12.9	63.0	14.1	67.1	15.4	75.3	18.0	83.5	20.9
	31	42.5	9.2	50.7	11.3	58.9	13.7	63.0	15.0	67.1	16.4	75.3	19.2	83.5	22.3
	33	42.5	9.7	50.7	12.0	58.9	14.6	63.0	16.0	67.1	17.4	75.3	20.5	83.5	23.8
	35	42.5	10.3	50.7	12.8	58.9	15.5	63.0	17.0	67.1	18.5	75.3	21.8	83.5	25.4
	37	42.5	10.9	50.7	13.6	58.9	16.5	63.0	18.1	67.1	19.7	75.3	23.2	83.5	27.0
	39	42.5	11.6	50.7	14.4	58.9	17.5	63.0	19.2	67.1	20.9	75.3	24.7	83.5	28.8
60 (480)	10	36.4	5.95	43.5	6.98	50.5	8.08	54.0	8.65	57.5	9.2	64.5	10.4	71.6	11.7
	12	36.4	6.03	43.5	7.09	50.5	8.21	54.0	8.80	57.5	9.4	64.5	10.6	71.6	11.9
	14	36.4	6.12	43.5	7.20	50.5	8.35	54.0	8.9	57.5	9.6	64.5	10.8	71.6	12.1
	16	36.4	6.21	43.5	7.32	50.5	8.49	54.0	9.1	57.5	9.7	64.5	11.0	71.6	12.4
	18	36.4	6.31	43.5	7.44	50.5	8.64	54.0	9.3	57.5	9.9	64.5	11.2	71.6	12.6
	20	36.4	6.41	43.5	7.56	50.5	8.80	54.0	9.4	57.5	10.1	64.5	11.4	71.6	12.9
	21	36.4	6.46	43.5	7.63	50.5	8.9	54.0	9.5	57.5	10.2	64.5	11.6	71.6	13.0
	23	36.4	6.56	43.5	7.76	50.5	9.0	54.0	9.7	57.5	10.4	64.5	12.0	71.6	13.8
	25	36.4	6.67	43.5	7.90	50.5	9.4	54.0	10.2	57.5	11.0	64.5	12.8	71.6	14.7
	27	36.4	6.91	43.5	8.38	50.5	10.0	54.0	10.9	57.5	11.8	64.5	13.7	71.6	15.7
	29	36.4	7.33	43.5	8.9	50.5	10.6	54.0	11.6	57.5	12.5	64.5	14.6	71.6	16.8
	31	36.4	7.76	43.5	9.4	50.5	11.3	54.0	12.3	57.5	13.3	64.5	15.5	71.6	17.9
	33	36.4	8.21	43.5	10.0	50.5	12.0	54.0	13.0	57.5	14.1	64.5	16.5	71.6	19.1
	35	36.4	8.68	43.5	10.6	50.5	12.7	54.0	13.8	57.5	15.0	64.5	17.6	71.6	20.3
	37	36.4	9.2	43.5	11.2	50.5	13.5	54.0	14.7	57.5	16.0	64.5	18.7	71.6	21.6
	39	36.4	9.7	43.5	11.9	50.5	14.3	54.0	15.6	57.5	16.9	64.5	19.8	71.6	23.0
50 (400)	10	30.4	5.11	36.2	5.92	42.1	6.77	45.0	7.21	47.9	7.67	53.8	8.61	59.6	9.6
	12	30.4	5.18	36.2	6.00	42.1	6.87	45.0	7.33	47.9	7.79	53.8	8.76	59.6	9.8
	14	30.4	5.25	36.2	6.09	42.1	6.98	45.0	7.45	47.9	7.92	53.8	8.9	59.6	9.9
	16	30.4	5.32	36.2	6.18	42.1	7.09	45.0	7.57	47.9	8.06	53.8	9.1	59.6	10.1
	18	30.4	5.39	36.2	6.27	42.1	7.21	45.0	7.69	47.9	8.19	53.8	9.2	59.6	10.3
	20	30.4	5.47	36.2	6.37	42.1	7.33	45.0	7.83	47.9	8.34	53.8	9.4	59.6	10.5
	21	30.4	5.51	36.2	6.42	42.1	7.39	45.0	7.90	47.9	8.41	53.8	9.5	59.6	10.6
	23	30.4	5.59	36.2	6.53	42.1	7.52	45.0	8.04	47.9	8.57	53.8	9.7	59.6	10.8
	25	30.4	5.68	36.2	6.63	42.1	7.65	45.0	8.20	47.9	8.83	53.8	10.1	59.6	11.6
	27	30.4	5.77	36.2	6.87	42.1	8.08	45.0	8.72	47.9	9.4	53.8	10.8	59.6	12.3
	29	30.4	6.10	36.2	7.28	42.1	8.57	45.0	9.3	47.9	10.0	53.8	11.5	59.6	13.1
	31	30.4	6.45	36.2	7.71	42.1	9.1	45.0	9.8	47.9	10.6	53.8	12.2	59.6	14.0
	33	30.4	6.81	36.2	8.15	42.1	9.6	45.0	10.4	47.9	11.2	53.8	13.0	59.6	14.8
	35	30.4	7.18	36.2	8.62	42.1	10.2	45.0	11.0	47.9	11.9	53.8	13.8	59.6	15.8
	37	30.4	7.58	36.2	9.1	42.1	10.8	45.0	11.7	47.9	12.6	53.8	14.6	59.6	16.8
	39	30.4	7.99	36.2	9.6	42.1	11.4	45.0	12.4	47.9	13.4	53.8	15.5	59.6	17.8

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
130 (1105)	10	82.5	14.1	98	17.2	114	20.5	118	20.9	120	20.5	123	19.7	126	18.8
	12	82.5	14.3	98	17.6	114	20.9	117	20.8	118	20.4	121	19.5	124	19.2
	14	82.5	14.6	98	17.9	114	21.2	115	20.7	117	20.3	120	20.1	123	20.3
	16	82.5	14.9	98	18.3	112	21.1	114	20.9	115	21.0	118	21.2	121	21.4
	18	82.5	15.2	98	18.6	111	21.9	112	22.0	114	22.1	117	22.3	120	22.5
	20	82.5	15.5	98	19.8	109	22.9	111	23.0	112	23.2	115	23.4	118	23.6
	21	82.5	15.9	98	20.5	108	23.5	110	23.6	111	23.7	114	23.9	117	24.2
	23	82.5	17.1	98	22.0	107	24.5	108	24.7	110	24.8	113	25.0	116	25.3
	25	82.5	18.2	98	23.6	105	25.6	107	25.7	108	25.9	111	26.1	114	26.4
	27	82.5	19.5	98	25.2	104	26.7	105	26.8	107	27.0	110	27.3	113	27.5
	29	82.5	20.8	98	27.0	102	27.8	104	27.9	105	28.1	108	28.4	111	28.7
	31	82.5	22.2	98	28.5	101	28.9	102	29.0	104	29.2	107	29.5	110	29.8
	33	82.5	23.6	96.3	29.6	99	30.0	101	30.1	102	30.3	105	30.6	108	31.0
	35	82.5	25.2	94.8	30.7	97.8	31.0	99	31.2	101	31.4	104	31.8	107	32.1
	37	82.5	26.8	93.3	31.8	96.3	32.2	97.7	32.3	99	32.5	102	32.9	105	33.3
	39	82.5	28.5	91.8	32.9	94.7	33.3	96.2	33.5	97.7	33.6	101	34.0	104	34.4
120 (1020)	10	76.1	12.9	90.8	15.7	105	18.7	113	20.2	118	21.1	121	20.3	123	19.5
	12	76.1	13.1	90.8	16.0	105	19.1	113	20.6	116	21.0	119	20.1	122	19.3
	14	76.1	13.4	90.8	16.3	105	19.4	113	21.0	115	20.8	118	20.0	120	20.2
	16	76.1	13.6	90.8	16.6	105	19.8	112	21.1	113	20.9	116	21.1	119	21.3
	18	76.1	13.9	90.8	17.0	105	20.5	111	21.9	112	22.0	115	22.1	117	22.3
	20	76.1	14.1	90.8	17.6	105	22.0	109	22.9	110	23.0	113	23.2	116	23.4
	21	76.1	14.3	90.8	18.3	105	22.8	108	23.4	110	23.6	112	23.8	115	24.0
	23	76.1	15.3	90.8	19.6	105	24.4	107	24.5	108	24.6	111	24.9	114	25.1
	25	76.1	16.3	90.8	21.0	104	25.5	105	25.6	107	25.7	109	26.0	112	26.2
	27	76.1	17.4	90.8	22.4	102	26.5	104	26.7	105	26.8	108	27.1	110	27.3
	29	76.1	18.6	90.8	23.9	101	27.6	102	27.7	103	27.9	106	28.2	109	28.4
	31	76.1	19.8	90.8	25.5	99	28.7	101	28.8	102	29.0	105	29.3	107	29.6
	33	76.1	21.1	90.8	27.2	97.7	29.8	99	29.9	100	30.1	103	30.4	106	30.7
	35	76.1	22.4	90.8	29.0	96.1	30.9	97.5	31.0	99	31.2	102	31.5	104	31.8
	37	76.1	23.9	90.8	30.9	94.6	31.9	96.0	32.1	97.4	32.3	100	32.6	103	33.0
	39	76.1	25.4	90.3	32.7	93.1	33.0	94.5	33.2	95.8	33.4	99	33.8	101	34.1
110 (935)	10	69.8	11.7	83.2	14.2	96.7	16.9	103	18.3	110	19.7	119	20.9	121	20.1
	12	69.8	11.9	83.2	14.5	96.7	17.2	103	18.6	110	20.0	117	20.8	120	20.0
	14	69.8	12.1	83.2	14.8	96.7	17.6	103	19.0	110	20.4	116	20.7	118	20.0
	16	69.8	12.3	83.2	15.1	96.7	17.9	103	19.3	110	20.8	114	20.9	117	21.1
	18	69.8	12.6	83.2	15.4	96.7	18.3	103	19.9	110	21.8	113	22.0	115	22.2
	20	69.8	12.8	83.2	15.7	96.7	19.3	103	21.4	108	22.9	111	23.1	114	23.3
	21	69.8	12.9	83.2	16.1	96.7	20.0	103	22.1	108	23.4	110	23.6	113	23.8
	23	69.8	13.6	83.2	17.3	96.7	21.5	103	23.7	106	24.5	109	24.7	111	24.9
	25	69.8	14.5	83.2	18.5	96.7	23.0	103	25.4	105	25.5	107	25.8	110	26.0
	27	69.8	15.4	83.2	19.7	96.7	24.6	102	26.5	103	26.6	106	26.9	108	27.1
	29	69.8	16.5	83.2	21.1	96.7	26.3	100	27.6	102	27.7	104	27.9	107	28.2
	31	69.8	17.5	83.2	22.5	96.7	28.1	99	28.6	100	28.8	103	29.0	105	29.3
	33	69.8	18.7	83.2	24.0	96.0	29.6	97.3	29.7	99	29.9	101	30.1	104	30.4
	35	69.8	19.8	83.2	25.5	94.5	30.7	95.8	30.8	97.0	31.0	100	31.3	102	31.6
	37	69.8	21.1	83.2	27.2	93.0	31.7	94.2	31.9	95.5	32.1	98	32.4	101	32.7
	39	69.8	22.4	83.2	28.9	91.4	32.8	92.7	33.0	94.0	33.2	96.5	33.5	99	33.8
100 (850)	10	63.4	10.5	75.7	12.8	87.9	15.1	94.0	16.4	100	17.6	112	20.1	119	20.8
	12	63.4	10.7	75.7	13.0	87.9	15.4	94.0	16.7	100	17.9	112	20.5	117	20.7
	14	63.4	10.9	75.7	13.3	87.9	15.7	94.0	17.0	100	18.3	112	20.9	116	20.6
	16	63.4	11.1	75.7	13.5	87.9	16.0	94.0	17.3	100	18.6	112	21.2	114	20.9
	18	63.4	11.3	75.7	13.8	87.9	16.3	94.0	17.7	100	19.0	110	21.8	113	22.0
	20	63.4	11.5	75.7	14.0	87.9	16.8	94.0	18.6	100	20.4	109	22.9	111	23.1
	21	63.4	11.7	75.7	14.2	87.9	17.4	94.0	19.2	100	21.1	108	23.4	110	23.6
	23	63.4	12.0	75.7	15.1	87.9	18.7	94.0	20.6	100	22.6	107	24.5	109	24.7
	25	63.4	12.8	75.7	16.2	87.9	20.0	94.0	22.0	100	24.2	105	25.6	107	25.8
	27	63.4	13.6	75.7	17.3	87.9	21.4	94.0	23.6	100	25.9	104	26.7	106	26.9
	29	63.4	14.5	75.7	18.4	87.9	22.8	94.0	25.2	100	27.5	102	27.7	104	28.0
	31	63.4	15.4	75.7	19.6	87.9	24.3	94.0	26.9	98	28.6	100	28.8	103	29.1
	33	63.4	16.4	75.7	20.9	87.9	26.0	94.0	28.7	96.7	29.7	99	29.9	101	30.2
	35	63.4	17.4	75.7	22.2	87.9	27.7	94.0	30.6	95.1	30.7	97.4	31.0	100	31.3
	37	63.4	18.5	75.7	23.7	87.9	29.5	92.5	31.7	93.6	31.8	95.9	32.1	98	32.4
	39	63.4	19.7	75.7	25.2	87.9	31.4	90.9	32.8	92.1	32.9	94.4	33.2	96.7	33.5

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
90 (765)	10	57.1	9.44	68.1	11.4	79.1	13.4	84.6	14.5	90.1	15.6	101	17.8	112	20.1
	12	57.1	9.60	68.1	11.6	79.1	13.7	84.6	14.8	90.1	15.9	101	18.1	112	20.4
	14	57.1	9.76	68.1	11.8	79.1	13.9	84.6	15.1	90.1	16.2	101	18.5	112	20.8
	16	57.1	9.94	68.1	12.0	79.1	14.2	84.6	15.3	90.1	16.5	101	18.9	112	21.2
	18	57.1	10.11	68.1	12.2	79.1	14.5	84.6	15.6	90.1	16.8	101	19.2	110	21.8
	20	57.1	10.30	68.1	12.5	79.1	14.8	84.6	16.0	90.1	17.5	101	20.7	109	22.9
	21	57.1	10.40	68.1	12.6	79.1	15.0	84.6	16.5	90.1	18.1	101	21.4	108	23.4
	23	57.1	10.6	68.1	13.1	79.1	16.1	84.6	17.7	90.1	19.4	101	23.0	107	24.5
	25	57.1	11.2	68.1	14.0	79.1	17.2	84.6	18.9	90.1	20.7	101	24.6	105	25.6
	27	57.1	11.9	68.1	14.9	79.1	18.4	84.6	20.2	90.1	22.1	101	26.3	104	26.7
	29	57.1	12.6	68.1	15.9	79.1	19.6	84.6	21.6	90.1	23.7	100	27.5	102	27.7
	31	57.1	13.4	68.1	17.0	79.1	20.9	84.6	23.0	90.1	25.2	98	28.6	100	28.8
	33	57.1	14.3	68.1	18.0	79.1	22.3	84.6	24.5	90.1	26.9	96.9	29.7	99	29.9
	35	57.1	15.2	68.1	19.2	79.1	23.7	84.6	26.1	90.1	28.7	95.3	30.8	97.4	31.0
	37	57.1	16.1	68.1	20.4	79.1	25.2	84.6	27.8	90.1	30.6	93.8	31.8	95.9	32.1
	39	57.1	17.1	68.1	21.7	79.1	26.8	84.6	29.6	90.1	32.6	92.3	32.9	94.3	33.2
80 (680)	10	50.8	8.38	60.5	10.03	70.3	11.8	75.2	12.7	80.1	13.6	89.9	15.5	100	17.5
	12	50.8	8.51	60.5	10.20	70.3	12.0	75.2	12.9	80.1	13.9	89.9	15.8	100	17.8
	14	50.8	8.65	60.5	10.38	70.3	12.2	75.2	13.2	80.1	14.1	89.9	16.1	100	18.2
	16	50.8	8.80	60.5	10.6	70.3	12.4	75.2	13.4	80.1	14.4	89.9	16.4	100	18.5
	18	50.8	8.95	60.5	10.8	70.3	12.7	75.2	13.7	80.1	14.7	89.9	16.8	100	18.9
	20	50.8	9.11	60.5	11.0	70.3	12.9	75.2	13.9	80.1	15.0	89.9	17.4	100	20.2
	21	50.8	9.19	60.5	11.1	70.3	13.1	75.2	14.1	80.1	15.3	89.9	18.0	100	20.9
	23	50.8	9.36	60.5	11.3	70.3	13.7	75.2	15.0	80.1	16.4	89.9	19.3	100	22.5
	25	50.8	9.67	60.5	12.0	70.3	14.6	75.2	16.0	80.1	17.5	89.9	20.6	100	24.1
	27	50.8	10.28	60.5	12.8	70.3	15.6	75.2	17.1	80.1	18.7	89.9	22.1	100	25.7
	29	50.8	10.9	60.5	13.6	70.3	16.6	75.2	18.2	80.1	19.9	89.9	23.6	100	27.5
	31	50.8	11.6	60.5	14.5	70.3	17.7	75.2	19.4	80.1	21.3	89.9	25.2	98	28.6
	33	50.8	12.3	60.5	15.4	70.3	18.8	75.2	20.7	80.1	22.7	89.9	26.8	96.6	29.6
	35	50.8	13.1	60.5	16.4	70.3	20.1	75.2	22.0	80.1	24.1	89.9	28.6	95.1	30.7
	37	50.8	13.8	60.5	17.4	70.3	21.3	75.2	23.5	80.1	25.7	89.9	30.5	93.5	31.8
	39	50.8	14.7	60.5	18.4	70.3	22.7	75.2	24.9	80.1	27.3	89.9	32.5	92.0	32.9
70 (595)	10	44.4	7.37	53.0	8.74	61.5	10.21	65.8	11.0	70.1	11.7	78.6	13.4	87.2	15.0
	12	44.4	7.48	53.0	8.89	61.5	10.38	65.8	11.2	70.1	12.0	78.6	13.6	87.2	15.3
	14	44.4	7.60	53.0	9.04	61.5	10.6	65.8	11.4	70.1	12.2	78.6	13.9	87.2	15.6
	16	44.4	7.72	53.0	9.19	61.5	10.8	65.8	11.6	70.1	12.4	78.6	14.1	87.2	15.9
	18	44.4	7.84	53.0	9.35	61.5	11.0	65.8	11.8	70.1	12.6	78.6	14.4	87.2	16.2
	20	44.4	7.98	53.0	9.52	61.5	11.2	65.8	12.0	70.1	12.9	78.6	14.7	87.2	16.6
	21	44.4	8.04	53.0	9.61	61.5	11.3	65.8	12.1	70.1	13.0	78.6	14.9	87.2	17.2
	23	44.4	8.18	53.0	9.79	61.5	11.5	65.8	12.5	70.1	13.6	78.6	16.0	87.2	18.5
	25	44.4	8.33	53.0	10.18	61.5	12.3	65.8	13.4	70.1	14.6	78.6	17.1	87.2	19.8
	27	44.4	8.81	53.0	10.8	61.5	13.1	65.8	14.3	70.1	15.5	78.6	18.2	87.2	21.1
	29	44.4	9.35	53.0	11.5	61.5	13.9	65.8	15.2	70.1	16.6	78.6	19.4	87.2	22.5
	31	44.4	9.91	53.0	12.2	61.5	14.8	65.8	16.2	70.1	17.6	78.6	20.7	87.2	24.1
	33	44.4	10.5	53.0	13.0	61.5	15.7	65.8	17.2	70.1	18.8	78.6	22.1	87.2	25.6
	35	44.4	11.1	53.0	13.8	61.5	16.7	65.8	18.3	70.1	20.0	78.6	23.5	87.2	27.3
	37	44.4	11.8	53.0	14.6	61.5	17.8	65.8	19.4	70.1	21.2	78.6	25.0	87.2	29.1
	39	44.4	12.5	53.0	15.5	61.5	18.9	65.8	20.7	70.1	22.6	78.6	26.6	87.2	31.0
60 (510)	10	38.1	6.41	45.4	7.52	52.7	8.70	56.4	9.32	60.1	9.95	67.4	11.3	74.7	12.6
	12	38.1	6.50	45.4	7.64	52.7	8.85	56.4	9.48	60.1	10.12	67.4	11.5	74.7	12.8
	14	38.1	6.59	45.4	7.76	52.7	9.00	56.4	9.64	60.1	10.30	67.4	11.7	74.7	13.1
	16	38.1	6.69	45.4	7.88	52.7	9.15	56.4	9.81	60.1	10.5	67.4	11.9	74.7	13.3
	18	38.1	6.80	45.4	8.01	52.7	9.31	56.4	9.98	60.1	10.7	67.4	12.1	74.7	13.6
	20	38.1	6.90	45.4	8.15	52.7	9.48	56.4	10.17	60.1	10.9	67.4	12.3	74.7	13.9
	21	38.1	6.96	45.4	8.22	52.7	9.56	56.4	10.26	60.1	11.0	67.4	12.5	74.7	14.0
	23	38.1	7.07	45.4	8.36	52.7	9.74	56.4	10.5	60.1	11.2	67.4	12.9	74.7	14.9
	25	38.1	7.19	45.4	8.52	52.7	10.12	56.4	11.0	60.1	11.9	67.4	13.8	74.7	15.9
	27	38.1	7.45	45.4	9.03	52.7	10.8	56.4	11.7	60.1	12.7	67.4	14.7	74.7	17.0
	29	38.1	7.89	45.4	9.58	52.7	11.4	56.4	12.4	60.1	13.5	67.4	15.7	74.7	18.1
	31	38.1	8.36	45.4	10.17	52.7	12.2	56.4	13.2	60.1	14.3	67.4	16.7	74.7	19.3
	33	38.1	8.84	45.4	10.8	52.7	12.9	56.4	14.1	60.1	15.2	67.4	17.8	74.7	20.5
	35	38.1	9.35	45.4	11.4	52.7	13.7	56.4	14.9	60.1	16.2	67.4	18.9	74.7	21.8
	37	38.1	9.88	45.4	12.1	52.7	14.5	56.4	15.8	60.1	17.2	67.4	20.1	74.7	23.2
	39	38.1	10.4	45.4	12.8	52.7	15.4	56.4	16.8	60.1	18.3	67.4	21.4	74.7	24.7
50 (425)	10	31.7	5.51	37.8	6.37	43.9	7.29	47.0	7.77	50.1	8.26	56.2	9.28	62.3	10.34
	12	31.7	5.58	37.8	6.46	43.9	7.41	47.0	7.90	50.1	8.40	56.2	9.44	62.3	10.5
	14	31.7	5.65	37.8	6.56	43.9	7.52	47.0	8.02	50.1	8.54	56.2	9.60	62.3	10.7
	16	31.7	5.73	37.8	6.66	43.9	7.64	47.0	8.15	50.1	8.68	56.2	9.77	62.3	10.9
	18	31.7	5.81	37.8	6.76	43.9	7.77	47.0	8.29	50.1	8.83	56.2	9.94	62.3	11.1
	20	31.7	5.89	37.8	6.86	43.9	7.90	47.0	8.43	50.1	8.98	56.2	10.12	62.3	11.3
	21	31.7	5.94	37.8	6.92	43.9	7.96	47.0	8.51	50.1	9.06	56.2	10.22	62.3	11.4
	23	31.7	6.02	37.8	7.03	43.9	8.10	47.0	8.66	50.1	9.23	56.2	10.4	62.3	11.7
	25	31.7	6.12	37.8	7.15	43.9	8.25	47.0	8.84	50.1	9.51	56.2	10.9	62.3	12.5
	27	31.7	6.21	37.8	7.40	43.9	8.70	47.0	9.40	50.1	10.12	56.2	11.6	62.3	13.3
	29	31.7	6.57	37.8	7.84	43.9	9.24	47.0	9.98	50.1	10.7	56.2	12.4	62.3	14.1
	31	31.7	6.95	37.8	8.30	43.9	9.79	47.0	10.6	50.1	11.4	56.2	13.2	62.3	15.0
	33	31.7	7.33	37.8	8.78	43.9	10.38	47.0	11.2	50.1	12.1	56.2	14.0	62.3	16.0
	35	31.7	7.74	37.8	9.29	43.9	11.0	47.0	11.9	50.1	12.8	56.2	14.8	62.3	17.0
	37	31.7	8.16	37.8	9.82	43.9	11.6	47.0	12.6	50.1	13.6	56.2	15.7	62.3	18.0
	39	31.7	8.61	37.8	10.37	43.9	12.3	47.0	13.3	50.1	14.4	56.2	16.7	62.3	19.2

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
130 (1170)	10	86.0	15.1	103	18.5	119	22.0	123	22.5	125	22.0	128	21.1	131	20.1
	12	86.0	15.4	103	18.8	119	22.4	122	22.3	123	21.9	126	20.9	130	20.6
	14	86.0	15.7	103	19.2	119	22.7	120	22.2	122	21.7	125	21.6	128	21.8
	16	86.0	16.0	103	19.6	117	22.6	119	22.4	120	22.5	123	22.7	126	23.0
	18	86.0	16.3	103	20.0	116	23.4	117	23.6	119	23.7	122	23.9	125	24.1
	20	86.0	16.6	103	21.3	114	24.6	115	24.7	117	24.8	120	25.1	123	25.3
	21	86.0	17.1	103	22.0	113	25.2	115	25.3	116	25.4	119	25.7	122	25.9
	23	86.0	18.3	103	23.6	112	26.3	113	26.4	115	26.6	118	26.8	121	27.1
	25	86.0	19.6	103	25.3	110	27.5	111	27.6	113	27.7	116	28.0	119	28.3
	27	86.0	20.9	103	27.0	108	28.6	110	28.8	111	28.9	115	29.2	118	29.5
	29	86.0	22.3	103	28.9	107	29.8	108	29.9	110	30.1	113	30.4	116	30.7
	31	86.0	23.8	102	30.6	105	30.9	107	31.1	108	31.3	111	31.6	114	31.9
	33	86.0	25.3	100	31.7	104	32.1	105	32.3	107	32.5	110	32.8	113	33.2
	35	86.0	27.0	99	32.9	102	33.3	104	33.5	105	33.7	108	34.0	111	34.4
	37	86.0	28.7	97	34.1	100	34.5	102	34.7	103	34.9	107	35.3	110	35.7
	39	86.0	30.6	95.7	35.2	99	35.6	100	35.9	102	36.1	105	36.5	108	36.9
120 (1080)	10	79.4	13.8	94.7	16.9	110	20.0	118	21.7	123	22.6	126	21.7	129	20.9
	12	79.4	14.1	94.7	17.2	110	20.4	118	22.1	121	22.5	124	21.6	127	20.7
	14	79.4	14.3	94.7	17.5	110	20.8	118	22.5	120	22.3	123	21.5	126	21.6
	16	79.4	14.6	94.7	17.8	110	21.2	117	22.7	118	22.4	121	22.6	124	22.8
	18	79.4	14.9	94.7	18.2	110	21.9	115	23.4	117	23.5	120	23.7	122	24.0
	20	79.4	15.2	94.7	18.9	110	23.6	114	24.6	115	24.7	118	24.9	121	25.1
	21	79.4	15.3	94.7	19.6	110	24.4	113	25.1	114	25.2	117	25.5	120	25.7
	23	79.4	16.4	94.7	21.0	110	26.2	111	26.3	113	26.4	116	26.7	118	26.9
	25	79.4	17.5	94.7	22.5	108	27.3	110	27.4	111	27.6	114	27.8	117	28.1
	27	79.4	18.7	94.7	24.0	107	28.4	108	28.6	109	28.7	112	29.0	115	29.3
	29	79.4	19.9	94.7	25.6	105	29.6	106	29.7	108	29.9	111	30.2	114	30.5
	31	79.4	21.2	94.7	27.4	103	30.7	105	30.9	106	31.1	109	31.4	112	31.7
	33	79.4	22.6	94.7	29.2	102	31.9	103	32.1	105	32.2	108	32.6	110	32.9
	35	79.4	24.0	94.7	31.1	100	33.1	102	33.2	103	33.4	106	33.8	109	34.1
	37	79.4	25.6	94.7	33.2	99	34.2	100	34.4	102	34.6	104	35.0	107	35.3
	39	79.4	27.2	94.2	35.0	97	35.4	98	35.6	100	35.8	103	36.2	106	36.6
110 (990)	10	72.8	12.5	86.8	15.3	101	18.1	108	19.6	115	21.1	124	22.4	126	21.6
	12	72.8	12.8	86.8	15.5	101	18.5	108	20.0	115	21.5	122	22.3	125	21.5
	14	72.8	13.0	86.8	15.8	101	18.8	108	20.3	115	21.9	121	22.1	123	21.5
	16	72.8	13.2	86.8	16.1	101	19.2	108	20.7	115	22.3	119	22.4	122	22.6
	18	72.8	13.5	86.8	16.5	101	19.6	108	21.3	115	23.4	117	23.6	120	23.8
	20	72.8	13.7	86.8	16.8	101	20.7	108	22.9	113	24.5	116	24.7	118	24.9
	21	72.8	13.9	86.8	17.3	101	21.5	108	23.7	112	25.1	115	25.3	118	25.5
	23	72.8	14.5	86.8	18.5	101	23.0	108	25.4	111	26.2	113	26.5	116	26.7
	25	72.8	15.5	86.8	19.8	101	24.6	108	27.3	109	27.4	112	27.6	114	27.9
	27	72.8	16.6	86.8	21.2	101	26.4	106	28.4	108	28.5	110	28.8	113	29.0
	29	72.8	17.6	86.8	22.6	101	28.2	105	29.6	106	29.7	109	30.0	111	30.2
	31	72.8	18.8	86.8	24.1	101	30.1	103	30.7	104	30.8	107	31.1	110	31.4
	33	72.8	20.0	86.8	25.7	100	31.7	101	31.9	103	32.0	105	32.3	108	32.6
	35	72.8	21.3	86.8	27.4	99	32.9	100	33.0	101	33.2	104	33.5	106	33.8
	37	72.8	22.6	86.8	29.1	96.9	34.0	98	34.2	100	34.4	102	34.7	105	35.0
	39	72.8	24.0	86.8	31.0	95.3	35.2	96.6	35.4	98	35.5	101	35.9	103	36.2
100 (900)	10	66.1	11.3	78.9	13.7	91.6	16.2	98	17.5	104	18.9	117	21.6	124	22.3
	12	66.1	11.5	78.9	14.0	91.6	16.5	98	17.9	104	19.2	117	22.0	122	22.2
	14	66.1	11.7	78.9	14.2	91.6	16.9	98	18.2	104	19.6	117	22.4	121	22.1
	16	66.1	11.9	78.9	14.5	91.6	17.2	98	18.6	104	20.0	117	22.7	119	22.4
	18	66.1	12.1	78.9	14.8	91.6	17.5	98	18.9	104	20.4	115	23.4	118	23.6
	20	66.1	12.4	78.9	15.1	91.6	18.1	98	19.9	104	21.8	114	24.6	116	24.7
	21	66.1	12.5	78.9	15.2	91.6	18.7	98	20.6	104	22.6	113	25.1	115	25.3
	23	66.1	12.8	78.9	16.2	91.6	20.0	98	22.1	104	24.2	111	26.3	114	26.5
	25	66.1	13.7	78.9	17.3	91.6	21.4	98	23.6	104	26.0	110	27.4	112	27.6
	27	66.1	14.6	78.9	18.5	91.6	22.9	98	25.3	104	27.8	108	28.6	110	28.8
	29	66.1	15.5	78.9	19.7	91.6	24.4	98	27.0	104	29.5	106	29.7	109	30.0
	31	66.1	16.5	78.9	21.0	91.6	26.1	98	28.8	102	30.6	105	30.9	107	31.2
	33	66.1	17.6	78.9	22.4	91.6	27.8	98	30.8	101	31.8	103	32.1	106	32.3
	35	66.1	18.7	78.9	23.8	91.6	29.6	98	32.8	99	32.9	102	33.2	104	33.5
	37	66.1	19.8	78.9	25.4	91.6	31.6	96.4	34.0	98	34.1	100	34.4	102	34.7
	39	66.1	21.1	78.9	27.0	91.6	33.6	94.8	35.1	96.0	35.3	98	35.6	101	35.9

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
90 (810)	10	59.5	10.12	71.0	12.2	82.5	14.4	88.2	15.5	93.9	16.7	105	19.1	117	21.5
	12	59.5	10.3	71.0	12.4	82.5	14.7	88.2	15.8	93.9	17.0	105	19.4	117	21.9
	14	59.5	10.5	71.0	12.6	82.5	14.9	88.2	16.1	93.9	17.3	105	19.8	117	22.3
	16	59.5	10.6	71.0	12.9	82.5	15.2	88.2	16.4	93.9	17.7	105	20.2	117	22.7
	18	59.5	10.8	71.0	13.1	82.5	15.5	88.2	16.8	93.9	18.0	105	20.6	115	23.4
	20	59.5	11.0	71.0	13.4	82.5	15.8	88.2	17.1	93.9	18.7	105	22.1	113	24.6
	21	59.5	11.1	71.0	13.5	82.5	16.1	88.2	17.7	93.9	19.4	105	22.9	113	25.1
	23	59.5	11.4	71.0	14.1	82.5	17.2	88.2	19.0	93.9	20.8	105	24.6	111	26.3
	25	59.5	12.0	71.0	15.0	82.5	18.4	88.2	20.3	93.9	22.2	105	26.3	110	27.4
	27	59.5	12.7	71.0	16.0	82.5	19.7	88.2	21.7	93.9	23.7	105	28.2	108	28.6
	29	59.5	13.5	71.0	17.1	82.5	21.0	88.2	23.1	93.9	25.4	104	29.5	106	29.7
	31	59.5	14.4	71.0	18.2	82.5	22.4	88.2	24.7	93.9	27.1	103	30.7	105	30.9
	33	59.5	15.3	71.0	19.3	82.5	23.9	88.2	26.3	93.9	28.9	101	31.8	103	32.1
	35	59.5	16.2	71.0	20.6	82.5	25.4	88.2	28.0	93.9	30.8	99	33.0	102	33.2
	37	59.5	17.2	71.0	21.9	82.5	27.0	88.2	29.8	93.9	32.8	98	34.1	100	34.4
	39	59.5	18.3	71.0	23.2	82.5	28.8	88.2	31.8	93.9	34.9	96.2	35.3	98	35.6
80 (720)	10	52.9	8.98	63.1	10.8	73.3	12.6	78.4	13.6	83.5	14.6	93.7	16.7	104	18.8
	12	52.9	9.13	63.1	10.9	73.3	12.9	78.4	13.9	83.5	14.9	93.7	17.0	104	19.1
	14	52.9	9.28	63.1	11.1	73.3	13.1	78.4	14.1	83.5	15.2	93.7	17.3	104	19.5
	16	52.9	9.43	63.1	11.3	73.3	13.3	78.4	14.4	83.5	15.4	93.7	17.6	104	19.9
	18	52.9	9.60	63.1	11.5	73.3	13.6	78.4	14.7	83.5	15.7	93.7	18.0	104	20.3
	20	52.9	9.77	63.1	11.8	73.3	13.9	78.4	15.0	83.5	16.1	93.7	18.6	104	21.7
	21	52.9	9.85	63.1	11.9	73.3	14.0	78.4	15.1	83.5	16.4	93.7	19.3	104	22.5
	23	52.9	10.04	63.1	12.1	73.3	14.7	78.4	16.1	83.5	17.5	93.7	20.7	104	24.1
	25	52.9	10.4	63.1	12.9	73.3	15.7	78.4	17.2	83.5	18.8	93.7	22.1	104	25.8
	27	52.9	11.0	63.1	13.7	73.3	16.7	78.4	18.3	83.5	20.0	93.7	23.7	104	27.6
	29	52.9	11.7	63.1	14.6	73.3	17.8	78.4	19.6	83.5	21.4	93.7	25.3	104	29.5
	31	52.9	12.4	63.1	15.5	73.3	19.0	78.4	20.8	83.5	22.8	93.7	27.0	102	30.6
	33	52.9	13.2	63.1	16.5	73.3	20.2	78.4	22.2	83.5	24.3	93.7	28.8	101	31.8
	35	52.9	14.0	63.1	17.5	73.3	21.5	78.4	23.6	83.5	25.9	93.7	30.7	99	32.9
	37	52.9	14.8	63.1	18.6	73.3	22.9	78.4	25.1	83.5	27.5	93.7	32.7	98	34.1
	39	52.9	15.7	63.1	19.8	73.3	24.3	78.4	26.7	83.5	29.3	93.7	34.8	95.9	35.3
70 (630)	10	46.3	7.90	55.2	9.37	64.1	10.9	68.6	11.8	73.1	12.6	82.0	14.3	90.9	16.1
	12	46.3	8.02	55.2	9.53	64.1	11.1	68.6	12.0	73.1	12.8	82.0	14.6	90.9	16.4
	14	46.3	8.14	55.2	9.69	64.1	11.3	68.6	12.2	73.1	13.0	82.0	14.8	90.9	16.7
	16	46.3	8.27	55.2	9.85	64.1	11.5	68.6	12.4	73.1	13.3	82.0	15.1	90.9	17.0
	18	46.3	8.41	55.2	10.02	64.1	11.7	68.6	12.6	73.1	13.5	82.0	15.4	90.9	17.4
	20	46.3	8.55	55.2	10.20	64.1	12.0	68.6	12.9	73.1	13.8	82.0	15.7	90.9	17.8
	21	46.3	8.62	55.2	10.3	64.1	12.1	68.6	13.0	73.1	13.9	82.0	16.0	90.9	18.5
	23	46.3	8.77	55.2	10.5	64.1	12.3	68.6	13.4	73.1	14.6	82.0	17.1	90.9	19.8
	25	46.3	8.93	55.2	10.9	64.1	13.1	68.6	14.3	73.1	15.6	82.0	18.3	90.9	21.2
	27	46.3	9.44	55.2	11.6	64.1	14.0	68.6	15.3	73.1	16.6	82.0	19.5	90.9	22.6
	29	46.3	10.02	55.2	12.3	64.1	14.9	68.6	16.3	73.1	17.7	82.0	20.8	90.9	24.2
	31	46.3	10.6	55.2	13.1	64.1	15.9	68.6	17.3	73.1	18.9	82.0	22.2	90.9	25.8
	33	46.3	11.3	55.2	13.9	64.1	16.9	68.6	18.5	73.1	20.1	82.0	23.7	90.9	27.5
	35	46.3	11.9	55.2	14.8	64.1	17.9	68.6	19.6	73.1	21.4	82.0	25.2	90.9	29.3
	37	46.3	12.6	55.2	15.7	64.1	19.0	68.6	20.8	73.1	22.8	82.0	26.8	90.9	31.2
	39	46.3	13.4	55.2	16.6	64.1	20.2	68.6	22.1	73.1	24.2	82.0	28.5	90.9	33.2
60 (540)	10	39.7	6.87	47.3	8.06	55.0	9.33	58.8	9.99	62.6	10.7	70.3	12.1	77.9	13.5
	12	39.7	6.97	47.3	8.19	55.0	9.48	58.8	10.16	62.6	10.8	70.3	12.3	77.9	13.8
	14	39.7	7.07	47.3	8.32	55.0	9.64	58.8	10.3	62.6	11.0	70.3	12.5	77.9	14.0
	16	39.7	7.17	47.3	8.45	55.0	9.81	58.8	10.5	62.6	11.2	70.3	12.7	77.9	14.3
	18	39.7	7.28	47.3	8.59	55.0	9.98	58.8	10.7	62.6	11.4	70.3	13.0	77.9	14.6
	20	39.7	7.40	47.3	8.74	55.0	10.16	58.8	10.9	62.6	11.7	70.3	13.2	77.9	14.8
	21	39.7	7.46	47.3	8.81	55.0	10.3	58.8	11.0	62.6	11.8	70.3	13.4	77.9	15.0
	23	39.7	7.58	47.3	8.97	55.0	10.4	58.8	11.2	62.6	12.0	70.3	13.9	77.9	15.9
	25	39.7	7.71	47.3	9.13	55.0	10.8	58.8	11.8	62.6	12.8	70.3	14.8	77.9	17.0
	27	39.7	7.99	47.3	9.68	55.0	11.5	58.8	12.5	62.6	13.6	70.3	15.8	77.9	18.2
	29	39.7	8.46	47.3	10.3	55.0	12.3	58.8	13.3	62.6	14.5	70.3	16.8	77.9	19.4
	31	39.7	8.96	47.3	10.9	55.0	13.0	58.8	14.2	62.6	15.4	70.3	17.9	77.9	20.7
	33	39.7	9.48	47.3	11.5	55.0	13.8	58.8	15.1	62.6	16.3	70.3	19.1	77.9	22.0
	35	39.7	10.02	47.3	12.2	55.0	14.7	58.8	16.0	62.6	17.4	70.3	20.3	77.9	23.4
	37	39.7	10.6	47.3	13.0	55.0	15.6	58.8	17.0	62.6	18.4	70.3	21.6	77.9	24.9
	39	39.7	11.2	47.3	13.7	55.0	16.5	58.8	18.0	62.6	19.6	70.3	22.9	77.9	26.5
50 (450)	10	33.1	5.90	39.4	6.83	45.8	7.82	49.0	8.33	52.2	8.86	58.6	9.95	64.9	11.1
	12	33.1	5.98	39.4	6.93	45.8	7.94	49.0	8.46	52.2	9.00	58.6	10.12	64.9	11.3
	14	33.1	6.06	39.4	7.03	45.8	8.06	49.0	8.60	52.2	9.15	58.6	10.3	64.9	11.5
	16	33.1	6.14	39.4	7.13	45.8	8.19	49.0	8.74	52.2	9.30	58.6	10.5	64.9	11.7
	18	33.1	6.23	39.4	7.24	45.8	8.32	49.0	8.89	52.2	9.46	58.6	10.7	64.9	11.9
	20	33.1	6.32	39.4	7.36	45.8	8.46	49.0	9.04	52.2	9.63	58.6	10.9	64.9	12.1
	21	33.1	6.36	39.4	7.42	45.8	8.54	49.0	9.12	52.2	9.72	58.6	11.0	64.9	12.2
	23	33.1	6.46	39.4	7.54	45.8	8.68	49.0	9.28	52.2	9.89	58.6	11.2	64.9	12.5
	25	33.1	6.56	39.4	7.66	45.8	8.84	49.0	9.48	52.2	10.20	58.6	11.7	64.9	13.4
	27	33.1	6.66	39.4	7.93	45.8	9.33	49.0	10.07	52.2	10.8	58.6	12.5	64.9	14.2
	29	33.1	7.05	39.4	8.41	45.8	9.90	49.0	10.7	52.2	11.5	58.6	13.3	64.9	15.2
	31	33.1	7.45	39.4	8.90	45.8	10.5	49.0	11.3	52.2	12.2	58.6	14.1	64.9	16.1
	33	33.1	7.86	39.4	9.42	45.8	11.1	49.0	12.0	52.2	13.0	58.6	15.0	64.9	17.1
	35	33.1	8.30	39.4	9.96	45.8	11.8	49.0	12.7	52.2	13.8	58.6	15.9	64.9	18.2
	37	33.1	8.75	39.4	10.5	45.8	12.5	49.0	13.5	52.2	14.6	58.6	16.9	64.9	19.3
	39	33.1	9.23	39.4	11.1	45.8	13.2	49.0	14.3	52.2	15.5	58.6	17.9	64.9	20.5

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
130 (1235)	10	92.0	14.1	110	17.2	128	20.5	132	20.9	134	20.5	137	19.7	140	18.8
	12	92.0	14.3	110	17.6	128	20.9	130	20.8	132	20.4	135	19.5	139	19.2
	14	92.0	14.6	110	17.9	127	21.2	129	20.7	130	20.3	134	20.1	137	20.3
	16	92.0	14.9	110	18.3	125	21.1	127	20.9	129	21.0	132	21.2	135	21.4
	18	92.0	15.2	110	18.6	124	21.9	125	22.0	127	22.1	130	22.3	134	22.5
	20	92.0	15.5	110	19.8	122	22.9	124	23.0	125	23.2	129	23.4	132	23.6
	21	92.0	15.9	110	20.5	121	23.5	123	23.6	124	23.7	128	23.9	131	24.2
	23	92.0	17.1	110	22.0	119	24.5	121	24.7	123	24.8	126	25.0	129	25.3
	25	92.0	18.2	110	23.6	118	25.6	119	25.7	121	25.9	124	26.1	128	26.4
	27	92.0	19.5	110	25.2	116	26.7	118	26.8	119	27.0	123	27.3	126	27.5
	29	92.0	20.8	110	27.0	114	27.8	116	27.9	118	28.1	121	28.4	124	28.7
	31	92.0	22.2	109	28.5	113	28.9	114	29.0	116	29.2	119	29.5	122	29.8
	33	92.0	23.6	108	29.6	111	30.0	112	30.1	114	30.3	117	30.6	121	31.0
	35	92.0	25.2	106	30.7	109	31.0	111	31.2	112	31.4	116	31.8	119	32.1
	37	92.0	26.8	104	31.8	107	32.2	109	32.3	111	32.5	114	32.9	117	33.3
	39	92.0	28.5	102	32.9	106	33.3	107	33.5	109	33.6	112	34.0	116	34.4
120 (1140)	10	85.0	12.9	101	15.7	118	18.7	126	20.2	132	21.1	135	20.3	138	19.5
	12	85.0	13.1	101	16.0	118	19.1	126	20.6	130	21.0	133	20.1	136	19.3
	14	85.0	13.4	101	16.3	118	19.4	126	21.0	128	20.8	131	20.0	134	20.2
	16	85.0	13.6	101	16.6	118	19.8	125	21.1	127	20.9	130	21.1	133	21.3
	18	85.0	13.9	101	17.0	118	20.5	123	21.9	125	22.0	128	22.1	131	22.3
	20	85.0	14.1	101	17.6	118	22.0	122	22.9	123	23.0	126	23.2	129	23.4
	21	85.0	14.3	101	18.3	118	22.8	121	23.4	122	23.6	125	23.8	128	24.0
	23	85.0	15.3	101	19.6	118	24.4	119	24.5	121	24.6	124	24.9	127	25.1
	25	85.0	16.3	101	21.0	116	25.5	117	25.6	119	25.7	122	26.0	125	26.2
	27	85.0	17.4	101	22.4	114	26.5	116	26.7	117	26.8	120	27.1	123	27.3
	29	85.0	18.6	101	23.9	112	27.6	114	27.7	115	27.9	119	28.2	122	28.4
	31	85.0	19.8	101	25.5	111	28.7	112	28.8	114	29.0	117	29.3	120	29.6
	33	85.0	21.1	101	27.2	109	29.8	111	29.9	112	30.1	115	30.4	118	30.7
	35	85.0	22.4	101	29.0	107	30.9	109	31.0	110	31.2	113	31.5	116	31.8
	37	85.0	23.9	101	30.9	106	31.9	107	32.1	109	32.3	112	32.6	115	33.0
	39	85.0	25.4	101	32.7	104	33.0	105	33.2	107	33.4	110	33.8	113	34.1
110 (1045)	10	77.9	11.7	92.9	14.2	108	16.9	115	18.3	123	19.7	132	20.9	135	20.1
	12	77.9	11.9	92.9	14.5	108	17.2	115	18.6	123	20.0	131	20.8	134	20.0
	14	77.9	12.1	92.9	14.8	108	17.6	115	19.0	123	20.4	129	20.7	132	20.0
	16	77.9	12.3	92.9	15.1	108	17.9	115	19.3	123	20.8	127	20.9	130	21.1
	18	77.9	12.6	92.9	15.4	108	18.3	115	19.9	123	21.8	126	22.0	128	22.2
	20	77.9	12.8	92.9	15.7	108	19.3	115	21.4	121	22.9	124	23.1	127	23.3
	21	77.9	12.9	92.9	16.1	108	20.0	115	22.1	120	23.4	123	23.6	126	23.8
	23	77.9	13.6	92.9	17.3	108	21.5	115	23.7	119	24.5	121	24.7	124	24.9
	25	77.9	14.5	92.9	18.5	108	23.0	115	25.4	117	25.5	120	25.8	122	26.0
	27	77.9	15.4	92.9	19.7	108	24.6	114	26.5	115	26.6	118	26.9	121	27.1
	29	77.9	16.5	92.9	21.1	108	26.3	112	27.6	113	27.7	116	27.9	119	28.2
	31	77.9	17.5	92.9	22.5	108	28.1	110	28.6	112	28.8	114	29.0	117	29.3
	33	77.9	18.7	92.9	24.0	107	29.6	109	29.7	110	29.9	113	30.1	116	30.4
	35	77.9	19.8	92.9	25.5	105	30.7	107	30.8	108	31.0	111	31.3	114	31.6
	37	77.9	21.1	92.9	27.2	104	31.7	105	31.9	107	32.1	109	32.4	112	32.7
	39	77.9	22.4	92.9	28.9	102	32.8	103	33.0	105	33.2	108	33.5	110	33.8
100 (950)	10	70.8	10.5	84.4	12.8	98	15.1	105	16.4	112	17.6	125	20.1	133	20.8
	12	70.8	10.7	84.4	13.0	98	15.4	105	16.7	112	17.9	125	20.5	131	20.7
	14	70.8	10.9	84.4	13.3	98	15.7	105	17.0	112	18.3	125	20.9	129	20.6
	16	70.8	11.1	84.4	13.5	98	16.0	105	17.3	112	18.6	125	21.2	127	20.9
	18	70.8	11.3	84.4	13.8	98	16.3	105	17.7	112	19.0	123	21.8	126	22.0
	20	70.8	11.5	84.4	14.0	98	16.8	105	18.6	112	20.4	122	22.9	124	23.1
	21	70.8	11.7	84.4	14.2	98	17.4	105	19.2	112	21.1	121	23.4	123	23.6
	23	70.8	12.0	84.4	15.1	98	18.7	105	20.6	112	22.6	119	24.5	122	24.7
	25	70.8	12.8	84.4	16.2	98	20.0	105	22.0	112	24.2	117	25.6	120	25.8
	27	70.8	13.6	84.4	17.3	98	21.4	105	23.6	112	25.9	116	26.7	118	26.9
	29	70.8	14.5	84.4	18.4	98	22.8	105	25.2	111	27.5	114	27.7	116	28.0
	31	70.8	15.4	84.4	19.6	98	24.3	105	26.9	110	28.6	112	28.8	115	29.1
	33	70.8	16.4	84.4	20.9	98	26.0	105	28.7	108	29.7	110	29.9	113	30.2
	35	70.8	17.4	84.4	22.2	98	27.7	105	30.6	106	30.7	109	31.0	111	31.3
	37	70.8	18.5	84.4	23.7	98	29.5	103	31.7	104	31.8	107	32.1	110	32.4
	39	70.8	19.7	84.4	25.2	98	31.4	101	32.8	103	32.9	105	33.2	108	33.5

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
90 (855)	10	63.7	9.4	76.0	11.4	88.3	13.4	94.4	14.5	101	15.6	113	17.8	125	20.1
	12	63.7	9.6	76.0	11.6	88.3	13.7	94.4	14.8	101	15.9	113	18.1	125	20.4
	14	63.7	9.8	76.0	11.8	88.3	13.9	94.4	15.1	101	16.2	113	18.5	125	20.8
	16	63.7	9.9	76.0	12.0	88.3	14.2	94.4	15.3	101	16.5	113	18.9	125	21.2
	18	63.7	10.1	76.0	12.2	88.3	14.5	94.4	15.6	101	16.8	113	19.2	123	21.8
	20	63.7	10.3	76.0	12.5	88.3	14.8	94.4	16.0	101	17.5	113	20.7	121	22.9
	21	63.7	10.4	76.0	12.6	88.3	15.0	94.4	16.5	101	18.1	113	21.4	121	23.4
	23	63.7	10.6	76.0	13.1	88.3	16.1	94.4	17.7	101	19.4	113	23.0	119	24.5
	25	63.7	11.2	76.0	14.0	88.3	17.2	94.4	18.9	101	20.7	113	24.6	117	25.6
	27	63.7	11.9	76.0	14.9	88.3	18.4	94.4	20.2	101	22.1	113	26.3	116	26.7
	29	63.7	12.6	76.0	15.9	88.3	19.6	94.4	21.6	101	23.7	112	27.5	114	27.7
	31	63.7	13.4	76.0	17.0	88.3	20.9	94.4	23.0	101	25.2	110	28.6	112	28.8
	33	63.7	14.3	76.0	18.0	88.3	22.3	94.4	24.5	101	26.9	108	29.7	110	29.9
	35	63.7	15.2	76.0	19.2	88.3	23.7	94.4	26.1	101	28.7	106	30.8	109	31.0
	37	63.7	16.1	76.0	20.4	88.3	25.2	94.4	27.8	101	30.6	105	31.8	107	32.1
	39	63.7	17.1	76.0	21.7	88.3	26.8	94.4	29.6	101	32.6	103	32.9	105	33.2
80 (760)	10	56.6	8.38	67.5	10.0	78.5	11.8	83.9	12.7	89.4	13.6	100	15.5	111	17.5
	12	56.6	8.51	67.5	10.2	78.5	12.0	83.9	12.9	89.4	13.9	100	15.8	111	17.8
	14	56.6	8.65	67.5	10.4	78.5	12.2	83.9	13.2	89.4	14.1	100	16.1	111	18.2
	16	56.6	8.80	67.5	10.6	78.5	12.4	83.9	13.4	89.4	14.4	100	16.4	111	18.5
	18	56.6	8.95	67.5	10.8	78.5	12.7	83.9	13.7	89.4	14.7	100	16.8	111	18.9
	20	56.6	9.11	67.5	11.0	78.5	12.9	83.9	13.9	89.4	15.0	100	17.4	111	20.2
	21	56.6	9.19	67.5	11.1	78.5	13.1	83.9	14.1	89.4	15.3	100	18.0	111	20.9
	23	56.6	9.4	67.5	11.3	78.5	13.7	83.9	15.0	89.4	16.4	100	19.3	111	22.5
	25	56.6	9.7	67.5	12.0	78.5	14.6	83.9	16.0	89.4	17.5	100	20.6	111	24.1
	27	56.6	10.3	67.5	12.8	78.5	15.6	83.9	17.1	89.4	18.7	100	22.1	111	25.7
	29	56.6	10.9	67.5	13.6	78.5	16.6	83.9	18.2	89.4	19.9	100	23.6	111	27.5
	31	56.6	11.6	67.5	14.5	78.5	17.7	83.9	19.4	89.4	21.3	100	25.2	109	28.6
	33	56.6	12.3	67.5	15.4	78.5	18.8	83.9	20.7	89.4	22.7	100	26.8	108	29.6
	35	56.6	13.1	67.5	16.4	78.5	20.1	83.9	22.0	89.4	24.1	100	28.6	106	30.7
	37	56.6	13.8	67.5	17.4	78.5	21.3	83.9	23.5	89.4	25.7	100	30.5	104	31.8
	39	56.6	14.7	67.5	18.4	78.5	22.7	83.9	24.9	89.4	27.3	100	32.5	103	32.9
70 (665)	10	49.6	7.37	59.1	8.74	68.7	10.2	73.4	11.0	78.2	11.7	87.8	13.4	97.3	15.0
	12	49.6	7.48	59.1	8.89	68.7	10.4	73.4	11.2	78.2	12.0	87.8	13.6	97.3	15.3
	14	49.6	7.60	59.1	9.04	68.7	10.6	73.4	11.4	78.2	12.2	87.8	13.9	97.3	15.6
	16	49.6	7.72	59.1	9.19	68.7	10.8	73.4	11.6	78.2	12.4	87.8	14.1	97.3	15.9
	18	49.6	7.84	59.1	9.4	68.7	11.0	73.4	11.8	78.2	12.6	87.8	14.4	97.3	16.2
	20	49.6	7.98	59.1	9.5	68.7	11.2	73.4	12.0	78.2	12.9	87.8	14.7	97.3	16.6
	21	49.6	8.04	59.1	9.6	68.7	11.3	73.4	12.1	78.2	13.0	87.8	14.9	97.3	17.2
	23	49.6	8.18	59.1	9.8	68.7	11.5	73.4	12.5	78.2	13.6	87.8	16.0	97.3	18.5
	25	49.6	8.33	59.1	10.2	68.7	12.3	73.4	13.4	78.2	14.6	87.8	17.1	97.3	19.8
	27	49.6	8.81	59.1	10.8	68.7	13.1	73.4	14.3	78.2	15.5	87.8	18.2	97.3	21.1
	29	49.6	9.3	59.1	11.5	68.7	13.9	73.4	15.2	78.2	16.6	87.8	19.4	97.3	22.5
	31	49.6	9.9	59.1	12.2	68.7	14.8	73.4	16.2	78.2	17.6	87.8	20.7	97.3	24.1
	33	49.6	10.5	59.1	13.0	68.7	15.7	73.4	17.2	78.2	18.8	87.8	22.1	97.3	25.6
	35	49.6	11.1	59.1	13.8	68.7	16.7	73.4	18.3	78.2	20.0	87.8	23.5	97.3	27.3
	37	49.6	11.8	59.1	14.6	68.7	17.8	73.4	19.4	78.2	21.2	87.8	25.0	97.3	29.1
	39	49.6	12.5	59.1	15.5	68.7	18.9	73.4	20.7	78.2	22.6	87.8	26.6	97.3	31.0
60 (570)	10	42.5	6.41	50.7	7.52	58.8	8.70	62.9	9.3	67.0	10.0	75.2	11.3	83.4	12.6
	12	42.5	6.50	50.7	7.64	58.8	8.85	62.9	9.5	67.0	10.1	75.2	11.5	83.4	12.8
	14	42.5	6.59	50.7	7.76	58.8	9.00	62.9	9.6	67.0	10.3	75.2	11.7	83.4	13.1
	16	42.5	6.69	50.7	7.88	58.8	9.15	62.9	9.8	67.0	10.5	75.2	11.9	83.4	13.3
	18	42.5	6.80	50.7	8.01	58.8	9.3	62.9	10.0	67.0	10.7	75.2	12.1	83.4	13.6
	20	42.5	6.90	50.7	8.15	58.8	9.5	62.9	10.2	67.0	10.9	75.2	12.3	83.4	13.9
	21	42.5	6.96	50.7	8.22	58.8	9.6	62.9	10.3	67.0	11.0	75.2	12.5	83.4	14.0
	23	42.5	7.07	50.7	8.36	58.8	9.7	62.9	10.5	67.0	11.2	75.2	12.9	83.4	14.9
	25	42.5	7.19	50.7	8.52	58.8	10.1	62.9	11.0	67.0	11.9	75.2	13.8	83.4	15.9
	27	42.5	7.45	50.7	9.03	58.8	10.8	62.9	11.7	67.0	12.7	75.2	14.7	83.4	17.0
	29	42.5	7.89	50.7	9.6	58.8	11.4	62.9	12.4	67.0	13.5	75.2	15.7	83.4	18.1
	31	42.5	8.36	50.7	10.2	58.8	12.2	62.9	13.2	67.0	14.3	75.2	16.7	83.4	19.3
	33	42.5	8.84	50.7	10.8	58.8	12.9	62.9	14.1	67.0	15.2	75.2	17.8	83.4	20.5
	35	42.5	9.3	50.7	11.4	58.8	13.7	62.9	14.9	67.0	16.2	75.2	18.9	83.4	21.8
	37	42.5	9.9	50.7	12.1	58.8	14.5	62.9	15.8	67.0	17.2	75.2	20.1	83.4	23.2
	39	42.5	10.4	50.7	12.8	58.8	15.4	62.9	16.8	67.0	18.3	75.2	21.4	83.4	24.7
50 (475)	10	35.4	5.51	42.2	6.37	49.0	7.29	52.5	7.77	55.9	8.26	62.7	9.3	69.5	10.3
	12	35.4	5.58	42.2	6.46	49.0	7.41	52.5	7.90	55.9	8.40	62.7	9.4	69.5	10.5
	14	35.4	5.65	42.2	6.56	49.0	7.52	52.5	8.02	55.9	8.54	62.7	9.6	69.5	10.7
	16	35.4	5.73	42.2	6.66	49.0	7.64	52.5	8.15	55.9	8.68	62.7	9.8	69.5	10.9
	18	35.4	5.81	42.2	6.76	49.0	7.77	52.5	8.29	55.9	8.83	62.7	9.9	69.5	11.1
	20	35.4	5.89	42.2	6.86	49.0	7.90	52.5	8.43	55.9	8.98	62.7	10.1	69.5	11.3
	21	35.4	5.94	42.2	6.92	49.0	7.96	52.5	8.51	55.9	9.06	62.7	10.2	69.5	11.4
	23	35.4	6.02	42.2	7.03	49.0	8.10	52.5	8.66	55.9	9.2	62.7	10.4	69.5	11.7
	25	35.4	6.12	42.2	7.15	49.0	8.25	52.5	8.84	55.9	9.5	62.7	10.9	69.5	12.5
	27	35.4	6.21	42.2	7.40	49.0	8.70	52.5	9.4	55.9	10.1	62.7	11.6	69.5	13.3
	29	35.4	6.57	42.2	7.84	49.0	9.2	52.5	10.0	55.9	10.7	62.7	12.4	69.5	14.1
	31	35.4	6.95	42.2	8.30	49.0	9.8	52.5	10.6	55.9	11.4	62.7	13.2	69.5	15.0
	33	35.4	7.33	42.2	8.78	49.0	10.4	52.5	11.2	55.9	12.1	62.7	14.0	69.5	16.0
	35	35.4	7.74	42.2	9.3	49.0	11.0	52.5	11.9	55.9	12.8	62.7	14.8	69.5	17.0
	37	35.4	8.16	42.2	9.8	49.0	11.6	52.5	12.6	55.9	13.6	62.7	15.7	69.5	18.0
	39	35.4	8.61	42.2	10.4	49.0	12.3	52.5	13.3	55.9	14.4	62.7	16.7	69.5	19.2

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

RXYQ40PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1300)	10	98.6	15.5	118	18.9	137	22.5	142	23.0	143	22.5	147	21.6	150	20.6
	12	98.6	15.8	118	19.3	137	23.0	140	22.9	142	22.4	145	21.4	149	21.1
	14	98.6	16.1	118	19.7	136	23.2	138	22.8	140	22.3	143	22.1	147	22.3
	16	98.6	16.4	118	20.0	134	23.1	136	23.0	138	23.1	141	23.3	145	23.5
	18	98.6	16.7	118	20.4	132	24.0	134	24.1	136	24.3	140	24.5	143	24.7
	20	98.6	17.0	118	21.8	131	25.2	132	25.3	134	25.4	138	25.7	141	25.9
	21	98.6	17.5	118	22.6	130	25.8	132	25.9	133	26.0	137	26.3	140	26.5
	23	98.6	18.7	118	24.2	128	26.9	130	27.1	131	27.2	135	27.5	139	27.8
	25	98.6	20.0	118	25.9	126	28.1	128	28.3	130	28.4	133	28.7	137	29.0
	27	98.6	21.4	118	27.7	124	29.3	126	29.5	128	29.6	131	29.9	135	30.2
	29	98.6	22.8	118	29.6	122	30.5	124	30.7	126	30.8	130	31.2	133	31.5
	31	98.6	24.4	117	31.3	121	31.7	122	31.9	124	32.0	128	32.4	131	32.7
	33	98.6	26.0	115	32.5	119	32.9	121	33.1	122	33.3	126	33.6	129	34.0
	35	98.6	27.7	113	33.7	117	34.1	119	34.3	120	34.5	124	34.9	128	35.3
	37	98.6	28.4	112	34.9	115	35.3	117	35.5	119	35.7	122	36.1	126	36.5
	39	98.6	31.3	110	36.1	113	36.5	115	36.7	117	36.9	120	37.4	124	37.8
120 (1200)	10	91.0	14.1	109	17.3	126	20.5	135	22.2	141	23.1	144	22.3	148	21.4
	12	91.0	14.4	109	17.6	126	20.9	135	22.6	139	23.0	143	22.1	146	21.2
	14	91.0	14.7	109	17.9	126	21.3	135	23.0	137	22.9	141	22.0	144	22.1
	16	91.0	14.9	109	18.3	126	21.7	134	23.2	136	22.9	139	22.9	142	23.3
	18	91.0	15.2	109	18.6	126	22.5	132	24.0	134	24.1	137	24.0	140	24.5
	20	91.0	15.5	109	19.4	126	24.2	130	25.2	132	25.3	135	25.3	139	25.7
	21	91.0	15.7	109	20.1	126	25.0	129	25.7	131	25.9	134	26.1	138	26.3
	23	91.0	16.7	109	21.5	126	26.8	128	26.9	129	27.0	133	27.3	136	27.6
	25	91.0	17.9	109	23.0	124	28.0	126	28.1	127	28.2	131	28.5	134	28.8
	27	91.0	19.1	109	24.6	122	29.1	124	29.3	126	29.4	129	29.7	132	30.0
	29	91.0	20.4	109	26.3	120	30.3	122	30.5	124	30.6	127	30.9	130	31.2
	31	91.0	21.7	109	28.0	119	31.5	120	31.7	122	31.8	125	32.1	128	32.5
	33	91.0	23.1	109	29.9	117	32.7	118	32.9	120	33.0	123	33.4	127	33.7
	35	91.0	24.6	109	31.9	115	33.9	117	34.1	118	34.2	122	34.6	125	34.9
	37	91.0	26.2	109	34.0	113	35.1	115	35.3	116	35.5	120	35.8	123	36.2
	39	91.0	27.9	108	35.9	113	36.3	113	36.5	115	36.7	118	37.1	122	37.5
110 (1100)	10	83.4	12.8	100	15.6	116	18.6	124	20.1	132	21.6	142	22.9	145	22.1
	12	83.4	13.1	100	15.9	116	18.9	124	20.4	132	22.0	140	22.8	143	22.0
	14	83.4	13.3	100	16.2	116	19.3	124	20.8	132	22.4	138	22.7	141	22.0
	16	83.4	13.6	100	16.5	116	19.7	124	21.2	132	22.9	136	22.9	139	23.2
	18	83.4	13.8	100	16.9	116	20.0	124	21.8	132	24.0	135	24.2	138	24.4
	20	83.4	14.1	100	17.2	116	21.2	124	23.5	130	25.1	133	25.3	136	25.5
	21	83.4	14.2	100	17.7	116	22.0	124	24.3	129	25.7	132	25.9	135	26.1
	23	83.4	14.9	100	19.0	116	23.6	124	26.1	127	26.9	130	27.1	133	27.3
	25	83.4	15.9	100	20.3	116	25.2	124	27.9	125	28.0	128	28.3	131	28.5
	27	83.4	17.0	100	21.7	116	27.0	122	29.1	123	29.2	126	29.5	129	29.8
	29	83.4	18.1	100	23.1	116	28.8	120	30.3	121	30.4	125	30.7	128	31.0
	31	83.4	19.2	100	24.7	116	30.8	118	31.5	120	31.6	123	31.9	126	32.2
	33	83.4	20.5	100	26.3	115	32.5	116	32.6	118	32.8	121	33.1	124	33.4
	35	83.4	21.8	100	28.0	113	33.7	115	33.8	116	34.0	119	34.3	122	34.6
	37	83.4	23.2	100	29.8	111	34.9	113	35.0	114	35.2	117	35.5	120	35.8
	39	83.4	24.6	100	31.8	109	36.0	111	36.2	112	36.4	115	36.8	118	37.1
100 (1000)	10	75.9	11.6	90.5	14.0	105	16.6	112	18.0	120	19.3	134	22.1	142	22.9
	12	75.9	11.8	90.5	14.3	105	16.9	112	18.3	120	19.7	134	22.5	140	22.7
	14	75.9	12.0	90.5	14.6	105	17.3	112	18.7	120	20.1	134	22.9	138	22.6
	16	75.9	12.2	90.5	14.8	105	17.6	112	19.0	120	20.5	134	23.2	137	23.0
	18	75.9	12.4	90.5	15.1	105	17.9	112	19.4	120	20.9	132	24.0	135	24.2
	20	75.9	12.7	90.5	15.4	105	18.5	112	20.4	120	22.4	130	25.2	133	25.3
	21	75.9	12.8	90.5	15.6	105	19.1	112	21.1	120	23.2	129	25.7	132	25.9
	23	75.9	13.1	90.5	16.6	105	20.5	112	22.6	120	24.8	127	26.9	130	27.1
	25	75.9	14.0	90.5	17.7	105	21.9	112	24.2	120	26.6	126	28.1	128	28.3
	27	75.9	14.9	90.5	18.9	105	23.5	112	25.9	120	28.5	124	29.3	127	29.5
	29	75.9	15.9	90.5	20.2	105	25.0	112	27.7	119	30.2	122	30.5	125	30.7
	31	75.9	16.9	90.5	21.5	105	26.7	112	29.5	117	31.4	120	31.6	123	31.9
	33	75.9	18.0	90.5	22.9	105	28.5	112	31.5	116	32.6	118	32.8	121	33.1
	35	75.9	19.1	90.5	24.4	105	30.4	112	33.6	114	33.7	117	34.0	119	34.3
	37	75.9	20.3	90.5	26.0	105	32.4	111	34.8	112	34.9	115	35.3	117	35.6
	39	75.9	21.6	90.5	27.6	105	34.5	109	36.0	110	36.1	113	36.5	116	36.8

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (900)	10	68.3	10.4	81.4	12.5	94.6	14.8	101	15.9	108	17.1	121	19.6	134	22.0
	12	68.3	10.5	81.4	12.7	94.6	15.0	101	16.2	108	17.4	121	19.9	134	22.5
	14	68.3	10.7	81.4	13.0	94.6	15.3	101	16.5	108	17.8	121	20.3	134	22.9
	16	68.3	10.9	81.4	13.2	94.6	15.6	101	16.8	108	18.1	121	20.7	134	23.3
	18	68.3	11.1	81.4	13.4	94.6	15.9	101	17.2	108	18.5	121	21.1	132	24.0
	20	68.3	11.3	81.4	13.7	94.6	16.2	101	17.5	108	19.2	121	22.7	130	25.2
	21	68.3	11.4	81.4	13.8	94.6	16.5	101	18.1	108	19.8	121	23.5	129	25.7
	23	68.3	11.6	81.4	14.4	94.6	17.7	101	19.4	108	21.3	121	25.2	127	26.9
	25	68.3	12.3	81.4	15.4	94.6	18.9	101	20.8	108	22.8	121	27.0	126	28.1
	27	68.3	13.0	81.4	16.4	94.6	20.2	101	22.2	108	24.3	121	28.9	124	29.3
	29	68.3	13.9	81.4	17.5	94.6	21.5	101	23.7	108	26.0	119	30.2	122	30.5
	31	68.3	14.8	81.4	18.6	94.6	22.9	101	25.3	108	27.7	118	31.4	120	31.6
	33	68.3	15.7	81.4	19.8	94.6	24.4	101	26.9	108	29.6	116	32.6	118	32.8
	35	68.3	16.6	81.4	21.1	94.6	26.0	101	28.7	108	31.5	114	33.8	116	34.0
	37	68.3	17.7	81.4	22.4	94.6	27.7	101	30.6	108	33.6	112	35.0	115	35.2
	39	68.3	18.7	81.4	23.8	94.6	29.5	101	32.6	108	35.8	110	36.2	113	36.5
80 (800)	10	60.7	9.2	72.4	11.0	84.1	12.9	89.9	13.9	95.8	15.0	107	17.1	119	19.2
	12	60.7	9.3	72.4	11.2	84.1	13.2	89.9	14.2	95.8	15.2	107	17.4	119	19.6
	14	60.7	9.5	72.4	11.4	84.1	13.4	89.9	14.5	95.8	15.5	107	17.7	119	20.0
	16	60.7	9.7	72.4	11.6	84.1	13.7	89.9	14.7	95.8	15.8	107	18.1	119	20.4
	18	60.7	9.8	72.4	11.8	84.1	13.9	89.9	15.0	95.8	16.1	107	18.4	119	20.8
	20	60.7	10.0	72.4	12.0	84.1	14.2	89.9	15.3	95.8	16.5	107	19.1	119	22.2
	21	60.7	10.1	72.4	12.2	84.1	14.3	89.9	15.5	95.8	16.8	107	19.8	119	23.0
	23	60.7	10.3	72.4	12.4	84.1	15.0	89.9	16.5	95.8	18.0	107	21.2	119	24.7
	25	60.7	10.6	72.4	13.2	84.1	16.1	89.9	17.6	95.8	19.2	107	22.7	119	26.4
	27	60.7	11.3	72.4	14.1	84.1	17.1	89.9	18.8	95.8	20.5	107	24.2	119	28.3
	29	60.7	12.0	72.4	15.0	84.1	18.3	89.9	20.0	95.8	21.9	107	25.9	119	30.2
	31	60.7	12.7	72.4	15.9	84.1	19.4	89.9	21.3	95.8	23.3	107	27.6	117	31.4
	33	60.7	13.5	72.4	16.9	84.1	20.7	89.9	22.7	95.8	24.9	107	29.5	115	33.7
	35	60.7	14.3	72.4	18.0	84.1	22.0	89.9	24.2	95.8	26.5	107	31.4	114	34.9
	37	60.7	15.2	72.4	19.1	84.1	23.4	89.9	25.4	95.8	28.2	107	33.5	112	36.1
	39	60.7	16.1	72.4	20.3	84.1	24.9	89.9	27.4	95.8	30.0	107	35.6	110	36.5
70 (700)	10	53.1	8.09	63.3	9.6	73.6	11.2	78.7	12.0	83.8	12.9	94.0	14.7	104	16.5
	12	53.1	8.21	63.3	9.8	73.6	11.4	78.7	12.3	83.8	13.1	94.0	14.9	104	16.8
	14	53.1	8.34	63.3	9.9	73.6	11.6	78.7	12.5	83.8	13.4	94.0	15.2	104	17.1
	16	53.1	8.47	63.3	10.1	73.6	11.8	78.7	12.7	83.8	13.6	94.0	15.5	104	17.4
	18	53.1	8.61	63.3	10.3	73.6	12.0	78.7	12.9	83.8	13.9	94.0	15.8	104	17.8
	20	53.1	8.76	63.3	10.5	73.6	12.3	78.7	13.2	83.8	14.1	94.0	16.1	104	18.3
	21	53.1	8.83	63.3	10.5	73.6	12.4	78.7	13.3	83.8	14.3	94.0	16.4	104	18.9
	23	53.1	9.0	63.3	10.7	73.6	12.6	78.7	13.8	83.8	15.0	94.0	17.5	104	20.3
	25	53.1	9.1	63.3	11.2	73.6	13.5	78.7	14.7	83.8	16.0	94.0	18.7	104	21.7
	27	53.1	9.7	63.3	11.9	73.6	14.3	78.7	15.7	83.8	17.1	94.0	20.0	104	23.2
	29	53.1	10.3	63.3	12.6	73.6	15.3	78.7	16.7	83.8	18.2	94.0	21.3	104	24.8
	31	53.1	10.9	63.3	13.4	73.6	16.3	78.7	17.8	83.8	19.4	94.0	22.7	104	26.4
	33	53.1	11.5	63.3	14.3	73.6	17.3	78.7	18.9	83.8	20.6	94.0	24.2	104	28.2
	35	53.1	12.2	63.3	15.1	73.6	18.4	78.7	20.1	83.8	21.9	94.0	25.8	104	30.0
	37	53.1	12.9	63.3	16.0	73.6	19.5	78.7	21.4	83.8	23.3	94.0	27.5	104	32.0
	39	53.1	13.7	63.3	17.0	73.6	20.7	78.7	22.7	83.8	24.8	94.0	29.2	104	34.1
60 (600)	10	45.5	7.04	54.3	8.26	63.1	9.6	67.4	10.2	71.8	10.9	80.6	12.4	89.4	13.8
	12	45.5	7.14	54.3	8.39	63.1	9.7	67.4	10.4	71.8	11.1	80.6	12.6	89.4	14.1
	14	45.5	7.24	54.3	8.52	63.1	9.9	67.4	10.6	71.8	11.3	80.6	12.8	89.4	14.4
	16	45.5	7.35	54.3	8.66	63.1	10.0	67.4	10.8	71.8	11.5	80.6	13.0	89.4	14.6
	18	45.5	7.46	54.3	8.80	63.1	10.2	67.4	11.0	71.8	11.7	80.6	13.3	89.4	14.9
	20	45.5	7.58	54.3	8.95	63.1	10.4	67.4	11.2	71.8	11.9	80.6	13.5	89.4	15.2
	21	45.5	7.64	54.3	9.0	63.1	10.5	67.4	11.3	71.8	12.1	80.6	13.7	89.4	15.4
	23	45.5	7.76	54.3	9.2	63.1	10.7	67.4	11.5	71.8	12.3	80.6	14.2	89.4	16.3
	25	45.5	7.89	54.3	9.4	63.1	11.1	67.4	12.1	71.8	13.1	80.6	15.2	89.4	17.4
	27	45.5	8.18	54.3	9.9	63.1	11.8	67.4	12.8	71.8	13.9	80.6	16.2	89.4	18.6
	29	45.5	8.67	54.3	10.5	63.1	12.6	67.4	13.7	71.8	14.8	80.6	17.2	89.4	19.9
	31	45.5	9.2	54.3	11.2	63.1	13.4	67.4	14.5	71.8	15.8	80.6	18.4	89.4	21.2
	33	45.5	9.7	54.3	11.8	63.1	14.2	67.4	15.4	71.8	16.7	80.6	19.5	89.4	22.5
	35	45.5	10.3	54.3	12.5	63.1	15.0	67.4	16.4	71.8	17.8	80.6	20.8	89.4	24.0
	37	45.5	10.8	54.3	13.3	63.1	15.9	67.4	17.4	71.8	18.9	80.6	22.1	89.4	25.5
	39	45.5	11.5	54.3	14.0	63.1	16.9	67.4	18.4	71.8	20.0	80.6	23.5	89.4	27.2
50 (500)	10	37.9	6.05	45.2	7.00	52.5	8.01	56.2	8.54	59.9	9.1	67.2	10.2	74.5	11.4
	12	37.9	6.13	45.2	7.10	52.5	8.13	56.2	8.67	59.9	9.2	67.2	10.4	74.5	11.5
	14	37.9	6.21	45.2	7.20	52.5	8.26	56.2	8.81	59.9	9.4	67.2	10.5	74.5	11.8
	16	37.9	6.29	45.2	7.31	52.5	8.39	56.2	8.95	59.9	9.5	67.2	10.7	74.5	12.0
	18	37.9	6.38	45.2	7.42	52.5	8.53	56.2	9.1	59.9	9.7	67.2	10.9	74.5	12.2
	20	37.9	6.47	45.2	7.54	52.5	8.67	56.2	9.3	59.9	9.9	67.2	11.1	74.5	12.4
	21	37.9	6.52	45.2	7.60	52.5	8.74	56.2	9.3	59.9	10.0	67.2	11.2	74.5	12.5
	23	37.9	6.61	45.2	7.72	52.5	8.90	56.2	9.5	59.9	10.1	67.2	11.4	74.5	12.8
	25	37.9	6.72	45.2	7.85	52.5	9.1	56.2	9.7	59.9	10.4	67.2	12.0	74.5	13.7
	27	37.9	6.82	45.2	8.13	52.5	9.6	56.2	10.3	59.9	11.1	67.2	12.8	74.5	14.6
	29	37.9	7.22	45.2	8.61	52.5	10.1	56.2	11.0	59.9	11.8	67.2	13.6	74.5	15.5
	31	37.9	7.63	45.2	9.1	52.5	10.8	56.2	11.6	59.9	12.5	67.2	14.5	74.5	16.5
	33	37.9	8.05	45.2	9.6	52.5	11.4	56.2	12.3	59.9	13.3	67.2	15.3	74.5	17.6
	35	37.9	8.50	45.2	10.2	52.5	12.1	56.2	13.1	59.9	14.1	67.2	16.3	74.5	18.7
	37	37.9	8.96	45.2	10.8	52.5	12.8	56.2	13.8	59.9	14.9	67.2	17.3	74.5	19.8
	39	37.9	9.5	45.2	11.4	52.5	13.5	56.2	14.6	59.9	15.8	67.2	18.3	74.5	21.0

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

RXYQ42PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (945)	10	70.7	11.0	84.3	13.3	97.9	15.7	105	17.0	112	18.2	125	20.8	139	23.5
	12	70.7	11.2	84.3	13.6	97.9	16.0	105	17.3	112	18.6	125	21.2	139	23.9
	14	70.7	11.4	84.3	13.8	97.9	16.3	105	17.6	112	18.9	125	21.6	139	24.4
	16	70.7	11.6	84.3	14.1	97.9	16.6	105	18.0	112	19.3	125	22.1	139	24.8
	18	70.7	11.8	84.3	14.3	97.9	16.9	105	18.3	112	19.7	125	22.5	137	25.6
	20	70.7	12.1	84.3	14.6	97.9	17.3	105	18.7	112	20.4	125	24.2	135	26.8
	21	70.7	12.2	84.3	14.7	97.9	17.6	105	19.3	112	21.1	125	25.0	134	27.4
	23	70.7	12.4	84.3	15.4	97.9	18.8	105	20.7	112	22.7	125	26.9	132	28.7
	25	70.7	13.1	84.3	16.4	97.9	20.1	105	22.1	112	24.2	125	28.8	130	29.9
	27	70.7	13.9	84.3	17.5	97.9	21.5	105	23.6	112	25.9	125	30.8	128	31.2
	29	70.7	14.8	84.3	18.6	97.9	22.9	105	25.2	112	27.7	124	32.2	126	32.4
	31	70.7	15.7	84.3	19.8	97.9	24.4	105	26.9	112	29.5	122	33.5	124	33.7
	33	70.7	16.7	84.3	21.1	97.9	26.0	105	28.7	112	31.5	120	34.7	122	35.0
	35	70.7	17.7	84.3	22.4	97.9	27.7	105	30.6	112	33.6	118	36.0	121	36.3
	37	70.7	18.8	84.3	23.9	97.9	29.5	105	32.6	112	35.8	116	37.3	119	37.6
	39	70.7	20.0	84.3	25.4	97.9	31.4	105	34.7	112	38.1	114	38.5	117	38.8
80 (840)	10	62.8	9.8	75.0	11.7	87.1	13.8	93.1	14.9	99	15.9	111	18.2	123	20.5
	12	62.8	10.0	75.0	11.9	87.1	14.0	93.1	15.1	99	16.2	111	18.5	123	20.9
	14	62.8	10.1	75.0	12.1	87.1	14.3	93.1	15.4	99	16.5	111	18.9	123	21.3
	16	62.8	10.3	75.0	12.4	87.1	14.6	93.1	15.7	99	16.9	111	19.2	123	21.7
	18	62.8	10.5	75.0	12.6	87.1	14.8	93.1	16.0	99	17.2	111	19.6	123	22.1
	20	62.8	10.7	75.0	12.8	87.1	15.1	93.1	16.3	99	17.5	111	20.3	123	23.7
	21	62.8	10.8	75.0	13.0	87.1	15.3	93.1	16.5	99	17.9	111	21.1	123	24.5
	23	62.8	11.0	75.0	13.2	87.1	16.0	93.1	17.5	99	19.1	111	22.6	123	26.3
	25	62.8	11.3	75.0	14.1	87.1	17.1	93.1	18.8	99	20.5	111	24.1	123	28.1
	27	62.8	12.0	75.0	15.0	87.1	18.3	93.1	20.0	99	21.9	111	25.8	123	30.1
	29	62.8	12.8	75.0	15.9	87.1	19.5	93.1	21.3	99	23.3	111	27.6	123	32.2
	31	62.8	13.6	75.0	17.0	87.1	20.7	93.1	22.7	99	24.9	111	29.4	121	33.4
	33	62.8	14.4	75.0	18.0	87.1	22.1	93.1	24.2	99	26.5	111	31.4	120	34.7
	35	62.8	15.3	75.0	19.1	87.1	23.5	93.1	25.8	99	28.2	111	33.5	118	35.9
	37	62.8	16.2	75.0	20.3	87.1	24.9	93.1	27.4	99	30.1	111	35.7	116	37.2
	39	62.8	17.2	75.0	21.6	87.1	26.5	93.1	29.2	99	32.0	111	38.0	114	38.5
70 (735)	10	55.0	8.62	65.6	10.2	76.2	11.9	81.5	12.8	86.8	13.7	97.4	15.6	108	17.6
	12	55.0	8.75	65.6	10.4	76.2	12.1	81.5	13.1	86.8	14.0	97.4	15.9	108	17.9
	14	55.0	8.89	65.6	10.6	76.2	12.4	81.5	13.3	86.8	14.2	97.4	16.2	108	18.2
	16	55.0	9.0	65.6	10.8	76.2	12.6	81.5	13.5	86.8	14.5	97.4	16.5	108	18.6
	18	55.0	9.2	65.6	10.9	76.2	12.8	81.5	13.8	86.8	14.8	97.4	16.8	108	19.0
	20	55.0	9.3	65.6	11.1	76.2	13.1	81.5	14.1	86.8	15.1	97.4	17.2	108	19.5
	21	55.0	9.4	65.6	11.2	76.2	13.2	81.5	14.2	86.8	15.2	97.4	17.4	108	20.2
	23	55.0	9.6	65.6	11.4	76.2	13.5	81.5	14.7	86.8	15.9	97.4	18.7	108	21.6
	25	55.0	9.7	65.6	11.9	76.2	14.3	81.5	15.7	86.8	17.0	97.4	20.0	108	23.1
	27	55.0	10.3	65.6	12.7	76.2	15.3	81.5	16.7	86.8	18.2	97.4	21.3	108	24.7
	29	55.0	10.9	65.6	13.5	76.2	16.3	81.5	17.8	86.8	19.4	97.4	22.7	108	26.4
	31	55.0	11.6	65.6	14.3	76.2	17.3	81.5	18.9	86.8	20.6	97.4	24.2	108	28.1
	33	55.0	12.3	65.6	15.2	76.2	18.4	81.5	20.1	86.8	22.0	97.4	25.8	108	30.0
	35	55.0	13.0	65.6	16.1	76.2	19.6	81.5	21.4	86.8	23.4	97.4	27.5	108	32.0
	37	55.0	13.8	65.6	17.1	76.2	20.8	81.5	22.8	86.8	24.8	97.4	29.3	108	34.1
	39	55.0	14.6	65.6	18.1	76.2	22.1	81.5	24.2	86.8	26.4	97.4	31.1	108	36.3
60 (630)	10	47.1	7.50	56.2	8.80	65.3	10.2	69.8	10.9	74.4	11.6	83.5	13.2	92.5	14.8
	12	47.1	7.60	56.2	8.94	65.3	10.4	69.8	11.1	74.4	11.8	83.5	13.4	92.5	15.0
	14	47.1	7.71	56.2	9.1	65.3	10.5	69.8	11.3	74.4	12.0	83.5	13.6	92.5	15.3
	16	47.1	7.83	56.2	9.2	65.3	10.7	69.8	11.5	74.4	12.3	83.5	13.9	92.5	15.6
	18	47.1	7.95	56.2	9.4	65.3	10.9	69.8	11.7	74.4	12.5	83.5	14.2	92.5	15.9
	20	47.1	8.07	56.2	9.5	65.3	11.1	69.8	11.9	74.4	12.7	83.5	14.4	92.5	16.2
	21	47.1	8.14	56.2	9.6	65.3	11.2	69.8	12.0	74.4	12.8	83.5	14.6	92.5	16.4
	23	47.1	8.27	56.2	9.8	65.3	11.4	69.8	12.2	74.4	13.1	83.5	15.1	92.5	17.4
	25	47.1	8.41	56.2	10.0	65.3	11.8	69.8	12.9	74.4	13.9	83.5	16.2	92.5	18.6
	27	47.1	8.72	56.2	10.6	65.3	12.6	69.8	13.7	74.4	14.8	83.5	17.2	92.5	19.8
	29	47.1	9.2	56.2	11.2	65.3	13.4	69.8	14.6	74.4	15.8	83.5	18.4	92.5	21.2
	31	47.1	9.8	56.2	11.9	65.3	14.2	69.8	15.5	74.4	16.8	83.5	19.6	92.5	22.6
	33	47.1	10.3	56.2	12.6	65.3	15.1	69.8	16.4	74.4	17.8	83.5	20.8	92.5	24.0
	35	47.1	10.9	56.2	13.4	65.3	16.0	69.8	17.5	74.4	18.9	83.5	22.1	92.5	25.6
	37	47.1	11.6	56.2	14.1	65.3	17.0	69.8	18.5	74.4	20.1	83.5	23.5	92.5	27.2
	39	47.1	12.2	56.2	15.0	65.3	18.0	69.8	19.6	74.4	21.4	83.5	25.0	92.5	28.9
50 (525)	10	39.3	6.44	46.8	7.46	54.4	8.53	58.2	9.1	62.0	9.7	69.6	10.9	77.1	12.1
	12	39.3	6.53	46.8	7.56	54.4	8.66	58.2	9.2	62.0	9.8	69.6	11.0	77.1	12.3
	14	39.3	6.61	46.8	7.67	54.4	8.80	58.2	9.4	62.0	10.0	69.6	11.2	77.1	12.5
	16	39.3	6.70	46.8	7.79	54.4	8.94	58.2	9.5	62.0	10.2	69.6	11.4	77.1	12.8
	18	39.3	6.80	46.8	7.91	54.4	9.1	58.2	9.7	62.0	10.3	69.6	11.6	77.1	13.0
	20	39.3	6.89	46.8	8.03	54.4	9.2	58.2	9.9	62.0	10.5	69.6	11.8	77.1	13.2
	21	39.3	6.94	46.8	8.09	54.4	9.3	58.2	10.0	62.0	10.6	69.6	12.0	77.1	13.4
	23	39.3	7.05	46.8	8.23	54.4	9.5	58.2	10.1	62.0	10.8	69.6	12.2	77.1	13.7
	25	39.3	7.16	46.8	8.36	54.4	9.6	58.2	10.3	62.0	11.1	69.6	12.8	77.1	14.6
	27	39.3	7.27	46.8	8.66	54.4	10.2	58.2	11.0	62.0	11.8	69.6	13.6	77.1	15.5
	29	39.3	7.69	46.8	9.2	54.4	10.8	58.2	11.7	62.0	12.6	69.6	14.5	77.1	16.5
	31	39.3	8.13	46.8	9.7	54.4	11.5	58.2	12.4	62.0	13.4	69.6	15.4	77.1	17.6
	33	39.3	8.58	46.8	10.3	54.4	12.1	58.2	13.1	62.0	14.2	69.6	16.4	77.1	18.7
	35	39.3	9.1	46.8	10.9	54.4	12.9	58.2	13.9	62.0	15.0	69.6	17.4	77.1	19.9
	37	39.3	9.6	46.8	11.5	54.4	13.6	58.2	14.7	62.0	15.9	69.6	18.4	77.1	21.1
	39	39.3	10.1	46.8	12.1	54.4	14.4	58.2	15.6	62.0	16.9	69.6	19.5	77.1	22.4

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1365)	10	102	16.5	122	20.2	141	24.0	147	24.5	148	24.0	152	23.0	156	22.0
	12	102	16.8	122	20.6	141	24.5	145	24.4	147	23.9	150	22.8	154	22.5
	14	102	17.1	122	21.0	141	24.8	143	24.3	145	23.7	148	23.5	152	23.8
	16	102	17.4	122	21.4	139	24.6	141	24.5	143	24.6	146	24.8	150	25.1
	18	102	17.8	122	21.8	137	25.6	139	25.7	141	25.8	145	26.1	148	26.3
	20	102	18.1	122	23.2	135	26.8	137	27.0	139	27.1	143	27.4	146	27.6
	21	102	18.6	122	24.0	134	27.5	136	27.6	138	27.7	142	28.0	145	28.3
	23	102	20.0	122	25.8	132	28.7	134	28.9	136	29.0	140	29.3	144	29.6
	25	102	21.3	122	27.6	131	30.0	132	30.1	134	30.3	138	30.6	142	30.9
	27	102	22.8	122	29.5	129	31.2	131	31.4	132	31.6	136	31.9	140	32.2
	29	102	24.3	122	31.5	127	32.5	129	32.7	130	32.8	134	33.2	138	33.5
	31	102	25.9	121	33.4	125	33.8	127	33.9	129	34.1	132	34.5	136	34.9
	33	102	27.7	119	34.7	123	35.0	125	35.2	127	35.4	130	35.8	134	36.2
	35	102	29.5	117	35.9	121	36.3	123	36.5	125	36.7	128	37.1	132	37.6
	37	102	31.4	116	37.2	119	37.6	121	37.8	123	38.0	127	38.5	130	38.9
	39	102	33.4	114	38.5	117	38.9	119	39.1	121	39.4	125	39.8	128	40.3
120 (1260)	10	94.3	15.1	112	18.4	131	21.9	140	23.6	146	24.6	150	23.7	153	22.8
	12	94.3	15.3	112	18.7	131	22.3	140	24.1	144	24.5	148	23.6	151	22.6
	14	94.3	15.6	112	19.1	131	22.7	140	24.6	142	24.4	146	23.4	149	23.6
	16	94.3	15.9	112	19.5	131	23.2	139	24.7	140	24.4	144	24.6	147	24.9
	18	94.3	16.2	112	19.9	131	24.0	137	25.6	139	25.7	142	25.9	145	26.1
	20	94.3	16.5	112	20.6	131	25.7	135	26.8	137	26.9	140	27.2	143	27.4
	21	94.3	16.7	112	21.4	131	26.7	134	27.4	136	27.6	139	27.8	143	28.1
	23	94.3	17.8	112	22.9	130	28.5	132	28.7	134	28.8	137	29.1	141	29.4
	25	94.3	19.1	112	24.5	129	29.8	130	29.9	132	30.1	135	30.4	139	30.7
	27	94.3	20.4	112	26.2	127	31.0	128	31.2	130	31.3	133	31.7	137	32.0
	29	94.3	21.7	112	28.0	125	32.3	126	32.5	128	32.6	132	32.9	135	33.3
	31	94.3	23.1	112	29.9	123	33.6	125	33.7	126	33.9	130	34.2	133	34.6
	33	94.3	24.7	112	31.9	121	34.8	123	35.0	124	35.2	128	35.5	131	35.9
	35	94.3	26.2	112	34.0	119	36.1	121	36.3	122	36.5	126	36.9	129	37.2
	37	94.3	27.9	112	36.2	117	37.4	119	37.6	121	37.8	124	38.2	127	38.6
	39	94.3	29.7	112	38.2	115	38.7	117	38.9	119	39.1	122	39.5	125	39.9
110 (1155)	10	86.4	13.7	103	16.7	120	19.8	128	21.4	136	23.0	147	24.4	150	23.6
	12	86.4	13.9	103	17.0	120	20.2	128	21.8	136	23.4	145	24.3	148	23.4
	14	86.4	14.2	103	17.3	120	20.5	128	22.2	136	23.9	143	24.2	146	23.4
	16	86.4	14.4	103	17.6	120	20.9	128	22.6	136	24.3	141	24.5	144	24.7
	18	86.4	14.7	103	18.0	120	21.4	128	23.3	136	25.5	139	25.7	142	25.9
	20	86.4	15.0	103	18.3	120	22.6	128	25.0	134	26.8	137	27.0	141	27.2
	21	86.4	15.1	103	18.9	120	23.4	128	25.9	133	27.4	137	27.6	140	27.9
	23	86.4	15.9	103	20.2	120	25.1	128	27.8	131	28.6	135	28.9	138	29.1
	25	86.4	16.9	103	21.6	120	26.9	128	29.8	130	29.9	133	30.1	136	30.4
	27	86.4	18.1	103	23.1	120	28.8	126	31.0	128	31.1	131	31.4	134	31.7
	29	86.4	19.3	103	24.7	120	30.7	124	32.3	126	32.4	129	32.7	132	33.0
	31	86.4	20.5	103	26.3	120	32.8	122	33.5	124	33.7	127	34.0	130	34.3
	33	86.4	21.8	103	28.0	119	34.6	120	34.8	122	34.9	125	35.3	128	35.6
	35	86.4	23.2	103	29.9	117	35.9	119	36.0	120	36.2	123	36.6	126	36.9
	37	86.4	24.7	103	31.8	115	37.1	117	37.3	118	37.5	121	37.9	124	38.2
	39	86.4	26.2	103	33.9	113	38.4	115	38.6	116	38.8	119	39.2	123	39.6
100 (1050)	10	78.6	12.3	93.7	15.0	109	17.7	116	19.1	124	20.6	139	23.5	147	24.4
	12	78.6	12.6	93.7	15.2	109	18.1	116	19.5	124	21.0	139	24.0	145	24.2
	14	78.6	12.8	93.7	15.5	109	18.4	116	19.9	124	21.4	139	24.4	143	24.1
	16	78.6	13.0	93.7	15.8	109	18.8	116	20.3	124	21.8	139	24.8	141	24.5
	18	78.6	13.2	93.7	16.1	109	19.1	116	20.7	124	22.2	137	25.6	140	25.8
	20	78.6	13.5	93.7	16.4	109	19.7	116	21.7	124	23.8	135	26.8	138	27.0
	21	78.6	13.6	93.7	16.6	109	20.4	116	22.5	124	24.7	134	27.4	137	27.6
	23	78.6	14.0	93.7	17.7	109	21.9	116	24.1	124	26.5	132	28.7	135	28.9
	25	78.6	14.9	93.7	18.9	109	23.4	116	25.8	124	28.3	130	29.9	133	30.2
	27	78.6	15.9	93.7	20.2	109	25.0	116	27.6	124	30.3	128	31.2	131	31.4
	29	78.6	16.9	93.7	21.5	109	26.7	116	29.5	123	32.2	126	32.5	129	32.7
	31	78.6	18.0	93.7	22.9	109	28.5	116	31.5	122	33.4	124	33.7	127	34.0
	33	78.6	19.2	93.7	24.4	109	30.4	116	33.6	120	34.7	123	35.0	125	35.3
	35	78.6	20.4	93.7	26.0	109	32.4	116	35.8	118	36.0	121	36.3	123	36.6
	37	78.6	21.6	93.7	27.7	109	34.5	115	37.1	116	37.2	119	37.6	122	37.9
	39	78.6	23.0	93.7	29.4	109	36.7	113	38.3	114	38.5	117	38.9	120	39.2

RXYQ44PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1430)	10	106	17.5	126	21.4	146	25.5	152	26.0	154	25.5	157	24.2	161	23.3
	12	106	17.8	126	21.8	146	26.0	150	25.9	152	25.3	155	24.2	159	23.9
	14	106	18.2	126	22.2	146	26.3	148	25.7	150	25.2	153	25.0	157	25.2
	16	106	18.5	126	22.7	144	26.2	146	26.0	148	26.1	151	26.3	155	26.6
	18	106	18.9	126	23.1	142	27.2	144	27.3	146	27.4	150	27.7	153	28.0
	20	106	19.2	126	24.6	140	28.5	142	28.6	144	28.8	148	29.0	151	29.3
	21	106	19.8	126	25.5	139	29.1	141	29.3	143	29.4	147	29.7	150	30.0
	23	106	21.2	126	27.4	137	30.5	139	30.6	141	30.8	145	31.1	148	31.4
	25	106	22.7	126	29.3	135	31.8	137	32.0	139	32.1	143	32.5	146	32.8
	27	106	24.2	126	31.3	133	33.1	135	33.3	137	33.5	141	33.8	145	34.2
	29	106	25.8	126	33.5	131	34.5	133	34.7	135	34.9	139	35.2	143	35.6
	31	106	27.5	125	35.4	129	35.8	131	36.0	133	36.2	137	36.6	141	37.0
	33	106	29.4	123	36.8	127	37.2	129	37.4	131	37.6	135	38.0	139	38.4
	35	106	31.3	121	38.1	125	38.6	127	38.8	129	39.0	133	39.4	137	39.9
	37	106	33.3	119	39.5	123	39.9	125	40.2	127	40.4	131	40.8	135	41.3
	39	106	35.5	118	40.8	121	41.3	123	41.5	125	41.8	129	42.3	133	42.8
120 (1320)	10	98	16.0	116	19.5	135	23.2	144	25.1	151	26.1	155	25.2	158	24.2
	12	98	16.3	116	19.9	135	23.7	144	25.6	149	26.0	153	25.0	156	24.0
	14	98	16.6	116	20.3	135	24.1	144	26.1	147	25.9	151	24.9	154	25.0
	16	98	16.9	116	20.7	135	24.6	144	26.3	145	25.9	149	26.2	152	26.4
	18	98	17.2	116	21.1	135	25.4	142	27.1	143	27.3	147	27.5	150	27.7
	20	98	17.6	116	21.9	135	27.3	140	28.5	141	28.6	145	28.8	148	29.1
	21	98	17.7	116	22.7	135	28.3	139	29.1	140	29.3	144	29.5	147	29.8
	23	98	18.9	116	24.3	135	30.3	137	30.4	138	30.6	142	30.9	145	31.2
	25	98	20.2	116	26.0	133	31.6	135	31.8	136	31.9	140	32.2	143	32.5
	27	98	21.6	116	27.8	131	33.0	133	33.1	134	33.3	138	33.6	142	33.9
	29	98	23.0	116	29.7	129	34.3	131	34.5	133	34.6	136	35.0	140	35.3
	31	98	24.6	116	31.7	125	35.6	129	35.8	131	36.0	134	36.3	138	36.7
	33	98	26.2	116	33.8	123	36.1	127	37.0	129	37.2	132	37.7	136	38.1
	35	98	27.9	116	36.1	121	38.4	123	38.7	125	38.9	129	39.1	134	39.5
	37	98	29.6	116	38.4	119	40.6	121	41.0	123	41.3	127	40.5	132	40.9
	39	98	31.5	116	40.6	119	41.7	121	41.9	123	41.9	125	41.5	130	42.4
110 (1210)	10	89.4	14.5	107	17.7	124	21.0	132	22.7	141	24.4	152	25.9	155	25.0
	12	89.4	14.8	107	18.0	124	21.4	132	23.1	141	24.9	150	25.8	153	24.9
	14	89.4	15.0	107	18.3	124	21.8	132	23.6	141	25.4	148	25.6	151	24.9
	16	89.4	15.3	107	18.7	124	22.2	132	24.0	141	25.8	146	26.0	149	26.2
	18	89.4	15.6	107	19.1	124	22.7	132	24.7	141	27.1	144	27.3	147	27.5
	20	89.4	15.9	107	19.4	124	24.0	132	26.5	139	28.4	142	28.6	145	28.9
	21	89.4	16.1	107	20.0	124	24.9	132	27.5	138	29.1	141	29.3	144	29.6
	23	89.4	16.8	107	21.5	124	26.7	132	29.5	136	30.4	139	30.7	142	30.9
	25	89.4	18.0	107	22.9	124	28.5	132	31.6	134	31.7	137	32.0	141	32.3
	27	89.4	19.2	107	24.5	124	30.5	130	32.9	132	33.1	135	33.4	139	33.6
	29	89.4	20.4	107	26.2	124	32.6	129	34.2	130	34.4	133	34.7	137	35.0
	31	89.4	21.8	107	27.9	124	34.8	127	35.6	128	35.7	131	36.1	135	36.4
	33	89.4	23.2	107	29.7	123	36.7	125	36.9	126	37.1	129	37.4	133	37.8
	35	89.4	24.6	107	31.7	121	38.1	123	38.3	124	38.4	127	38.8	131	39.2
	37	89.4	26.2	107	33.8	119	39.4	121	39.6	122	39.8	126	40.2	129	40.6
	39	89.4	27.9	107	35.9	117	40.8	119	41.0	120	41.2	124	41.6	127	42.0
100 (1100)	10	81.3	13.1	96.9	15.9	113	18.8	120	20.3	128	21.9	144	25.0	152	25.9
	12	81.3	13.3	96.9	16.2	113	19.2	120	20.7	128	22.3	144	25.5	150	25.7
	14	81.3	13.6	96.9	16.5	113	19.5	120	21.1	128	22.7	144	25.9	148	25.6
	16	81.3	13.8	96.9	16.8	113	19.9	120	21.5	128	23.1	143	26.3	146	26.0
	18	81.3	14.1	96.9	17.1	113	20.3	120	21.9	128	23.6	141	27.1	144	27.3
	20	81.3	14.3	96.9	17.4	113	20.9	120	23.0	128	25.3	139	28.4	142	28.7
	21	81.3	14.5	96.9	17.6	113	21.7	120	23.9	128	26.2	139	29.1	141	29.3
	23	81.3	14.9	96.9	18.8	113	23.2	120	25.6	128	28.1	137	30.4	139	30.7
	25	81.3	15.8	96.9	20.1	113	24.8	120	27.4	128	30.1	135	31.8	138	32.0
	27	81.3	16.9	96.9	21.4	113	26.5	120	29.3	128	32.2	133	33.1	136	33.4
	29	81.3	18.0	96.9	22.9	113	28.3	120	31.3	128	34.2	131	34.4	134	34.7
	31	81.3	19.1	96.9	24.4	113	30.2	120	33.4	126	35.5	129	35.8	132	36.1
	33	81.3	20.4	96.9	25.9	113	32.2	120	35.6	124	36.8	127	37.1	130	37.5
	35	81.3	21.6	96.9	27.6	113	34.3	120	38.0	122	38.2	125	38.5	128	38.8
	37	81.3	23.0	96.9	29.4	113	36.6	118	39.3	120	39.5	123	39.9	126	40.2
	39	81.3	24.4	96.9	31.3	113	39.0	116	40.7	118	40.9	121	41.2	124	41.6

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (990)	10	73.1	11.7	87.2	14.1	101	16.7	108	18.0	115	19.4	129	22.1	144	24.9
	12	73.1	11.9	87.2	14.4	101	17.0	108	18.3	115	19.7	129	22.5	144	25.4
	14	73.1	12.1	87.2	14.6	101	17.3	108	18.7	115	20.1	129	23.0	144	25.9
	16	73.1	12.3	87.2	14.9	101	17.6	108	19.1	115	20.5	129	23.4	143	26.3
	18	73.1	12.6	87.2	15.2	101	18.0	108	19.4	115	20.9	129	23.9	141	27.1
	20	73.1	12.8	87.2	15.5	101	18.3	108	19.8	115	21.7	129	25.7	139	28.4
	21	73.1	12.9	87.2	15.6	101	18.7	108	20.5	115	22.4	129	26.6	138	29.1
	23	73.1	13.2	87.2	16.3	101	20.0	108	22.0	115	24.0	129	28.5	136	30.4
	25	73.1	13.9	87.2	17.4	101	21.4	108	23.5	115	25.7	129	30.5	135	31.8
	27	73.1	14.8	87.2	18.6	101	22.8	108	25.1	115	27.5	129	32.7	133	33.1
	29	73.1	15.7	87.2	19.8	101	24.3	108	26.8	115	29.4	128	34.2	131	34.4
	31	73.1	16.7	87.2	21.0	101	25.9	108	28.6	115	31.4	126	35.5	129	35.8
	33	73.1	17.7	87.2	22.4	101	27.6	108	30.5	115	33.4	124	36.9	127	37.1
	35	73.1	18.8	87.2	23.8	101	29.4	108	32.5	115	35.6	122	38.2	125	38.5
	37	73.1	20.0	87.2	25.3	101	31.3	108	34.6	115	38.0	120	39.5	123	39.9
	39	73.1	21.2	87.2	26.9	101	33.3	108	36.8	115	40.5	118	40.9	121	41.2
80 (880)	10	65.0	10.4	77.5	12.5	90.1	14.6	96.3	15.8	103	16.9	115	19.3	128	21.7
	12	65.0	10.6	77.5	12.7	90.1	14.9	96.3	16.1	103	17.2	115	19.7	128	22.2
	14	65.0	10.7	77.5	12.9	90.1	15.2	96.3	16.4	103	17.6	115	20.0	128	22.6
	16	65.0	10.9	77.5	13.1	90.1	15.5	96.3	16.7	103	17.9	115	20.4	128	23.0
	18	65.0	11.1	77.5	13.4	90.1	15.8	96.3	17.0	103	18.2	115	20.8	128	23.5
	20	65.0	11.3	77.5	13.6	90.1	16.1	96.3	17.3	103	18.6	115	21.6	128	25.1
	21	65.0	11.4	77.5	13.7	90.1	16.2	96.3	17.5	103	19.0	115	22.4	128	26.0
	23	65.0	11.6	77.5	14.0	90.1	17.0	96.3	18.6	103	20.3	115	24.0	128	27.9
	25	65.0	12.0	77.5	14.9	90.1	18.2	96.3	19.9	103	21.7	115	25.6	128	29.9
	27	65.0	12.8	77.5	15.9	90.1	19.4	96.3	21.2	103	23.2	115	27.4	128	32.0
	29	65.0	13.6	77.5	16.9	90.1	20.6	96.3	22.7	103	24.8	115	29.3	128	34.1
	31	65.0	14.4	77.5	18.0	90.1	22.0	96.3	24.1	103	26.4	115	31.2	128	35.5
	33	65.0	15.3	77.5	19.1	90.1	23.4	96.3	25.7	103	28.1	115	33.3	124	36.8
	35	65.0	16.2	77.5	20.3	90.1	24.9	96.3	27.4	103	30.0	115	35.5	122	38.2
	37	65.0	17.2	77.5	21.6	90.1	26.5	96.3	29.1	103	31.9	115	37.8	120	39.5
	39	65.0	18.2	77.5	22.9	90.1	28.1	96.3	31.0	103	34.0	115	40.3	118	40.9
70 (770)	10	56.9	9.15	67.8	10.9	78.8	12.7	84.3	13.6	89.8	14.6	101	16.6	112	18.6
	12	56.9	9.3	67.8	11.0	78.8	12.9	84.3	13.9	89.8	14.8	101	16.9	112	19.0
	14	56.9	9.4	67.8	11.2	78.8	13.1	84.3	14.1	89.8	15.1	101	17.2	112	19.4
	16	56.9	9.6	67.8	11.4	78.8	13.4	84.3	14.4	89.8	15.4	101	17.5	112	19.7
	18	56.9	9.7	67.8	11.6	78.8	13.6	84.3	14.6	89.8	15.7	101	17.9	112	20.1
	20	56.9	9.9	67.8	11.8	78.8	13.9	84.3	14.9	89.8	16.0	101	18.2	112	20.7
	21	56.9	10.0	67.8	11.9	78.8	14.0	84.3	15.1	89.8	16.2	101	18.5	112	21.4
	23	56.9	10.2	67.8	12.2	78.8	14.3	84.3	15.6	89.8	16.9	101	19.8	112	22.9
	25	56.9	10.3	67.8	12.6	78.8	15.2	84.3	16.6	89.8	18.1	101	21.2	112	24.5
	27	56.9	10.9	67.8	13.4	78.8	16.2	84.3	17.7	89.8	19.3	101	22.6	112	26.2
	29	56.9	11.6	67.8	14.3	78.8	17.3	84.3	18.9	89.8	20.6	101	24.1	112	28.0
	31	56.9	12.3	67.8	15.2	78.8	18.4	84.3	20.1	89.8	21.9	101	25.7	112	29.9
	33	56.9	13.0	67.8	16.1	78.8	19.5	84.3	21.4	89.8	23.3	101	27.4	112	31.9
	35	56.9	13.8	67.8	17.1	78.8	20.8	84.3	22.7	89.8	24.8	101	29.2	112	33.9
	37	56.9	14.6	67.8	18.1	78.8	22.0	84.3	24.2	89.8	26.4	101	31.1	112	36.1
	39	56.9	15.5	67.8	19.2	78.8	23.4	84.3	25.7	89.8	28.0	101	33.1	112	38.5
60 (660)	10	48.8	7.96	58.1	9.3	67.5	10.8	72.2	11.6	76.9	12.4	86.3	14.0	95.7	15.7
	12	48.8	8.19	58.1	9.5	67.5	11.0	72.2	11.8	76.9	12.6	86.3	14.2	95.7	15.9
	14	48.8	8.31	58.1	9.6	67.5	11.2	72.2	12.0	76.9	12.8	86.3	14.5	95.7	16.2
	16	48.8	8.44	58.1	9.8	67.5	11.4	72.2	12.2	76.9	13.0	86.3	14.8	95.7	16.5
	18	48.8	8.57	58.1	10.0	67.5	11.6	72.2	12.4	76.9	13.3	86.3	15.0	95.7	16.9
	20	48.8	8.57	58.1	10.1	67.5	11.8	72.2	12.6	76.9	13.5	86.3	15.3	95.7	17.2
	21	48.8	8.64	58.1	10.2	67.5	11.9	72.2	12.7	76.9	13.6	86.3	15.5	95.7	17.4
	23	48.8	8.78	58.1	10.4	67.5	12.1	72.2	13.0	76.9	13.9	86.3	16.1	95.7	18.5
	25	48.8	8.93	58.1	10.6	67.5	12.6	72.2	13.6	76.9	14.8	86.3	17.2	95.7	19.7
	27	48.8	9.3	58.1	11.2	67.5	13.4	72.2	14.5	76.9	15.7	86.3	18.3	95.7	21.1
	29	48.8	9.8	58.1	11.9	67.5	14.2	72.2	15.5	76.9	16.7	86.3	19.5	95.7	22.5
	31	48.8	10.4	58.1	12.6	67.5	15.1	72.2	16.4	76.9	17.8	86.3	20.8	95.7	23.9
	33	48.8	11.0	58.1	13.4	67.5	16.0	72.2	17.5	76.9	18.9	86.3	22.1	95.7	25.5
	35	48.8	11.6	58.1	14.2	67.5	17.0	72.2	18.5	76.9	20.1	86.3	23.5	95.7	27.1
	37	48.8	12.3	58.1	15.0	67.5	18.0	72.2	19.7	76.9	21.4	86.3	25.0	95.7	28.9
	39	48.8	13.0	58.1	15.9	67.5	19.1	72.2	20.9	76.9	22.7	86.3	26.5	95.7	30.7
50 (550)	10	40.6	6.84	48.5	7.92	56.3	9.06	60.2	9.7	64.1	10.3	71.9	11.5	79.8	12.8
	12	40.6	6.93	48.5	8.03	56.3	9.2	60.2	9.8	64.1	10.4	71.9	11.7	79.8	13.1
	14	40.6	7.02	48.5	8.14	56.3	9.3	60.2	10.0	64.1	10.6	71.9	11.9	79.8	13.3
	16	40.6	7.12	48.5	8.27	56.3	9.5	60.2	10.1	64.1	10.8	71.9	12.1	79.8	13.5
	18	40.6	7.21	48.5	8.39	56.3	9.6	60.2	10.3	64.1	11.0	71.9	12.3	79.8	13.8
	20	40.6	7.32	48.5	8.52	56.3	9.8	60.2	10.5	64.1	11.2	71.9	12.6	79.8	14.0
	21	40.6	7.37	48.5	8.59	56.3	9.9	60.2	10.6	64.1	11.3	71.9	12.7	79.8	14.2
	23	40.6	7.48	48.5	8.73	56.3	10.1	60.2	10.8	64.1	11.5	71.9	12.9	79.8	14.5
	25	40.6	7.59	48.5	8.88	56.3	10.2	60.2	11.0	64.1	11.8	71.9	13.6	79.8	15.5
	27	40.6	7.72	48.5	9.19	56.3	10.8	60.2	11.7	64.1	12.6	71.9	14.5	79.8	16.5
	29	40.6	8.16	48.5	9.7	56.3	11.5	60.2	12.4	64.1	13.3	71.9	15.4	79.8	17.6
	31	40.6	8.63	48.5	10.3	56.3	12.2	60.2	13.1	64.1	14.2	71.9	16.3	79.8	18.7
	33	40.6	9.11	48.5	10.9	56.3	12.9	60.2	13.9	64.1	15.0	71.9	17.4	79.8	19.9
	35	40.6	9.6	48.5	11.5	56.3	13.6	60.2	14.8	64.1	15.9	71.9	18.4	79.8	21.1
	37	40.6	10.1	48.5	12.2	56.3	14.4	60.2	15.6	64.1	16.9	71.9	19.6	79.8	22.4
	39	40.6	10.7	48.5	12.9	56.3	15.3	60.2	16.6	64.1	17.9	71.9	20.7	79.8	23.8

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

RXYQ46PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	14.0°CWB kW	16.0°CWB TC	16.0°CWB PI	16.0°CWB kW	18.0°CWB TC	18.0°CWB PI	18.0°CWB kW	19.0°CWB TC	19.0°CWB PI	19.0°CWB kW	20.0°CWB TC	20.0°CWB PI	20.0°CWB kW	22.0°CWB TC	22.0°CWB PI	22.0°CWB kW	24.0°CWB TC	24.0°CWB PI	24.0°CWB kW
130 (1495)	10	111	18.7	132	22.9	153	27.3	159	27.9	161	27.3	165	26.1	169	25.0							
	12	111	19.1	132	23.4	153	27.8	157	27.7	159	27.1	163	26.0	167	25.6							
	14	111	19.4	132	23.8	153	28.2	155	27.6	157	27.0	161	26.8	165	27.0							
	16	111	19.8	132	24.3	151	28.0	153	27.8	155	27.9	159	28.2	163	28.5							
	18	111	20.2	132	24.8	149	29.1	150	29.2	152	29.4	156	29.7	160	29.9							
	20	111	20.6	132	26.4	146	30.5	148	30.7	150	30.8	154	31.1	158	31.4							
	21	111	21.2	132	27.3	145	31.2	147	31.4	149	31.5	153	31.8	157	32.2							
	23	111	22.7	132	29.3	143	32.6	145	32.8	147	33.0	151	33.3	155	33.6							
	25	111	24.3	132	31.4	141	34.1	143	34.2	145	34.4	149	34.8	153	35.1							
	27	111	25.9	132	33.6	139	35.5	141	35.7	143	35.9	147	36.2	151	36.6							
	29	111	27.7	132	35.9	137	36.9	139	37.1	141	37.3	145	37.7	149	38.1							
	31	111	29.5	131	38.0	135	38.4	137	38.6	139	38.8	143	39.2	147	39.6							
	33	111	31.4	129	39.4	133	39.8	135	40.1	137	40.3	141	40.7	145	41.2							
	35	111	33.5	127	40.8	131	41.3	133	41.5	135	41.8	139	42.2	143	42.7							
	37	111	35.7	125	42.3	129	42.8	131	43.0	133	43.3	137	43.7	141	44.2							
	39	111	38.0	123	43.7	127	44.2	129	44.5	131	44.8	135	45.3	139	45.8							
120 (1380)	10	102	17.1	122	20.9	141	24.9	151	26.9	158	28.0	162	27.0	166	25.9							
	12	102	17.4	122	21.3	141	25.3	151	27.4	156	27.9	160	26.8	163	25.7							
	14	102	17.8	122	21.7	141	25.8	151	27.9	154	27.7	158	26.6	161	26.8							
	16	102	18.1	122	22.1	141	26.3	150	28.1	152	27.8	156	28.0	159	28.3							
	18	102	18.4	122	22.6	141	27.2	148	29.1	150	29.2	154	29.5	157	29.7							
	20	102	18.8	122	23.5	141	29.3	146	30.5	148	30.6	152	30.9	155	31.2							
	21	102	19.0	122	24.3	141	30.3	145	31.2	147	31.3	151	31.6	154	31.9							
	23	102	20.3	122	26.0	141	32.5	143	32.6	145	32.8	149	33.1	152	33.4							
	25	102	21.7	122	27.9	139	33.9	141	34.0	143	34.2	146	34.5	150	34.8							
	27	102	23.1	122	29.8	137	35.3	139	35.5	141	35.6	144	36.0	148	36.3							
	29	102	24.7	122	31.8	135	36.7	137	36.9	139	37.1	142	37.5	146	37.8							
	31	102	26.3	122	34.0	133	38.2	135	38.3	137	38.5	140	38.9	144	39.3							
	33	102	28.0	122	36.2	131	39.6	133	39.8	135	40.0	138	40.4	142	40.8							
	35	102	29.8	122	38.6	129	41.0	131	41.3	133	41.5	136	41.9	140	42.3							
	37	102	31.7	122	41.2	127	42.3	129	42.7	131	42.9	134	43.4	138	43.9							
	39	102	33.8	121	43.2	125	43.9	127	44.2	128	44.4	132	44.9	136	45.4							
110 (1265)	10	93.5	15.5	112	18.9	130	22.5	139	24.3	148	26.1	159	27.8	162	26.8							
	12	93.5	15.8	112	19.3	130	22.9	139	24.8	148	26.6	157	27.6	160	26.6							
	14	93.5	16.1	112	19.7	130	23.3	139	25.2	148	27.2	155	27.5	158	26.6							
	16	93.5	16.4	112	20.0	130	23.8	139	25.7	148	27.7	153	27.8	156	28.1							
	18	93.5	16.7	112	20.4	130	24.3	139	26.4	147	29.0	151	29.3	154	29.5							
	20	93.5	17.1	112	20.8	130	25.7	139	28.4	145	30.4	149	30.9	152	30.9							
	21	93.5	17.2	112	21.5	130	26.6	139	29.4	144	31.1	148	31.4	151	31.7							
	23	93.5	18.0	112	23.0	130	28.6	139	31.6	142	32.6	146	32.8	149	33.1							
	25	93.5	19.3	112	24.6	130	30.6	139	33.8	140	34.0	144	34.3	147	34.6							
	27	93.5	20.5	112	26.3	130	32.7	137	35.2	138	35.4	142	35.7	145	36.0							
	29	93.5	21.9	112	28.0	130	34.9	135	36.7	136	36.8	140	37.2	143	37.5							
	31	93.5	23.3	112	29.9	130	37.3	132	38.1	134	38.3	138	38.6	141	39.0							
	33	93.5	24.8	112	31.9	129	39.3	130	39.5	132	39.7	135	40.1	139	40.5							
	35	93.5	26.4	112	33.9	127	40.8	128	41.0	130	41.2	133	41.6	137	42.0							
	37	93.5	28.1	112	36.2	125	42.2	126	42.4	128	42.6	131	43.1	135	43.5							
	39	93.5	29.8	112	38.5	123	43.7	124	43.9	126	44.1	129	44.5	133	45.0							
100 (1150)	10	85.0	14.0	101	17.0	118	20.1	126	21.8	134	23.4	151	26.8	159	27.7							
	12	85.0	14.3	101	17.3	118	20.5	126	22.2	134	23.9	151	27.3	155	27.5							
	14	85.0	14.5	101	17.6	118	20.9	126	22.6	134	24.3	151	27.8	155	27.4							
	16	85.0	14.8	101	18.0	118	21.3	126	23.0	134	24.8	150	28.2	153	27.9							
	18	85.0	15.1	101	18.3	118	21.7	126	23.5	134	25.3	148	29.1	151	29.3							
	20	85.0	15.3	101	18.7	118	22.4	126	24.7	134	27.1	146	30.5	149	30.7							
	21	85.0	15.5	101	18.9	118	23.2	126	25.6	134	28.1	145	31.2	148	31.4							
	23	85.0	15.9	101	20.1	118	24.8	126	27.4	134	30.1	143	32.6	146	32.9							
	25	85.0	17.0	101	21.5	118	26.6	126	29.3	134	32.2	141	34.0	144	34.3							
	27	85.0	18.1	101	22.9	118	28.4	126	31.4	134	34.5	139	35.5	142	35.7							
	29	85.0	19.3	101	24.5	118	30.3	126	33.5	134	36.6	137	36.9	140	37.2							
	31	85.0	20.5	101	26.1	118	32.4	126	35.8	132	38.0	135	38.3	138	38.7							
	33	85.0	21.8	101	27.8	118	34.5	126	38.2	130	39.4	133	39.8	136	40.1							
	35	85.0	23.2	101	29.6	118	36.8	126	40.7	128	40.9	131	41.2	134	41.6							
	37	85.0	24.6	101	31.5	118	39.2	124	42.1	125	42.3	129	42.7	132	43.1							
	39	85.0	26.1	101	33.5	118	41.8	122	43.6	123	43.8	127	44.2	130	44.6							

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	14.0°CWB kW	16.0°CWB TC	16.0°CWB PI	16.0°CWB kW	18.0°CWB TC	18.0°CWB PI	18.0°CWB kW	19.0°CWB TC	19.0°CWB PI	19.0°CWB kW	20.0°CWB TC	20.0°CWB PI	20.0°CWB kW	22.0°CWB TC	22.0°CWB PI	22.0°CWB kW	24.0°CWB TC	24.0°CWB PI	24.0°CWB kW
90 (1035)	10	76.5	12.6	91.3	15.1	106	17.9	113	19.3	121	20.7	136	23.7	150	26.7							
	12	76.5	12.8	91.3	15.4	106	18.2	113	19.6	121	21.1	136	24.1	150	27.2							
	14	76.5	13.0	91.3	15.7	106	18.5	113	20.0	121	21.5	136	24.6	150	27.7							
	16	76.5	13.2	91.3	16.0	106	18.9	113	20.4	121	21.9	136	25.1	150	28.2							
	18	76.5	13.5	91.3	16.3	106	19.3	113	20.8	121	22.4	136	25.6	148	29.1							
	20	76.5	13.7	91.3	16.6	106	19.7	113	21.2	121	23.2	136	27.5	146	30.5							
	21	76.5	13.8	91.3	16.8	106	20.0	113	22.0	121	24.0	136	28.5	145	31.2							
	23	76.5	14.1	91.3	17.5	106	21.4	113	23.5	121	25.8	136	30.5	143	32.6							
	25	76.5	14.8	91.3	18.6	106	22.9	113	25.2	121	27.6	136	32.7	141	34.0							
	27	76.5	15.8	91.3	19.9	106	24.4	113	26.9	121	29.5	136	35.0	139	35.4							
	29	76.5	16.8	91.3	21.2	106	26.1	113	28.7	121	31.5	134	36.6	137	36.9							
	31	76.5	17.9	91.3	22.5	106	27.8	113	30.6	121	33.6	132	38.0	135	38.3							
	33	76.5	19.0	91.3	24.0	106	29.6	113	32.6	121	35.8	130	39.5	133	39.8							
	35	76.5	20.2	91.3	25.5	106	31.5	113	34.8	121	38.2	128	40.9	131	41.2							
	37	76.5	21.4	91.3	27.1	106	33.6	113	37.0	121	40.7	126	42.4	128	42.7							
	39	76.5	22.7	91.3	28.8	106	35.7	113	39.4	121	43.4	124	43.8	126	44.2							
80 (920)	10	68.0	11.1	81.1	13.3	94.2	15.7	101	16.9	107	18.1	120	20.7	134	23.3							
	12	68.0	11.3	81.1	13.6	94.2	16.0	101	17.2	107	18.5	120	21.1	134	23.7							
	14	68.0	11.5	81.1	13.8	94.2	16.3	101	17.5	107	18.8	120	21.5	134	24.2							
	16	68.0	11.7	81.1	14.1	94.2	16.6	101	17.8	107	19.2	120	21.9	134	24.7							
	18	68.0	11.9	81.1	14.3	94.2	16.9	101	18.2	107	19.5	120	22.3	134	25.1							
	20	68.0	12.1	81.1	14.6	94.2	17.2	101	18.6	107	19.9	120	23.1	134	26.9							
	21	68.0	12.2	81.1	14.7	94.2	17.4	101	18.7	107	20.3	120	23.9	134	27.9							
	23	68.0	12.5	81.1	15.0	94.2	18.2	101	19.9	107	21.8	120	25.7	134	29.9							
	25	68.0	12.9	81.1	16.0	94.2	19.4	101	21.3	107	23.3	120	27.5	134	32.0							
	27	68.0	13.7	81.1	17.0	94.2	20.7	101	22.8	107	24.9	120	29.3	134	34.2							
	29	68.0	14.5	81.1	18.1	94.2	22.1	101	24.3	107	26.5	120	31.3	134	36.6							
	31	68.0	15.4	81.1	19.3	94.2	23.6	101	25.9	107	28.3	120	33.5	132	38.0							
	33	68.0	16.4	81.1	20.5	94.2	25.1	101	27.5	107	30.1	120	35.7	129	39.4							
	35	68.0	17.4	81.1	21.8	94.2	26.7	101	29.3	107	32.1	120	38.0	127	40.9							
	37	68.0	18.4	81.1	23.1	94.2	28.4	101	31.2	107	34.2	120	40.5	125	42.3							
	39	68.0	19.5	81.1	24.5	94.2	30.2	101	33.2	107	36.4	120	43.2	123	43.8							
70 (805)	10	59.5	9.8	71.0	11.6	82.5	13.6	88.2	14.6	93.9	15.6	105	17.8	117	20.0							
	12	59.5	9.9	71.0	11.8	82.5	13.8	88.2	14.8	93.9	15.9	105	18.1	117	20.3							
	14	59.5	10.1	71.0	12.0	82.5	14.1	88.2	15.1	93.9	16.2	105	18.4	117	20.7							
	16	59.5	10.3	71.0	12.2	82.5	14.3	88.2	15.4	93.9	16.5	105	18.8	117	21.1							
	18	59.5	10.4	71.0	12.4	82.5	14.6	88.2	15.7	93.9	16.8	105	19.1	117	21.5							
	20	59.5	10.6	71.0	12.7	82.5	14.8	88.2	16.0	93.9	17.1	105	19.5	117	22.1							
	21	59.5	10.7	71.0	12.8	82.5	15.0	88.2	16.1	93.9	17.3	105	19.8	117	22.9							
	23	59.5	10.9	71.0	13.0	82.5	15.3	88.2	16.7	93.9	18.1	105	21.2	117	24.6							
	25	59.5	11.1	71.0	13.5	82.5	16.3	88.2	17.8	93.9	19.4	105	22.7	117	26.3							
	27	59.5	11.7	71.0	14.4	82.5	17.4	88.2	19.0	93.9	20.7	105	24.2	117	28.1							
	29	59.5	12.4	71.0	15.3	82.5	18.5	88.2	20.2	93.9	22.0	105	25.8	117	30.0							
	31	59.5	13.2	71.0	16.3	82.5	19.7	88.2	21.5	93.9	23.4	105	27.5	117	32.0							
	33	59.5	14.0	71.0	17.3	82.5	20.9	88.2	22.9	93.9	25.0	105	29.4	117	34.1							
	35	59.5	14.8	71.0	18.3	82.5	22.2	88.2	24.3	93.9	26.5	105	31.3	117	36.4							
	37	59.5	15.7	71.0	19.4	82.5	23.6	88.2	25.9	93.9	28.2	105	33.3	117	38.7							
	39	59.5	16.6	71.0	20.6	82.5	25.1	88.2	27.5	93.9	30.0	105	35.4	117	41.3							
60 (690)	10	51.0	8.52	60.9	10.0	70.7	11.6	75.6	12.4	80.5	13.2	90.3	15.0	100	16.8							
	12	51.0	8.64	60.9	10.2	70.7	11.8	75.6	12.6	80.5	13.5	90.3	15.2	100	17.1							
	14	51.0	8.77	60.9	10.3	70.7	12.0	75.6	12.8	80.5	13.7	90.3	15.5	100	17.4							
	16	51.0	8.90	60.9	10.5	70.7	12.2	75.6	13.0	80.5	13.9	90.3	15.8	100	17.7							
	18	51.0	9.0	60.9	10.7	70.7	12.4	75.6	13.3	80.5	14.2	90.3	16.1	100	18.1							
	20	51.0	9.2	60.9	10.8	70.7	12.6	75.6	13.5	80.5	14.5	90.3	16.4	100	18.4							
	21	51.0	9.3	60.9	10.9	70.7	12.7	75.6	13.7	80.5	14.6	90.3	16.6	100	18.6							
	23	51.0	9.4	60.9	11.1	70.7	13.0	75.6	13.9	80.5	14.9	90.3	17.2	100	19.8							
	25	51.0	9.6	60.9	11.3	70.7	13.5	75.6	14.6	80.5	15.8	90.3	18.4	100	21.1							
	27	51.0	9.9	60.9	12.0	70.7	14.3	75.6	15.6	80.5	16.9	90.3	19.6	100	22.6							
	29	51.0	10.5	60.9	12.7	70.7	15.2	75.6	16.6	80.5	17.9	90.3	20.9	100	24.1							
	31	51.0	11.1	60.9	13.5	70.7	16.2	75.6	17.6	80.5	19.1	90.3	22.2	100	25.6							
	33	51.0	11.8	60.9	14.3	70.7	17.2	75.6	18.7	80.5	20.3	90.3	23.7	100	27.3							
	35	51.0	12.4	60.9	15.2	70.7	18.2	75.6	19.8	80.5	21.5	90.3	25.2	100	29.1							
	37	51.0	13.1	60.9	16.1	70.7	19.3	75.6	21.1	80.5	22.9	90.3	26.7	100	30.9							
	39	51.0	13.9	60.9	17.0	70.7	20.5	75.6	22.3	80.5	24.3	90.3	28.4	100	32.9							
50 (575)	10	42.5	7.33	50.7	8.48	58.9	9.7	63.0	10.3	67.1	11.0	75.3	12.3	83.5	13.8							
	12	42.5	7.42	50.7	8.60	58.9	9.9	63.0	10.5	67.1	11.2	75.3	12.6	83.5	14.0							
	14	42.5	7.52	50.7	8.72	58.9	10.0	63.0	10.7	67.1	11.4	75.3	12.8	83.5	14.2							
	16	42.5	7.62	50.7	8.85	58.9	10.2	63.0	10.8	67.1	11.5	75.3	13.0	83.5	14.5							
	18	42.5	7.73	50.7	9.0	58.9	10.3	63.0	11.0	67.1	11.7	75.3	13.2	83.5	14.8							
	20	42.5	7.84	50.7	9.1	58.9	10.5	63.0	11.2	67.1	11.9	75.3	13.5	83.5	15.0							
	21	42.5	7.89	50.7	9.2	58.9	10.6	63.0	11.3	67.1	12.1	75.3	13.6	83.5	15.2							
	23	42.5	8.01	50.7	9.4	58.9	10.8	63.0	11.5	67.1	12.3	75.3	13.8	83.5	15.5							
	25	42.5	8.13	50.7	9.5	58.9	11.0	63.0	11.8	67.1	12.7	75.3	14.5	83.5	16.6							
	27	42.5	8.27	50.7	9.8	58.9	11.6	63.0	12.5	67.1	13.5	75.3	15.5	83.5	17.7							
	29	42.5	8.74	50.7	10.4	58.9	12.3	63.0	13.3	67.1	14.3	75.3	16.5	83.5	18.8							
	31	42.5	9.2	50.7	11.0	58.9	13.0	63.0	14.1	67.1	15.2	75.3	17.5	83.5	20.0							
	33	42.5	9.8	50.7	11.7	58.9	13.8	63.0	14.9	67.1	16.1	75.3	18.6	83.5	21.3							
	35	42.5	10.3	50.7	12.4	58.9	14.6	63.0	15.8	67.1	17.1	75.3	19.7	83.5	22.6							
	37	42.5	10.9	50.7	13.1	58.9	15.5	63.0	16.8	67.1	18.1	75.3	20.9	83.5	24.0							
	39	42.5	11.4	50.7	13.8	58.9	16.4	63.0	17.7	67.1	19.2	75.3	22.2	83.5	25.5							

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

14

RXYQ48PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination (%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1560)	10	115	19.2	138	23.5	160	28.0	166	28.5	168	28.0	172	26.8	176	25.6
	12	115	19.6	138	23.9	160	28.5	163	28.4	166	27.8	170	26.6	174	26.2
	14	115	19.9	138	24.4	159	28.8	161	28.2	163	27.6	168	27.4	172	27.7
	16	115	20.3	138	24.9	157	28.7	159	28.5	161	28.6	165	28.9	170	29.2
	18	115	20.7	138	25.4	155	29.8	157	30.0	159	30.1	163	30.4	167	30.7
	20	115	21.1	138	27.0	153	31.3	155	31.4	157	31.6	161	31.9	165	32.2
	21	115	21.7	138	28.0	152	32.0	154	32.1	156	32.3	160	32.6	164	32.9
	23	115	23.2	138	30.0	150	33.4	152	33.6	154	33.8	158	34.1	162	34.5
	25	115	24.9	138	32.1	147	34.9	150	35.1	152	35.3	156	35.6	160	36.0
	27	115	26.6	138	34.4	145	36.4	147	36.6	150	36.8	154	37.1	158	37.5
	29	115	28.3	138	36.7	143	37.8	145	38.1	147	38.3	152	38.7	156	39.1
	31	115	30.2	137	38.9	141	39.3	143	39.5	145	39.8	149	40.2	154	40.6
	33	115	32.2	135	40.4	139	40.8	141	41.0	143	41.3	147	41.7	151	42.2
	35	115	34.3	133	41.8	137	42.3	139	42.6	141	42.8	145	43.3	149	43.7
	37	115	36.5	131	43.3	135	43.8	137	44.1	139	44.3	143	44.8	147	45.3
	39	115	38.9	128	44.8	133	45.3	135	45.6	137	45.9	141	46.4	145	46.9
120 (1440)	10	106	17.5	127	21.4	148	25.5	158	27.5	165	28.7	169	27.6	173	26.5
	12	106	17.9	127	21.8	148	26.0	158	28.1	163	28.6	167	27.5	171	26.3
	14	106	18.2	127	22.2	148	26.5	158	28.6	161	28.4	165	27.3	168	27.5
	16	106	18.5	127	22.7	148	27.0	157	28.8	159	28.5	163	28.7	166	29.0
	18	106	18.9	127	23.1	148	27.9	155	29.8	157	29.9	160	30.2	164	30.5
	20	106	19.3	127	24.0	148	30.0	152	31.2	154	31.4	158	31.7	162	31.9
	21	106	19.5	127	24.9	148	31.1	151	32.0	153	32.1	157	32.4	161	32.7
	23	106	20.8	127	26.7	147	33.3	149	33.4	151	33.6	155	33.9	159	34.2
	25	106	22.2	127	28.6	145	34.7	147	34.9	149	35.0	153	35.4	157	35.7
	27	106	23.7	127	30.5	143	36.2	145	36.3	147	36.5	151	36.9	155	37.2
	29	106	25.3	127	32.6	141	37.6	143	37.8	145	38.0	149	38.4	152	38.7
	31	106	27.0	127	34.8	139	39.1	141	39.3	143	39.5	146	39.9	150	40.3
	33	106	28.7	127	37.1	137	40.6	139	40.8	140	41.0	144	41.4	148	41.8
	35	106	30.6	127	39.6	135	42.0	138	42.3	138	42.5	142	42.9	146	43.4
	37	106	32.5	127	42.2	130	43.5	134	43.8	136	44.0	140	44.5	144	44.9
	39	106	34.6	126	44.2	130	45.3	134	45.6	134	45.8	138	46.0	142	46.5
110 (1320)	10	98	15.9	116	19.4	135	23.0	145	24.9	154	25.8	166	28.4	169	27.5
	12	98	16.2	116	19.8	135	23.5	145	25.4	154	27.3	164	28.3	167	27.3
	14	98	16.5	116	20.1	135	23.9	145	25.9	154	27.8	162	28.1	165	27.3
	16	98	16.8	116	20.5	135	24.4	145	26.4	154	28.4	160	28.5	163	28.8
	18	98	17.1	116	20.9	135	24.9	145	27.1	154	29.7	157	30.0	161	30.2
	20	98	17.5	116	21.3	135	26.3	145	29.1	152	31.2	155	31.4	159	31.7
	21	98	17.6	116	22.0	135	27.3	145	30.2	151	31.9	154	32.2	158	32.4
	23	98	18.5	116	23.5	135	29.3	145	32.4	149	33.4	152	33.6	156	33.9
	25	98	19.7	116	25.2	135	31.3	145	34.7	146	34.8	150	35.1	153	35.4
	27	98	21.0	116	26.9	135	33.5	143	36.1	144	36.3	148	36.6	151	36.9
	29	98	22.4	116	28.7	135	35.8	140	37.6	142	37.7	146	38.1	149	38.4
	31	98	23.9	116	30.6	135	38.2	138	39.0	140	39.2	144	39.6	147	39.9
	33	98	25.4	116	32.6	134	40.3	136	40.5	138	40.7	141	41.1	145	41.5
	35	98	27.0	116	34.8	132	41.8	134	42.0	136	42.2	139	42.6	143	43.0
	37	98	28.8	116	37.0	130	43.3	132	43.5	134	43.7	137	44.1	141	44.5
	39	98	30.6	116	39.4	128	44.7	130	45.0	131	45.2	135	45.6	138	46.1
100 (1200)	10	88.7	14.4	106	17.4	123	20.6	132	22.3	140	24.0	157	27.4	166	28.4
	12	88.7	14.6	106	17.7	123	21.0	132	22.7	140	24.4	157	27.9	164	28.2
	14	88.7	14.9	106	18.1	123	21.4	132	23.2	140	24.9	157	28.5	162	28.1
	16	88.7	15.2	106	18.4	123	21.8	132	23.6	140	25.4	157	28.8	160	28.5
	18	88.7	15.4	106	18.8	123	22.3	132	24.1	140	25.9	154	29.8	158	30.0
	20	88.7	15.7	106	19.1	123	22.9	132	25.3	140	27.7	152	31.2	156	31.5
	21	88.7	15.9	106	19.3	123	23.8	132	26.2	140	28.7	151	31.9	154	32.2
	23	88.7	16.3	106	20.6	123	25.5	132	28.1	140	30.8	149	33.4	152	33.7
	25	88.7	17.4	106	22.0	123	27.2	132	30.0	140	33.0	147	34.9	150	35.1
	27	88.7	18.5	106	23.5	123	29.1	132	32.1	140	35.3	145	36.3	148	36.6
	29	88.7	19.7	106	25.1	123	31.1	132	34.3	140	37.5	143	37.8	146	38.1
	31	88.7	21.0	106	26.7	123	33.2	132	36.6	137	38.9	141	39.3	144	39.6
	33	88.7	22.3	106	28.5	123	35.4	132	39.1	135	40.4	138	40.8	142	41.1
	35	88.7	23.7	106	30.3	123	37.7	132	41.7	133	41.9	136	42.3	140	42.6
	37	88.7	25.2	106	32.2	123	40.2	129	43.2	131	43.4	134	43.8	137	44.1
	39	88.7	26.8	106	34.3	123	42.8	127	44.6	129	44.8	132	45.3	135	45.7

Cooling capacity

Combination (%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (1080)	10	79.9	12.9	95.3	15.5	111	18.3	118	19.8	126	21.2	141	24.3	157	27.3
	12	79.9	13.1	95.3	15.8	111	18.7	118	20.1	126	21.6	141	24.7	157	27.9
	14	79.9	13.3	95.3	16.1	111	19.0	118	20.5	126	22.1	141	25.2	157	28.4
	16	79.9	13.5	95.3	16.4	111	19.4	118	20.9	126	22.5	141	25.7	157	28.9
	18	79.9	13.8	95.3	16.7	111	19.7	118	21.3	126	22.9	141	26.2	154	29.8
	20	79.9	14.0	95.3	17.0	111	20.1	118	21.7	126	23.8	141	28.2	152	31.2
	21	79.9	14.2	95.3	17.2	111	20.5	118	22.5	126	24.6	141	29.2	151	31.9
	23	79.9	14.4	95.3	17.9	111	21.9	118	24.1	126	26.4	141	31.3	149	33.4
	25	79.9	15.2	95.3	19.1	111	23.4	118	25.8	126	28.2	141	33.5	147	34.9
	27	79.9	16.2	95.3	20.4	111	25.0	118	27.5	126	30.2	141	35.8	145	36.3
	29	79.9	17.2	95.3	21.7	111	26.7	118	29.4	126	32.2	140	37.5	143	37.8
	31	79.9	18.3	95.3	23.1	111	28.5	118	31.4	126	34.4	138	39.0	141	39.3
	33	79.9	19.5	95.3	24.6	111	30.3	118	33.4	126	36.7	135	40.4	138	40.8
	35	79.9	20.7	95.3	26.1	111	32.3	118	35.6	126	39.1	133	41.9	136	42.2
	37	79.9	21.9	95.3	27.8	111	34.4	118	37.9	126	41.7	131	43.4	134	43.7
	39	79.9	23.3	95.3	29.5	111	36.6	118	40.4	126	44.4	129	44.9	132	45.3
80 (960)	10	71.0	11.4	84.7	13.7	98	16.1	105	17.3	112	18.6	126	21.2	139	23.9
	12	71.0	11.6	84.7	13.9	98	16.4	105	17.6	112	18.9	126	21.6	139	24.3
	14	71.0	11.8	84.7	14.2	98	16.7	105	17.9	112	19.3	126	22.0	139	24.8
	16	71.0	12.0	84.7	14.4	98	17.0	105	18.3	112	19.6	126	22.4	139	25.3
	18	71.0	12.2	84.7	14.7	98	17.3	105	18.6	112	20.0	126	22.9	139	25.8
	20	71.0	12.4	84.7	14.9	98	17.6	105	19.0	112	20.4	126	23.7	139	27.6
	21	71.0	12.5	84.7	15.1	98	17.8	105	19.2	112	20.8	126	24.5	139	28.5
	23	71.0	12.8	84.7	15.4	98	18.7	105	20.4	112	22.3	126	26.3	139	30.6
	25	71.0	13.2	84.7	16.4	98	19.9	105	21.8	112	23.8	126	28.1	139	32.8
	27	71.0	14.0	84.7	17.4	98	21.3	105	23.3	112	25.5	126	30.1	139	35.1
	29	71.0	14.9	84.7	18.6	98	22.7	105	24.9	112	27.2	126	32.1	139	37.5
	31	71.0	15.8	84.7	19.7	98	24.1	105	26.5	112	29.0	126	34.3	137	38.9
	33	71.0	16.8	84.7	21.0	98	25.7	105	28.2	112	30.9	126	36.6	135	40.4
	35	71.0	17.8	84.7	22.3	98	27.3	105	30.0	112	32.9	126	39.0	133	41.9
	37	71.0	18.9	84.7	23.7	98	29.1	105	32.0	112	35.0	126	41.5	131	43.3
	39	71.0	20.0	84.7	25.1	98	30.9	105	34.0	112	37.3	126	44.2	129	44.8
70 (840)	10	62.1	10.0	74.1	11.9	86.1	13.9	92.1	14.9	98	16.0	110	18.2	122	20.5
	12	62.1	10.2	74.1	12.1	86.1	14.1	92.1	15.2	98	16.3	110	18.5	122	20.8
	14	62.1	10.4	74.1	12.3	86.1	14.4	92.1	15.5	98	16.6	110	18.9	122	21.2
	16	62.1	10.5	74.1	12.5	86.1	14.7	92.1	15.8	98	16.9	110	19.2	122	21.6
	18	62.1	10.7	74.1	12.7	86.1	14.9	92.1	16.1	98	17.2	110	19.6	122	22.1
	20	62.1	10.9	74.1	13.0	86.1	15.2	92.1	16.4	98	17.6	110	20.0	122	22.7
	21	62.1	11.0	74.1	13.1	86.1	15.4	92.1	16.5	98	17.7	110	20.3	122	23.5
	23	62.1	11.2	74.1	13.3	86.1	15.7	92.1	17.1	98	18.6	110	21.7	122	25.2
	25	62.1	11.4	74.1	13.9	86.1	16.7	92.1	18.2	98	19.8	110	23.2	122	26.9
	27	62.1	12.0	74.1	14.8	86.1	17.8	92.1	19.4	98	21.2	110	24.8	122	28.8
	29	62.1	12.7	74.1	15.7	86.1	19.0	92.1	20.7	98	22.6	110	26.5	122	30.7
	31	62.1	13.5	74.1	16.7	86.1	20.2	92.1	22.1	98	24.0	110	28.2	122	32.8
	33	62.1	14.3	74.1	17.7	86.1	21.4	92.1	23.5	98	25.6	110	30.1	122	35.0
	35	62.1	15.2	74.1	18.8	86.1	22.8	92.1	24.9	98	27.2	110	32.0	122	37.3
	37	62.1	16.0	74.1	19.9	86.1	24.2	92.1	26.5	98	28.9	110	34.1	122	39.7
	39	62.1	17.0	74.1	21.1	86.1	25.7	92.1	28.2	98	30.7	110	36.3	122	42.3
60 (720)	10	53.2	8.7	63.5	10.2	73.8	11.9	78.9	12.7	84.0	13.6	94.3	15.3	105	17.2
	12	53.2	8.9	63.5	10.4	73.8	12.1	78.9	12.9	84.0	13.8	94.3	15.6	105	17.5
	14	53.2	9.0	63.5	10.6	73.8	12.3	78.9	13.1	84.0	14.0	94.3	15.9	105	17.8
	16	53.2	9.1	63.5	10.7	73.8	12.5	78.9	13.4	84.0	14.3	94.3	16.2	105	18.2
	18	53.2	9.3	63.5	10.9	73.8	12.7	78.9	13.6	84.0	14.5	94.3	16.5	105	18.5
	20	53.2	9.4	63.5	11.1	73.8	12.9	78.9	13.9	84.0	14.8	94.3	16.8	105	18.9
	21	53.2	9.5	63.5	11.2	73.8	13.0	78.9	14.0	84.0	15.0	94.3	17.0	105	19.1
	23	53.2	9.6	63.5	11.4	73.8	13.3	78.9	14.3	84.0	15.3	94.3	17.6	105	20.3
	25	53.2	9.8	63.5	11.6	73.8	13.8	78.9	15.0	84.0	16.2	94.3	18.8	105	21.7
	27	53.2	10.2	63.5	12.3	73.8	14.7	78.9	15.9	84.0	17.3	94.3	20.1	105	23.1
	29	53.2	10.8	63.5	13.1	73.8	15.6	78.9	17.0	84.0	18.4	94.3	21.4	105	24.7
	31	53.2	11.4	63.5	13.9	73.8	16.6	78.9	18.0	84.0	19.5	94.3	22.8	105	26.3
	33	53.2	12.1	63.5	14.7	73.8	17.6	78.9	19.1	84.0	20.8	94.3	24.2	105	28.0
	35	53.2	12.7	63.5	15.6	73.8	18.7	78.9	20.3	84.0	22.1	94.3	25.8	105	29.8
	37	53.2	13.5	63.5	16.5	73.8	19.8	78.9	21.6	84.0	23.4	94.3	27.4	105	31.7
	39	53.2	14.2	63.5	17.4	73.8	21.0	78.9	22.9	84.0	24.9	94.3	29.1	105	33.7
50 (600)	10	44.4	7.51	52.9	8.7	61.5	9.9	65.8	10.6	70.0	11.3	78.6	12.6	87.1	14.1
	12	44.4	7.60	52.9	8.8	61.5	10.1	65.8	10.8	70.0	11.4	78.6	12.9	87.1	14.3
	14	44.4	7.70	52.9	8.9	61.5	10.2	65.8	10.9	70.0	11.6	78.6	13.1	87.1	14.6
	16	44.4	7.81	52.9	9.1	61.5	10.4	65.8	11.1	70.0	11.8	78.6	13.3	87.1	14.9
	18	44.4	7.92	52.9	9.2	61.5	10.6	65.8	11.3	70.0	12.0	78.6	13.5	87.1	15.1
	20	44.4	8.03	52.9	9.4	61.5	10.8	65.8	11.5	70.0	12.2	78.6	13.8	87.1	15.4
	21	44.4	8.09	52.9	9.4	61.5	10.9	65.8	11.6	70.0	12.4	78.6	13.9	87.1	15.6
	23	44.4	8.21	52.9	9.6	61.5	11.0	65.8	11.8	70.0	12.6	78.6	14.2	87.1	15.9
	25	44.4	8.33	52.9	9.7	61.5	11.2	65.8	12.0	70.0	13.0	78.6	14.9	87.1	17.0
	27	44.4	8.47	52.9	10.1	61.5	11.9	65.8	12.8	70.0	13.8	78.6	15.9	87.1	18.1
	29	44.4	9.0	52.9	10.7	61.5	12.6	65.8	13.6	70.0	14.6	78.6	16.9	87.1	19.3
	31	44.4	9.5	52.9	11.3	61.5	13.3	65.8	14.4	70.0	15.6	78.6	17.9	87.1	20.5
	33	44.4	10.0	52.9	12.0	61.5	14.1	65.8	15.3	70.0	16.5	78.6	19.0	87.1	21.8
	35	44.4	10.5	52.9	12.7	61.5	15.0	65.8	16.2	70.0	17.5	78.6	20.2	87.1	23.2
	37	44.4	11.1	52.9	13.4	61.5	15.8	65.8	17.2	70.0	18.5	78.6	21.5	87.1	24.6
	39	44.4	11.7	52.9	14.1	61.5	16.8	65.8	18.2	70.0	19.6	78.6	22.8	87.1	26.1

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

RXYQ50PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (1125)	10	83.8	13.9	100.0	16.8	116	19.9	124	21.4	132	23.0	148	26.3	165	29.6
	12	83.8	14.2	100.0	17.1	116	20.2	124	21.8	132	23.5	148	26.8	165	30.2
	14	83.8	14.4	100.0	17.4	116	20.6	124	22.2	132	23.9	148	27.3	165	30.8
	16	83.8	14.7	100.0	17.7	116	21.0	124	22.7	132	24.4	148	27.8	164	31.3
	18	83.8	14.9	100.0	18.1	116	21.4	124	23.1	132	24.8	148	28.4	162	32.3
	20	83.8	15.2	100.0	18.4	116	21.8	124	23.6	132	25.8	148	30.5	160	33.8
	21	83.8	15.4	100.0	18.6	116	22.2	124	24.4	132	26.7	148	31.6	159	34.6
	23	83.8	15.7	100.0	19.4	116	23.8	124	26.1	132	28.6	148	33.9	156	36.2
	25	83.8	16.5	100.0	20.7	116	25.4	124	27.9	132	30.6	148	36.3	154	37.8
	27	83.8	17.6	100.0	22.1	116	27.1	124	29.9	132	32.7	148	38.8	152	39.4
	29	83.8	18.7	100.0	23.5	116	28.9	124	31.9	132	34.9	147	40.7	150	41.0
	31	83.8	19.8	100.0	25.0	116	30.9	124	34.0	132	37.3	144	42.2	147	42.6
	33	83.8	21.1	100.0	26.6	116	32.9	124	36.2	132	39.8	142	43.8	145	44.2
	35	83.8	22.4	100.0	28.3	116	35.0	124	38.6	132	42.4	140	45.4	143	45.8
	37	83.8	23.8	100.0	30.1	116	37.3	124	41.1	132	45.2	138	47.0	141	47.4
	39	83.8	25.2	100.0	32.0	116	39.7	124	43.8	132	48.1	135	48.6	138	49.0
80 (1000)	10	74.5	12.4	88.9	14.8	103	17.4	110	18.8	118	20.1	132	23.0	146	25.9
	12	74.5	12.6	88.9	15.1	103	17.7	110	19.1	118	20.5	132	23.4	146	26.4
	14	74.5	12.8	88.9	15.3	103	18.0	110	19.5	118	20.9	132	23.8	146	26.9
	16	74.5	13.0	88.9	15.6	103	18.4	110	19.8	118	21.3	132	24.3	146	27.4
	18	74.5	13.2	88.9	15.9	103	18.7	110	20.2	118	21.7	132	24.8	146	27.9
	20	74.5	13.5	88.9	16.2	103	19.1	110	20.6	118	22.1	132	25.7	146	29.9
	21	74.5	13.6	88.9	16.4	103	19.3	110	20.8	118	22.6	132	26.6	146	30.9
	23	74.5	13.8	88.9	16.7	103	20.2	110	22.2	118	24.2	132	28.5	146	33.2
	25	74.5	14.3	88.9	17.7	103	21.6	110	23.7	118	25.8	132	30.5	146	35.5
	27	74.5	15.2	88.9	18.9	103	23.0	110	25.3	118	27.6	132	32.6	146	38.0
	29	74.5	16.1	88.9	20.1	103	24.6	110	27.0	118	29.5	132	34.8	146	40.6
	31	74.5	17.1	88.9	21.4	103	26.2	110	28.7	118	31.4	132	37.2	144	42.2
	33	74.5	18.2	88.9	22.7	103	27.8	110	30.6	118	33.5	132	39.6	142	43.8
	35	74.5	19.3	88.9	24.2	103	29.6	110	32.6	118	35.6	132	42.2	140	45.4
	37	74.5	20.4	88.9	25.7	103	31.5	110	34.6	118	37.9	132	45.0	137	47.0
	39	74.5	21.7	88.9	27.2	103	33.5	110	36.9	118	40.4	132	48.0	135	48.6
70 (875)	10	65.2	10.9	77.8	12.9	90.3	15.1	96.6	16.2	103	17.3	115	19.7	128	22.2
	12	65.2	11.0	77.8	13.1	90.3	15.3	96.6	16.5	103	17.7	115	20.1	128	22.6
	14	65.2	11.2	77.8	13.3	90.3	15.6	96.6	16.8	103	18.0	115	20.5	128	23.0
	16	65.2	11.4	77.8	13.6	90.3	15.9	96.6	17.1	103	18.3	115	20.8	128	23.5
	18	65.2	11.6	77.8	13.8	90.3	16.2	96.6	17.4	103	18.7	115	21.3	128	23.9
	20	65.2	11.8	77.8	14.1	90.3	16.5	96.6	17.7	103	19.0	115	21.7	128	24.6
	21	65.2	11.9	77.8	14.2	90.3	16.6	96.6	17.9	103	19.2	115	22.0	128	25.5
	23	65.2	12.1	77.8	14.5	90.3	17.0	96.6	18.5	103	20.1	115	23.6	128	27.3
	25	65.2	12.3	77.8	15.0	90.3	18.1	96.6	19.8	103	21.5	115	25.2	128	29.2
	27	65.2	13.0	77.8	16.0	90.3	19.3	96.6	21.1	103	22.9	115	26.9	128	31.2
	29	65.2	13.8	77.8	17.0	90.3	20.6	96.6	22.5	103	24.4	115	28.7	128	33.3
	31	65.2	14.6	77.8	18.1	90.3	21.9	96.6	23.9	103	26.0	115	30.6	128	35.5
	33	65.2	15.5	77.8	19.2	90.3	23.2	96.6	25.4	103	27.7	115	32.6	128	37.9
	35	65.2	16.4	77.8	20.3	90.3	24.7	96.6	27.0	103	29.5	115	34.7	128	40.4
	37	65.2	17.4	77.8	21.6	90.3	26.2	96.6	28.7	103	31.4	115	36.9	128	43.0
	39	65.2	18.4	77.8	22.9	90.3	27.8	96.6	30.5	103	33.3	115	39.3	128	45.8
60 (750)	10	55.9	9.5	66.6	11.1	77.4	12.9	82.8	13.8	88.2	14.7	99.0	16.6	110	18.6
	12	55.9	9.6	66.6	11.3	77.4	13.1	82.8	14.0	88.2	15.0	99.0	16.9	110	19.0
	14	55.9	9.7	66.6	11.5	77.4	13.3	82.8	14.2	88.2	15.2	99.0	17.2	110	19.3
	16	55.9	9.9	66.6	11.6	77.4	13.5	82.8	14.5	88.2	15.5	99.0	17.5	110	19.7
	18	55.9	10.0	66.6	11.8	77.4	13.8	82.8	14.7	88.2	15.8	99.0	17.9	110	20.1
	20	55.9	10.2	66.6	12.0	77.4	14.0	82.8	15.0	88.2	16.1	99.0	18.2	110	20.5
	21	55.9	10.3	66.6	12.1	77.4	14.1	82.8	15.2	88.2	16.2	99.0	18.4	110	20.7
	23	55.9	10.4	66.6	12.4	77.4	14.4	82.8	15.4	88.2	16.5	99.0	19.1	110	22.0
	25	55.9	10.6	66.6	12.6	77.4	15.0	82.8	16.2	88.2	17.6	99.0	20.4	110	23.5
	27	55.9	11.0	66.6	13.3	77.4	15.9	82.8	17.3	88.2	18.7	99.0	21.8	110	25.1
	29	55.9	11.7	66.6	14.2	77.4	16.9	82.8	18.4	88.2	19.9	99.0	23.2	110	26.7
	31	55.9	12.3	66.6	15.0	77.4	18.0	82.8	19.5	88.2	21.2	99.0	24.7	110	28.5
	33	55.9	13.1	66.6	15.9	77.4	19.1	82.8	20.8	88.2	22.5	99.0	26.3	110	30.3
	35	55.9	13.8	66.6	16.9	77.4	20.2	82.8	22.0	88.2	23.9	99.0	27.9	110	32.3
	37	55.9	14.6	66.6	17.9	77.4	21.5	82.8	23.4	88.2	25.4	99.0	29.7	110	34.3
	39	55.9	15.4	66.6	18.9	77.4	22.7	82.8	24.8	88.2	27.0	99.0	31.6	110	36.5
50 (625)	10	46.6	8.14	55.5	9.4	64.5	10.8	69.0	11.5	73.5	12.2	82.5	13.7	91.4	15.3
	12	46.6	8.24	55.5	9.5	64.5	10.9	69.0	11.7	73.5	12.4	82.5	13.9	91.4	15.5
	14	46.6	8.35	55.5	9.7	64.5	11.1	69.0	11.8	73.5	12.6	82.5	14.2	91.4	15.8
	16	46.6	8.46	55.5	9.8	64.5	11.3	69.0	12.0	73.5	12.8	82.5	14.4	91.4	16.1
	18	46.6	8.58	55.5	10.0	64.5	11.5	69.0	12.2	73.5	13.0	82.5	14.7	91.4	16.4
	20	46.6	8.70	55.5	10.1	64.5	11.7	69.0	12.5	73.5	13.3	82.5	15.0	91.4	16.7
	21	46.6	8.77	55.5	10.2	64.5	11.8	69.0	12.6	73.5	13.4	82.5	15.1	91.4	16.9
	23	46.6	8.90	55.5	10.4	64.5	12.0	69.0	12.8	73.5	13.6	82.5	15.4	91.4	17.3
	25	46.6	9.03	55.5	10.6	64.5	12.2	69.0	13.1	73.5	14.0	82.5	16.2	91.4	18.4
	27	46.6	9.18	55.5	10.9	64.5	12.9	69.0	13.9	73.5	14.9	82.5	17.2	91.4	19.6
	29	46.6	9.7	55.5	11.6	64.5	13.6	69.0	14.7	73.5	15.9	82.5	18.3	91.4	20.9
	31	46.6	10.3	55.5	12.3	64.5	14.5	69.0	15.6	73.5	16.9	82.5	19.4	91.4	22.2
	33	46.6	10.8	55.5	13.0	64.5	15.3	69.0	16.6	73.5	17.9	82.5	20.6	91.4	23.6
	35	46.6	11.4	55.5	13.7	64.5	16.2	69.0	17.6	73.5	19.0	82.5	21.9	91.4	25.1
	37	46.6	12.1	55.5	14.5	64.5	17.2	69.0	18.6	73.5	20.1	82.5	23.3	91.4	26.7
	39	46.6	12.7	55.5	15.3	64.5	18.2	69.0	19.7	73.5	21.3	82.5	24.7	91.4	28.3

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1625)	10	121	20.8	144	25.5	168	30.3	174	30.9	176	30.3	180	29.0	185	27.7
	12	121	21.2	144	26.0	168	30.9	172	30.8	174	30.1	178	28.8	182	28.4
	14	121	21.6	144	26.5	167	31.3	169	30.6	172	30.0	176	29.7	180	30.0
	16	121	22.0	144	27.0	165	31.1	167	30.9	169	31.0	174	31.3	178	31.6
	18	121	22.4	144	27.5	163	32.3	165	32.5	167	32.6	171	32.9	176	33.3
	20	121	22.9	144	29.3	160	33.9	163	34.0	165	34.2	169	34.6	173	34.9
	21	121	23.5	144	30.4	159	34.7	161	34.8	164	35.0	168	35.4	172	35.7
	23	121	25.2	144	32.5	157	36.2	159	36.4	161	36.6	166	37.0	170	37.4
	25	121	26.9	144	34.8	155	37.8	157	38.0	159	38.2	164	38.6	168	39.0
	27	121	28.8	144	37.3	153	39.4	155	39.6	157	39.8	161	40.3	166	40.7
	29	121	30.7	144	39.8	150	41.0	152	41.2	155	41.5	159	41.9	163	42.3
	31	121	32.8	144	42.2	148	42.6	150	42.9	152	43.1	157	43.6	161	44.0
	33	121	34.9	141	43.7	146	44.2	148	44.5	150	44.7	155	45.2	159	45.7
	35	121	37.2	139	45.3	144	45.9	146	46.1	148	46.4	152	46.9	157	47.4
	37	121	39.6	137	46.9	141	47.5	144	47.8	146	48.0	150	48.6	154	49.1
	39	121	42.2	135	48.5	139	49.1	141	49.4	143	49.7	148	50.3	152	50.9
120 (1500)	10	112	19.0	133	23.2	155	27.6	166	29.9	173	31.1	177	29.9	181	28.8
	12	112	19.4	133	23.7	155	28.1	166	30.4	171	30.9	175	29.8	179	28.6
	14	112	19.7	133	24.1	155	28.7	166	31.0	169	30.8	173	29.6	177	29.8
	16	112	20.1	133	24.6	155	29.2	164	31.2	167	30.8	171	31.1	175	31.4
	18	112	20.5	133	25.1	155	30.2	162	32.3	164	32.4	168	32.7	172	33.0
	20	112	20.9	133	26.1	155	32.5	160	33.8	162	34.0	166	34.3	170	34.6
	21	112	21.1	133	27.0	155	33.7	159	34.6	161	34.8	165	35.1	169	35.4
	23	112	22.5	133	28.9	155	36.0	157	36.2	159	36.4	163	36.7	167	37.1
	25	112	24.1	133	31.0	152	37.6	154	37.8	156	38.0	160	38.3	164	38.7
	27	112	25.7	133	33.1	150	39.2	152	39.4	154	39.6	158	40.0	162	40.3
	29	112	27.4	133	35.3	148	40.8	150	41.0	152	41.2	156	41.6	160	42.0
	31	112	29.2	133	37.7	146	42.4	148	42.6	150	42.8	154	43.2	158	43.7
	33	112	31.1	133	40.2	143	44.0	145	44.2	147	44.4	151	44.9	155	45.3
	35	112	33.1	133	42.9	141	45.6	143	45.8	145	46.1	149	46.5	153	47.0
	37	112	35.3	133	45.7	139	47.2	141	47.4	143	47.7	147	48.2	151	48.7
	39	112	37.5	133	48.3	137	48.8	139	49.1	141	49.3	145	49.9	149	50.4
110 (1375)	10	102	17.3	122	21.0	142	25.0	152	27.0	162	29.0	174	30.8	178	29.8
	12	102	17.6	122	21.4	142	25.4	152	27.5	162	29.6	172	30.7	176	29.6
	14	102	17.9	122	21.8	142	25.9	152	28.0	162	30.2	170	30.5	173	29.6
	16	102	18.2	122	22.2	142	26.4	152	28.6	162	30.7	167	30.9	171	31.2
	18	102	18.6	122	22.7	142	27.0	152	29.4	162	32.2	165	32.5	169	32.8
	20	102	18.9	122	23.1	142	28.6	152	31.6	159	33.8	163	34.1	167	34.4
	21	102	19.1	122	23.8	142	29.6	152	32.7	158	34.6	162	34.9	166	35.2
	23	102	20.0	122	25.5	142	31.7	152	35.1	156	36.2	160	36.5	163	36.8
	25	102	21.4	122	27.3	142	34.0	152	37.6	154	37.7	157	38.1	161	38.4
	27	102	22.8	122	29.2	142	36.3	150	39.1	151	39.3	155	39.7	159	40.0
	29	102	24.3	122	31.1	142	38.8	147	40.7	149	40.9	153	41.3	157	41.7
	31	102	25.9	122	33.2	142	41.4	145	42.3	147	42.5	151	42.9	154	43.3
	33	102	27.6	122	35.4	141	43.7	143	43.9	145	44.1	148	44.5	152	44.9
	35	102	29.3	122	37.7	139	45.3	141	45.5	142	45.7	146	46.2	150	46.6
	37	102	31.2	122	40.1	136	46.9	138	47.1	140	47.3	144	47.8	148	48.3
	39	102	33.1	122	42.7	134	48.5	136	48.7	138	49.0	142	49.5	145	50.0
100 (1250)	10	93.1	15.6	111	18.9	129	22.4	138	24.2	147	26.0	165	29.7	174	30.8
	12	93.1	15.8	111	19.2	129	22.8	138	24.6	147	26.5	165	30.3	172	30.6
	14	93.1	16.1	111	19.6	129	23.2	138	25.1	147	27.0	165	30.9	170	30.4
	16	93.1	16.4	111	20.0	129	23.7	138	25.6	147	27.5	164	31.3	168	30.9
	18	93.1	16.7	111	20.3	129	24.1	138	26.1	147	28.1	162	32.3	165	32.5
	20	93.1	17.0	111	20.7	129	24.9	138	27.4	147	30.1	160	33.8	163	34.1
	21	93.1	17.2	111	21.0	129	25.8	138	28.4	147	31.2	159	34.6	162	34.9
	23	93.1	17.7	111	22.3	129	27.6	138	30.4	147	33.4	157	36.2	160	36.5
	25	93.1	18.8	111	23.9	129	29.5	138	32.6	147	35.8	154	37.8	158	38.1
	27	93.1	20.1	111	25.5	129	31.5	138	34.8	147	38.3	152	39.4	155	39.7
	29	93.1	21.4	111	27.2	129	33.7	138	37.2	146	40.6	150	41.0	153	41.3
	31	93.1	22.8	111	29.0	129	35.9	138	39.7	144	42.2	148	42.6	151	42.9
	33	93.1	24.2	111	30.9	129	38.3	138	42.4	142	43.8	145	44.2	149	44.6
	35	93.1	25.7	111	32.8	129	40.9	138	45.2	140	45.4	143	45.8	146	46.2
	37	93.1	27.3	111	35.0	129	43.5	136	46.8	137	47.0	141	47.4	144	47.8
	39	93.1	29.0	111	37.2	129	46.4	134	48.4	135	48.6	139	49.1	142	49.5

RXYQ52PAY1, PAYL, PTL [50/60Hz]

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1690)	10	125	21.6	150	26.5	174	31.5	180	32.2	182	31.5	187	30.2	191	28.8
	12	125	22.0	150	27.0	174	32.1	178	32.0	180	31.3	185	30.0	189	29.5
	14	125	22.5	150	27.5	173	32.5	175	31.8	178	31.2	182	30.9	187	31.2
	16	125	22.9	150	28.0	171	32.3	173	32.1	175	32.3	180	32.6	184	32.9
	18	125	23.3	150	28.6	169	33.6	171	33.8	173	33.9	178	34.3	182	34.6
	20	125	23.8	150	30.5	166	35.2	168	35.4	171	35.6	175	35.9	180	36.3
	21	125	24.5	150	31.6	165	36.0	167	36.2	170	36.4	174	36.8	179	37.1
	23	125	26.2	150	33.8	163	37.7	165	37.9	167	38.1	172	38.5	176	38.8
	25	125	28.0	150	36.2	160	39.3	163	39.5	165	39.7	169	40.2	174	40.6
	27	125	29.9	150	38.8	158	41.0	160	41.2	163	41.4	167	41.9	172	42.3
	29	125	31.9	150	41.4	156	42.7	158	42.9	160	43.1	165	43.6	169	44.0
	31	125	34.1	149	43.8	153	44.3	156	44.6	158	44.8	162	45.3	167	45.8
	33	125	36.3	147	45.5	151	46.0	153	46.3	156	46.5	160	47.0	165	47.5
	35	125	38.7	144	47.1	149	47.7	151	48.0	153	48.2	158	48.8	162	49.3
	37	125	41.2	142	48.8	146	49.4	149	49.7	151	50.0	155	50.5	160	51.1
	39	125	43.8	140	50.5	144	51.1	146	51.4	149	51.7	153	52.3	158	52.9
120 (1560)	10	116	19.8	138	24.2	160	28.7	172	31.0	180	32.3	184	31.1	188	29.9
	12	116	20.1	138	24.6	160	29.3	172	31.6	177	32.2	181	30.9	186	29.7
	14	116	20.5	138	25.1	160	29.8	172	32.2	175	32.0	179	30.8	183	31.0
	16	116	20.9	138	25.6	160	30.4	170	32.5	173	32.1	177	32.4	181	32.6
	18	116	21.3	138	26.1	160	31.4	168	33.6	170	33.7	174	34.0	179	34.3
	20	116	21.7	138	27.1	160	33.8	166	35.2	168	35.4	172	35.7	176	36.0
	21	116	21.9	138	28.1	160	35.0	165	36.0	167	36.2	171	36.5	175	36.8
	23	116	23.4	138	30.1	160	37.5	162	37.7	164	37.8	169	38.2	173	38.5
	25	116	25.0	138	32.2	158	39.1	160	39.3	162	39.5	166	39.9	170	40.2
	27	116	26.7	138	34.4	156	40.8	158	41.0	160	41.2	164	41.6	168	42.0
	29	116	28.5	138	36.7	153	42.4	155	42.6	157	42.8	162	43.2	166	43.7
	31	116	30.4	138	39.2	151	44.1	153	44.3	155	44.5	159	45.0	163	45.4
	33	116	32.4	138	41.8	149	45.7	151	46.0	153	46.2	157	46.7	161	47.1
	35	116	34.5	138	44.6	146	47.4	148	47.6	150	47.9	155	48.4	159	48.9
	37	116	36.7	138	47.5	144	49.1	146	49.3	148	49.6	152	50.1	156	50.6
	39	116	39.0	137	50.2	142	50.8	144	51.0	146	51.3	150	51.9	154	52.4
110 (1430)	10	106	18.0	127	21.9	147	26.0	157	28.1	168	30.2	180	32.1	184	30.9
	12	106	18.3	127	22.3	147	26.5	157	28.6	168	30.8	178	31.9	182	30.8
	14	106	18.6	127	22.7	147	27.0	157	29.1	168	31.4	176	31.7	180	30.8
	16	106	19.0	127	23.1	147	27.5	157	29.7	168	32.0	174	32.1	177	32.4
	18	106	19.3	127	23.6	147	28.0	157	30.5	167	33.5	171	33.8	175	34.1
	20	106	19.7	127	24.1	147	28.7	157	32.8	165	35.1	169	35.4	173	35.7
	21	106	19.9	127	24.8	147	30.8	157	34.0	164	36.0	168	36.3	172	36.6
	23	106	20.8	127	26.5	147	33.0	157	36.5	162	37.6	165	37.9	169	38.2
	25	106	22.2	127	28.4	147	35.3	157	39.1	159	39.2	163	39.6	167	39.9
	27	106	23.7	127	30.3	147	37.8	155	40.7	157	40.9	161	41.2	165	41.6
	29	106	25.3	127	32.4	147	40.4	153	42.3	155	42.5	158	42.9	162	43.3
	31	106	26.9	127	34.5	147	43.1	150	44.0	152	44.2	156	44.6	160	45.0
	33	106	28.7	127	36.8	146	45.4	148	45.7	150	45.9	154	46.3	158	46.7
	35	106	30.5	127	39.2	144	47.1	146	47.3	148	47.5	151	48.0	155	48.5
	37	106	32.4	127	41.7	141	48.8	143	49.0	145	49.2	149	49.7	153	50.2
	39	106	34.4	127	44.4	139	50.4	141	50.7	143	50.9	147	51.4	151	51.9
100 (1300)	10	96.5	16.2	115	19.6	134	23.3	143	25.1	152	27.0	171	30.9	181	32.0
	12	96.5	16.5	115	20.0	134	23.7	143	25.6	152	27.5	171	31.5	178	31.8
	14	96.5	16.8	115	20.4	134	24.2	143	26.1	152	28.1	171	32.1	176	31.6
	16	96.5	17.1	115	20.8	134	24.6	143	26.6	152	28.6	170	32.5	174	32.2
	18	96.5	17.4	115	21.2	134	25.1	143	27.1	152	29.2	168	33.6	171	33.8
	20	96.5	17.7	115	21.6	134	25.9	143	28.5	152	31.3	166	35.2	169	35.5
	21	96.5	17.9	115	21.8	134	26.8	143	29.5	152	32.4	165	36.0	168	36.3
	23	96.5	18.4	115	23.2	134	28.7	143	31.6	152	34.7	162	37.6	166	37.9
	25	96.5	19.6	115	24.8	134	30.7	143	33.9	152	37.2	160	39.3	163	39.6
	27	96.5	20.9	115	26.5	134	32.8	143	36.2	152	39.8	158	40.9	161	41.3
	29	96.5	22.2	115	28.3	134	35.0	143	38.7	152	42.3	155	42.6	159	43.0
	31	96.5	23.7	115	30.1	134	37.4	143	41.3	149	43.9	153	44.3	156	44.6
	33	96.5	25.2	115	32.1	134	39.9	143	44.1	147	45.5	151	45.9	154	46.3
	35	96.5	26.8	115	34.2	134	42.5	143	47.0	145	47.2	148	47.6	152	48.0
	37	96.5	28.4	115	36.3	134	45.3	141	48.7	142	48.9	146	49.3	149	49.8
	39	96.5	30.2	115	38.7	134	48.2	138	50.3	140	50.5	144	51.0	147	51.5

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC	14.0°CWB PI	16.0°CWB TC	16.0°CWB PI	18.0°CWB TC	18.0°CWB PI	19.0°CWB TC	19.0°CWB PI	20.0°CWB TC	20.0°CWB PI	22.0°CWB TC	22.0°CWB PI	24.0°CWB TC	24.0°CWB PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
90 (1170)	10	86.9	14.5	103.6	17.5	120	20.6	129	22.3	137	23.9	154	27.3	171	30.8
	12	86.9	14.7	103.6	17.8	120	21.0	129	22.7	137	24.4	154	27.9	171	31.4
	14	86.9	15.0	103.6	18.1	120	21.4	129	23.1	137	24.9	154	28.4	171	32.0
	16	86.9	15.3	103.6	18.5	120	21.8	129	23.6	137	25.3	154	29.0	170	32.5
	18	86.9	15.5	103.6	18.8	120	22.2	129	24.0	137	25.8	154	29.5	168	33.5
	20	86.9	15.8	103.6	19.2	120	22.7	129	24.5	137	26.8	154	31.7	166	35.2
	21	86.9	16.0	103.6	19.4	120	23.1	129	25.4	137	27.8	154	32.9	164	36.0
	23	86.9	16.3	103.6	20.2	120	24.7	129	27.2	137	29.7	154	35.3	162	37.6
	25	86.9	17.1	103.6	21.5	120	26.4	129	29.1	137	31.8	154	37.8	160	39.3
	27	86.9	18.2	103.6	22.9	120	28.2	129	31.0	137	34.0	154	40.4	157	40.9
	29	86.9	19.4	103.6	24.5	120	30.1	129	33.1	137	36.3	152	42.3	155	42.6
	31	86.9	20.6	103.6	26.0	120	32.1	129	35.3	137	38.8	150	43.9	153	44.3
	33	86.9	21.9	103.6	27.7	120	34.2	129	37.7	137	41.4	147	45.6	150	45.9
	35	86.9	23.3	103.6	29.5	120	36.4	129	40.2	137	44.1	145	47.2	148	47.6
	37	86.9	24.7	103.6	31.3	120	38.7	129	42.8	137	47.0	143	48.9	146	49.3
	39	86.9	26.2	103.6	33.3	120	41.2	129	45.5	137	50.1	140	50.6	144	51.0
80 (1040)	10	77.2	12.9	92.1	15.4	107	18.1	114	19.5	122	20.9	137	23.9	152	26.9
	12	77.2	13.1	92.1	15.7	107	18.4	114	19.9	122	21.3	137	24.3	152	27.4
	14	77.2	13.3	92.1	15.9	107	18.8	114	20.2	122	21.7	137	24.8	152	27.9
	16	77.2	13.5	92.1	16.2	107	19.1	114	20.6	122	22.1	137	25.3	152	28.5
	18	77.2	13.8	92.1	16.5	107	19.5	114	21.0	122	22.6	137	25.8	152	29.0
	20	77.2	14.0	92.1	16.8	107	19.9	114	21.4	122	23.0	137	26.7	152	31.1
	21	77.2	14.1	92.1	17.0	107	20.1	114	21.6	122	23.5	137	27.7	152	32.2
	23	77.2	14.4	92.1	17.3	107	21.0	114	23.0	122	25.1	137	29.6	152	34.5
	25	77.2	14.8	92.1	18.4	107	22.5	114	24.6	122	26.9	137	31.7	152	36.9
	27	77.2	15.8	92.1	19.7	107	24.0	114	26.3	122	28.7	137	33.9	152	39.5
	29	77.2	16.8	92.1	20.9	107	25.5	114	28.0	122	30.6	137	36.2	152	42.2
	31	77.2	17.8	92.1	22.3	107	27.2	114	29.9	122	32.7	137	38.6	149	43.9
	33	77.2	18.9	92.1	23.7	107	29.0	114	31.8	122	34.8	137	41.2	147	45.5
	35	77.2	20.1	92.1	25.1	107	30.8	114	33.9	122	37.1	137	43.9	145	47.2
	37	77.2	21.3	92.1	26.7	107	32.8	114	36.0	122	39.5	137	46.8	142	48.9
	39	77.2	22.5	92.1	28.3	107	34.8	114	38.3	122	41.9	137	49.7	142	50.5
70 (910)	10	67.6	11.3	80.6	13.4	93.6	15.7	100.1	16.8	107	18.0	120	20.5	133	23.1
	12	67.6	11.5	80.6	13.6	93.6	15.9	100.1	17.1	107	18.4	120	20.9	133	23.5
	14	67.6	11.7	80.6	13.9	93.6	16.2	100.1	17.4	107	18.7	120	21.3	133	23.9
	16	67.6	11.9	80.6	14.1	93.6	16.5	100.1	17.8	107	19.0	120	21.7	133	24.4
	18	67.6	12.0	80.6	14.4	93.6	16.8	100.1	18.1	107	19.4	120	22.1	133	24.9
	20	67.6	12.3	80.6	14.6	93.6	17.1	100.1	18.5	107	19.8	120	22.5	133	25.6
	21	67.6	12.4	80.6	14.8	93.6	17.3	100.1	18.6	107	20.0	120	22.9	133	26.5
	23	67.6	12.6	80.6	15.0	93.6	17.7	100.1	19.3	107	20.9	120	24.5	133	28.4
	25	67.6	12.8	80.6	15.6	93.6	18.8	100.1	20.6	107	22.4	120	26.2	133	30.3
	27	67.6	13.5	80.6	16.6	93.6	20.1	100.1	21.9	107	23.9	120	28.0	133	32.4
	29	67.6	14.4	80.6	17.7	93.6	21.4	100.1	23.4	107	25.4	120	29.8	133	34.6
	31	67.6	15.2	80.6	18.8	93.6	22.7	100.1	24.9	107	27.1	120	31.8	133	36.9
	33	67.6	16.1	80.6	19.9	93.6	24.2	100.1	26.4	107	28.8	120	33.9	133	39.4
	35	67.6	17.1	80.6	21.2	93.6	25.7	100.1	28.1	107	30.7	120	36.1	133	42.0
	37	67.6	18.1	80.6	22.4	93.6	27.3	100.1	29.9	107	32.6	120	38.4	133	44.7
	39	67.6	19.1	80.6	23.8	93.6	29.0	100.1	31.7	107	34.7	120	40.9	133	47.6
60 (780)	10	57.9	9.8	69.1	11.6	80.2	13.4	85.8	14.3	91.4	15.3	102.5	17.3	114	19.4
	12	57.9	10.0	69.1	11.7	80.2	13.6	85.8	14.6	91.4	15.5	102.5	17.6	114	19.7
	14	57.9	10.1	69.1	11.9	80.2	13.8	85.8	14.8	91.4	15.8	102.5	17.9	114	20.1
	16	57.9	10.3	69.1	12.1	80.2	14.1	85.8	15.1	91.4	16.1	102.5	18.2	114	20.5
	18	57.9	10.4	69.1	12.3	80.2	14.3	85.8	15.3	91.4	16.4	102.5	18.6	114	20.9
	20	57.9	10.6	69.1	12.5	80.2	14.6	85.8	15.6	91.4	16.7	102.5	18.9	114	21.3
	21	57.9	10.7	69.1	12.6	80.2	14.7	85.8	15.8	91.4	16.9	102.5	19.1	114	21.5
	23	57.9	10.9	69.1	12.8	80.2	15.0	85.8	16.1	91.4	17.2	102.5	19.9	114	22.8
	25	57.9	11.0	69.1	13.1	80.2	15.5	85.8	16.9	91.4	18.3	102.5	21.2	114	24.4
	27	57.9	11.4	69.1	13.9	80.2	16.5	85.8	18.0	91.4	19.5	102.5	22.6	114	26.1
	29	57.9	12.1	69.1	14.7	80.2	17.6	85.8	19.1	91.4	20.7	102.5	24.1	114	27.8
	31	57.9	12.8	69.1	15.6	80.2	18.7	85.8	20.3	91.4	22.0	102.5	25.7	114	29.6
	33	57.9	13.6	69.1	16.5	80.2	19.8	85.8	21.6	91.4	23.4	102.5	27.3	114	31.5
	35	57.9	14.4	69.1	17.5	80.2	21.0	85.8	22.9	91.4	24.9	102.5	29.1	114	33.6
	37	57.9	15.2	69.1	18.6	80.2	22.3	85.8	24.3	91.4	26.4	102.5	30.9	114	35.7
	39	57.9	16.0	69.1	19.6	80.2	23.6	85.8	25.8	91.4	28.0	102.5	32.8	114	38.0
50 (650)	10	48.3	8.46	57.6	9.8	66.9	11.2	71.5	11.9	76.1	12.7	85.4	14.3	94.7	15.9
	12	48.3	8.57	57.6	9.9	66.9	11.4	71.5	12.1	76.1	12.9	85.4	14.5	94.7	16.2
	14	48.3	8.68	57.6	10.1	66.9	11.6	71.5	12.3	76.1	13.1	85.4	14.7	94.7	16.4
	16	48.3	8.80	57.6	10.2	66.9	11.7	71.5	12.5	76.1	13.3	85.4	15.0	94.7	16.7
	18	48.3	8.92	57.6	10.4	66.9	11.9	71.5	12.7	76.1	13.6	85.4	15.3	94.7	17.0
	20	48.3	9.05	57.6	10.5	66.9	12.1	71.5	13.0	76.1	13.8	85.4	15.5	94.7	17.4
	21	48.3	9.12	57.6	10.6	66.9	12.2	71.5	13.1	76.1	13.9	85.4	15.7	94.7	17.5
	23	48.3	9.25	57.6	10.8	66.9	12.4	71.5	13.3	76.1	14.2	85.4	16.0	94.7	17.9
	25	48.3	9.39	57.6	11.0	66.9	12.7	71.5	13.6	76.1	14.6	85.4	16.8	94.7	19.1
	27	48.3	9.55	57.6	11.4	66.9	13.4	71.5	14.4	76.1	15.5	85.4	17.9	94.7	20.4
	29	48.3	10.1	57.6	12.0	66.9	14.2	71.5	15.3	76.1	16.5	85.4	19.0	94.7	21.7
	31	48.3	10.7	57.6	12.8	66.9	15.0	71.5	16.3	76.1	17.5	85.4	20.2	94.7	23.1
	33	48.3	11.3	57.6	13.5	66.9	15.9	71.5	17.2	76.1	18.6	85.4	21.5	94.7	24.6
	35	48.3	11.9	57.6	14.3	66.9	16.9	71.5	18.3	76.1	19.7	85.4	22.8	94.7	26.1
	37	48.3	12.5	57.6	15.1	66.9	17.9	71.5	19.3	76.1	20.9	85.4	24.2	94.7	27.7
	39	48.3	13.2	57.6	15.9	66.9	18.9	71.5	20.5	76.1	22.1	85.4	25.7	94.7	29.4

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
130 (1755)	10	129	22.7	154	27.7	179	33.0	185	33.7	187	33.0	192	31.6	197	30.2
	12	129	23.1	154	28.3	179	33.6	183	33.5	185	32.8	190	31.4	194	30.9
	14	129	23.5	154	28.8	178	34.0	180	33.3	183	32.6	187	32.4	192	32.7
	16	129	24.0	154	29.4	176	33.9	178	33.6	180	33.8	185	34.1	190	34.4
	18	129	24.4	154	29.9	173	35.2	176	35.3	178	35.5	183	35.9	187	36.2
	20	129	24.9	154	31.9	171	36.9	173	37.1	176	37.2	180	37.6	185	38.0
	21	129	25.6	154	33.0	170	37.7	172	37.9	174	38.1	179	38.5	184	38.9
	23	129	27.4	154	35.4	167	39.5	170	39.7	172	39.9	177	40.3	181	40.7
	25	129	29.3	154	37.9	165	41.2	167	41.4	170	41.6	174	42.0	179	42.5
	27	129	31.3	154	40.6	162	42.9	165	43.1	167	43.4	172	43.8	176	44.3
	29	129	33.4	154	43.4	160	44.7	162	44.9	165	45.1	169	45.6	174	46.1
	31	129	35.7	153	45.9	158	46.4	160	46.7	162	46.9	167	47.4	172	47.9
	33	129	38.0	151	47.6	155	48.2	158	48.4	160	48.7	165	49.2	169	49.8
	35	129	40.5	148	49.4	153	49.9	155	50.2	158	50.5	162	51.1	167	51.6
	37	129	43.1	146	51.1	151	51.7	153	52.0	155	52.3	160	52.9	164	53.5
	39	129	45.9	143	52.8	148	53.5	150	53.8	153	54.1	157	54.7	162	55.4
120 (1620)	10	119	20.7	142	25.3	165	30.1	176	32.5	185	33.9	189	32.6	193	31.3
	12	119	21.1	142	25.8	165	30.6	176	33.1	182	33.7	186	32.4	191	31.1
	14	119	21.5	142	26.3	165	31.2	176	33.7	180	33.5	184	32.2	188	32.4
	16	119	21.9	142	26.8	165	31.8	175	34.0	177	33.6	182	33.9	186	34.2
	18	119	22.3	142	27.3	165	32.9	173	35.1	175	35.3	179	35.6	184	35.9
	20	119	22.7	142	28.4	165	35.4	170	36.8	173	37.0	177	37.4	181	37.7
	21	119	23.0	142	29.4	165	36.7	169	37.7	171	37.9	176	38.2	180	38.6
	23	119	24.5	142	31.5	165	39.2	167	39.4	169	39.6	173	40.0	178	40.3
	25	119	26.2	142	33.7	162	40.9	164	41.1	167	41.3	171	41.7	175	42.1
	27	119	28.0	142	36.0	160	42.7	162	42.9	164	43.1	169	43.5	173	43.9
	29	119	29.8	142	38.5	158	44.4	160	44.6	162	44.8	166	45.3	170	45.7
	31	119	31.8	142	41.1	155	46.1	157	46.4	159	46.6	164	47.1	168	47.5
	33	119	33.9	142	43.8	153	47.9	155	48.1	157	48.4	161	48.8	166	49.3
	35	119	36.1	142	46.7	150	49.6	153	49.9	155	50.1	159	50.7	163	51.2
	37	119	38.4	142	49.8	148	51.4	150	51.6	152	51.9	157	52.5	161	53.0
	39	119	40.8	141	52.5	146	53.1	148	53.4	150	53.7	154	54.3	158	54.9
110 (1485)	10	109	18.8	130	22.9	151	27.2	162	29.4	172	31.6	186	33.6	189	32.4
	12	109	19.1	130	23.3	151	27.7	162	29.9	172	32.2	183	33.4	187	32.2
	14	109	19.5	130	23.8	151	28.2	162	30.5	172	32.8	181	33.2	185	32.2
	16	109	19.8	130	24.2	151	28.8	162	31.1	172	33.5	178	33.6	182	33.9
	18	109	20.2	130	24.7	151	29.3	162	32.0	172	35.1	176	35.4	180	35.7
	20	109	20.6	130	25.2	151	31.1	162	34.4	170	36.8	174	37.1	178	37.4
	21	109	20.8	130	25.9	151	32.2	162	35.6	168	37.6	172	38.0	176	38.3
	23	109	21.8	130	27.8	151	34.5	162	38.2	166	39.4	170	39.7	174	40.0
	25	109	23.3	130	29.7	151	37.0	162	40.9	164	41.1	168	41.4	172	41.8
	27	109	24.8	130	31.7	151	39.5	159	42.6	161	42.8	165	43.2	169	43.6
	29	109	26.5	130	33.9	151	42.2	157	44.3	159	44.5	163	44.9	167	45.3
	31	109	28.2	130	36.1	151	45.1	155	46.1	157	46.3	160	46.7	164	47.1
	33	109	30.0	130	38.5	150	47.6	152	47.8	154	48.0	158	48.5	162	48.9
	35	109	31.9	130	41.0	148	49.3	150	49.5	152	49.8	156	50.3	160	50.7
	37	109	33.9	130	43.7	145	51.0	147	51.3	149	51.5	153	52.0	157	52.5
	39	109	36.1	130	46.5	143	52.8	145	53.0	147	53.3	151	53.8	155	54.4
100 (1350)	10	99.2	17.0	118	20.6	137	24.4	147	26.3	157	28.3	176	32.3	186	33.5
	12	99.2	17.2	118	20.9	137	24.8	147	26.8	157	28.8	176	33.0	183	33.3
	14	99.2	17.6	118	21.3	137	25.3	147	27.3	157	29.4	176	33.6	181	33.1
	16	99.2	17.9	118	21.7	137	25.8	147	27.9	157	30.0	175	34.0	179	33.7
	18	99.2	18.2	118	22.1	137	26.3	147	28.4	157	30.6	173	35.1	176	35.4
	20	99.2	18.6	118	22.6	137	27.1	147	29.8	157	32.7	170	36.8	174	37.1
	21	99.2	18.7	118	22.8	137	28.0	147	30.9	157	33.9	169	37.7	173	38.0
	23	99.2	19.2	118	24.3	137	30.0	147	33.1	157	36.4	167	39.4	170	39.7
	25	99.2	20.5	118	26.0	137	32.1	147	35.5	157	38.9	164	41.1	168	41.5
	27	99.2	21.9	118	27.7	137	34.3	147	37.9	157	41.7	162	42.9	166	43.2
	29	99.2	23.3	118	29.6	137	36.7	147	40.5	156	44.2	160	44.6	163	45.0
	31	99.2	24.8	118	31.5	137	39.1	147	43.2	154	46.0	157	46.3	161	46.7
	33	99.2	26.3	118	33.6	137	41.7	147	46.1	151	47.7	155	48.1	158	48.5
	35	99.2	28.0	118	35.8	137	44.5	147	49.2	149	49.4	152	49.9	156	50.3
	37	99.2	29.8	118	38.0	137	47.4	145	50.9	146	51.2	150	51.6	154	52.1
	39	99.2	31.6	118	40.5	137	50.5	142	52.7	144	52.9	148	53.4	151	53.9

Cooling capacity

Combination(%) (Capacity index)	Outdoor air temp. °CDB	Indoor air temp. 14.0°CWB TC kW	14.0°CWB PI kW	16.0°CWB TC kW	16.0°CWB PI kW	18.0°CWB TC kW	18.0°CWB PI kW	19.0°CWB TC kW	19.0°CWB PI kW	20.0°CWB TC kW	20.0°CWB PI kW	22.0°CWB TC kW	22.0°CWB PI kW	24.0°CWB TC kW	24.0°CWB PI kW
90 (1215)	10	89.3	15.2	106.5	18.3	124	21.6	132	23.3	141	25.1	158	28.6	175	32.3
	12	89.3	15.4	106.5	18.6	124	22.0	132	23.8	141	25.5	158	29.2	175	32.9
	14	89.3	15.7	106.5	19.0	124	22.4	132	24.2	141	26.0	158	29.7	175	33.5
	16	89.3	16.0	106.5	19.3	124	22.8	132	24.7	141	26.5	158	30.3	175	34.1
	18	89.3	16.3	106.5	19.7	124	23.3	132	25.2	141	27.0	158	30.9	173	35.1
	20	89.3	16.6	106.5	20.1	124	23.8	132	25.7	141	28.1	158	33.2	170	36.8
	21	89.3	16.7	106.5	20.3	124	24.2	132	26.6	141	29.1	158	34.4	169	37.7
	23	89.3	17.0	106.5	21.1	124	25.9	132	28.4	141	31.1	158	36.9	167	39.4
	25	89.3	17.9	106.5	22.5	124	27.6	132	30.4	141	33.3	158	39.5	164	41.1
	27	89.3	19.1	106.5	24.0	124	29.5	132	32.5	141	35.6	158	42.3	162	42.9
	29	89.3	20.3	106.5	25.6	124	31.5	132	34.7	141	38.0	156	44.3	159	44.6
	31	89.3	21.6	106.5	27.3	124	33.6	132	37.0	141	40.6	154	46.0	157	46.3
	33	89.3	23.0	106.5	29.0	124	35.8	132	39.4	141	43.3	151	47.7	155	48.1
	35	89.3	24.4	106.5	30.8	124	38.1	132	42.0	141	46.2	149	49.5	152	49.8
	37	89.3	25.9	106.5	32.8	124	40.6	132	44.8	141	49.2	147	51.2	150	51.6
	39	89.3	27.4	106.5	34.8	124	43.2	132	47.7	141	52.4	144	53.0	148	53.4
80 (1080)	10	79.4	13.5	94.7	16.1	110	19.0	118	20.4	125	21.9	141	25.0	156	28.2
	12	79.4	13.7	94.7	16.4	110	19.3	118	20.8	125	22.3	141	25.5	156	28.7
	14	79.4	13.9	94.7	16.7	110	19.6	118	21.2	125	22.7	141	25.9	156	29.2
	16	79.4	14.1	94.7	17.0	110	20.0	118	21.6	125	23.2	141	26.4	156	29.8
	18	79.4	14.4	94.7	17.3	110	20.4	118	22.0	125	23.6	141	27.0	156	30.4
	20	79.4	14.6	94.7	17.6	110	20.8	118	22.4	125	24.1	141	28.0	156	32.5
	21	79.4	14.8	94.7	17.8	110	21.0	118	22.6	125	24.6	141	29.0	156	33.7
	23	79.4	15.1	94.7	18.1	110	22.0	118	24.1	125	26.3	141	31.0	156	36.1
	25	79.4	15.5	94.7	19.3	110	23.5	118	25.8	125	28.1	141	33.2	156	38.7
	27	79.4	16.5	94.7	20.6	110	25.1	118	27.5	125	30.0	141	35.5	156	41.4
	29	79.4	17.6	94.7	21.9	110	26.7	118	29.3	125	32.1	141	37.9	156	44.2
	31	79.4	18.7	94.7	23.3	110	28.5	118	31.3	125	34.2	141	40.4	153	45.9
	33	79.4	19.8	94.7	24.8	110	30.3	118	33.3	125	36.4	141	43.1	151	47.7
	35	79.4	21.0	94.7	26.3	110	32.2	118	35.4	125	38.8	141	46.0	149	49.4
	37	79.4	22.3	94.7	27.9	110	34.3	118	37.7	125	41.3	141	49.0	146	51.1
	39	79.4	23.6	94.7	29.7	110	36.4	118	40.1	125	44.0	141	52.2	144	52.9
70 (945)	10	69.4	11.8	82.8	14.1	96.2	16.4	102.9	17.6	110	18.9	123	21.5	136	24.1
	12	69.4	12.0	82.8	14.3	96.2	16.7	102.9	17.9	110	19.2	123	21.9	136	24.6
	14	69.4	12.2	82.8	14.5	96.2	17.0	102.9	18.3	110	19.6	123	22.3	136	25.1
	16	69.4	12.4	82.8	14.8	96.2	17.3	102.9	18.6	110	19.9	123	22.7	136	25.5
	18	69.4	12.6	82.8	15.0	96.2	17.6	102.9	19.0	110	20.3	123	23.1	136	26.0
	20	69.4	12.8	82.8	15.3	96.2	17.9	102.9	19.3	110	20.7	123	23.6	136	26.8
	21	69.4	12.9	82.8	15.4	96.2	18.1	102.9	19.5	110	20.9	123	24.0	136	27.7
	23	69.4	13.2	82.8	15.7	96.2	18.5	102.9	20.2	110	21.9	123	25.7	136	29.7
	25	69.4	13.4	82.8	16.4	96.2	19.7	102.9	21.5	110	23.4	123	27.4	136	31.8
	27	69.4	14.2	82.8	17.4	96.2	21.0	102.9	22.9	110	25.0	123	29.3	136	33.9
	29	69.4	15.0	82.8	18.5	96.2	22.4	102.9	24.4	110	26.6	123	31.2	136	36.2
	31	69.4	15.9	82.8	19.7	96.2	23.8	102.9	26.0	110	28.3	123	33.3	136	38.7
	33	69.4	16.9	82.8	20.9	96.2	25.3	102.9	27.7	110	30.2	123	35.5	136	41.2
	35	69.4	17.9	82.8	22.1	96.2	26.9	102.9	29.4	110	32.1	123	37.8	136	44.0
	37	69.4	18.9	82.8	23.5	96.2	28.5	102.9	31.3	110	34.1	123	40.2	136	46.8
	39	69.4	20.0	82.8	24.9	96.2	30.3	102.9	33.2	110	36.3	123	42.8	136	49.9
60 (810)	10	59.5	10.3	71.0	12.1	82.5	14.0	88.2	15.0	93.9	16.0	105.4	18.1	117	20.3
	12	59.5	10.5	71.0	12.3	82.5	14.2	88.2	15.2	93.9	16.3	105.4	18.4	117	20.6
	14	59.5	10.6	71.0	12.5	82.5	14.5	88.2	15.5	93.9	16.6	105.4	18.8	117	21.0
	16	59.5	10.8	71.0	12.7	82.5	14.7	88.2	15.8	93.9	16.9	105.4	19.1	117	21.4
	18	59.5	10.9	71.0	12.9	82.5	15.0	88.2	16.1	93.9	17.2	105.4	19.5	117	21.8
	20	59.5	11.1	71.0	13.1	82.5	15.2	88.2	16.3	93.9	17.5	105.4	19.8	117	22.3
	21	59.5	11.2	71.0	13.2	82.5	15.4	88.2	16.5	93.9	17.7	105.4	20.0	117	22.5
	23	59.5	11.4	71.0	13.4	82.5	15.7	88.2	16.8	93.9	18.0	105.4	20.8	117	23.9
	25	59.5	11.6	71.0	13.7	82.5	16.3	88.2	17.7	93.9	19.1	105.4	22.2	117	25.6
	27	59.5	12.0	71.0	14.5	82.5	17.3	88.2	18.8	93.9	20.4	105.4	23.7	117	27.3
	29	59.5	12.7	71.0	15.4	82.5	18.4	88.2	20.0	93.9	21.7	105.4	25.2	117	29.1
	31	59.5	13.4	71.0	16.3	82.5	19.6	88.2	21.3	93.9	23.1	105.4	26.9	117	31.0
	33	59.5	14.2	71.0	17.3	82.5	20.8	88.2	22.6	93.9	24.5	105.4	28.6	117	33.0
	35	59.5	15.0	71.0	18.4	82.5	22.0	88.2	24.0	93.9	26.0	105.4	30.4	117	35.1
	37	59.5	15.9	71.0	19.4	82.5	23.4	88.2	25.5	93.9	27.6	105.4	32.3	117	37.4
	39	59.5	16.8	71.0	20.6	82.5	24.8	88.2	27.0	93.9	29.3	105.4	34.4	117	39.8
50 (675)	10	49.6	8.86	59.2	10.2	68.7	11.7	73.5	12.5	78.3	13.3	87.8	14.9	97.4	16.6
	12	49.6	8.97	59.2	10.4	68.7	11.9	73.5	12.7	78.3	13.5	87.8	15.2	97.4	16.9
	14	49.6	9.09	59.2	10.5	68.7	12.1	73.5	12.9	78.3	13.7	87.8	15.4	97.4	17.2
	16	49.6	9.21	59.2	10.7	68.7	12.3	73.5	13.1	78.3	14.0	87.8	15.7	97.4	17.5
	18	49.6	9.34	59.2	10.9	68.7	12.5	73.5	13.3	78.3	14.2	87.8	16.0	97.4	17.8
	20	49.6	9.47	59.2	11.0	68.7	12.7	73.5	13.6	78.3	14.4	87.8	16.3	97.4	18.2
	21	49.6	9.54	59.2	11.1	68.7	12.8	73.5	13.7	78.3	14.6	87.8	16.4	97.4	18.4
	23	49.6	9.69	59.2	11.3	68.7	13.0	73.5	13.9	78.3	14.8	87.8	16.7	97.4	18.8
	25	49.6	9.83	59.2	11.5	68.7	13.3	73.5	14.2	78.3	15.3	87.8	17.6	97.4	20.0
	27	49.6	9.99	59.2	11.9	68.7	14.0	73.5	15.1	78.3	16.3	87.8	18.7	97.4	21.3
	29	49.6	10.6	59.2	12.6	68.7	14.8	73.5	16.0	78.3	17.3	87.8	19.9	97.4	22.7
	31	49.6	11.2	59.2	13.4	68.7	15.7	73.5	17.0	78.3	18.3	87.8	21.2	97.4	24.2
	33	49.6	11.8	59.2	14.1	68.7	16.7	73.5	18.0	78.3	19.5	87.8	22.5	97.4	25.7
	35	49.6	12.4	59.2	14.9	68.7	17.7	73.5	19.1	78.3	20.6	87.8	23.9	97.4	27.3
	37	49.6	13.1	59.2	15.8	68.7	18.7	73.5	20.3	78.3	21.9	87.8	25.3	97.4	29.0
	39	49.6	13.8	59.2	16.7	68.7	19.8	73.5	21.4	78.3	23.2	87.8	26.9	97.4	30.8

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)
Note1: The above table shows the average value of conditions which may occur.

8.2 Heating Capacity (RXYQ-P(A))

RXYQ5PAY1, PAYL, PTL [50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.	Indoor air temp. °CDB																			
		16.0		18.0		20.0		21.0		22.0		24.0									
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI								
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW							
130 (162.5)	-19.8	-20.0	10.6	2.83	10.5	3.02	10.5	3.22	10.5	3.31	10.4	3.41	10.4	3.60							
	-18.8	-19.0	10.9	2.94	10.8	3.12	10.8	3.31	10.8	3.40	10.8	3.50	10.7	3.68							
	-16.7	-17.0	11.5	3.13	11.5	3.30	11.4	3.48	11.4	3.57	11.4	3.66	11.3	3.83							
	-14.7	-15.0	12.1	3.30	12.1	3.47	12.0	3.63	12.0	3.72	12.0	3.80	12.0	3.96							
	-12.6	-13.0	12.7	3.45	12.7	3.61	12.7	3.77	12.7	3.85	12.6	3.93	12.6	4.08							
	-10.5	-11.0	13.4	3.59	13.3	3.74	13.3	3.89	13.3	3.97	13.3	4.04	13.2	4.19							
	-9.5	-10.0	13.7	3.66	13.7	3.80	13.6	3.95	13.6	4.02	13.6	4.10	13.5	4.24							
	-8.5	-9.1	14.0	3.71	13.9	3.86	13.9	4.00	13.9	4.07	13.9	4.14	13.8	4.29							
	-7.0	-7.6	14.4	3.80	14.4	3.94	14.4	4.08	14.3	4.15	14.3	4.22	14.3	4.36							
	-5.0	-5.6	15.1	3.91	15.0	4.04	15.0	4.18	15.0	4.24	14.9	4.31	14.9	4.44							
	-3.0	-3.7	15.7	4.01	15.6	4.13	15.6	4.26	15.6	4.32	15.5	4.39	15.5	4.52							
	0.0	-0.7	16.6	4.14	16.6	4.26	16.5	4.38	16.5	4.44	16.5	4.50	16.4	4.63							
	3.0	2.2	17.5	4.26	17.5	4.37	17.4	4.49	17.4	4.55	17.4	4.60	17.4	4.72							
	5.0	4.1	18.1	4.33	18.1	4.44	18.0	4.55	18.0	4.61	18.0	4.66	18.0	4.77							
	7.0	6.0	18.7	4.40	18.7	4.51	18.6	4.61	18.6	4.67	18.6	4.72	18.1	4.65							
	9.0	7.9	19.3	4.46	19.3	4.57	19.2	4.67	19.2	4.72	19.2	4.77	18.1	4.48							
	11.0	9.8	19.9	4.52	19.8	4.62	19.8	4.72	19.8	4.72	19.5	4.70	18.1	4.31							
	13.0	11.8	20.5	4.58	20.5	4.68	20.4	4.78	20.1	4.72	19.5	4.53	18.1	4.15							
	15.0	13.7	21.1	4.63	21.1	4.73	20.8	4.74	20.1	4.55	19.5	4.37	18.1	4.01							
120 (150)	-19.8	-20.0	10.5	3.09	10.5	3.27	10.4	3.45	10.4	3.54	10.4	3.62	10.4	3.80							
	-18.8	-19.0	10.8	3.19	10.8	3.36	10.8	3.53	10.8	3.62	10.7	3.71	10.7	3.88							
	-16.7	-17.0	11.4	3.37	11.4	3.53	11.4	3.69	11.4	3.77	11.3	3.85	11.3	4.02							
	-14.7	-15.0	12.1	3.52	12.0	3.68	12.0	3.83	12.0	3.91	12.0	3.98	11.9	4.14							
	-12.6	-13.0	12.7	3.67	12.7	3.81	12.6	3.96	12.6	4.03	12.6	4.10	12.6	4.25							
	-10.5	-11.0	13.3	3.80	13.3	3.93	13.3	4.07	13.2	4.14	13.2	4.21	13.2	4.35							
	-9.5	-10.0	13.6	3.86	13.6	3.99	13.6	4.13	13.6	4.19	13.5	4.26	13.5	4.40							
	-8.5	-9.1	13.9	3.91	13.9	4.04	13.9	4.17	13.8	4.24	13.8	4.30	13.8	4.44							
	-7.0	-7.6	14.4	3.99	14.4	4.12	14.3	4.24	14.3	4.31	14.3	4.37	14.3	4.50							
	-5.0	-5.6	15.0	4.09	15.0	4.21	14.9	4.33	14.9	4.40	14.9	4.46	14.9	4.58							
	-3.0	-3.7	15.6	4.18	15.6	4.30	15.5	4.41	15.5	4.47	15.5	4.53	15.5	4.65							
	0.0	-0.7	16.5	4.30	16.5	4.42	16.5	4.53	16.5	4.58	16.4	4.64	16.4	4.75							
	3.0	2.2	17.5	4.41	17.4	4.52	17.4	4.63	17.4	4.68	17.4	4.73	16.7	4.58							
	5.0	4.1	18.1	4.48	18.0	4.58	18.0	4.68	18.0	4.74	17.9	4.79	16.7	4.39							
	7.0	6.0	18.6	4.54	18.6	4.64	18.6	4.74	18.6	4.81	18.0	4.60	16.7	4.22							
	9.0	7.9	19.2	4.60	19.2	4.70	19.2	4.79	18.6	4.61	18.0	4.43	16.7	4.06							
	11.0	9.8	19.8	4.66	19.8	4.75	19.2	4.62	18.6	4.44	18.0	4.26	16.7	3.92							
	13.0	11.8	20.5	4.71	20.4	4.80	19.2	4.45	18.6	4.28	18.0	4.11	16.7	3.77							
	15.0	13.7	21.1	4.76	20.4	4.64	19.2	4.30	18.6	4.13	18.0	3.97	16.7	3.65							
110 (137.5)	-19.8	-20.0	10.5	3.35	10.4	3.51	10.4	3.68	10.4	3.76	10.4	3.84	10.3	4.00							
	-18.8	-19.0	10.8	3.44	10.7	3.60	10.7	3.76	10.7	3.84	10.7	3.91	10.6	4.07							
	-16.7	-17.0	11.4	3.60	11.4	3.75	11.3	3.90	11.3	3.98	11.3	4.05	11.3	4.20							
	-14.7	-15.0	12.0	3.75	12.0	3.89	12.0	4.03	11.9	4.10	11.9	4.17	11.9	4.31							
	-12.6	-13.0	12.6	3.88	12.6	4.01	12.6	4.15	12.6	4.21	12.6	4.28	12.5	4.41							
	-10.5	-11.0	13.3	4.00	13.2	4.13	13.2	4.25	13.2	4.32	13.2	4.38	13.2	4.51							
	-9.5	-10.0	13.6	4.05	13.6	4.18	13.5	4.30	13.5	4.36	13.5	4.43	13.5	4.55							
	-8.5	-9.1	13.9	4.10	13.8	4.22	13.8	4.34	13.8	4.40	13.8	4.47	13.7	4.59							
	-7.0	-7.6	14.3	4.18	14.3	4.29	14.3	4.41	14.3	4.47	14.2	4.53	14.2	4.65							
	-5.0	-5.6	15.0	4.27	14.9	4.38	14.9	4.49	14.9	4.55	14.8	4.61	14.8	4.72							
	-3.0	-3.7	15.6	4.35	15.5	4.46	15.5	4.57	15.5	4.62	15.5	4.67	15.3	4.73							
	0.0	-0.7	16.5	4.47	16.5	4.57	16.4	4.67	16.4	4.72	16.4	4.77	15.3	4.40							
	3.0	2.2	17.4	4.57	17.4	4.67	17.3	4.76	17.0	4.68	16.5	4.49	15.3	4.12							
	5.0	4.1	18.0	4.63	18.0	4.72	17.6	4.67	17.0	4.49	16.5	4.31	15.3	3.96							
	7.0	6.0	18.6	4.69	18.6	4.78	17.6	4.49	17.0	4.31	16.5	4.14	15.3	3.80							
	9.0	7.9	19.2	4.74	18.7	4.66	17.6	4.32	17.0	4.15	16.5	3.99	15.3	3.66							
	11.0	9.8	19.8	4.79	18.7	4.49	17.6	4.16	17.0	4.00	16.5	3.84	15.3	3.53							
	13.0	11.8	19.9	4.64	18.7	4.32	17.6	4.01	17.0	3.85	16.5	3.70	15.3	3.41							
	15.0	13.7	19.9	4.48	18.7	4.17	17.6	3.87	17.0	3.72	16.5	3.58	15.3	3.30							

1. This table indicates the situation of 50~130% combination of indoor units.
2. If connecting the indoor units over 130% of outdoor unit capacity, capacity of indoor unit will decrease.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.	Indoor air temp. °CDB																			
		16.0		18.0		20.0		21.0		22.0		24.0									
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI								
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW							
100 (125)	-19.8	-20.0	10.4	3.87	10.4	4.00	10.3	4.14	10.3	4.20	10.3	4.27									
	-18.8	-19.0	10.7	3.94	10.6	4.07	10.6	4.20	10.6	4.27	10.6	4.33									
	-16.7	-17.0	11.3	4.08	11.2	4.20	11.2	4.32	11.2	4.38	11.2	4.44									
	-14.7	-15.0	11.9	4.31	11.9	4.43	11.9	4.53	11.8	4.63	11.8	4.68									
	-12.6	-13.0	12.5	4.42	12.5	4.53	12.5	4.63	12.4	4.71	12.4	4.73									
	-10.5	-11.0	13.2	4.51	13.1	4.61	13.1	4.70	12.8	4.73	12.4	4.50									
	-9.5	-10.0	13.4	4.55	13.4	4.65	13.4	4.70	12.8	4.73	12.4	4.32									
	-8.5	-9.1	13.7	4.59	13.7	4.69	13.7	4.74	12.8	4.73	12.4	4.21									
	-7.0	-7.6	14.2	4.65	14.2	4.74	13.9	4.66	12.8	4.73	12.4	4.04									
	-5.0	-5.6	14.9	4.72	14.4	4.60	13.9	4.42	12.8	4.73	12.4	3.84									
	-3.0	-3.7	15.3	4.73	14.4	4.08	13.9	3.92	12.8	4.73	12.4	3.66									
	0.0	-0.7	15.3	4.40	14.4	3.82	13.9	3.68	12.8	4.73	12.4	3.52									
	3.0	2.2	15.3	4.12	14.4	3.67	13.9	3.53	12.8	4.73	12.4	3.41									
	5.0	4.1	15.3	3.95	14.4	3.53	13.9	3.40	12.8	4.73	12.4	3.29									
	7.0	6.0	15.3	3.80	14.4	3.40	13.9	3.28	12.8	4.73	12.4	3.17									
	9.0	7.9	15.3	3.66	14.4	3.29	13.9	3.17	12.8	4.73	12.4	3.06									
	11.0	9.8	15.3	3.53	14.4	3.17	13.9	3.06	12.8	4.73	12.4	2.96									
	13.0	11.8	15.3	3.41	14.4	3.07	13.9	2.96	12.8	4.73	12.4	2.85									
	15.0	13.7	15.3	3.29	14.4	2.96	13.5	2.85	12.8	4.73	12.4	2.74									
90 (112.5)	-19.8	-20.0	10.4	4.00	10.3	4.14	10.3	4.20	10.3	4.27											
	-18.8	-19.0	10.7	4.07	10.6	4.20	10.6	4.27	10.6	4.33											
	-16.7	-17.0	11.3	4.20	11.2	4.32	11.2	4.38	11.2	4.44											
	-14.7	-15.0	11.9	4.31	11.9	4.43	11.9	4.49	11.8	4.54											
	-12.6	-13.0	12.5	4.42	12.5	4.53	12.5	4.58	12.4	4.63											
	-10.5	-11.0	13.2	4.51	13.1	4.61	13.1	4.66	12.8	4.66											
	-9.5	-10.0	13.4	4.55	13.4	4.65	13.4	4.70	12.8	4.66											
	-8.5	-9.1	13.7	4.59	13.7	4.69	13.7	4.74	12.8	4.66											
	-7.0	-7.6	14.2	4.65	14.2	4.74	13.9	4.66	12.8	4.66											
	-5.0	-5.6	14.9	4.72	14.4	4.60	13.9	4.42	12.8	4.66											
	-3.0	-3.7	15.3	4.73	14.4	4.08	13.9	3.92	12.8	4.66											
	0.0	-0.7	16.3	4.40	14.4	3.82	13.9	3.68	12.8	4.66											
	3.0	2.2	16.3	4.12	14.4	3.67	13.9	3.53	12.8	4.66											
	5.0	4.1	16.3	3.95	14.4	3.53	13.9	3.40	12.8	4.66											
	7.0	6.0	16.3	3.80	14.4	3.40	13.9	3.28	12.8	4.66											
	9.0	7.9	16.3	3.66	14.4	3.29	13.9	3.17	12.8	4.66											
	11.0	9.8	16.3	3.53	14.4	3.17	13.9	3.06	12.8	4.66											
	13.0	11.8	16.3	3.41	14.4	3.07	13.9	2.96	12.8	4.66											
	15.0	13.7	16.3	3.29	14.4	2.96	13.5	2.85	12.8	4.66											
80 (100)	-19.8	-20.0	10.3	4.13	10.3	4.25	10.3	4.37	10.3	4.43	10.2	4.49									
	-18.8	-19.0	10.6	4.20	10.6	4.31	10.6	4.43	10.6	4.48	10.6	4.54									
	-16.7	-17.0	11.2	4.42	11.2	4.53	11.2	4.59	11.2	4.64	11.2	4.64									
	-14.7	-15.0	11.9	4.53	11.8	4.63	11.8	4.68	11.8	4.68	11.8	4.73									
	-12.6	-13.0	12.5	4.52	12.5	4.63	12.4	4.71	12.4	4.73	12.4	4.54									
	-10.5	-11.0	13.1	4.61	13.1	4.70	12.8	4.63	12.4	4.45	12.4	4.27									
	-9.5	-10.0	13.4	4.65	13.4	4.74	12.8	4.73	12.4	4.32	12.4	4.15									
	-8.5	-9.1	13.6	4.68	13.6	4.73	12.8	4.53	12.4	4.21	12.4	4.04									
	-7.0	-7.6	14.2	4.74	13.6	4.62	12.8	4.38	12.4	4.04	12.4	3.88									
	-5.0	-5.6	14.4	4.62	13.6	4.30	12.8	4.12	12.4	3.84	12.4	3.69									
	-3.0	-3.7	14.4	4.40	13.6	4.10	12.8	3.93	12.4	3.66	12.4	3.52									
	0.0	-0.7	14.4	4.09	13.6	3.82	12.8	3.55	12.4	3.41	12.0	3.28									
	3.0	2.2	14.4	3.84	13.6	3.58	12.8	3.33	12.4	3.21	12.0	3.09									
	5.0	4.1	14.4	3.68	13.6	3.44	12.8	3.20	12.4	3.09	12.0	2.97									
	7.0	6.0	14.4	3.55	13.6	3.31	12.8	3.09	12.4	2.97	11.2	2.86									
	9.0	7.9	14.4	3.42	13.6	3.19	12.8	2.98	12.4	2.87	11.2	2.77									
	11.0	9.8	14.4	3.30	13.6	3.09	12.8	2.88	12.4	2.78	11.2	2.67									
	13.0	11.8	14.4	3.18	13.6	2.98	12.8	2.78	12.4	2.68	12.0	2.59									
	15.0	13.7	14.4	3.08	13.6	2.88	12.8	2.69	12.4	2.60	12.0	2.51									

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (87.5)	-19.8	-20.0	10.3	4.39	10.2	4.49	10.2	4.60	10.2	4.65	10.2	4.70	9.76	4.50				
	-18.8	-19.0	10.6	4.45	10.6	4.55	10.5	4.65	10.5	4.70	10.5	4.73	9.76	4.33				
	-16.7	-17.0	11.2	4.55	11.2	4.65	11.2	4.74	10.8	4.58	10.5	4.40	9.76	4.03				
	-14.7	-15.0	11.8	4.65	11.8	4.74	11.2	4.46	10.8	4.28	10.5	4.11	9.76	3.78				
	-12.6	-13.0	12.5	4.73	11.9	4.51	11.2	4.18	10.8	4.02	10.5	3.86	9.76	3.55				
	-10.5	-11.0	12.6	4.56	11.9	4.24	11.2	3.94	10.8	3.79	10.5	3.64	9.76	3.35				
	-9.5	-10.0	12.6	4.43	11.9	4.12	11.2	3.83	10.8	3.68	10.5	3.54	9.76	3.26				
	-8.5	-9.1	12.6	4.31	11.9	4.02	11.2	3.73	10.8	3.59	10.5	3.45	9.76	3.18				
	-7.0	-7.6	12.6	4.14	11.9	3.86	11.2	3.59	10.8	3.45	10.5	3.32	9.76	3.06				
	-5.0	-5.6	12.6	3.93	11.9	3.67	11.2	3.41	10.8	3.28	10.5	3.16	9.76	2.92				
	-3.0	-3.7	12.6	3.75	11.9	3.50	11.2	3.26	10.8	3.14	10.5	3.02	9.76	2.79				
	0.0	-0.7	12.6	3.49	11.9	3.27	11.2	3.04	10.8	2.93	10.5	2.83	9.76	2.61				
	3.0	2.2	12.6	3.28	11.9	3.07	11.2	2.86	10.8	2.76	10.5	2.66	9.76	2.47				
	5.0	4.1	12.6	3.16	11.9	2.96	11.2	2.76	10.8	2.66	10.5	2.57	9.76	2.38				
	7.0	6.0	12.6	3.04	11.9	2.85	11.2	2.66	10.8	2.57	10.5	2.48	9.76	2.30				
	9.0	7.9	12.6	2.94	11.9	2.75	11.2	2.57	10.8	2.48	10.5	2.39	9.76	2.22				
	11.0	9.8	12.6	2.84	11.9	2.66	11.2	2.49	10.8	2.40	10.5	2.32	9.76	2.15				
	13.0	11.8	12.6	2.74	11.9	2.57	11.2	2.41	10.8	2.32	10.5	2.24	9.76	2.08				
	15.0	13.7	12.6	2.66	11.9	2.49	11.2	2.33	10.8	2.25	10.5	2.18	9.76	2.02				
60 (75)	-19.8	-20.0	10.2	4.65	10.2	4.74	9.60	4.41	9.29	4.23	8.98	4.06	8.37	3.73				
	-18.8	-19.0	10.5	4.70	10.2	4.58	9.60	4.24	9.29	4.08	8.98	3.92	8.37	3.60				
	-16.7	-17.0	10.8	4.58	10.2	4.26	9.60	3.95	9.29	3.80	8.98	3.65	8.37	3.36				
	-14.7	-15.0	10.8	4.28	10.2	3.99	9.60	3.70	9.29	3.56	8.98	3.43	8.37	3.16				
	-12.6	-13.0	10.8	4.02	10.2	3.75	9.60	3.48	9.29	3.35	8.98	3.23	8.37	2.98				
	-10.5	-11.0	10.8	3.79	10.2	3.53	9.60	3.29	9.29	3.17	8.98	3.05	8.37	2.82				
	-9.5	-10.0	10.8	3.68	10.2	3.44	9.60	3.20	9.29	3.08	8.98	2.97	8.37	2.74				
	-8.5	-9.1	10.8	3.59	10.2	3.35	9.60	3.12	9.29	3.01	8.98	2.90	8.37	2.68				
	-7.0	-7.6	10.8	3.45	10.2	3.23	9.60	3.01	9.29	2.90	8.98	2.79	8.37	2.58				
	-5.0	-5.6	10.8	3.28	10.2	3.07	9.60	2.86	9.29	2.76	8.98	2.66	8.37	2.46				
	-3.0	-3.7	10.8	3.14	10.2	2.94	9.60	2.74	9.29	2.64	8.98	2.55	8.37	2.36				
	0.0	-0.7	10.8	2.93	10.2	2.75	9.60	2.57	9.29	2.48	8.98	2.39	8.37	2.22				
	3.0	2.2	10.8	2.76	10.2	2.59	9.60	2.42	9.29	2.34	8.98	2.26	8.37	2.10				
	5.0	4.1	10.8	2.66	10.2	2.50	9.60	2.34	9.29	2.26	8.98	2.18	8.37	2.03				
	7.0	6.0	10.8	2.57	10.2	2.41	9.60	2.26	9.29	2.18	8.98	2.11	8.37	1.96				
	9.0	7.9	10.8	2.48	10.2	2.33	9.60	2.18	9.29	2.11	8.98	2.04	8.37	1.90				
	11.0	9.8	10.8	2.40	10.2	2.26	9.60	2.12	9.29	2.05	8.98	1.98	8.37	1.84				
	13.0	11.8	10.8	2.32	10.2	2.18	9.60	2.05	9.29	1.98	8.98	1.92	8.37	1.79				
	15.0	13.7	10.8	2.25	10.2	2.12	9.60	1.99	9.29	1.93	8.98	1.86	8.37	1.74				
50 (62.5)	-19.8	-20.0	9.03	4.09	8.51	3.81	8.00	3.54	7.74	3.41	7.49	3.28	6.97	3.03				
	-18.8	-19.0	9.03	3.94	8.51	3.68	8.00	3.42	7.74	3.29	7.49	3.17	6.97	2.92				
	-16.7	-17.0	9.03	3.68	8.51	3.43	8.00	3.20	7.74	3.08	7.49	2.96	6.97	2.74				
	-14.7	-15.0	9.03	3.45	8.51	3.22	8.00	3.00	7.74	2.89	7.49	2.79	6.97	2.58				
	-12.6	-13.0	9.03	3.24	8.51	3.04	8.00	2.83	7.74	2.73	7.49	2.63	6.97	2.44				
	-10.5	-11.0	9.03	3.07	8.51	2.87	8.00	2.68	7.74	2.59	7.49	2.49	6.97	2.31				
	-9.5	-10.0	9.03	2.98	8.51	2.80	8.00	2.61	7.74	2.52	7.49	2.43	6.97	2.25				
	-8.5	-9.1	9.03	2.91	8.51	2.73	8.00	2.55	7.74	2.46	7.49	2.38	6.97	2.21				
	-7.0	-7.6	9.03	2.81	8.51	2.63	8.00	2.46	7.74	2.38	7.49	2.29	6.97	2.13				
	-5.0	-5.6	9.03	2.68	8.51	2.51	8.00	2.35	7.74	2.27	7.49	2.19	6.97	2.04				
	-3.0	-3.7	9.03	2.56	8.51	2.41	8.00	2.25	7.74	2.18	7.49	2.10	6.97	1.96				
	0.0	-0.7	9.03	2.40	8.51	2.26	8.00	2.12	7.74	2.05	7.49	1.98	6.97	1.84				
	3.0	2.2	9.03	2.27	8.51	2.14	8.00	2.00	7.74	1.94	7.49	1.87	6.97	1.75				
	5.0	4.1	9.03	2.19	8.51	2.06	8.00	1.94	7.74	1.87	7.49	1.81	6.97	1.69				
	7.0	6.0	9.03	2.12	8.51	1.99	8.00	1.87	7.74	1.82	7.49	1.76	6.97	1.64				
	9.0	7.9	9.03	2.05	8.51	1.93	8.00	1.82	7.74	1.76	7.49	1.70	6.97	1.59				
	11.0	9.8	9.03	1.99	8.51	1.87	8.00	1.76	7.74	1.71	7.49	1.65	6.97	1.55				
	13.0	11.8	9.03	1.93	8.51	1.82	8.00	1.71	7.74	1.66	7.49	1.60	6.97	1.50				
	15.0	13.7	9.03	1.87	8.51	1.77	8.00	1.66	7.74	1.61	7.49	1.56	6.97	1.46				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

14

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (260)	-19.8	-20.0	16.2	3.88	16.2	4.16	16.1	4.44	16.1	4.57	16.1	4.71	16.0	4.99
	-18.8	-19.0	16.7	4.03	16.7	4.30	16.6	4.57	16.6	4.70	16.5	4.84	16.5	5.10
	-16.7	-17.0	17.7	4.31	17.6	4.56	17.6	4.81	17.5	4.94	17.5	5.06	17.4	5.32
	-14.7	-15.0	18.6	4.55	18.6	4.79	18.5	5.03	18.5	5.15	18.5	5.27	18.4	5.51
	-12.6	-13.0	19.6	4.77	19.5	5.00	19.5	5.23	19.4	5.34	19.4	5.45	19.4	5.68
	-10.5	-11.0	20.6	4.97	20.5	5.19	20.4	5.40	20.4	5.51	20.4	5.62	20.3	5.84
	-9.5	-10.0	21.0	5.07	21.0	5.28	20.9	5.49	20.9	5.59	20.9	5.70	20.8	5.91
	-8.5	-9.1	21.5	5.15	21.4	5.35	21.4	5.56	21.3	5.66	21.3	5.76	21.2	5.97
	-7.0	-7.6	22.2	5.27	22.1	5.47	22.1	5.67	22.0	5.77	22.0	5.87	22.0	6.07
	-5.0	-5.6	23.1	5.43	23.1	5.62	23.0	5.81	23.0	5.91	23.0	6.00	22.9	6.19
	-3.0	-3.7	24.1	5.57	24.0	5.75	23.9	5.93	23.9	6.02	23.9	6.12	23.8	6.30
	0.0	-0.7	25.5	5.76	25.4	5.93	25.4	6.11	25.4	6.19	25.3	6.28	25.3	6.45
	3.0	2.2	26.9	5.93	26.8	6.10	26.8	6.26	26.8	6.34	26.7	6.42	26.7	6.59
	5.0	4.1	27.8	6.03	27.8	6.19	27.7	6.35	27.7	6.43	27.6	6.51	27.6	6.67
	7.0	6.0	28.7	6.13	28.7	6.28	28.6	6.44	28.6	6.51	28.6	6.59	28.3	6.68
	9.0	7.9	29.6	6.22	29.6	6.37	29.5	6.52	29.5	6.59	29.5	6.67	28.3	6.42
	11.0	9.8	30.6	6.31	30.5	6.45	30.4	6.59	30.4	6.67	30.4	6.74	28.3	6.19
	13.0	11.8	31.5	6.39	31.5	6.53	31.4	6.67	31.4	6.74	30.4	6.49	28.3	5.96
	15.0	13.7	32.4	6.47	32.4	6.60	32.3	6.74	31.5	6.53	30.4	6.27	28.3	5.75
120 (240)	-19.8	-20.0	16.2	4.26	16.1	4.51	16.0	4.77	16.0	4.89	16.0	5.02	15.9	5.27
	-18.8	-19.0	16.6	4.39	16.6	4.64	16.5	4.89	16.5	5.01	16.5	5.14	16.4	5.38
	-16.7	-17.0	17.6	4.65	17.5	4.88	17.5	5.11	17.5	5.23	17.4	5.35	17.4	5.58
	-14.7	-15.0	18.6	4.88	18.5	5.10	18.4	5.32	18.4	5.43	18.4	5.54	18.3	5.76
	-12.6	-13.0	19.5	5.08	19.5	5.29	19.4	5.50	19.4	5.60	19.4	5.71	19.3	5.92
	-10.5	-11.0	20.5	5.26	20.4	5.46	20.4	5.66	20.3	5.76	20.3	5.86	20.3	6.06
	-9.5	-10.0	21.0	5.35	20.9	5.54	20.9	5.74	20.8	5.84	20.8	5.93	20.7	6.13
	-8.5	-9.1	21.4	5.42	21.3	5.61	21.3	5.81	21.3	5.90	21.2	6.00	21.2	6.19
	-7.0	-7.6	22.1	5.54	22.1	5.73	22.0	5.91	22.0	6.00	22.0	6.09	21.9	6.28
	-5.0	-5.6	23.1	5.69	23.0	5.86	23.0	6.04	22.9	6.13	22.9	6.21	22.9	6.39
	-3.0	-3.7	24.0	5.81	23.9	5.98	23.9	6.15	23.9	6.24	23.8	6.32	23.8	6.49
	0.0	-0.7	25.4	5.99	25.4	6.15	25.3	6.31	25.3	6.39	25.3	6.47	25.2	6.63
	3.0	2.2	26.8	6.15	26.8	6.30	26.7	6.45	26.7	6.53	26.7	6.61	26.1	6.57
	5.0	4.1	27.7	6.25	27.7	6.39	27.6	6.54	27.6	6.61	27.6	6.69	26.1	6.30
	7.0	6.0	28.6	6.34	28.6	6.48	28.5	6.62	28.5	6.69	28.1	6.61	26.1	6.06
	9.0	7.9	29.6	6.42	29.5	6.56	29.5	6.69	29.0	6.62	28.1	6.35	26.1	5.83
	11.0	9.8	30.5	6.50	30.4	6.63	30.0	6.64	29.0	6.38	28.1	6.12	26.1	5.62
	13.0	11.8	31.4	6.58	31.4	6.71	30.0	6.39	29.0	6.14	28.1	5.89	26.1	5.41
	15.0	13.7	32.3	6.65	31.9	6.65	30.0	6.17	29.0	5.93	28.1	5.69	26.1	5.23
110 (220)	-19.8	-20.0	16.1	4.63	16.0	4.86	16.0	5.10	16.0	5.21	15.9	5.33	15.9	5.56
	-18.8	-19.0	16.6	4.76	16.5	4.98	16.5	5.21	16.4	5.32	16.4	5.44	16.4	5.66
	-16.7	-17.0	17.5	4.99	17.5	5.20	17.4	5.42	17.4	5.52	17.4	5.63	17.3	5.84
	-14.7	-15.0	18.5	5.20	18.4	5.40	18.4	5.60	18.4	5.70	18.3	5.80	18.3	6.01
	-12.6	-13.0	19.4	5.39	19.4	5.58	19.3	5.77	19.3	5.87	19.3	5.96	19.2	6.15
	-10.5	-11.0	20.4	5.56	20.4	5.74	20.3	5.92	20.3	6.01	20.3	6.10	20.2	6.29
	-9.5	-10.0	20.9	5.63	20.8	5.81	20.8	5.99	20.8	6.08	20.7	6.17	20.7	6.35
	-8.5	-9.1	21.3	5.70	21.3	5.88	21.2	6.05	21.2	6.14	21.2	6.23	21.1	6.40
	-7.0	-7.6	22.0	5.81	22.0	5.98	21.9	6.15	21.9	6.23	21.9	6.32	21.8	6.49
	-5.0	-5.6	23.0	5.94	22.9	6.11	22.9	6.27	22.9	6.35	22.8	6.43	22.8	6.59
	-3.0	-3.7	23.9	6.06	23.9	6.22	23.8	6.37	23.8	6.45	23.8	6.53	23.7	6.68
	0.0	-0.7	25.3	6.23	25.3	6.37	25.3	6.52	25.2	6.59	25.2	6.67	24.0	6.31
	3.0	2.2	26.7	6.37	26.7	6.51	26.6	6.65	26.6	6.72	25.7	6.44	24.0	5.91
	5.0	4.1	27.7	6.46	27.6	6.60	27.5	6.71	26.6	6.44	25.7	6.18	24.0	5.68
	7.0	6.0	28.6	6.54	28.5	6.67	27.5	6.44	26.6	6.19	25.7	5.94	24.0	5.46
	9.0	7.9	29.5	6.62	29.3	6.69	27.5	6.20	26.6	5.96	25.7	5.72	24.0	5.26
	11.0	9.8	30.4	6.69	29.3	6.44	27.5	5.97	26.6	5.74	25.7	5.51	24.0	5.07
	13.0	11.8	31.0	6.66	29.3	6.20	27.5	5.75	26.6	5.53	25.7	5.31	24.0	4.89
	15.0	13.7	31.0	6.43	29.3	5.98	27.5	5.56	26.6	5.34	25.7	5.14	24.0	4.73

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (200)	-19.8	-20.0	16.0	5.00	16.0	5.21	15.9	5.43	15.9	5.53	15.9	5.64	15.8	5.85
	-18.8	-19.0	16.5	5.12	16.4	5.32	16.4	5.53	16.4	5.63	16.3	5.74	16.3	5.94
	-16.7	-17.0	17.4	5.33	17.4	5.52	17.4	5.72	17.3	5.82	17.3	5.91	17.3	6.11
	-14.7	-15.0	18.4	5.52	18.4	5.70	18.3	5.89	18.3	5.98	18.3	6.07	18.2	6.26
	-12.6	-13.0	19.4	5.69	19.3	5.87	19.3	6.04	19.3	6.13	19.2	6.21	19.2	6.39
	-10.5	-11.0	20.3	5.85	20.3	6.01	20.2	6.18	20.2	6.26	20.2	6.34	20.1	6.51
	-9.5	-10.0	20.8	5.92	20.8	6.08	20.7	6.24	20.7	6.32	20.7	6.41	20.6	6.57
	-8.5	-9.1	21.2	5.98	21.2	6.14	21.1	6.30	21.1	6.38	21.1	6.46	21.1	6.62
	-7.0	-7.6	22.0	6.08	21.9	6.23	21.9	6.39	21.8	6.46	21.8	6.54	21.8	6.69
	-5.0	-5.6	22.9	6.20	22.9	6.35	22.8	6.50	22.8	6.57	22.8	6.64	21.8	6.35
	-3.0	-3.7	23.8	6.31	23.8	6.45	23.7	6.59	23.7	6.66	23.4	6.60	21.8	6.05
	0.0	-0.7	25.3	6.46	25.2	6.59	25.0	6.65	24.2	6.39	23.4	6.13	21.8	5.63
	3.0	2.2	26.7	6.59	26.6	6.71	25.0	6.22	24.2	5.98	23.4	5.74	21.8	5.28
	5.0	4.1	27.6	6.68	26.6	6.44	25.0	5.97	24.2	5.74	23.4	5.52	21.8	5.07
	7.0	6.0	28.2	6.65	26.6	6.19	25.0	5.74	24.2	5.52	23.4	5.31	21.8	4.88
	9.0	7.9	28.2	6.39	26.6	5.95	25.0	5.53	24.2	5.32	23.4	5.11	21.8	4.71
	11.0	9.8	28.2	6.16	26.6	5.74	25.0	5.33	24.2	5.13	23.4	4.93	21.8	4.55
	13.0	11.8	28.2	5.93	26.6	5.53	25.0	5.14	24.2	4.95	23.4	4.76	21.8	4.39
	15.0	13.7	28.2	5.73	26.6	5.34	25.0	4.97	24.2	4.78	23.4	4.60	21.8	4.25
90 (180)	-19.8	-20.0	15.9	5.37	15.9	5.57	15.8	5.76	15.8	5.85	15.8	5.95	15.8	6.14
	-18.8	-19.0	16.4	5.48	16.4	5.66	16.3	5.85	16.3	5.94	16.3	6.03	16.2	6.22
	-16.7	-17.0	17.4	5.67	17.3	5.85	17.3	6.02	17.3	6.11	17.2	6.20	17.2	6.37
	-14.7	-15.0	18.3	5.84	18.3	6.01	18.2	6.17	18.2	6.26	18.2	6.34	18.2	6.50
	-12.6	-13.0	19.3	6.00	19.2	6.15	19.2	6.31	19.2	6.39	19.2	6.47	19.1	6.63
	-10.5	-11.0	20.2	6.14	20.2	6.29	20.2	6.44	20.1	6.51	20.1	6.59	19.6	6.48
	-9.5	-10.0	20.7	6.20	20.7	6.35	20.6	6.50	20.6	6.57	20.6	6.64	19.6	6.30
	-8.5	-9.1	21.2	6.26	21.1	6.40	21.1	6.55	21.1	6.62	21.0	6.69	19.6	6.14
	-7.0	-7.6	21.9	6.35	21.8	6.49	21.8	6.63	21.8	6.69	21.1	6.42	19.6	5.89
	-5.0	-5.6	22.8	6.46	22.8	6.59	22.5	6.60	21.8	6.34	21.1	6.09	19.6	5.59
	-3.0	-3.7	23.8	6.56	23.7	6.68	22.5	6.29	21.8	6.04	21.1	5.80	19.6	5.33
	0.0	-0.7	25.2	6.70	23.9	6.31	22.5	5.85	21.8	5.63	21.1	5.41	19.6	4.97
	3.0	2.2	25.4	6.34	23.9	5.91	22.5	5.48	21.8	5.28	21.1	5.07	19.6	4.67
	5.0	4.1	25.4	6.08	23.9	5.67	22.5	5.27	21.8	5.07	21.1	4.88	19.6	4.49
	7.0	6.0	25.4	5.85	23.9	5.45	22.5	5.07	21.8	4.88	21.1	4.69	19.6	4.33
	9.0	7.9	25.4	5.63	23.9	5.25	22.5	4.89	21.8	4.71	21.1	4.53	19.6	4.18
	11.0	9.8	25.4	5.43	23.9	5.07	22.5	4.72	21.8	4.54	21.1	4.37	19.6	4.04
	13.0	11.8	25.4	5.23	23.9	4.89	22.5	4.55	21.8	4.39	21.1	4.22	19.6	3.90
	15.0	13.7	25.4	5.06	23.9	4.73	22.5	4.40	21.8	4.25	21.1	4.09	19.6	3.78
80 (160)	-19.8	-20.0	15.8	5.75	15.8	5.92	15.8	6.09	15.8	6.17	15.7	6.26	15.7	6.43
	-18.8	-19.0	16.3	5.84	16.3	6.01	16.3	6.17	16.2	6.25	16.2	6.33	16.2	6.50
	-16.7	-17.0	17.3	6.01	17.2	6.17	17.2	6.32	17.2	6.40	17.2	6.48	17.1	6.63
	-14.7	-15.0	18.2	6.17	18.2	6.31	18.2	6.46	18.2	6.53	18.1	6.61	17.4	6.36
	-12.6	-13.0	19.2	6.30	19.2	6.44	19.1	6.58	19.1	6.65	18.7	6.51	17.4	5.97
	-10.5	-11.0	20.2	6.43	20.1	6.56	20.0	6.64	19.4	6.38	18.7	6.13	17.4	5.62
	-9.5	-10.0	20.6	6.49	20.6	6.62	20.0	6.45	19.4	6.20	18.7	5.95	17.4	5.47
	-8.5	-9.1	21.1	6.54	21.0	6.67	20.0	6.29	19.4	6.04	18.7	5.80	17.4	5.33
	-7.0	-7.6	21.8	6.62	21.3	6.51	20.0	6.03	19.4	5.80	18.7	5.57	17.4	5.12
	-5.0	-5.6	22.6	6.63	21.3	6.17	20.0	5.72	19.4	5.50	18.7	5.29	17.4	4.87
	-3.0	-3.7	22.6	6.31	21.3	5.88	20.0	5.46	19.4	5.25	18.7	5.05	17.4	4.65
	0.0	-0.7	22.6	5.87	21.3	5.48	20.0	5.09	19.4	4.90	18.7	4.71	17.4	4.35
	3.0	2.2	22.6	5.50	21.3	5.14	20.0	4.78	19.4	4.60	18.7	4.43	17.4	4.09
	5.0	4.1	22.6	5.29	21.3	4.94	20.0	4.60	19.4	4.43	18.7	4.26	17.4	3.94
	7.0	6.0	22.6	5.09	21.3	4.75	20.0	4.43	19.4	4.27	18.7	4.11	17.4	3.80
	9.0	7.9	22.6	4.90	21.3	4.58	20.0	4.27	19.4	4.12	18.7	3.97	17.4	3.67
	11.0	9.8	22.6	4.73	21.3	4.43	20.0	4.13	19.4	3.98	18.7	3.84	17.4	3.55
	13.0	11.8	22.6	4.57	21.3	4.27	20.0	3.99	19.4	3.85	18.7	3.71	17.4	3.44
	15.0	13.7	22.6	4.42	21.3	4.14	20.0	3.86	19.4	3.73	18.7	3.60	17.4	3.33

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
70 (140)	-19.8	-20.0	15.8	6.12	15.7	6.27	15.7	6.42	15.7	6.49	15.7	6.57	15.3	6.45
	-18.8	-19.0	16.2	6.20	16.2	6.35	16.2	6.49	16.2	6.56	16.2	6.63	15.3	6.21
	-16.7	-17.0	17.2	6.35	17.2	6.49	17.1	6.62	16.9	6.57	16.4	6.31	15.3	5.79
	-14.7	-15.0	18.2	6.49	18.1	6.62	17.5	6.39	16.9	6.14	16.4	5.90	15.3	5.42
	-12.6	-13.0	19.1	6.61	18.6	6.47	17.5	6.00	16.9	5.77	16.4	5.54	15.3	5.09
	-10.5	-11.0	19.7	6.54	18.6	6.09	17.5	5.65	16.9	5.44	16.4	5.22	15.3	4.81
	-9.5	-10.0	19.7	6.35	18.6	5.92	17.5	5.49	16.9	5.28	16.4	5.08	15.3	4.68
	-8.5	-9.1	19.7	6.19	18.6	5.77	17.5	5.36	16.9	5.16	16.4	4.96	15.3	4.57
	-7.0	-7.6	19.7	5.94	18.6	5.54	17.5	5.15	16.9	4.95	16.4	4.77	15.3	4.39
	-5.0	-5.6	19.7	5.64	18.6	5.26	17.5	4.89	16.9	4.71	16.4	4.53	15.3	4.18
	-3.0	-3.7	19.7	5.38	18.6	5.02	17.5	4.67	16.9	4.50	16.4	4.33	15.3	4.00
	0.0	-0.7	19.7	5.02	18.6	4.69	17.5	4.37	16.9	4.21	16.4	4.06	15.3	3.75
	3.0	2.2	19.7	4.71	18.6	4.41	17.5	4.11	16.9	3.96	16.4	3.82	15.3	3.54
	5.0	4.1	19.7	4.53	18.6	4.24	17.5	3.96	16.9	3.82	16.4	3.68	15.3	3.41
	7.0	6.0	19.7	4.37	18.6	4.09	17.5	3.82	16.9	3.69	16.4	3.55	15.3	3.30
	9.0	7.9	19.7	4.21	18.6	3.95	17.5	3.69	16.9	3.56	16.4	3.44	15.3	3.19
	11.0	9.8	19.7	4.07	18.6	3.82	17.5	3.57	16.9	3.45	16.4	3.33	15.3	3.09
	13.0	11.8	19.7	3.93	18.6	3.69	17.5	3.45	16.9	3.33	16.4	3.22	15.3	2.99
	15.0	13.7	19.7	3.81	18.6	3.58	17.5	3.35	16.9	3.24	16.4	3.12	15.3	2.90
60 (120)	-19.8	-20.0	15.7	6.49	15.7	6.62	15.0	6.32	14.5	6.08	14.0	5.83	13.1	5.36
	-18.8	-19.0	16.2	6.56	16.0	6.57	15.0	6.09	14.5	5.85	14.0	5.62	13.1	5.17
	-16.7	-17.0	16.9	6.57	16.0	6.12	15.0	5.67	14.5	5.46	14.0	5.24	13.1	4.83
	-14.7	-15.0	16.9	6.14	16.0	5.72	15.0	5.31	14.5	5.11	14.0	4.92	13.1	4.53
	-12.6	-13.0	16.9	5.76	16.0	5.38	15.0	5.00	14.5	4.81	14.0	4.63	13.1	4.27
	-10.5	-11.0	16.9	5.43	16.0	5.07	15.0	4.72	14.5	4.55	14.0	4.37	13.1	4.04
	-9.5	-10.0	16.9	5.28	16.0	4.93	15.0	4.59	14.5	4.42	14.0	4.26	13.1	3.94
	-8.5	-9.1	16.9	5.15	16.0	4.81	15.0	4.48	14.5	4.32	14.0	4.16	13.1	3.85
	-7.0	-7.6	16.9	4.95	16.0	4.63	15.0	4.31	14.5	4.16	14.0	4.01	13.1	3.71
	-5.0	-5.6	16.9	4.71	16.0	4.40	15.0	4.11	14.5	3.96	14.0	3.82	13.1	3.54
	-3.0	-3.7	16.9	4.50	16.0	4.21	15.0	3.93	14.5	3.79	14.0	3.66	13.1	3.39
	0.0	-0.7	16.9	4.21	16.0	3.94	15.0	3.68	14.5	3.56	14.0	3.43	13.1	3.18
	3.0	2.2	16.9	3.96	16.0	3.72	15.0	3.48	14.5	3.36	14.0	3.24	13.1	3.01
	5.0	4.1	16.9	3.82	16.0	3.58	15.0	3.35	14.5	3.24	14.0	3.13	13.1	2.91
	7.0	6.0	16.9	3.68	16.0	3.46	15.0	3.24	14.5	3.13	14.0	3.02	13.1	2.81
	9.0	7.9	16.9	3.56	16.0	3.34	15.0	3.13	14.5	3.03	14.0	2.93	13.1	2.72
	11.0	9.8	16.9	3.44	16.0	3.24	15.0	3.04	14.5	2.94	14.0	2.84	13.1	2.64
	13.0	11.8	16.9	3.33	16.0	3.13	15.0	2.94	14.5	2.84	14.0	2.75	13.1	2.56
	15.0	13.7	16.9	3.23	16.0	3.04	15.0	2.86	14.5	2.76	14.0	2.67	13.1	2.49
50 (100)	-19.8	-20.0	14.1	5.87	13.3	5.47	12.5	5.08	12.1	4.90	11.7	4.71	10.9	4.34
	-18.8	-19.0	14.1	5.66	13.3	5.28	12.5	4.91	12.1	4.72	11.7	4.55	10.9	4.20
	-16.7	-17.0	14.1	5.28	13.3	4.93	12.5	4.59	12.1	4.42	11.7	4.25	10.9	3.93
	-14.7	-15.0	14.1	4.95	13.3	4.62	12.5	4.31	12.1	4.15	11.7	4.00	10.9	3.70
	-12.6	-13.0	14.1	4.66	13.3	4.36	12.5	4.06	12.1	3.92	11.7	3.78	10.9	3.50
	-10.5	-11.0	14.1	4.40	13.3	4.12	12.5	3.85	12.1	3.71	11.7	3.58	10.9	3.32
	-9.5	-10.0	14.1	4.28	13.3	4.01	12.5	3.75	12.1	3.62	11.7	3.49	10.9	3.24
	-8.5	-9.1	14.1	4.18	13.3	3.92	12.5	3.66	12.1	3.54	11.7	3.41	10.9	3.17
	-7.0	-7.6	14.1	4.03	13.3	3.78	12.5	3.53	12.1	3.41	11.7	3.29	10.9	3.06
	-5.0	-5.6	14.1	3.84	13.3	3.60	12.5	3.37	12.1	3.26	11.7	3.14	10.9	2.92
	-3.0	-3.7	14.1	3.68	13.3	3.45	12.5	3.23	12.1	3.12	11.7	3.02	10.9	2.81
	0.0	-0.7	14.1	3.45	13.3	3.24	12.5	3.04	12.1	2.94	11.7	2.84	10.9	2.65
	3.0	2.2	14.1	3.26	13.3	3.06	12.5	2.88	12.1	2.78	11.7	2.69	10.9	2.51
	5.0	4.1	14.1	3.14	13.3	2.96	12.5	2.78	12.1	2.69	11.7	2.60	10.9	2.43
	7.0	6.0	14.1	3.04	13.3	2.86	12.5	2.69	12.1	2.60	11.7	2.52	10.9	2.35
	9.0	7.9	14.1	2.94	13.3	2.77	12.5	2.61	12.1	2.52	11.7	2.44	10.9	2.28
	11.0	9.8	14.1	2.85	13.3	2.69	12.5	2.53	12.1	2.45	11.7	2.37	10.9	2.22
	13.0	11.8	14.1	2.76	13.3	2.61	12.5	2.45	12.1	2.38	11.7	2.30	10.9	2.15
	15.0	13.7	14.1	2.69	13.3	2.54	12.5	2.39	12.1	2.31	11.7	2.24	10.9	2.10

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

14

RXYQ10PAY1, PAYL, PTL [50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (325)	-19.8	-20.0	20.4	5.44	20.3	5.82	20.2	6.21	20.2	6.40	20.1	6.59	20.1	6.98
	-18.8	-19.0	20.7	5.56	20.6	5.94	20.6	6.32	20.5	6.51	20.5	6.69	20.4	7.07
	-16.7	-17.0	21.5	5.82	21.4	6.18	21.3	6.55	21.3	6.73	21.3	6.91	21.2	7.27
	-14.7	-15.0	22.4	6.09	22.3	6.44	22.2	6.79	22.2	6.96	22.1	7.14	22.1	7.49
	-12.6	-13.0	23.3	6.36	23.3	6.70	23.2	7.03	23.1	7.20	23.1	7.37	23.0	7.70
	-10.5	-11.0	24.4	6.64	24.3	6.96	24.2	7.28	24.2	7.44	24.2	7.60	24.1	7.92
	-9.5	-10.0	25.0	6.78	24.9	7.09	24.8	7.40	24.8	7.56	24.7	7.71	24.7	8.02
	-8.5	-9.1	25.5	6.90	25.4	7.20	25.4	7.51	25.3	7.66	25.3	7.81	25.2	8.12
	-7.0	-7.6	26.4	7.10	26.4	7.40	26.3	7.69	26.3	7.84	26.2	7.98	26.1	8.28
	-5.0	-5.6	27.8	7.37	27.7	7.65	27.6	7.93	27.6	8.07	27.5	8.20	27.5	8.48
	-3.0	-3.7	29.1	7.61	29.0	7.88	29.0	8.14	28.9	8.28	28.9	8.41	28.8	8.67
	0.0	-0.7	31.4	7.98	31.4	8.23	31.3	8.47	31.3	8.59	31.2	8.72	31.2	8.96
	3.0	2.2	33.9	8.31	33.8	8.54	33.7	8.77	33.7	8.88	33.7	9.00	33.6	9.22
	5.0	4.1	35.6	8.52	35.5	8.74	35.5	8.95	35.4	9.06	35.4	9.17	35.3	9.38
	7.0	6.0	37.4	8.72	37.3	8.92	37.3	9.13	37.2	9.23	37.2	9.33	35.7	8.96
	9.0	7.9	39.3	8.90	39.2	9.10	39.2	9.29	39.1	9.39	38.3	9.19	35.7	8.42
	11.0	9.8	41.3	9.08	41.2	9.26	41.0	9.38	39.6	9.01	38.3	8.64	35.7	7.93
	13.0	11.8	43.5	9.25	43.4	9.43	41.0	8.79	39.6	8.44	38.3	8.11	35.7	7.44
	15.0	13.7	45.6	9.41	43.6	8.93	41.0	8.28	39.6	7.96	38.3	7.64	35.7	7.02
120 (300)	-19.8	-20.0	20.3	5.96	20.2	6.31	20.1	6.67	20.1	6.84	20.1	7.02	20.0	7.38
	-18.8	-19.0	20.6	6.07	20.5	6.42	20.5	6.77	20.4	6.94	20.4	7.12	20.3	7.47
	-16.7	-17.0	21.4	6.31	21.3	6.65	21.2	6.98	21.2	7.15	21.2	7.32	21.1	7.65
	-14.7	-15.0	22.3	6.56	22.2	6.88	22.1	7.20	22.1	7.37	22.1	7.53	22.0	7.85
	-12.6	-13.0	23.2	6.81	23.2	7.12	23.1	7.43	23.1	7.59	23.0	7.74	23.0	8.05
	-10.5	-11.0	24.3	7.07	24.2	7.36	24.2	7.66	24.1	7.81	24.1	7.95	24.0	8.25
	-9.5	-10.0	24.9	7.20	24.8	7.49	24.7	7.77	24.7	7.92	24.7	8.06	24.6	8.35
	-8.5	-9.1	25.4	7.31	25.3	7.59	25.3	7.87	25.2	8.01	25.2	8.16	25.1	8.44
	-7.0	-7.6	26.3	7.50	26.3	7.77	26.2	8.04	26.2	8.18	26.1	8.31	26.1	8.58
	-5.0	-5.6	27.7	7.74	27.6	8.00	27.5	8.26	27.5	8.39	27.5	8.52	27.4	8.77
	-3.0	-3.7	29.0	7.97	29.0	8.22	28.9	8.46	28.9	8.58	28.8	8.71	28.8	8.95
	0.0	-0.7	31.3	8.31	31.3	8.54	31.2	8.76	31.2	8.88	31.1	8.99	31.1	9.22
	3.0	2.2	33.8	8.62	33.7	8.83	33.7	9.04	33.6	9.15	33.6	9.25	32.9	9.20
	5.0	4.1	35.5	8.81	35.4	9.01	35.4	9.21	35.3	9.31	35.3	9.41	32.9	8.64
	7.0	6.0	37.3	8.99	37.3	9.18	37.2	9.37	36.6	9.24	35.4	8.86	32.9	8.13
	9.0	7.9	39.2	9.17	39.1	9.35	37.8	9.04	36.6	8.68	35.4	8.33	32.9	7.65
	11.0	9.8	41.2	9.33	40.2	9.17	37.8	8.50	36.6	8.17	35.4	7.84	32.9	7.21
	13.0	11.8	42.7	9.24	40.2	8.60	37.8	7.97	36.6	7.67	35.4	7.37	32.9	6.78
	15.0	13.7	42.7	8.70	40.2	8.10	37.8	7.52	36.6	7.23	35.4	6.95	32.9	6.40
110 (275)	-19.8	-20.0	20.2	6.48	20.1	6.80	20.0	7.13	20.0	7.29	20.0	7.45	19.9	7.78
	-18.8	-19.0	20.5	6.58	20.4	6.90	20.4	7.22	20.4	7.38	20.3	7.54	20.3	7.86
	-16.7	-17.0	21.3	6.80	21.2	7.11	21.2	7.42	21.1	7.57	21.1	7.73	21.0	8.03
	-14.7	-15.0	22.2	7.03	22.1	7.33	22.0	7.62	22.0	7.77	22.0	7.92	21.9	8.21
	-12.6	-13.0	23.1	7.27	23.1	7.55	23.0	7.83	23.0	7.97	22.9	8.11	22.9	8.40
	-10.5	-11.0	24.2	7.50	24.1	7.77	24.1	8.04	24.0	8.18	24.0	8.31	24.0	8.58
	-9.5	-10.0	24.8	7.62	24.7	7.88	24.6	8.15	24.6	8.28	24.6	8.41	24.5	8.67
	-8.5	-9.1	25.3	7.72	25.2	7.98	25.2	8.24	25.1	8.37	25.1	8.50	25.1	8.75
	-7.0	-7.6	26.2	7.90	26.2	8.14	26.1	8.39	26.1	8.52	26.1	8.64	26.0	8.89
	-5.0	-5.6	27.6	8.12	27.5	8.36	27.4	8.59	27.4	8.71	27.4	8.83	27.3	9.07
	-3.0	-3.7	28.9	8.33	28.9	8.55	28.8	8.78	28.8	8.89	28.7	9.00	28.7	9.23
	0.0	-0.7	31.2	8.64	31.2	8.85	31.1	9.06	31.1	9.16	31.1	9.27	30.2	9.09
	3.0	2.2	33.7	8.93	33.6	9.12	33.6	9.31	33.5	9.40	32.4	9.02	30.2	8.27
	5.0	4.1	35.4	9.10	35.4	9.29	34.7	9.20	33.5	8.83	32.4	8.48	30.2	7.78
	7.0	6.0	37.2	9.27	36.9	9.33	34.7	8.64	33.5	8.30	32.4	7.97	30.2	7.32
	9.0	7.9	39.1	9.42	36.9	8.77	34.7	8.13	33.5	7.81	32.4	7.50	30.2	6.90
	11.0	9.8	39.1	8.86	36.9	8.25	34.7	7.65	33.5	7.36	32.4	7.07	30.2	6.51
	13.0	11.8	39.1	8.31	36.9	7.74	34.7	7.19	33.5	6.92	32.4	6.65	30.2	6.13
	15.0	13.7	39.1	7.83	36.9	7.30	34.7	6.79	33.5	6.53	32.4	6.29	30.2	5.80

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (250)	-19.8	-20.0	20.1	7.00	20.0	7.29	20.0	7.59	19.9	7.74	19.9	7.88	19.8	8.18
	-18.8	-19.0	20.4	7.09	20.4	7.38	20.3	7.67	20.3	7.82	20.2	7.97	20.2	8.26
	-16.7	-17.0	21.2	7.29	21.1	7.57	21.1	7.85	21.0	7.99	21.0	8.13	21.0	8.41
	-14.7	-15.0	22.1	7.50	22.0	7.77	21.9	8.04	21.9	8.18	21.9	8.31	21.8	8.58
	-12.6	-13.0	23.0	7.72	23.0	7.97	22.9	8.23	22.9	8.36	22.9	8.49	22.8	8.75
	-10.5	-11.0	24.1	7.93	24.0	8.18	24.0	8.42	24.0	8.55	23.9	8.67	23.9	8.91
	-9.5	-10.0	24.7	8.04	24.6	8.28	24.6	8.52	24.5	8.64	24.5	8.76	24.4	9.00
	-8.5	-9.1	25.2	8.13	25.1	8.37	25.1	8.60	25.1	8.72	25.0	8.84	25.0	9.07
	-7.0	-7.6	26.1	8.29	26.1	8.52	26.0	8.74	26.0	8.86	26.0	8.97	25.9	9.20
	-5.0	-5.6	27.5	8.50	27.4	8.71	27.4	8.93	27.3	9.03	27.3	9.14	27.2	9.36
	-3.0	-3.7	28.8	8.69	28.8	8.89	28.7	9.10	28.7	9.20	28.7	9.30	27.5	8.91
	0.0	-0.7	31.1	8.97	31.1	9.16	31.0	9.35	30.5	9.20	29.5	8.82	27.5	8.09
	3.0	2.2	33.6	9.23	33.5	9.40	31.5	8.70	30.5	8.36	29.5	8.03	27.5	7.37
	5.0	4.1	35.3	9.40	33.5	8.83	31.5	8.18	30.5	7.87	29.5	7.56	27.5	6.95
	7.0	6.0	35.5	8.92	33.5	8.30	31.5	7.70	30.5	7.41	29.5	7.12	27.5	6.55
	9.0	7.9	35.5	8.38	33.5	7.81	31.5	7.25	30.5	6.98	29.5	6.71	27.5	6.18
	11.0	9.8	35.5	7.89	33.5	7.36	31.5	6.84	30.5	6.58	29.5	6.33	27.5	5.84
	13.0	11.8	35.5	7.41	33.5	6.92	31.5	6.44	30.5	6.20	29.5	5.97	27.5	5.51
	15.0	13.7	35.5	6.99	33.5	6.53	31.5	6.08	30.5	5.86	29.5	5.64	27.5	5.22
90 (225)	-19.8	-20.0	20.0	7.52	19.9	7.78	19.9	8.05	19.8	8.18	19.8	8.32	19.8	8.58
	-18.8	-19.0	20.3	7.60	20.3	7.87	20.2	8.13	20.2	8.26	20.2	8.39	20.1	8.65
	-16.7	-17.0	21.1	7.79	21.0	8.04	21.0	8.29	21.0	8.42	20.9	8.54	20.9	8.79
	-14.7	-15.0	22.0	7.98	21.9	8.22	21.9	8.46	21.8	8.58	21.8	8.70	21.8	8.94
	-12.6	-13.0	22.9	8.17	22.9	8.40	22.8	8.63	22.8	8.75	22.8	8.86	22.7	9.09
	-10.5	-11.0	24.0	8.36	24.0	8.58	23.9	8.80	23.9	8.91	23.9	9.03	23.8	9.25
	-9.5	-10.0	24.6	8.46	24.5	8.68	24.5	8.89	24.4	9.00	24.4	9.11	24.4	9.32
	-8.5	-9.1	25.1	8.55	25.1	8.76	25.0	8.97	25.0	9.07	25.0	9.18	24.7	9.27
	-7.0	-7.6	26.0	8.69	26.0	8.89	25.9	9.10	25.9	9.20	25.9	9.30	24.7	8.85
	-5.0	-5.6	27.4	8.88	27.3	9.07	27.3	9.26	27.2	9.36	26.5	9.07	24.7	8.32
	-3.0	-3.7	28.7	9.05	28.7	9.23	28.4	9.27	27.4	8.90	26.5	8.54	24.7	7.84
	0.0	-0.7	31.1	9.31	30.2	9.08	28.4	8.41	27.4	8.08	26.5	7.76	24.7	7.13
	3.0	2.2	32.0	8.87	30.2	8.26	28.4	7.66	27.4	7.37	26.5	7.08	24.7	6.52
	5.0	4.1	32.0	8.34	30.2	7.77	28.4	7.22	27.4	6.94	26.5	6.68	24.7	6.15
	7.0	6.0	32.0	7.84	30.2	7.32	28.4	6.80	27.4	6.55	26.5	6.30	24.7	5.81
	9.0	7.9	32.0	7.39	30.2	6.89	28.4	6.41	27.4	6.18	26.5	5.95	24.7	5.49
	11.0	9.8	32.0	6.96	30.2	6.50	28.4	6.06	27.4	5.84	26.5	5.62	24.7	5.20
	13.0	11.8	32.0	6.55	30.2	6.13	28.4	5.71	27.4	5.51	26.5	5.31	24.7	4.91
	15.0	13.7	32.0	6.19	30.2	5.79	28.4	5.41	27.4	5.22	26.5	5.03	24.7	4.66
80 (200)	-19.8	-20.0	19.9	8.04	19.8	8.27	19.8	8.51	19.8	8.63	19.7	8.75	19.7	8.98
	-18.8	-19.0	20.2	8.11	20.2	8.35	20.1	8.58	20.1	8.70	20.1	8.81	20.0	9.05
	-16.7	-17.0	21.0	8.28	20.9	8.50	20.9	8.73	20.9	8.84	20.9	8.95	20.8	9.17
	-14.7	-15.0	21.9	8.45	21.8	8.66	21.8	8.88	21.8	8.98	21.7	9.09	21.7	9.31
	-12.6	-13.0	22.8	8.62	22.8	8.83	22.7	9.03	22.7	9.13	22.7	9.24	22.0	8.99
	-10.5	-11.0	23.9	8.79	23.9	8.99	23.8	9.19	23.8	9.28	23.6	9.26	22.0	8.49
	-9.5	-10.0	24.5	8.88	24.4	9.07	24.4	9.26	24.4	9.36	23.6	8.99	22.0	8.24
	-8.5	-9.1	25.0	8.96	25.0	9.15	24.9	9.33	24.4	9.12	23.6	8.75	22.0	8.02
	-7.0	-7.6	25.9	9.09	25.9	9.27	25.2	9.07	24.4	8.71	23.6	8.36	22.0	7.67
	-5.0	-5.6	27.3	9.25	26.8	9.20	25.2	8.52	24.4	8.19	23.6	7.86	22.0	7.22
	-3.0	-3.7	28.4	9.30	26.8	8.66	25.2	8.02	24.4	7.72	23.6	7.41	22.0	6.82
	0.0	-0.7	28.4	8.44	26.8	7.86	25.2	7.30	24.4	7.03	23.6	6.75	22.0	6.22
	3.0	2.2	28.4	7.69	26.8	7.17	25.2	6.67	24.4	6.42	23.6	6.18	22.0	5.70
	5.0	4.1	28.4	7.24	26.8	6.76	25.2	6.29	24.4	6.06	23.6	5.84	22.0	5.39
	7.0	6.0	28.4	6.82	26.8	6.38	25.2	5.94	24.4	5.73	23.6	5.52	22.0	5.10
	9.0	7.9	28.4	6.44	26.8	6.02	25.2	5.61	24.4	5.41	23.6	5.22	22.0	4.83
	11.0	9.8	28.4	6.08	26.8	5.69	25.2	5.31	24.4	5.12	23.6	4.94	22.0	4.58
	13.0	11.8	28.4	5.73	26.8	5.37	25.2	5.02	24.4	4.84	23.6	4.67	22.0	4.33
	15.0	13.7	28.4	5.42	26.8	5.09	25.2	4.76	24.4	4.59	23.6	4.43	22.0	4.12

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0	
	°CDB	°CWB	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW
70 (175)	-19.8	-20.0	19.8	8.56	19.7	8.76	19.7	8.97	19.7	9.07	19.7	9.18	19.2	9.08
	-18.8	-19.0	20.1	8.63	20.1	8.83	20.0	9.03	20.0	9.13	20.0	9.24	19.2	8.89
	-16.7	-17.0	20.9	8.77	20.9	8.97	20.8	9.16	20.8	9.26	20.6	9.25	19.2	8.48
	-14.7	-15.0	21.8	8.92	21.7	9.11	21.7	9.30	21.3	9.16	20.6	8.79	19.2	8.06
	-12.6	-13.0	22.7	9.07	22.7	9.25	22.1	9.03	21.3	8.68	20.6	8.33	19.2	7.64
	-10.5	-11.0	23.8	9.22	23.5	9.21	22.1	8.53	21.3	8.20	20.6	7.87	19.2	7.23
	-9.5	-10.0	24.4	9.30	23.5	8.94	22.1	8.28	21.3	7.96	20.6	7.65	19.2	7.03
	-8.5	-9.1	24.9	9.35	23.5	8.70	22.1	8.06	21.3	7.75	20.6	7.45	19.2	6.85
	-7.0	-7.6	24.9	8.93	23.5	8.31	22.1	7.71	21.3	7.42	20.6	7.13	19.2	6.56
	-5.0	-5.6	24.9	8.39	23.5	7.82	22.1	7.26	21.3	6.98	20.6	6.71	19.2	6.19
	-3.0	-3.7	24.9	7.90	23.5	7.37	22.1	6.85	21.3	6.59	20.6	6.34	19.2	5.85
	0.0	-0.7	24.9	7.19	23.5	6.72	22.1	6.25	21.3	6.02	20.6	5.80	19.2	5.36
	3.0	2.2	24.9	6.57	23.5	6.15	22.1	5.73	21.3	5.52	20.6	5.32	19.2	4.92
	5.0	4.1	24.9	6.20	23.5	5.80	22.1	5.42	21.3	5.22	20.6	5.03	19.2	4.66
	7.0	6.0	24.9	5.86	23.5	5.49	22.1	5.12	21.3	4.94	20.6	4.77	19.2	4.42
	9.0	7.9	24.9	5.54	23.5	5.19	22.1	4.85	21.3	4.68	20.6	4.52	19.2	4.19
	11.0	9.8	24.9	5.24	23.5	4.91	22.1	4.60	21.3	4.44	20.6	4.29	19.2	3.98
	13.0	11.8	24.9	4.95	23.5	4.65	22.1	4.35	21.3	4.21	20.6	4.06	19.2	3.78
	15.0	13.7	24.9	4.69	23.5	4.41	22.1	4.13	21.3	4.00	20.6	3.86	19.2	3.60
60 (150)	-19.8	-20.0	19.7	9.08	19.6	9.25	18.9	8.90	18.3	8.55	17.7	8.21	16.5	7.53
	-18.8	-19.0	20.0	9.14	20.0	9.31	18.9	8.71	18.3	8.37	17.7	8.03	16.5	7.37
	-16.7	-17.0	20.8	9.26	20.1	8.97	18.9	8.31	18.3	7.99	17.7	7.67	16.5	7.05
	-14.7	-15.0	21.3	9.16	20.1	8.52	18.9	7.90	18.3	7.60	17.7	7.30	16.5	6.71
	-12.6	-13.0	21.3	8.67	20.1	8.07	18.9	7.49	18.3	7.21	17.7	6.93	16.5	6.38
	-10.5	-11.0	21.3	8.19	20.1	7.63	18.9	7.09	18.3	6.82	17.7	6.56	16.5	6.05
	-9.5	-10.0	21.3	7.96	20.1	7.42	18.9	6.89	18.3	6.64	17.7	6.38	16.5	5.88
	-8.5	-9.1	21.3	7.75	20.1	7.23	18.9	6.72	18.3	6.47	17.7	6.22	16.5	5.74
	-7.0	-7.6	21.3	7.41	20.1	6.92	18.9	6.43	18.3	6.20	17.7	5.96	16.5	5.51
	-5.0	-5.6	21.3	6.98	20.1	6.52	18.9	6.07	18.3	5.85	17.7	5.63	16.5	5.21
	-3.0	-3.7	21.3	6.59	20.1	6.16	18.9	5.74	18.3	5.54	17.7	5.33	16.5	4.93
	0.0	-0.7	21.3	6.02	20.1	5.64	18.9	5.26	18.3	5.08	17.7	4.89	16.5	4.53
	3.0	2.2	21.3	5.52	20.1	5.18	18.9	4.84	18.3	4.67	17.7	4.51	16.5	4.18
	5.0	4.1	21.3	5.22	20.1	4.90	18.9	4.58	18.3	4.43	17.7	4.27	16.5	3.97
	7.0	6.0	21.3	4.94	20.1	4.64	18.9	4.34	18.3	4.20	17.7	4.06	16.5	3.77
	9.0	7.9	21.3	4.68	20.1	4.40	18.9	4.12	18.3	3.99	17.7	3.85	16.5	3.59
	11.0	9.8	21.3	4.44	20.1	4.18	18.9	3.92	18.3	3.79	17.7	3.66	16.5	3.42
	13.0	11.8	21.3	4.20	20.1	3.96	18.9	3.72	18.3	3.60	17.7	3.48	16.5	3.25
	15.0	13.7	21.3	4.00	20.1	3.76	18.9	3.54	18.3	3.43	17.7	3.32	16.5	3.10
50 (125)	-19.8	-20.0	17.8	8.26	16.8	7.69	15.8	7.14	15.2	6.88	14.7	6.61	13.7	6.09
	-18.8	-19.0	17.8	8.08	16.8	7.53	15.8	7.00	15.2	6.73	14.7	6.47	13.7	5.97
	-16.7	-17.0	17.8	7.71	16.8	7.19	15.8	6.69	15.2	6.44	14.7	6.20	13.7	5.72
	-14.7	-15.0	17.8	7.34	16.8	6.85	15.8	6.37	15.2	6.14	14.7	5.91	13.7	5.46
	-12.6	-13.0	17.8	6.97	16.8	6.51	15.8	6.06	15.2	5.84	14.7	5.62	13.7	5.20
	-10.5	-11.0	17.8	6.60	16.8	6.17	15.8	5.75	15.2	5.54	14.7	5.34	13.7	4.94
	-9.5	-10.0	17.8	6.42	16.8	6.00	15.8	5.60	15.2	5.40	14.7	5.20	13.7	4.81
	-8.5	-9.1	17.8	6.26	16.8	5.86	15.8	5.46	15.2	5.27	14.7	5.08	13.7	4.70
	-7.0	-7.6	17.8	6.00	16.8	5.62	15.8	5.24	15.2	5.06	14.7	4.88	13.7	4.52
	-5.0	-5.6	17.8	5.66	16.8	5.31	15.8	4.96	15.2	4.79	14.7	4.62	13.7	4.28
	-3.0	-3.7	17.8	5.36	16.8	5.03	15.8	4.70	15.2	4.54	14.7	4.38	13.7	4.07
	0.0	-0.7	17.8	4.92	16.8	4.62	15.8	4.33	15.2	4.18	14.7	4.04	13.7	3.76
	3.0	2.2	17.8	4.53	16.8	4.26	15.8	3.99	15.2	3.86	14.7	3.73	13.7	3.46
	5.0	4.1	17.8	4.30	16.8	4.04	15.8	3.79	15.2	3.67	14.7	3.55	13.7	3.31
	7.0	6.0	17.8	4.08	16.8	3.84	15.8	3.61	15.2	3.49	14.7	3.38	13.7	3.16
	9.0	7.9	17.8	3.87	16.8	3.65	15.8	3.43	15.2	3.33	14.7	3.22	13.7	3.01
	11.0	9.8	17.8	3.68	16.8	3.47	15.8	3.27	15.2	3.17	14.7	3.07	13.7	2.87
	13.0	11.8	17.8	3.50	16.8	3.30	15.8	3.11	15.2	3.02	14.7	2.92	13.7	2.74
	15.0	13.7	17.8	3.33	16.8	3.15	15.8	2.97	15.2	2.88	14.7	2.79	13.7	2.62

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ■.
Note2: The above table shows the average value of conditions which may occur.

14

RXYQ12PAY1, PAYL, PTL [50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.	Indoor air temp. °CDB																					
		16.0			18.0			20.0			21.0			22.0			24.0						
		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI	
	°CDB	°CWB	kW	kW		kW	kW		kW	kW		kW	kW		kW	kW		kW	kW		kW	kW	
130 (390)	-19.8	-20.0	23.7	6.00		23.6	6.46		23.5	6.91		23.5	7.14		23.5	7.36		23.4	7.82				
	-18.8	-19.0	24.1	6.15		24.1	6.60		24.0	7.04		23.9	7.27		23.9	7.49		23.8	7.94				
	-16.7	-17.0	25.1	6.47		25.0	6.89		24.9	7.32		24.9	7.53		24.8	7.75		24.7	8.18				
	-14.7	-15.0	26.1	6.78		26.0	7.19		25.9	7.60		25.9	7.81		25.9	8.01		25.8	8.42				
	-12.6	-13.0	27.2	7.10		27.2	7.50		27.1	7.89		27.0	8.08		27.0	8.28		26.9	8.67				
	-10.5	-11.0	28.5	7.42		28.4	7.80		28.3	8.17		28.3	8.36		28.2	8.54		28.2	8.92				
	-9.5	-10.0	29.2	7.58		29.1	7.95		29.0	8.31		28.9	8.49		28.9	8.68		28.8	9.04				
	-8.5	-9.1	29.8	7.72		29.7	8.08		29.6	8.44		29.6	8.62		29.5	8.79		29.4	9.15				
	-7.0	-7.6	30.9	7.95		30.8	8.30		30.7	8.64		30.6	8.81		30.6	8.99		30.5	9.33				
	-5.0	-5.6	32.4	8.26		32.3	8.58		32.2	8.91		32.2	9.07		32.1	9.24		32.0	9.56				
	-3.0	-3.7	33.9	8.53		33.9	8.84		33.8	9.16		33.7	9.31		33.7	9.47		33.6	9.78				
	0.0	-0.7	36.6	8.95		36.5	9.24		36.4	9.52		36.4	9.67		36.3	9.81		36.2	10.10				
	3.0	2.2	39.4	9.32		39.3	9.59		39.2	9.86		39.1	9.99		39.1	10.12		39.0	10.39				
	5.0	4.1	41.3	9.55		41.2	9.81		41.1	10.06		41.1	10.19		41.0	10.31		41.0	10.57				
	7.0	6.1	43.3	9.77		43.2	10.01		43.2	10.26		43.1	10.38		43.1	10.50		42.5	10.64				
	9.0	7.9	45.5	9.98		45.4	10.21		45.3	10.44		45.2	10.55		45.2	10.67		42.5	9.92				
	11.0	9.8	47.7	10.18		47.6	10.40		47.5	10.61		47.2	10.62		45.6	10.19		42.5	9.35				
	13.0	11.8	50.1	10.37		50.0	10.58		48.8	10.38		47.2	9.97		45.6	9.57		42.5	8.79				
	15.0	13.7	52.5	10.55		51.9	10.56		48.8	9.79		47.2	9.41		45.6	9.03		42.5	8.30				
120 (360)	-19.8	-20.0	23.6	6.62		23.5	7.04		23.4	7.45		23.4	7.66		23.4	7.87		23.3	8.29				
	-18.8	-19.0	24.0	6.76		23.9	7.17		23.9	7.58		23.8	7.78		23.8	7.99		23.7	8.40				
	-16.7	-17.0	25.0	7.04		24.9	7.44		24.8	7.83		24.8	8.03		24.7	8.23		24.6	8.62				
	-14.7	-15.0	26.0	7.34		25.9	7.72		25.8	8.09		25.8	8.28		25.8	8.47		25.7	8.85				
	-12.6	-13.0	27.1	7.63		27.1	7.99		27.0	8.36		26.9	8.54		26.9	8.72		26.8	9.08				
	-10.5	-11.0	28.4	7.93		28.3	8.27		28.2	8.62		28.2	8.79		28.1	8.96		28.1	9.31				
	-9.5	-10.0	29.0	8.07		29.0	8.41		28.9	8.75		28.8	8.92		28.8	9.09		28.7	9.42				
	-8.5	-9.1	29.7	8.21		29.6	8.53		29.5	8.86		29.5	9.03		29.4	9.19		29.3	9.52				
	-7.0	-7.6	30.7	8.42		30.7	8.74		30.6	9.05		30.5	9.21		30.5	9.37		30.4	9.69				
	-5.0	-5.6	32.3	8.70		32.2	9.00		32.1	9.30		32.1	9.45		32.0	9.60		32.0	9.90				
	-3.0	-3.7	33.8	8.95		33.7	9.24		33.7	9.53		33.6	9.67		33.6	9.82		33.5	10.10				
	0.0	-0.7	36.5	9.34		36.4	9.60		36.3	9.87		36.3	10.00		36.2	10.13		36.1	10.40				
	3.0	2.2	39.2	9.68		39.2	9.93		39.1	10.18		39.0	10.30		39.0	10.42		38.9	10.67				
	5.0	4.1	41.2	9.90		41.1	10.13		41.0	10.36		41.0	10.48		40.9	10.60		39.2	10.16				
	7.0	6.0	43.2	10.10		43.1	10.32		43.1	10.54		43.0	10.66		42.1	10.43		39.2	9.56				
	9.0	7.9	45.3	10.29		45.3	10.50		45.2	10.65		43.6	10.23		42.1	9.81		39.2	9.01				
	11.0	9.8	47.6	10.47		47.5	10.67		45.0	10.02		43.6	9.63		42.1	9.25		39.2	8.50				
	13.0	11.8	50.0	10.65		47.9	10.16		45.0	9.42		43.6	9.06		42.1	8.70		39.2	8.00				
	15.0	13.7	50.8	10.29		47.9	9.58		45.0	8.89		43.6	8.55		42.1	8.22		39.2	7.57				
110 (330)	-19.8	-20.0	23.5	7.23		23.4	7.61		23.3	8.00		23.3	8.19		23.3	8.38		23.2	8.76				
	-18.8	-19.0	23.9	7.36		23.8	7.73		23.8	8.11		23.7	8.30		23.7	8.49		23.6	8.86				
	-16.7	-17.0	24.8	7.62		24.8	7.98		24.7	8.34		24.7	8.53		24.6	8.71		24.5	9.07				
	-14.7	-15.0	25.9	7.89		25.8	8.24		25.7	8.58		25.7	8.76		25.7	8.93		25.6	9.28				
	-12.6	-13.0	27.0	8.16		26.9	8.49		26.9	8.83		26.8	8.99		26.8	9.16		26.7	9.49				
	-10.5	-11.0	28.3	8.43		28.2	8.75		28.1	9.07		28.1	9.22		28.0	9.38		28.0	9.70				
	-9.5	-10.0	28.9	8.57		28.9	8.88		28.8	9.18		28.7	9.34		28.7	9.49		28.6	9.80				
	-8.5	-9.1	29.5	8.69		29.5	8.99		29.4	9.29		29.4	9.44		29.3	9.59		29.3	9.90				
	-7.0	-7.6	30.6	8.88		30.6	9.17		30.5	9.47		30.4	9.61		30.4	9.76		30.3	10.05				
	-5.0	-5.6	32.2	9.14		32.1	9.42		32.0	9.69		32.0	9.83		31.9	9.97		31.9	10.25				
	-3.0	-3.7	33.7	9.37		33.6	9.64		33.6	9.90		33.5	10.03		33.4	10.16		33.4	10.43				
	0.0	-0.7	36.3	9.73		36.3	9.97		36.2	10.21		36.2	10.33		36.1	10.46		35.9	10.65				
	3.0	2.2	39.1	10.04		39.1	10.27		39.0	10.49		38.9	10.61		38.9	10.59		35.9	9.71				
	5.0	4.1	41.1	10.24		41.0	10.45		40.9	10.67		38.9	10.38		38.6	9.96		35.9	9.14				
	7.0	6.1	43.1	10.42		43.0	10.63		41.3	10.17		38.9	9.77		38.6	9.38		35.9	8.62				
	9.0	7.9	45.2	10.60		43.9	10.33		41.3	9.57		38.9	9.20		38.6	8.84		35.9	8.13				
	11.0	9.8	46.6	10.45		43.9	9.73		41.3	9.02		38.9	8.68		38.6	8.34		35.9	7.68				
	13.0	11.8	46.6	9.81		43.9	9.14		41.3	8.49		38.9	8.17		38.6	7.86		35.9	7.24				
	15.0	13.7	46.6	9.26		43.9	8.63		41.3	8.02		38.9	7.73		38.6	7.43		35.9	6.85				

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.	Indoor air temp. °CDB																					
		16.0			18.0			20.0			21.0			22.0			24.0						
		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI	
	°CDB	°CWB	kW	kW		kW	kW		kW	kW		kW	kW		kW	kW		kW	kW		kW	kW	
100 (300)	-19.8	-20.0	23.4	7.84		23.3	7.96		23.2	8.07		23.2	8.13		23.2	8.19		23.1	8.31				
	-18.8	-19.0	23.8	7.96		23.7	8.07		23.6	8.19		23.6	8.24		23.6	8.30		23.5	8.42				
	-16.7	-17.0	24.7	8.20		24.7	8.31		24.6	8.42		24.5	8.47		24.5	8.53		24.4	8.65				
	-14.7	-15.0	25.8	8.44		25.7	8.54		25.7	8.65		25.6	8.70		25.6	8.76		25.5	8.87				
	-12.6	-13.0	26.9	8.69		26.8	8.80		26.8	8.91		26.7	8.96		26.7	9.02		26.6	9.13				
	-10.5	-11.0	28.1	8.94		28.1	9.06		28.0	9.17		28.0	9.23		28.0	9.29		27.9	9.40				
	-9.5	-10.0	28.8	9.06		28.7	9.17		28.7	9.28		28.6	9.34		28.6	9.40		28.5	9.51				
	-8.5	-9.1	29.4	9.17		29.4	9.28		29.3	9.39		29.3	9.44		29.3	9.50		29.2	9.62				
	-7.0	-7.6	30.5	9.35		30.4	9.46		30.4	9.57		30.4	9.61		30.4	9.67		30.3	9.78				
	-5.0	-5.6	32.0	9.58		32.0	9.69		31.9	9.80		31.9	9.83		31.9	9.89		31.8	10.00				
	-3.0	-3.7	33.6	9.79		33.5	10.03		33.5	10.03		33.5	10.03		33.5	10.03		33.4	10.27				
	0.0	-0.7	36.2	10.11		36.2	10.40		36.1	10.58		35.9	10.02		35.9	10.02		35.9	10.25				
	3.0	2.2	39.0	10.40		38.9	10.58		37.5	9.06		35.9	9.01		35.9	9.01		35.9	9.22				
	5.0	4.1	40.9	10.58		39.9	9.87		37.5	8.54		35.9	8.68		35.9	8.68		35.9	8.87				
	7.0	6.1	42.3	9.87		39.9	9.20		37.5	8.06		35.9	8.17		35.9	8.17		35.9	8.37				
	9.0	7.9	42.3	9.30		39.9	8.68		37.5	7.60		35.9	7.72		35.9	7.72		35.9	7.91				
	11.0	9.8	42.3	8.75		39.9	8.17		37.5	7.19		35.9	7.25		35.9	7.25		35.9	7.44				
	13.0	11.8	42.3	8.27		39.9	7.72		37.5	6.93		35.9	6.97		35.9	6.97		35.9	7.04				
	15.0	13.7	42.3	8.27		39.9	7.72		37.5	7.19		35.9	7.25		35.9	7.25		35.9	7.44				
90 (270)	-19.8	-20.0	23.2	8.46		23.2	8.56		23.1	8.66		23.1	8.71		23.1	8.77		23.1	9.08		23.1	9.24	
	-18.8	-19.0	23.7	8.56		23.6	8.66		23.6	8.77		23.6	8.82		23.6	8.87		23.6	9.18		23.5	9.33	
	-16.7	-17.0	24.6	8.78		24.5	8.88		24.5	8.99		24.5	9.04		24.5	9.07		24.5	9.37		24.5	9.52	
	-14.7	-15.0	25.6	9.00		25.6	9.10		25.6	9.21		25.6	9.26		25.6	9.28		25.5	9.57		25.5	9.71	
	-12.6	-13.0	26.8	9.22		26.7	9.32		26.7	9.43		26.7	9.48		26.7	9.49		26.7	9.76		26.6	9.90	
	-10.5	-11.0	28.0	9.44		28.0	9.55		28.0	9.65		28.0	9.70		28.0	9.70		27.9	9.96		27.9	10.09	
	-9.5	-10.0	28.7	9.55		28.6	9.65		28.6	9.76		28.6	9.81		28.6	9.81		28.6	10.06		28.5	10.18	
	-8.5	-9.1	29.3	9.65		29.3	9.75		29.2	9.86		29.2	9.90		29.2	9.90		29.2	10.15		29.2	10.27	
	-7.0	-7.6	30.4	9.81		30.3	10.05		30.3	10.05		30.3	10.05		30.3	10.05		30.3	10.29		30.2	10.41	
	-5.0	-5.6	31.9	10.02		31.9	10.25		31.8	10.47		31.8	10.47		31.8	10.47		31.8	10.47		31.8	10.59	
	-3.0	-3.7	33.5	10.21		33.4	10.43		33.4	10.65		33.4	10.65		33.4	10.65		33.4	10.65		32.7	10.42	
	0.0	-0.7	36.1	10.41		35.9	9.70		35.9	9.70		35.9	9.70		35.9	9.70		33.8	9.00		32.7	8.65	
	3.0	2.2	38.1	10.60		35.9	9.13		35.9	9.13		35.9	9.13		35.9	9.13		33.8	8.48		32.7	8.16	
	5.0	4.1	38.1	9.80		35.9	8.61		35.9	8.61		35.9	8.61		35.9	8.61		33.8	8.00		32.7	7.70	
	7.0	6.0	38.1	9.23		35.9	8.12		35.9	8.12		35.9	8.12		35.9	8.12		33.8	7.56		32.7	7.28	
	9.0	7.9	38.1	8.70		35.9	7.67		35.9	7.67		35.9	7.67		35.9	7.67		33.8	7.14		32.7	6.88	
	11.0	9.8	38.1	8.21		35.9	7.23		35.9	7.23		35.9	7.23		35.9	7.23		33.8	6.74		32.7	6.50	
	13.0	11.8	38.1	7.74		35.9	6.85		35.9	6.85		35.9	6.85		35.9	6.85		33.8	6.39		32.7	6.16	
	15.0	13.7	38.1	7.32		35.9	6.85		35.9	6.85		35.9	6.85		35.9	6.85		33.8	6.39		32.7	6.16	
80 (240)	-19.8	-20.0	23.1	9.07		23.1	9.07		23.0	9.07		23.0	9.07		23.0	9.35		23.0	9.63		23.0	9.77	
	-18.8	-19.0	23.6	9.16		23.5	9.16		23.5	9.16		23.5	9.16		23.5	9.35		23.5	9.71		23.4	9.85	
	-16.7	-17.0	24.5	9.35		24.4	9.62		24.4	9.62		24.4	9.62		24.4	9.88		24.4	10.01		24.3	10.14	
	-14.7	-15.0	25.5	9.55		25.5	9.80		25.4	10.06		25.4	10.18		25.4	10.31		25.3	10.56				
	-12.6	-13.0	26.7	9.75		26.6	9.99		26.6	10.23		26.5	10.35		26.5	10.47		26.1	10.51				
	-10.5	-11.0	27.9	9.95		27.9	10.18		27.8	10.41		27.8	10.52		27.8	10.64		26.1	9.92				
	-9.5	-10.0	28.6	10.05		28.5	10.27		28.4	10.50		28.1	10.61		28.1	10.51		26.1	9.64				
	-8.5	-9.1	29.1	10.13		29.1	10.35		29.0	10.57		29.0	10.66		28.1	10.23		26.1	9.38				
	-7.0	-7.6	30.2	10.28		30.0	10.49		30.0	10.60		29.0	10.19		28.1	9.78		26.1	8.97				
	-5.0	-5.6	31.8	10.46		30.0	10.66		30.0	9.97		29.0	9.58		28.1	9.20		26.1	8.45				
	-3.0	-3.7	31.9	10.13		30.0	9.39		29.0	9.03		28.1	8.68		26.1	7.98							
	0.0	-0.7	31.9	9.89		30.0	8.56		29.0	8.24		28.1	7.92		26.1	7.30							
	5.0	4.1	31.9	8.51		30.0	7.40		29.0	7.13		28.1	6.86		26.1	6.34							
	7.0	6.0	31.9	8.03		30.0	6.99		29.0	6.74		28.1	6.49		26.1	6.00							
	9.0	7.9	31.9	7.58		30.0	6.61		29.0	6.38		28.1	6.14		26.1	5.69							
	11.0	9.8	31.9	7.17		30.0	6.26		29.0	6.04		28.1	5.82		26.1	5.40							
	13.0	11.8	31.9	6.77		30.0	5.92		29.0	5.72		28.1	5.51		26.1	5.11							
	15.0	13.7	33.9	6.41		30.0	5.62		29.0	5.43		28.1	5.24		26.1	4.86							

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ▒ shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0			18.0			20.0			21.0			22.0			24.0	
			TC	PI		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI
	°CDB	°CWB	kW	kW		kW	kW		kW	kW		kW	kW		kW	kW		kW	kW
70 (210)	-19.8	-20.0	23.0	9.66		23.0	9.93		22.9	10.17		22.9	10.29		22.9	10.41		22.8	10.66
	-18.8	-19.0	23.4	9.76		23.4	10.00		23.4	10.24		23.3	10.36		23.3	10.48		22.9	10.44
	-16.7	-17.0	24.4	9.93		24.3	10.16		24.3	10.39		24.3	10.51		24.2	10.62		22.9	9.94
	-14.7	-15.0	25.4	10.10		25.4	10.33		25.3	10.55		25.3	10.66		24.6	10.29		22.9	9.44
	-12.6	-13.0	26.6	10.28		26.5	10.49		26.3	10.57		25.4	10.15		24.6	9.74		22.9	8.94
	-10.5	-11.0	27.8	10.45		27.8	10.65		26.3	9.97		25.4	9.58		24.6	9.20		22.9	8.46
	-9.5	-10.0	28.5	10.54		27.9	10.45		26.3	9.68		25.4	9.31		24.6	8.94		22.9	8.22
	-8.5	-9.1	29.1	10.62		27.9	10.17		26.3	9.43		25.4	9.07		24.6	8.71		22.9	8.01
	-7.0	-7.6	29.6	10.44		27.9	9.72		26.3	9.02		25.4	8.67		24.6	8.33		22.9	7.67
	-5.0	-5.6	29.6	9.81		27.9	9.14		26.3	8.49		25.4	8.17		24.6	7.86		22.9	7.24
	-3.0	-3.7	29.6	9.25		27.9	8.63		26.3	8.02		25.4	7.72		24.6	7.43		22.9	6.85
	0.0	-0.7	29.6	8.43		27.9	7.87		26.3	7.33		25.4	7.06		24.6	6.80		22.9	6.28
	3.0	2.2	29.6	7.72		27.9	7.22		26.3	6.73		25.4	6.49		24.6	6.25		22.9	5.78
	5.0	4.1	29.6	7.29		27.9	6.82		26.3	6.36		25.4	6.14		24.6	5.92		22.9	5.48
	7.0	6.0	29.6	6.89		27.9	6.45		26.3	6.03		25.4	5.82		24.6	5.61		22.9	5.20
	9.0	7.9	29.6	6.52		27.9	6.11		26.3	5.71		25.4	5.52		24.6	5.32		22.9	4.94
	11.0	9.8	29.6	6.18		27.9	5.79		26.3	5.42		25.4	5.24		24.6	5.05		22.9	4.70
	13.0	11.8	29.6	5.84		27.9	5.48		26.3	5.14		25.4	4.96		24.6	4.79		22.9	4.46
	15.0	13.7	29.6	5.54		27.9	5.21		26.3	4.88		25.4	4.72		24.6	4.56		22.9	4.25
60 (180)	-19.8	-20.0	22.9	10.29		22.9	10.50		22.5	10.47		21.8	10.06		21.1	9.66		19.6	8.87
	-18.8	-19.0	23.3	10.36		23.3	10.57		22.5	10.23		21.8	9.83		21.1	9.44		19.6	8.67
	-16.7	-17.0	24.3	10.51		23.9	10.52		22.5	9.74		21.8	9.37		21.1	9.00		19.6	8.27
	-14.7	-15.0	25.3	10.66		23.9	9.98		22.5	9.25		21.8	8.90		21.1	8.55		19.6	7.87
	-12.6	-13.0	25.4	10.14		23.9	9.45		22.5	8.77		21.8	8.44		21.1	8.11		19.6	7.47
	-10.5	-11.0	25.4	9.58		23.9	8.93		22.5	8.29		21.8	7.98		21.1	7.68		19.6	7.08
	-9.5	-10.0	25.4	9.30		23.9	8.67		22.5	8.06		21.8	7.76		21.1	7.47		19.6	6.89
	-8.5	-9.1	25.4	9.06		23.9	8.45		22.5	7.86		21.8	7.57		21.1	7.28		19.6	6.72
	-7.0	-7.6	25.4	8.67		23.9	8.09		22.5	7.53		21.8	7.25		21.1	6.98		19.6	6.44
	-5.0	-5.6	25.4	8.17		23.9	7.63		22.5	7.10		21.8	6.85		21.1	6.59		19.6	6.10
	-3.0	-3.7	25.4	7.72		23.9	7.21		22.5	6.72		21.8	6.48		21.1	6.25		19.6	5.78
	0.0	-0.7	25.4	7.06		23.9	6.61		22.5	6.17		21.8	5.95		21.1	5.74		19.6	5.32
	3.0	2.2	25.4	6.48		23.9	6.08		22.5	5.68		21.8	5.49		21.1	5.29		19.6	4.91
	5.0	4.1	25.4	6.14		23.9	5.76		22.5	5.39		21.8	5.20		21.1	5.02		19.6	4.67
	7.0	6.0	25.4	5.81		23.9	5.46		22.5	5.11		21.8	4.94		21.1	4.77		19.6	4.44
	9.0	7.9	25.4	5.51		23.9	5.18		22.5	4.86		21.8	4.70		21.1	4.54		19.6	4.23
	11.0	9.8	25.4	5.23		23.9	4.92		22.5	4.62		21.8	4.47		21.1	4.32		19.6	4.03
	13.0	11.8	25.4	4.96		23.9	4.67		22.5	4.38		21.8	4.24		21.1	4.11		19.6	3.83
	15.0	13.7	25.4	4.72		23.9	4.45		22.5	4.18		21.8	4.05		21.1	3.92		19.6	3.66
50 (150)	-19.8	-20.0	21.2	9.72		20.0	9.05		18.8	8.41		18.1	8.09		17.5	7.78		16.3	7.17
	-18.8	-19.0	21.2	9.50		20.0	8.85		18.8	8.22		18.1	7.92		17.5	7.61		16.3	7.02
	-16.7	-17.0	21.2	9.05		20.0	8.44		18.8	7.85		18.1	7.56		17.5	7.27		16.3	6.71
	-14.7	-15.0	21.2	8.60		20.0	8.03		18.8	7.47		18.1	7.20		17.5	6.93		16.3	6.40
	-12.6	-13.0	21.2	8.16		20.0	7.62		18.8	7.10		18.1	6.84		17.5	6.58		16.3	6.09
	-10.5	-11.0	21.2	7.72		20.0	7.22		18.8	6.73		18.1	6.49		17.5	6.25		16.3	5.78
	-9.5	-10.0	21.2	7.51		20.0	7.02		18.8	6.55		18.1	6.32		17.5	6.09		16.3	5.64
	-8.5	-9.1	21.2	7.32		20.0	6.85		18.8	6.39		18.1	6.17		17.5	5.94		16.3	5.50
	-7.0	-7.6	21.2	7.02		20.0	6.57		18.8	6.13		18.1	5.92		17.5	5.71		16.3	5.29
	-5.0	-5.6	21.2	6.63		20.0	6.21		18.8	5.81		18.1	5.61		17.5	5.41		16.3	5.02
	-3.0	-3.7	21.2	6.28		20.0	5.89		18.8	5.51		18.1	5.32		17.5	5.14		16.3	4.77
	0.0	-0.7	21.2	5.77		20.0	5.42		18.8	5.07		18.1	4.91		17.5	4.74		16.3	4.41
	3.0	2.2	21.2	5.32		20.0	5.00		18.8	4.69		18.1	4.54		17.5	4.39		16.3	4.09
	5.0	4.1	21.2	5.05		20.0	4.75		18.8	4.46		18.1	4.32		17.5	4.17		16.3	3.89
	7.0	6.0	21.2	4.80		20.0	4.52		18.8	4.25		18.1	4.11		17.5	3.98		16.3	3.71
	9.0	7.9	21.2	4.56		20.0	4.30		18.8	4.04		18.1	3.92		17.5	3.79		16.3	3.54
	11.0	9.8	21.2	4.34		20.0	4.10		18.8	3.85		18.1	3.74		17.5	3.62		16.3	3.38
	13.0	11.8	21.2	4.13		20.0	3.90		18.8	3.67		18.1	3.56		17.5	3.45		16.3	3.23
	15.0	13.7	21.2	3.94		20.0	3.72		18.8	3.51		18.1	3.40		17.5	3.30		16.3	3.09

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (461)	-19.8	-20.0	28.1	7.25	28.0	7.82	27.9	8.38	27.9	8.66	27.8	8.95	27.7	9.51
	-18.8	-19.0	28.7	7.44	28.5	7.99	28.4	8.55	28.4	8.83	28.3	9.10	28.2	9.66
	-16.7	-17.0	29.8	7.82	29.7	8.36	29.6	8.89	29.5	9.16	29.4	9.43	29.3	9.96
	-14.7	-15.0	31.0	8.22	30.9	8.73	30.8	9.24	30.7	9.50	30.7	9.76	30.6	10.27
	-12.6	-13.0	32.3	8.62	32.2	9.11	32.1	9.60	32.1	9.84	32.0	10.09	31.9	10.58
	-10.5	-11.0	33.8	9.02	33.7	9.49	33.6	9.95	33.6	10.19	33.5	10.42	33.4	10.9
	-9.5	-10.0	34.6	9.22	34.5	9.67	34.4	10.13	34.3	10.36	34.3	10.58	34.2	11.0
	-8.5	-9.1	35.3	9.39	35.2	9.84	35.1	10.28	35.1	10.51	35.0	10.73	34.9	11.2
	-7.0	-7.6	36.6	9.68	36.5	10.11	36.4	10.54	36.4	10.75	36.3	11.0	36.2	11.4
	-5.0	-5.6	38.4	10.06	38.3	10.47	38.2	10.9	38.2	11.1	38.1	11.3	38.0	11.7
	-3.0	-3.7	40.3	10.40	40.2	10.79	40.1	11.2	40.0	11.4	40.0	11.6	39.9	12.0
	0.0	-0.7	43.4	10.9	43.3	11.3	43.2	11.6	43.1	11.8	43.1	12.0	43.0	12.4
	3.0	2.2	46.7	11.4	46.6	11.7	46.5	12.1	46.4	12.2	46.4	12.4	46.3	12.7
	5.0	4.1	49.0	11.7	48.9	12.0	48.8	12.3	48.7	12.5	48.7	12.6	48.6	12.9
	7.0	6.0	51.4	11.9	51.3	12.2	51.2	12.6	51.2	12.7	51.1	12.9	51.0	13.1
	9.0	7.9	53.9	12.2	53.8	12.5	53.7	12.8	53.7	12.9	53.6	13.1	51.0	12.4
	11.0	9.8	56.6	12.5	56.5	12.7	56.4	13.0	56.3	13.1	54.7	12.7	51.0	11.7
	13.0	11.8	59.5	12.7	59.4	13.0	58.5	12.9	56.6	12.4	54.7	11.9	51.0	11.0
	15.0	13.7	62.3	12.9	62.2	13.2	58.5	12.2	56.6	11.7	54.7	11.3	51.0	10.4
120 (426)	-19.8	-20.0	28.0	8.01	27.9	8.54	27.8	9.06	27.8	9.32	27.7	9.58	27.6	10.10
	-18.8	-19.0	28.5	8.19	28.4	8.70	28.3	9.21	28.3	9.47	28.2	9.73	28.1	10.24
	-16.7	-17.0	29.6	8.55	29.5	9.04	29.4	9.53	29.4	9.78	29.3	10.02	29.2	10.52
	-14.7	-15.0	30.8	8.91	30.8	9.38	30.7	9.86	30.6	10.09	30.6	10.33	30.5	10.80
	-12.6	-13.0	32.2	9.28	32.1	9.73	32.0	10.18	32.0	10.41	31.9	10.63	31.8	11.1
	-10.5	-11.0	33.7	9.65	33.6	10.08	33.5	10.51	33.4	10.73	33.4	10.9	33.3	11.4
	-9.5	-10.0	34.5	9.83	34.4	10.25	34.3	10.67	34.2	10.9	34.2	11.1	34.1	11.5
	-8.5	-9.1	35.2	9.99	35.1	10.41	35.0	10.8	35.0	11.0	34.9	11.2	34.8	11.6
	-7.0	-7.6	36.5	10.26	36.4	10.66	36.3	11.1	36.2	11.3	36.2	11.4	36.1	11.8
	-5.0	-5.6	38.3	10.61	38.2	11.0	38.1	11.4	38.1	11.5	38.0	11.7	37.9	12.1
	-3.0	-3.7	40.1	10.9	40.0	11.3	39.9	11.6	39.9	11.8	39.8	12.0	39.8	12.4
	0.0	-0.7	43.3	11.4	43.2	11.7	43.1	12.1	43.0	12.2	43.0	12.4	42.9	12.7
	3.0	2.2	46.6	11.8	46.5	12.1	46.4	12.5	46.3	12.6	46.3	12.8	46.2	13.1
	5.0	4.1	48.9	12.1	48.8	12.4	48.7	12.7	48.6	12.8	48.6	13.0	47.1	12.7
	7.0	6.0	51.3	12.4	51.2	12.6	51.1	12.9	51.0	13.1	50.5	13.0	47.1	11.9
	9.0	7.9	53.8	12.6	53.7	12.9	53.6	13.1	52.3	12.8	50.5	12.2	47.1	11.2
	11.0	9.8	56.4	12.8	56.3	13.1	54.0	12.5	52.3	12.0	50.5	11.5	47.1	10.6
	13.0	11.8	59.3	13.0	57.5	12.7	54.0	11.7	52.3	11.3	50.5	10.9	47.1	10.0
	15.0	13.7	60.9	12.8	57.5	11.9	54.0	11.1	52.3	10.7	50.5	10.3	47.1	9.4
110 (391)	-19.8	-20.0	27.9	8.78	27.8	9.26	27.7	9.74	27.6	9.98	27.6	10.21	27.5	10.69
	-18.8	-19.0	28.4	8.94	28.3	9.41	28.2	9.88	28.2	10.11	28.1	10.35	28.0	10.82
	-16.7	-17.0	29.5	9.27	29.4	9.72	29.3	10.17	29.3	10.39	29.2	10.62	29.1	11.07
	-14.7	-15.0	30.7	9.60	30.6	10.04	30.5	10.47	30.5	10.68	30.4	10.90	30.4	11.3
	-12.6	-13.0	32.1	9.94	32.0	10.36	31.9	10.77	31.8	11.0	31.8	11.2	31.7	11.6
	-10.5	-11.0	33.5	10.28	33.5	10.67	33.4	11.1	33.3	11.3	33.3	11.5	33.2	11.9
	-9.5	-10.0	34.3	10.45	34.2	10.8	34.2	11.2	34.1	11.4	34.1	11.6	34.0	12.0
	-8.5	-9.1	35.1	10.60	35.0	11.0	34.9	11.3	34.8	11.5	34.8	11.7	34.7	12.1
	-7.0	-7.6	36.3	10.8	36.3	11.2	36.2	11.6	36.1	11.7	36.1	11.9	36.0	12.3
	-5.0	-5.6	38.2	11.2	38.1	11.5	38.0	11.8	37.9	12.0	37.9	12.2	37.8	12.5
	-3.0	-3.7	40.0	11.5	39.9	11.8	39.8	12.1	39.8	12.3	39.7	12.4	39.6	12.8
	0.0	-0.7	43.1	11.9	43.0	12.2	43.0	12.5	42.9	12.7	42.9	12.8	42.8	13.1
	3.0	2.2	46.4	12.3	46.3	12.6	46.2	12.9	46.2	13.0	46.2	13.1	43.1	12.1
	5.0	4.1	48.7	12.5	48.6	12.8	48.5	13.1	47.9	12.9	46.3	12.4	43.1	11.4
	7.0	6.0	51.1	12.8	51.0	13.0	49.5	12.7	47.9	12.2	46.3	11.7	43.1	10.7
	9.0	7.9	53.7	13.0	52.7	12.9	49.5	11.9	47.9	11.5	46.3	11.0	43.1	10.1
	11.0	9.8	55.9	13.0	52.7	12.1	49.5	11.3	47.9	10.8	46.3	10.4	43.1	9.6
	13.0	11.8	55.9	12.2	52.7	11.4	49.5	10.6	47.9	10.2	46.3	9.8	43.1	9.03
	15.0	13.7	55.9	11.5	52.7	10.8	49.5	10.0	47.9	9.6	46.3	9.3	43.1	8.55

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (355)	-19.8	-20.0	27.7	9.54	27.6	9.98	27.6	10.41	27.5	10.63	27.5	10.85	27.4	11.28
	-18.8	-19.0	28.2	9.69	28.2	10.12	28.1	10.54	28.0	10.76	28.0	10.97	27.9	11.4
	-16.7	-17.0	29.3	9.99	29.3	10.40	29.2	10.81	29.1	11.01	29.1	11.2	29.0	11.6
	-14.7	-15.0	30.6	10.29	30.5	10.69	30.4	11.1	30.4	11.3	30.3	11.5	30.3	11.9
	-12.6	-13.0	31.9	10.60	31.8	11.0	31.8	11.4	31.7	11.5	31.7	11.7	31.6	12.1
	-10.5	-11.0	33.4	10.9	33.3	11.3	33.2	11.6	33.2	11.8	33.2	12.0	33.1	12.3
	-9.5	-10.0	34.2	11.1	34.1	11.4	34.0	11.8	34.0	11.9	34.0	12.1	33.9	12.5
	-8.5	-9.1	34.9	11.2	34.8	11.5	34.8	11.9	34.7	12.1	34.7	12.2	34.6	12.6
	-7.0	-7.6	36.2	11.4	36.1	11.8	36.0	12.1	36.0	12.2	36.0	12.4	35.9	12.7
	-5.0	-5.6	38.0	11.7	37.9	12.0	37.9	12.3	37.8	12.5	37.8	12.7	37.7	13.0
	-3.0	-3.7	39.9	12.0	39.8	12.3	39.7	12.6	39.7	12.7	39.6	12.9	39.2	13.0
	0.0	-0.7	43.0	12.4	42.9	12.7	42.8	12.9	42.8	13.1	42.1	12.9	39.2	11.8
	3.0	2.2	46.3	12.7	46.2	13.0	45.0	12.7	43.6	12.2	42.1	11.8	39.2	10.8
	5.0	4.1	48.6	13.0	47.9	12.9	45.0	12.0	43.6	11.5	42.1	11.1	39.2	10.2
	7.0	6.0	50.8	13.1	47.9	12.2	45.0	11.3	43.6	10.9	42.1	10.4	39.2	9.61
	9.0	7.9	50.8	12.3	47.9	11.5	45.0	10.7	43.6	10.3	42.1	9.9	39.2	9.08
	11.0	9.8	50.8	11.6	47.9	10.8	45.0	10.1	43.6	9.7	42.1	9.31	39.2	8.59
	13.0	11.8	50.8	10.9	47.9	10.2	45.0	9.5	43.6	9.13	42.1	8.79	39.2	8.11
	15.0	13.7	50.8	10.3	47.9	9.6	45.0	8.97	43.6	8.64	42.1	8.32	39.2	7.69
90 (320)	-19.8	-20.0	27.6	10.31	27.5	10.70	27.4	11.09	27.4	11.29	27.4	11.5	27.3	11.9
	-18.8	-19.0	28.1	10.44	28.0	10.82	28.0	11.21	27.9	11.4	27.9	11.6	27.8	12.0
	-16.7	-17.0	29.2	10.71	29.1	11.08	29.1	11.4	29.0	11.6	29.0	11.8	28.9	12.2
	-14.7	-15.0	30.4	10.98	30.4	11.3	30.3	11.7	30.3	11.9	30.2	12.0	30.1	12.4
	-12.6	-13.0	31.8	11.3	31.7	11.6	31.6	11.9	31.6	12.1	31.6	12.3	31.5	12.6
	-10.5	-11.0	33.3	11.5	33.2	11.9	33.1	12.2	33.1	12.3	33.0	12.5	33.0	12.8
	-9.5	-10.0	34.0	11.7	34.0	12.0	33.9	12.3	33.9	12.5	33.8	12.6	33.8	12.9
	-8.5	-9.1	34.8	11.8	34.7	12.1	34.6	12.4	34.6	12.6	34.6	12.7	34.5	13.0
	-7.0	-7.6	36.1	12.0	36.0	12.3	35.9	12.6	35.9	12.7	35.8	12.9	35.3	12.9
	-5.0	-5.6	37.9	12.3	37.8	12.5	37.7	12.8	37.7	13.0	37.7	13.1	35.3	12.1
	-3.0	-3.7	39.7	12.5	39.6	12.8	39.6	13.0	39.2	13.0	37.9	12.5	35.3	11.4
	0.0	-0.7	42.8	12.9	42.8	13.1	40.5	12.3	39.2	11.8	37.9	11.3	35.3	10.4
	3.0	2.2	45.7	13.0	43.1	12.1	40.5	11.2	39.2	10.8	37.9	10.4	35.3	9.55
	5.0	4.1	45.7	12.2	43.1	11.4	40.5	10.6	39.2	10.2	37.9	9.79	35.3	9.02
	7.0	6.0	45.7	11.5	43.1	10.7	40.5	10.0	39.2	9.61	37.9	9.24	35.3	8.53
	9.0	7.9	45.7	10.9	43.1	10.1	40.5	9.42	39.2	9.08	37.9	8.74	35.3	8.07
	11.0	9.8	45.7	10.2	43.1	9.6	40.5	8.91	39.2	8.59	37.9	8.27	35.3	7.64
	13.0	11.8	45.7	9.6	43.1	9.02	40.5	8.41	39.2	8.11	37.9	7.81	35.3	7.23
	15.0	13.7	45.7	9.1	43.1	8.54	40.5	7.97	39.2	7.69	37.9	7.41	35.3	6.86
80 (284)	-19.8	-20.0	27.5	11.07	27.4	11.42	27.3	11.8	27.3	11.9	27.3	12.1	27.2	12.5
	-18.8	-19.0	28.0	11.19	27.9	11.5	27.8	11.9	27.8	12.0	27.8	12.2	27.7	12.6
	-16.7	-17.0	29.1	11.4	29.0	11.8	28.9	12.1	28.9	12.2	28.9	12.4	28.8	12.7
	-14.7	-15.0	30.3	11.7	30.2	12.0	30.2	12.3	30.1	12.5	30.1	12.6	30.0	12.9
	-12.6	-13.0	31.6	11.9	31.6	12.2	31.5	12.5	31.5	12.7	31.5	12.8	31.4	13.1
	-10.5	-11.0	33.1	12.2	33.1	12.5	33.0	12.7	33.0	12.9	32.9	13.0	31.4	12.4
	-9.5	-10.0	33.9	12.3	33.8	12.6	33.8	12.9	33.8	13.0	33.7	13.1	31.4	12.0
	-8.5	-9.1	34.6	12.4	34.6	12.7	34.5	12.9	34.5	13.1	33.7	12.8	31.4	11.7
	-7.0	-7.6	35.9	12.6	35.9	12.8	35.8	13.1	34.8	12.7	33.7	12.2	31.4	11.2
	-5.0	-5.6	37.7	12.8	37.7	13.1	36.0	12.4	34.8	11.9	33.7	11.5	31.4	10.5
	-3.0	-3.7	39.6	13.0	38.3	12.6	36.0	11.7	34.8	11.3	33.7	10.8	31.4	9.96
	0.0	-0.7	40.6	12.3	38.3	11.5	36.0	10.7	34.8	10.3	33.7	9.88	31.4	9.10
	3.0	2.2	40.6	11.3	38.3	10.5	36.0	9.77	34.8	9.41	33.7	9.05	31.4	8.35
	5.0	4.1	40.6	10.6	38.3	9.9	36.0	9.22	34.8	8.89	33.7	8.56	31.4	7.90
	7.0	6.0	40.6	10.0	38.3	9.36	36.0	8.72	34.8	8.40	33.7	8.09	31.4	7.48
	9.0	7.9	40.6	9.46	38.3	8.85	36.0	8.25	34.8	7.95	33.7	7.66	31.4	7.09
	11.0	9.8	40.6	8.94	38.3	8.37	36.0	7.81	34.8	7.54	33.7	7.27	31.4	6.73
	13.0	11.8	40.6	8.44	38.3	7.91	36.0	7.38	34.8	7.13	33.7	6.88	31.4	6.38
	15.0	13.7	40.6	8.00	38.3	7.50	36.0	7.01	34.8	6.77	33.7	6.53	31.4	6.07

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0			18.0			20.0			21.0			22.0			24.0	
			TC	PI		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI
	°CDB	°CWB	kW	kW		kW	kW		kW	kW		kW	kW		kW	kW		kW	kW
70 (249)	-19.8	-20.0	27.3	11.8		27.3	12.1		27.2	12.4		27.2	12.6		27.1	12.8		27.1	13.1
	-18.8	-19.0	27.8	11.9		27.8	12.2		27.7	12.5		27.7	12.7		27.7	12.8		27.5	13.0
	-16.7	-17.0	28.9	12.1		28.9	12.4		28.8	12.7		28.8	12.9		28.8	13.0		27.5	12.4
	-14.7	-15.0	30.2	12.4		30.1	12.6		30.0	12.9		30.0	13.1		29.5	12.8		27.5	11.8
	-12.6	-13.0	31.5	12.6		31.5	12.8		31.4	13.1		30.5	12.7		29.5	12.1		27.5	11.2
	-10.5	-11.0	33.0	12.8		32.9	13.0		31.5	12.4		30.5	12.0		29.5	11.5		27.5	10.5
	-9.5	-10.0	33.8	12.9		33.5	13.0		31.5	12.1		30.5	11.6		29.5	11.2		27.5	10.3
	-8.5	-9.1	34.5	13.0		33.5	12.7		31.5	11.8		30.5	11.3		29.5	10.9		27.5	9.99
	-7.0	-7.6	35.5	13.0		33.5	12.1		31.5	11.2		30.5	10.8		29.5	10.4		27.5	9.57
	-5.0	-5.6	35.5	12.2		33.5	11.4		31.5	10.6		30.5	10.19		29.5	9.80		27.5	9.03
	-3.0	-3.7	35.5	11.5		33.5	10.8		31.5	10.00		30.5	9.63		29.5	9.26		27.5	8.55
	0.0	-0.7	35.5	10.5		33.5	9.82		31.5	9.14		30.5	8.81		29.5	8.48		27.5	7.83
	3.0	2.2	35.5	9.63		33.5	9.00		31.5	8.39		30.5	8.09		29.5	7.79		27.5	7.21
	5.0	4.1	35.5	9.09		33.5	8.51		31.5	7.94		30.5	7.66		29.5	7.38		27.5	6.84
	7.0	6.0	35.5	8.60		33.5	8.05		31.5	7.52		30.5	7.26		29.5	7.00		27.5	6.49
	9.0	7.9	35.5	8.13		33.5	7.62		31.5	7.13		30.5	6.88		29.5	6.64		27.5	6.16
	11.0	9.8	35.5	7.70		33.5	7.23		31.5	6.76		30.5	6.53		29.5	6.30		27.5	5.86
	13.0	11.8	35.5	7.28		33.5	6.84		31.5	6.40		30.5	6.19		29.5	5.98		27.5	5.56
	15.0	13.7	35.5	6.92		33.5	6.50		31.5	6.09		30.5	5.89		29.5	5.69		27.5	5.30
60 (213)	-19.8	-20.0	27.2	12.6		27.1	12.9		27.0	13.1		26.1	12.6		25.3	12.0		23.5	11.1
	-18.8	-19.0	27.7	12.7		27.6	12.9		27.0	12.8		26.1	12.3		25.3	11.8		23.5	10.8
	-16.7	-17.0	28.8	12.9		28.7	13.1		27.0	12.2		26.1	11.7		25.3	11.2		23.5	10.3
	-14.7	-15.0	30.0	13.1		28.7	12.4		27.0	11.5		26.1	11.1		25.3	10.7		23.5	9.81
	-12.6	-13.0	30.5	12.7		28.7	11.8		27.0	10.9		26.1	10.5		25.3	10.1		23.5	9.31
	-10.5	-11.0	30.5	11.9		28.7	11.1		27.0	10.3		26.1	9.96		25.3	9.57		23.5	8.83
	-9.5	-10.0	30.5	11.6		28.7	10.8		27.0	10.06		26.1	9.68		25.3	9.31		23.5	8.59
	-8.5	-9.1	30.5	11.3		28.7	10.5		27.0	9.80		26.1	9.44		25.3	9.08		23.5	8.38
	-7.0	-7.6	30.5	10.8		28.7	10.09		27.0	9.39		26.1	9.04		25.3	8.70		23.5	8.04
	-5.0	-5.6	30.5	10.19		28.7	9.52		27.0	8.86		26.1	8.54		25.3	8.22		23.5	7.60
	-3.0	-3.7	30.5	9.62		28.7	9.00		27.0	8.39		26.1	8.09		25.3	7.79		23.5	7.21
	0.0	-0.7	30.5	8.80		28.7	8.24		27.0	7.69		26.1	7.42		25.3	7.16		23.5	6.63
	3.0	2.2	30.5	8.08		28.7	7.58		27.0	7.08		26.1	6.84		25.3	6.60		23.5	6.13
	5.0	4.1	30.5	7.65		28.7	7.18		27.0	6.72		26.1	6.49		25.3	6.27		23.5	5.82
	7.0	6.0	30.5	7.25		28.7	6.81		27.0	6.38		26.1	6.16		25.3	5.95		23.5	5.54
	9.0	7.9	30.5	6.88		28.7	6.46		27.0	6.06		26.1	5.86		25.3	5.66		23.5	5.27
	11.0	9.8	30.5	6.53		28.7	6.14		27.0	5.76		26.1	5.57		25.3	5.39		23.5	5.02
	13.0	11.8	30.5	6.19		28.7	5.82		27.0	5.47		26.1	5.29		25.3	5.12		23.5	4.78
	15.0	13.7	30.5	5.89		28.7	5.55		27.0	5.21		26.1	5.05		25.3	4.88		23.5	4.56
50 (178)	-19.8	-20.0	25.4	12.1		23.9	11.3		22.5	10.5		21.8	10.1		21.1	9.7		19.6	8.95
	-18.8	-19.0	25.4	11.8		23.9	11.0		22.5	10.3		21.8	9.9		21.1	9.5		19.6	8.76
	-16.7	-17.0	25.4	11.3		23.9	10.5		22.5	9.8		21.8	9.43		21.1	9.07		19.6	8.37
	-14.7	-15.0	25.4	10.7		23.9	10.0		22.5	9.32		21.8	8.98		21.1	8.64		19.6	7.98
	-12.6	-13.0	25.4	10.2		23.9	9.50		22.5	8.85		21.8	8.53		21.1	8.21		19.6	7.59
	-10.5	-11.0	25.4	9.63		23.9	9.00		22.5	8.39		21.8	8.09		21.1	7.80		19.6	7.21
	-9.5	-10.0	25.4	9.37		23.9	8.76		22.5	8.17		21.8	7.88		21.1	7.59		19.6	7.03
	-8.5	-9.1	25.4	9.13		23.9	8.55		22.5	7.97		21.8	7.69		21.1	7.41		19.6	6.87
	-7.0	-7.6	25.4	8.75		23.9	8.20		22.5	7.65		21.8	7.38		21.1	7.12		19.6	6.60
	-5.0	-5.6	25.4	8.27		23.9	7.75		22.5	7.24		21.8	6.99		21.1	6.74		19.6	6.26
	-3.0	-3.7	25.4	7.83		23.9	7.35		22.5	6.87		21.8	6.64		21.1	6.41		19.6	5.95
	0.0	-0.7	25.4	7.20		23.9	6.76		22.5	6.33		21.8	6.12		21.1	5.91		19.6	5.50
	3.0	2.2	25.4	6.64		23.9	6.24		22.5	5.85		21.8	5.66		21.1	5.47		19.6	5.10
	5.0	4.1	25.4	6.30		23.9	5.93		22.5	5.56		21.8	5.38		21.1	5.21		19.6	4.86
	7.0	6.0	25.4	5.98		23.9	5.64		22.5	5.29		21.8	5.13		21.1	4.96		19.6	4.63
	9.0	7.9	25.4	5.69		23.9	5.36		22.5	5.04		21.8	4.88		21.1	4.73		19.6	4.42
	11.0	9.8	25.4	5.41		23.9	5.11		22.5	4.81		21.8	4.66		21.1	4.51		19.6	4.22
	13.0	11.8	25.4	5.15		23.9	4.86		22.5	4.58		21.8	4.44		21.1	4.30		19.6	4.03
	15.0	13.7	25.4	4.91		23.9	4.64		22.5	4.37		21.8	4.24		21.1	4.11		19.6	3.86

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (520)	-19.8	-20.0	30.7	7.80	30.6	8.45	30.4	9.09	30.4	9.42	30.3	9.74	30.2	10.39
	-18.8	-19.0	31.2	8.02	31.1	8.65	31.0	9.28	30.9	9.60	30.9	9.92	30.8	10.55
	-16.7	-17.0	32.4	8.46	32.3	9.07	32.2	9.68	32.1	9.98	32.1	10.29	32.0	10.90
	-14.7	-15.0	33.8	8.91	33.6	9.50	33.5	10.08	33.5	10.37	33.4	10.66	33.3	11.25
	-12.6	-13.0	35.2	9.37	35.1	9.93	35.0	10.48	34.9	10.76	34.9	11.04	34.8	11.60
	-10.5	-11.0	36.8	9.82	36.7	10.36	36.6	10.89	36.6	11.15	36.5	11.42	36.4	12.0
	-9.5	-10.0	37.7	10.05	37.6	10.57	37.5	11.09	37.4	11.35	37.4	11.6	37.2	12.1
	-8.5	-9.1	38.5	10.25	38.4	10.76	38.3	11.27	38.2	11.52	38.2	11.8	38.0	12.3
	-7.0	-7.6	39.9	10.58	39.8	11.07	39.7	11.6	39.6	11.8	39.5	12.0	39.4	12.5
	-5.0	-5.6	41.9	11.01	41.8	11.47	41.6	11.9	41.6	12.2	41.5	12.4	41.4	12.9
	-3.0	-3.7	43.9	11.40	43.8	11.8	43.6	12.3	43.6	12.5	43.5	12.7	43.4	13.2
	0.0	-0.7	47.3	12.0	47.2	12.4	47.0	12.8	47.0	13.0	46.9	13.2	46.8	13.6
	3.0	2.2	50.9	12.5	50.7	12.9	50.6	13.3	50.6	13.5	50.5	13.7	50.4	14.0
	5.0	4.1	53.4	12.9	53.2	13.2	53.1	13.6	53.1	13.8	53.0	13.9	52.9	14.3
	7.0	6.0	56.0	13.2	55.9	13.5	55.8	13.9	55.7	14.0	55.6	14.2	55.5	14.5
	9.0	7.9	58.7	13.5	58.6	13.8	58.5	14.1	58.5	14.3	58.4	14.4	56.6	14.1
	11.0	9.8	61.6	13.7	61.5	14.1	61.4	14.4	61.3	14.5	60.8	14.5	56.6	13.3
	13.0	11.8	64.8	14.0	64.6	14.3	64.5	14.6	62.9	14.2	60.8	13.6	56.6	12.5
	15.0	13.7	67.9	14.3	67.8	14.6	65.0	13.9	62.9	13.4	60.8	12.9	56.6	11.8
120 (480)	-19.8	-20.0	30.5	8.67	30.4	9.27	30.3	9.87	30.3	10.17	30.2	10.46	30.1	11.06
	-18.8	-19.0	31.1	8.87	31.0	9.46	30.9	10.04	30.8	10.34	30.7	10.63	30.6	11.21
	-16.7	-17.0	32.3	9.28	32.2	9.84	32.1	10.41	32.0	10.69	32.0	10.97	31.8	11.53
	-14.7	-15.0	33.6	9.70	33.5	10.24	33.4	10.78	33.3	11.05	33.3	11.32	33.2	11.9
	-12.6	-13.0	35.1	10.12	35.0	10.64	34.9	11.15	34.8	11.41	34.8	11.7	34.7	12.2
	-10.5	-11.0	36.7	10.54	36.6	11.03	36.5	11.52	36.4	11.8	36.4	12.0	36.3	12.5
	-9.5	-10.0	37.5	10.75	37.4	11.23	37.3	11.7	37.3	11.9	37.2	12.2	37.1	12.7
	-8.5	-9.1	38.3	10.94	38.2	11.40	38.1	11.9	38.1	12.1	38.0	12.3	37.9	12.8
	-7.0	-7.6	39.7	11.24	39.6	11.7	39.5	12.1	39.5	12.4	39.4	12.6	39.3	13.0
	-5.0	-5.6	41.7	11.6	41.6	12.1	41.5	12.5	41.4	12.7	41.4	12.9	41.3	13.4
	-3.0	-3.7	43.7	12.0	43.6	12.4	43.5	12.8	43.4	13.0	43.4	13.2	43.3	13.6
	0.0	-0.7	47.1	12.5	47.0	12.9	46.9	13.3	46.9	13.5	46.8	13.7	46.7	14.1
	3.0	2.2	50.7	13.0	50.6	13.4	50.5	13.7	50.4	13.9	50.4	14.1	50.3	14.4
	5.0	4.1	53.2	13.3	53.1	13.7	53.0	14.0	52.9	14.2	52.9	14.3	52.3	14.5
	7.0	6.0	55.8	13.6	55.7	13.9	55.6	14.3	55.6	14.4	55.5	14.6	52.3	13.6
	9.0	7.9	58.6	13.9	58.5	14.2	58.4	14.5	58.1	14.6	56.1	14.0	52.3	12.8
	11.0	9.8	61.5	14.2	61.3	14.5	60.0	14.3	58.1	13.7	56.1	13.2	52.3	12.1
	13.0	11.8	64.6	14.4	63.9	14.5	60.0	13.4	58.1	12.9	56.1	12.4	52.3	11.4
	15.0	13.7	67.7	14.6	63.9	13.6	60.0	12.7	58.1	12.2	56.1	11.7	52.3	10.8
110 (440)	-19.8	-20.0	30.4	9.55	30.3	10.09	30.2	10.64	30.1	10.91	30.1	11.19	30.0	11.73
	-18.8	-19.0	30.9	9.73	30.8	10.27	30.7	10.80	30.7	11.07	30.6	11.34	30.5	11.88
	-16.7	-17.0	32.1	10.10	32.0	10.62	31.9	11.14	31.9	11.39	31.8	11.65	31.7	12.2
	-14.7	-15.0	33.5	10.49	33.4	10.98	33.3	11.48	33.2	11.72	33.2	12.0	33.1	12.5
	-12.6	-13.0	34.9	10.88	34.8	11.35	34.7	11.8	34.7	12.1	34.6	12.3	34.5	12.8
	-10.5	-11.0	36.5	11.26	36.4	11.7	36.3	12.2	36.3	12.4	36.2	12.6	36.1	13.1
	-9.5	-10.0	37.4	11.45	37.3	11.9	37.2	12.3	37.1	12.6	37.1	12.8	37.0	13.2
	-8.5	-9.1	38.2	11.6	38.1	12.1	38.0	12.5	37.9	12.7	37.9	12.9	37.8	13.3
	-7.0	-7.6	39.6	11.9	39.5	12.3	39.4	12.7	39.3	12.9	39.3	13.1	39.2	13.6
	-5.0	-5.6	41.6	12.3	41.5	12.7	41.4	13.1	41.3	13.2	41.3	13.4	41.2	13.8
	-3.0	-3.7	43.6	12.6	43.5	13.0	43.4	13.3	43.3	13.5	43.3	13.7	43.2	14.1
	0.0	-0.7	47.0	13.1	46.9	13.4	46.8	13.8	46.7	14.0	46.7	14.1	46.6	14.5
	3.0	2.2	50.6	13.6	50.5	13.9	50.4	14.2	50.3	14.4	50.3	14.5	47.9	13.8
	5.0	4.1	53.1	13.8	53.0	14.1	52.9	14.4	52.8	14.6	51.5	14.2	47.9	13.0
	7.0	6.0	55.7	14.1	55.6	14.4	55.0	14.5	53.2	13.9	51.5	13.4	47.9	12.3
	9.0	7.9	58.4	14.3	58.3	14.6	55.0	13.6	53.2	13.1	51.5	12.6	47.9	11.6
	11.0	9.8	61.3	14.6	58.5	13.8	55.0	12.8	53.2	12.4	51.5	11.9	47.9	10.9
	13.0	11.8	62.1	14.0	58.5	13.0	55.0	12.1	53.2	11.6	51.5	11.2	47.9	10.3
	15.0	13.7	62.1	13.2	58.5	12.3	55.0	11.4	53.2	11.0	51.5	10.6	47.9	9.8

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (400)	-19.8	-20.0	30.2	10.42	30.1	10.92	30.0	11.41	30.0	11.66	29.9	11.91	29.9	12.4
	-18.8	-19.0	30.8	10.59	30.7	11.07	30.6	11.56	30.5	11.80	30.5	12.05	30.4	12.5
	-16.7	-17.0	32.0	10.93	31.9	11.40	31.8	11.86	31.7	12.1	31.7	12.3	31.6	12.8
	-14.7	-15.0	33.3	11.28	33.2	11.73	33.1	12.2	33.1	12.4	33.0	12.6	32.9	13.1
	-12.6	-13.0	34.8	11.63	34.7	12.1	34.6	12.5	34.6	12.7	34.5	12.9	34.4	13.3
	-10.5	-11.0	36.4	12.0	36.3	12.4	36.2	12.8	36.2	13.0	36.1	13.2	36.0	13.6
	-9.5	-10.0	37.2	12.2	37.1	12.6	37.1	13.0	37.0	13.2	37.0	13.4	36.9	13.8
	-8.5	-9.1	38.0	12.3	37.9	12.7	37.9	13.1	37.8	13.3	37.8	13.5	37.7	13.9
	-7.0	-7.6	39.4	12.6	39.3	12.9	39.3	13.3	39.2	13.5	39.2	13.7	39.1	14.1
	-5.0	-5.6	41.4	12.9	41.3	13.3	41.2	13.6	41.2	13.8	41.1	14.0	41.0	14.3
	-3.0	-3.7	43.4	13.2	43.3	13.5	43.2	13.9	43.2	14.1	43.1	14.2	43.1	14.6
	0.0	-0.7	46.8	13.7	46.7	14.0	46.6	14.3	46.6	14.4	46.5	14.6	43.6	13.5
	3.0	2.2	50.4	14.1	50.3	14.4	50.0	14.5	48.4	14.0	46.8	13.4	43.6	12.3
	5.0	4.1	52.9	14.3	52.8	14.6	50.0	13.7	48.4	13.2	46.8	12.6	43.6	11.6
	7.0	6.0	55.5	14.6	53.2	13.9	50.0	12.9	48.4	12.4	46.8	11.9	43.6	11.0
	9.0	7.9	56.4	14.1	53.2	13.1	50.0	12.2	48.4	11.7	46.8	11.3	43.6	10.4
	11.0	9.8	56.4	13.2	53.2	12.4	50.0	11.5	48.4	11.1	46.8	10.6	43.6	9.8
	13.0	11.8	56.4	12.5	53.2	11.6	50.0	10.8	48.4	10.4	46.8	10.0	43.6	9.3
	15.0	13.7	56.4	11.8	53.2	11.0	50.0	10.2	48.4	9.9	46.8	9.5	43.6	8.78
90 (360)	-19.8	-20.0	30.1	11.29	30.0	11.74	29.9	12.19	29.9	12.4	29.8	12.6	29.7	13.1
	-18.8	-19.0	30.6	11.44	30.5	11.88	30.4	12.3	30.4	12.5	30.4	12.8	30.3	13.2
	-16.7	-17.0	31.8	11.75	31.7	12.2	31.6	12.6	31.6	12.8	31.6	13.0	31.5	13.4
	-14.7	-15.0	33.1	12.1	33.1	12.5	33.0	12.9	32.9	13.1	32.9	13.3	32.8	13.7
	-12.6	-13.0	34.6	12.4	34.5	12.8	34.5	13.2	34.4	13.3	34.4	13.5	34.3	13.9
	-10.5	-11.0	36.2	12.7	36.1	13.1	36.1	13.4	36.0	13.6	36.0	13.8	35.9	14.2
	-9.5	-10.0	37.1	12.9	37.0	13.2	36.9	13.6	36.9	13.8	36.8	13.9	36.8	14.3
	-8.5	-9.1	37.9	13.0	37.8	13.3	37.7	13.7	37.7	13.9	37.6	14.1	37.6	14.4
	-7.0	-7.6	39.3	13.2	39.2	13.6	39.1	13.9	39.1	14.1	39.0	14.2	39.0	14.6
	-5.0	-5.6	41.2	13.5	41.2	13.8	41.1	14.2	41.0	14.3	41.0	14.5	39.2	13.9
	-3.0	-3.7	43.2	13.8	43.2	14.1	43.1	14.4	43.1	14.6	42.1	14.2	39.2	13.1
	0.0	-0.7	46.7	14.2	46.6	14.5	45.0	14.0	43.6	13.5	42.1	13.0	39.2	11.9
	3.0	2.2	50.2	14.6	47.9	13.8	45.0	12.8	43.6	12.3	42.1	11.8	39.2	10.9
	5.0	4.1	50.8	14.0	47.9	13.0	45.0	12.1	43.6	11.6	42.1	11.2	39.2	10.3
	7.0	6.0	50.8	13.1	47.9	12.3	45.0	11.4	43.6	11.0	42.1	10.6	39.2	9.7
	9.0	7.9	50.8	12.4	47.9	11.6	45.0	10.8	43.6	10.4	42.1	10.0	39.2	9.21
	11.0	9.8	50.8	11.7	47.9	10.9	45.0	10.2	43.6	9.8	42.1	9.4	39.2	8.73
	13.0	11.8	50.8	11.0	47.9	10.3	45.0	9.6	43.6	9.3	42.1	8.92	39.2	8.25
	15.0	13.7	50.8	10.4	47.9	9.8	45.0	9.1	43.6	8.78	42.1	8.46	39.2	7.83
80 (320)	-19.8	-20.0	29.9	12.17	29.8	12.6	29.8	13.0	29.7	13.2	29.7	13.4	29.6	13.8
	-18.8	-19.0	30.4	12.3	30.4	12.7	30.3	13.1	30.3	13.3	30.2	13.5	30.2	13.9
	-16.7	-17.0	31.7	12.6	31.6	12.9	31.5	13.3	31.5	13.5	31.4	13.7	31.4	14.1
	-14.7	-15.0	33.0	12.9	32.9	13.2	32.8	13.6	32.8	13.8	32.8	13.9	32.7	14.3
	-12.6	-13.0	34.5	13.1	34.4	13.5	34.3	13.8	34.3	14.0	34.3	14.2	34.2	14.5
	-10.5	-11.0	36.1	13.4	36.0	13.7	35.9	14.1	35.9	14.2	35.9	14.4	34.9	14.1
	-9.5	-10.0	36.9	13.6	36.9	13.9	36.8	14.2	36.8	14.4	36.7	14.5	34.9	13.7
	-8.5	-9.1	37.7	13.7	37.7	14.0	37.6	14.3	37.6	14.5	37.4	14.6	34.9	13.4
	-7.0	-7.6	39.1	13.9	39.0	14.2	39.0	14.5	38.7	14.5	37.4	13.9	34.9	12.8
	-5.0	-5.6	41.1	14.2	41.0	14.4	40.0	14.2	38.7	13.6	37.4	13.1	34.9	12.0
	-3.0	-3.7	43.1	14.4	42.6	14.4	40.0	13.4	38.7	12.9	37.4	12.4	34.9	11.4
	0.0	-0.7	45.1	14.1	42.6	13.1	40.0	12.2	38.7	11.7	37.4	11.3	34.9	10.4
	3.0	2.2	45.1	12.9	42.6	12.0	40.0	11.2	38.7	10.7	37.4	10.3	34.9	9.54
	5.0	4.1	45.1	12.1	42.6	11.3	40.0	10.5	38.7	10.1	37.4	9.77	34.9	9.02
	7.0	6.0	45.1	11.4	42.6	10.7	40.0	10.0	38.7	9.59	37.4	9.24	34.9	8.54
	9.0	7.9	45.1	10.8	42.6	10.1	40.0	9.42	38.7	9.08	37.4	8.75	34.9	8.10
	11.0	9.8	45.1	10.2	42.6	9.6	40.0	8.92	38.7	8.60	37.4	8.29	34.9	7.69
	13.0	11.8	45.1	9.6	42.6	9.03	40.0	8.43	38.7	8.14	37.4	7.85	34.9	7.28
	15.0	13.7	45.1	9.1	42.6	8.56	40.0	8.00	38.7	7.73	37.4	7.46	34.9	6.92

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0			18.0			20.0			21.0			22.0			24.0	
			TC	PI		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI
	°CDB	°CWB	kW	kW		kW	kW		kW	kW		kW	kW		kW	kW		kW	kW
70 (280)	-19.8	-20.0	29.7	13.0		29.7	13.4		29.6	13.7		29.6	13.9		29.6	14.1		29.5	14.4
	-18.8	-19.0	30.3	13.2		30.2	13.5		30.2	13.8		30.1	14.0		30.1	14.2		30.0	14.5
	-16.7	-17.0	31.5	13.4		31.4	13.7		31.4	14.1		31.3	14.2		31.3	14.4		30.5	14.2
	-14.7	-15.0	32.8	13.6		32.8	14.0		32.7	14.3		32.7	14.4		32.7	14.6		30.5	13.4
	-12.6	-13.0	34.3	13.9		34.2	14.2		34.2	14.5		33.9	14.5		32.8	13.9		30.5	12.7
	-10.5	-11.0	35.9	14.1		35.9	14.4		35.0	14.2		33.9	13.6		32.8	13.1		30.5	12.0
	-9.5	-10.0	36.8	14.3		36.7	14.5		35.0	13.8		33.9	13.3		32.8	12.7		30.5	11.7
	-8.5	-9.1	37.6	14.4		37.2	14.5		35.0	13.4		33.9	12.9		32.8	12.4		30.5	11.4
	-7.0	-7.6	39.0	14.5		37.2	13.8		35.0	12.8		33.9	12.3		32.8	11.9		30.5	10.9
	-5.0	-5.6	39.5	14.0		37.2	13.0		35.0	12.1		33.9	11.6		32.8	11.2		30.5	10.31
	-3.0	-3.7	39.5	13.2		37.2	12.3		35.0	11.4		33.9	11.0		32.8	10.6		30.5	9.76
	0.0	-0.7	39.5	12.0		37.2	11.2		35.0	10.4		33.9	10.06		32.8	9.68		30.5	8.94
	3.0	2.2	39.5	11.0		37.2	10.3		35.0	9.56		33.9	9.24		32.8	8.90		30.5	8.23
	5.0	4.1	39.5	10.4		37.2	9.71		35.0	9.06		33.9	8.74		32.8	8.43		30.5	7.81
	7.0	6.0	39.5	9.8		37.2	9.19		35.0	8.58		33.9	8.28		32.8	7.99		30.5	7.41
	9.0	7.9	39.5	9.28		37.2	8.70		35.0	8.13		33.9	7.85		32.8	7.58		30.5	7.03
	11.0	9.8	39.5	8.79		37.2	8.25		35.0	7.72		33.9	7.46		32.8	7.20		30.5	6.69
	13.0	11.8	39.5	8.32		37.2	7.81		35.0	7.31		33.9	7.07		32.8	6.82		30.5	6.35
	15.0	13.7	39.5	7.89		37.2	7.42		35.0	6.95		33.9	6.72		32.8	6.50		30.5	6.05
60 (240)	-19.8	-20.0	29.6	13.9		29.5	14.2		29.5	14.5		29.0	14.3		28.1	13.8		26.1	12.6
	-18.8	-19.0	30.1	14.0		30.1	14.3		30.0	14.6		29.0	14.0		28.1	13.4		26.1	12.3
	-16.7	-17.0	31.3	14.2		31.3	14.5		30.0	13.9		29.0	13.3		28.1	12.8		26.1	11.8
	-14.7	-15.0	32.7	14.4		31.9	14.2		30.0	13.2		29.0	12.7		28.1	12.2		26.1	11.2
	-12.6	-13.0	33.9	14.4		31.9	13.4		30.0	12.5		29.0	12.0		28.1	11.5		26.1	10.6
	-10.5	-11.0	33.9	13.6		31.9	12.7		30.0	11.8		29.0	11.4		28.1	10.9		26.1	10.08
	-9.5	-10.0	33.9	13.2		31.9	12.4		30.0	11.5		29.0	11.1		28.1	10.6		26.1	9.81
	-8.5	-9.1	33.9	12.9		31.9	12.0		30.0	11.2		29.0	10.8		28.1	10.4		26.1	9.57
	-7.0	-7.6	33.9	12.3		31.9	11.5		30.0	10.7		29.0	10.32		28.1	9.94		26.1	9.18
	-5.0	-5.6	33.9	11.6		31.9	10.9		30.0	10.12		29.0	9.75		28.1	9.39		26.1	8.68
	-3.0	-3.7	33.9	11.0		31.9	10.27		30.0	9.58		29.0	9.23		28.1	8.89		26.1	8.23
	0.0	-0.7	33.9	10.05		31.9	9.41		30.0	8.78		29.0	8.47		28.1	8.17		26.1	7.57
	3.0	2.2	33.9	9.23		31.9	8.65		30.0	8.09		29.0	7.81		28.1	7.54		26.1	7.00
	5.0	4.1	33.9	8.74		31.9	8.20		30.0	7.67		29.0	7.41		28.1	7.15		26.1	6.65
	7.0	6.0	33.9	8.28		31.9	7.77		30.0	7.28		29.0	7.04		28.1	6.79		26.1	6.32
	9.0	7.9	33.9	7.85		31.9	7.38		30.0	6.91		29.0	6.69		28.1	6.46		26.1	6.02
	11.0	9.8	33.9	7.45		31.9	7.01		30.0	6.58		29.0	6.36		28.1	6.15		26.1	5.73
	13.0	11.8	33.9	7.06		31.9	6.65		30.0	6.24		29.0	6.04		28.1	5.85		26.1	5.45
	15.0	13.7	33.9	6.72		31.9	6.33		30.0	5.95		29.0	5.76		28.1	5.58		26.1	5.21
50 (200)	-19.8	-20.0	28.2	13.8		26.6	12.9		25.0	12.0		24.2	11.5		23.4	11.1		21.8	10.2
	-18.8	-19.0	28.2	13.5		26.6	12.6		25.0	11.7		24.2	11.3		23.4	10.8		21.8	10.0
	-16.7	-17.0	28.2	12.9		26.6	12.0		25.0	11.2		24.2	10.8		23.4	10.4		21.8	9.55
	-14.7	-15.0	28.2	12.2		26.6	11.4		25.0	10.6		24.2	10.2		23.4	9.86		21.8	9.11
	-12.6	-13.0	28.2	11.6		26.6	10.8		25.0	10.10		24.2	9.74		23.4	9.38		21.8	8.67
	-10.5	-11.0	28.2	11.0		26.6	10.3		25.0	9.58		24.2	9.24		23.4	8.90		21.8	8.24
	-9.5	-10.0	28.2	10.7		26.6	10.00		25.0	9.33		24.2	8.99		23.4	8.67		21.8	8.02
	-8.5	-9.1	28.2	10.4		26.6	9.76		25.0	9.10		24.2	8.78		23.4	8.46		21.8	7.84
	-7.0	-7.6	28.2	9.99		26.6	9.36		25.0	8.73		24.2	8.43		23.4	8.13		21.8	7.53
	-5.0	-5.6	28.2	9.44		26.6	8.85		25.0	8.27		24.2	7.98		23.4	7.70		21.8	7.14
	-3.0	-3.7	28.2	8.94		26.6	8.39		25.0	7.84		24.2	7.58		23.4	7.31		21.8	6.79
	0.0	-0.7	28.2	8.21		26.6	7.72		25.0	7.23		24.2	6.98		23.4	6.75		21.8	6.28
	3.0	2.2	28.2	7.58		26.6	7.12		25.0	6.68		24.2	6.46		23.4	6.25		21.8	5.82
	5.0	4.1	28.2	7.19		26.6	6.77		25.0	6.35		24.2	6.15		23.4	5.94		21.8	5.54
	7.0	6.0	28.2	6.83		26.6	6.43		25.0	6.04		24.2	5.85		23.4	5.66		21.8	5.29
	9.0	7.9	28.2	6.49		26.6	6.12		25.0	5.76		24.2	5.58		23.4	5.40		21.8	5.05
	11.0	9.8	28.2	6.18		26.6	5.83		25.0	5.49		24.2	5.32		23.4	5.15		21.8	4.82
	13.0	11.8	28.2	5.87		26.6	5.55		25.0	5.23		24.2	5.07		23.4	4.91		21.8	4.60
	15.0	13.7	28.2	5.60		26.6	5.30		25.0	4.99		24.2	4.84		23.4	4.70		21.8	4.40

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (585)	-19.8	-20.0	31.4	6.62	31.3	7.38	31.2	8.14	31.1	8.52	31.1	8.90	30.9	9.7
	-18.8	-19.0	32.0	6.87	31.9	7.62	31.8	8.37	31.7	8.74	31.6	9.1	31.5	9.9
	-16.7	-17.0	33.2	7.40	33.1	8.11	33.0	8.83	32.9	9.2	32.8	9.6	32.7	10.3
	-14.7	-15.0	34.6	7.93	34.5	8.62	34.3	9.3	34.3	9.7	34.2	10.0	34.1	10.7
	-12.6	-13.0	36.1	8.48	36.0	9.1	35.8	9.8	35.8	10.1	35.7	10.5	35.6	11.1
	-10.5	-11.0	37.7	9.0	37.6	9.6	37.5	10.3	37.4	10.6	37.3	10.9	37.2	11.5
	-9.5	-10.0	38.6	9.3	38.5	9.9	38.3	10.5	38.3	10.8	38.2	11.1	38.1	11.7
	-8.5	-9.1	39.4	9.5	39.3	10.1	39.2	10.7	39.1	11.0	39.0	11.3	38.9	11.9
	-7.0	-7.6	40.8	9.9	40.7	10.5	40.6	11.1	40.5	11.4	40.4	11.7	40.3	12.2
	-5.0	-5.6	42.8	10.4	42.7	11.0	42.6	11.5	42.5	11.8	42.5	12.1	42.3	12.6
	-3.0	-3.7	44.9	10.9	44.8	11.4	44.6	11.9	44.6	12.2	44.5	12.5	44.4	13.0
	0.0	-0.7	48.4	11.6	48.2	12.1	48.1	12.6	48.0	12.8	48.0	13.1	47.8	13.5
	3.0	2.2	52.0	12.2	51.9	12.7	51.7	13.1	51.7	13.4	51.6	13.6	51.5	14.0
	5.0	4.1	54.5	12.6	54.4	13.1	54.3	13.5	54.2	13.7	54.2	13.9	54.0	14.4
	7.0	6.0	57.2	13.0	57.1	13.4	57.0	13.8	56.9	14.0	56.8	14.2	56.7	14.6
	9.0	7.9	60.0	13.4	59.9	13.8	59.8	14.2	59.7	14.3	59.6	14.5	59.5	14.9
	11.0	9.8	62.9	13.7	62.8	14.1	62.7	14.5	62.6	14.6	62.6	14.8	62.4	15.2
	13.0	11.8	66.2	14.1	66.0	14.4	65.9	14.8	65.8	14.9	65.8	15.1	64.0	14.9
	15.0	13.7	69.3	14.4	69.2	14.7	69.1	15.0	69.0	15.2	68.7	15.3	64.0	14.1
120 (540)	-19.8	-20.0	31.3	7.65	31.2	8.35	31.0	9.05	31.0	9.4	30.9	9.8	30.8	10.5
	-18.8	-19.0	31.8	7.88	31.7	8.57	31.6	9.3	31.5	9.6	31.5	9.9	31.4	10.6
	-16.7	-17.0	33.1	8.37	32.9	9.0	32.8	9.7	32.8	10.0	32.7	10.4	32.6	11.0
	-14.7	-15.0	34.4	8.9	34.3	9.5	34.2	10.1	34.1	10.5	34.1	10.8	33.9	11.4
	-12.6	-13.0	35.9	9.4	35.8	10.0	35.7	10.6	35.6	10.9	35.6	11.2	35.4	11.8
	-10.5	-11.0	37.6	9.9	37.4	10.4	37.3	11.0	37.3	11.3	37.2	11.6	37.1	12.2
	-9.5	-10.0	38.4	10.1	38.3	10.7	38.2	11.2	38.1	11.5	38.1	11.8	38.0	12.4
	-8.5	-9.1	39.2	10.3	39.1	10.9	39.0	11.4	38.9	11.7	38.9	12.0	38.8	12.6
	-7.0	-7.6	40.7	10.7	40.5	11.2	40.4	11.8	40.4	12.0	40.3	12.3	40.2	12.8
	-5.0	-5.6	42.7	11.2	42.6	11.7	42.4	12.2	42.4	12.4	42.3	12.7	42.2	13.2
	-3.0	-3.7	44.7	11.6	44.6	12.1	44.5	12.6	44.4	12.8	44.3	13.1	44.2	13.5
	0.0	-0.7	48.2	12.3	48.1	12.7	47.9	13.2	47.9	13.4	47.8	13.6	47.7	14.1
	3.0	2.2	51.8	12.9	51.7	13.3	51.6	13.7	51.5	13.9	51.5	14.1	51.3	14.5
	5.0	4.1	54.4	13.2	54.3	13.6	54.1	14.0	54.1	14.2	54.0	14.4	53.9	14.8
	7.0	6.0	57.0	13.6	56.9	13.9	56.8	14.3	56.7	14.5	56.7	14.7	56.6	15.1
	9.0	7.9	59.8	13.9	59.7	14.3	59.6	14.6	59.5	14.8	59.5	15.0	59.1	15.2
	11.0	9.8	62.8	14.2	62.6	14.6	62.5	14.9	62.5	15.1	62.4	15.2	59.1	14.4
	13.0	11.8	66.0	14.5	65.9	14.9	65.7	15.2	65.6	15.3	63.4	14.7	59.1	13.5
	15.0	13.7	69.2	14.8	69.0	15.1	67.8	15.0	65.6	14.5	63.4	13.9	59.1	12.8
110 (495)	-19.8	-20.0	31.1	8.67	31.0	9.3	30.9	10.0	30.8	10.3	30.8	10.6	30.7	11.2
	-18.8	-19.0	31.7	8.89	31.6	9.5	31.4	10.2	31.4	10.5	31.3	10.8	31.2	11.4
	-16.7	-17.0	32.9	9.3	32.8	9.9	32.7	10.6	32.6	10.9	32.6	11.2	32.4	11.8
	-14.7	-15.0	34.2	9.8	34.1	10.4	34.0	11.0	34.0	11.2	33.9	11.5	33.8	12.1
	-12.6	-13.0	35.7	10.3	35.6	10.8	35.5	11.4	35.5	11.6	35.4	11.9	35.3	12.5
	-10.5	-11.0	37.4	10.7	37.3	11.2	37.2	11.8	37.1	12.0	37.1	12.3	36.9	12.8
	-9.5	-10.0	38.3	10.9	38.1	11.5	38.0	12.0	38.0	12.2	37.9	12.5	37.8	13.0
	-8.5	-9.1	39.1	11.1	39.0	11.7	38.8	12.2	38.8	12.4	38.7	12.7	38.6	13.2
	-7.0	-7.6	40.5	11.5	40.4	12.0	40.3	12.5	40.2	12.7	40.2	12.9	40.0	13.4
	-5.0	-5.6	42.5	11.9	42.4	12.4	42.3	12.8	42.2	13.1	42.2	13.3	42.1	13.8
	-3.0	-3.7	44.5	12.3	44.4	12.8	44.3	13.2	44.3	13.4	44.2	13.6	44.1	14.1
	0.0	-0.7	48.0	12.9	47.9	13.3	47.8	13.7	47.7	13.9	47.7	14.2	47.6	14.6
	3.0	2.2	51.7	13.5	51.5	13.8	51.4	14.2	51.4	14.4	51.3	14.6	51.2	15.0
	5.0	4.1	54.2	13.8	54.1	14.2	54.0	14.5	53.9	14.7	53.9	14.9	53.8	15.3
	7.0	6.0	56.9	14.1	56.8	14.5	56.7	14.8	56.6	15.0	56.5	15.2	54.2	14.5
	9.0	7.9	59.7	14.4	59.6	14.8	59.5	15.1	59.4	15.2	58.2	14.9	54.2	13.7
	11.0	9.8	62.6	14.7	62.5	15.0	62.2	15.3	60.2	14.7	58.2	14.1	54.2	13.0
	13.0	11.8	65.8	15.0	65.7	15.3	62.2	14.4	60.2	13.8	58.2	13.3	54.2	12.2
	15.0	13.7	69.0	15.3	66.1	14.6	62.2	13.6	60.2	13.1	58.2	12.6	54.2	11.6

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (450)	-19.8	-20.0	30.9	9.7	30.8	10.3	30.7	10.9	30.7	11.2	30.6	11.5	30.5	12.0
	-18.8	-19.0	31.5	9.9	31.4	10.5	31.3	11.0	31.2	11.3	31.2	11.6	31.1	12.2
	-16.7	-17.0	32.7	10.3	32.6	10.9	32.5	11.4	32.5	11.7	32.4	12.0	32.3	12.5
	-14.7	-15.0	34.1	10.7	34.0	11.3	33.9	11.8	33.8	12.0	33.8	12.3	33.7	12.8
	-12.6	-13.0	35.6	11.1	35.5	11.7	35.4	12.2	35.3	12.4	35.3	12.7	35.2	13.2
	-10.5	-11.0	37.2	11.6	37.1	12.0	37.0	12.5	37.0	12.8	36.9	13.0	36.8	13.5
	-9.5	-10.0	38.1	11.8	38.0	12.2	37.9	12.7	37.8	13.0	37.8	13.2	37.7	13.7
	-8.5	-9.1	38.9	12.0	38.8	12.4	38.7	12.9	38.6	13.1	38.6	13.3	38.5	13.8
	-7.0	-7.6	40.3	12.3	40.2	12.7	40.1	13.2	40.1	13.4	40.0	13.6	39.9	14.0
	-5.0	-5.6	42.3	12.7	42.2	13.1	42.1	13.5	42.1	13.7	42.0	13.9	41.9	14.4
	-3.0	-3.7	44.4	13.0	44.3	13.4	44.2	13.8	44.1	14.0	44.1	14.2	44.0	14.6
	0.0	-0.7	47.8	13.6	47.7	13.9	47.6	14.3	47.6	14.5	47.5	14.7	47.4	15.1
	3.0	2.2	51.5	14.1	51.4	14.4	51.3	14.8	51.2	14.9	51.2	15.1	49.2	14.6
	5.0	4.1	54.0	14.4	53.9	14.7	53.8	15.0	53.8	15.2	52.9	15.0	49.2	13.8
	7.0	6.0	56.7	14.7	56.6	15.0	56.5	15.3	54.7	14.7	52.9	14.1	49.2	13.0
	9.0	7.9	59.5	14.9	59.4	15.2	56.5	14.4	54.7	13.9	52.9	13.4	49.2	12.3
	11.0	9.8	62.4	15.2	60.1	14.7	56.5	13.6	54.7	13.1	52.9	12.6	49.2	11.6
	13.0	11.8	63.8	14.8	60.1	13.8	56.5	12.9	54.7	12.4	52.9	11.9	49.2	11.0
	15.0	13.7	63.8	14.0	60.1	13.1	56.5	12.2	54.7	11.7	52.9	11.3	49.2	10.4
90 (405)	-19.8	-20.0	30.7	10.7	30.7	11.3	30.6	11.8	30.5	12.0	30.5	12.3	30.4	12.8
	-18.8	-19.0	31.3	10.9	31.2	11.4	31.1	11.9	31.1	12.2	31.0	12.5	31.0	13.0
	-16.7	-17.0	32.5	11.3	32.4	11.8	32.4	12.3	32.3	12.5	32.3	12.8	32.2	13.3
	-14.7	-15.0	33.9	11.7	33.8	12.1	33.7	12.6	33.7	12.8	33.6	13.1	33.5	13.6
	-12.6	-13.0	35.4	12.0	35.3	12.5	35.2	12.9	35.2	13.2	35.1	13.4	35.0	13.9
	-10.5	-11.0	37.0	12.4	36.9	12.8	36.9	13.3	36.8	13.5	36.8	13.7	36.7	14.2
	-9.5	-10.0	37.9	12.6	37.8	13.0	37.7	13.4	37.7	13.7	37.6	13.9	37.5	14.3
	-8.5	-9.1	38.7	12.8	38.6	13.2	38.5	13.6	38.5	13.8	38.5	14.0	38.4	14.4
	-7.0	-7.6	40.1	13.0	40.0	13.4	40.0	13.8	39.9	14.0	39.9	14.2	39.8	14.6
	-5.0	-5.6	42.1	13.4	42.1	13.8	42.0	14.2	41.9	14.4	41.9	14.5	41.8	14.9
	-3.0	-3.7	44.2	13.7	44.1	14.1	44.0	14.5	44.0	14.6	43.9	14.8	43.8	15.2
	0.0	-0.7	47.7	14.2	47.6	14.6	47.5	14.9	47.4	15.1	47.4	15.2	44.3	14.1
	3.0	2.2	51.3	14.7	51.2	15.0	50.9	15.2	49.2	14.6	47.6	14.0	44.3	12.9
	5.0	4.1	53.9	15.0	53.8	15.3	50.9	14.3	49.2	13.8	47.6	13.2	44.3	12.2
	7.0	6.0	56.5	15.2	54.1	14.5	50.9	13.5	49.2	13.0	47.6	12.5	44.3	11.5
	9.0	7.9	57.4	14.7	54.1	13.7	50.9	12.8	49.2	12.3	47.6	11.8	44.3	10.9
	11.0	9.8	57.4	13.9	54.1	13.0	50.9	12.1	49.2	11.6	47.6	11.2	44.3	10.4
	13.0	11.8	57.4	13.1	54.1	12.2	50.9	11.4	49.2	11.0	47.6	10.6	44.3	9.8
	15.0	13.7	57.4	12.4	54.1	11.6	50.9	10.8	49.2	10.4	47.6	10.1	44.3	9.31
80 (360)	-19.8	-20.0	30.6	11.8	30.5	12.2	30.4	12.7	30.4	12.9	30.3	13.2	30.3	13.6
	-18.8	-19.0	31.1	11.9	31.1	12.4	31.0	12.8	30.9	13.1	30.9	13.3	30.8	13.8
	-16.7	-17.0	32.4	12.2	32.3	12.7	32.2	13.1	32.2	13.3	32.1	13.6	32.0	14.0
	-14.7	-15.0	33.7	12.6	33.6	13.0	33.6	13.4	33.5	13.6	33.5	13.9	33.4	14.3
	-12.6	-13.0	35.2	12.9	35.1	13.3	35.1	13.7	35.0	13.9	35.0	14.1	34.9	14.5
	-10.5	-11.0	36.9	13.3	36.8	13.6	36.7	14.0	36.7	14.2	36.6	14.4	36.5	14.8
	-9.5	-10.0	37.7	13.4	37.7	13.8	37.6	14.2	37.5	14.4	37.5	14.6	37.4	14.9
	-8.5	-9.1	38.5	13.6	38.5	13.9	38.4	14.3	38.3	14.5	38.3	14.7	38.2	15.1
	-7.0	-7.6	40.0	13.8	39.9	14.2	39.8	14.5	39.8	14.7	39.7	14.9	39.4	15.1
	-5.0	-5.6	42.0	14.1	41.9	14.5	41.8	14.8	41.8	15.0	41.7	15.2	39.4	14.2
	-3.0	-3.7	44.0	14.4	43.9	14.8	43.9	15.1	43.7	15.2	42.3	14.6	39.4	13.4
	0.0	-0.7	47.5	14.9	47.4	15.2	45.2	14.4	43.7	13.9	42.3	13.3	39.4	12.3
	3.0	2.2	51.0	15.2	48.1	14.2	45.2	13.2	43.7	12.7	42.3	12.2	39.4	11.3
	5.0	4.1	51.0	14.4	48.1	13.4	45.2	12.5	43.7	12.0	42.3	11.6	39.4	10.7
	7.0	6.0	51.0	13.6	48.1	12.7	45.2	11.8	43.7	11.4	42.3	11.0	39.4	10.1
	9.0	7.9	51.0	12.8	48.1	12.0	45.2	11.2	43.7	10.8	42.3	10.4	39.4	9.61
	11.0	9.8	51.0	12.1	48.1	11.3	45.2	10.6	43.7	10.2	42.3	9.8	39.4	9.12
	13.0	11.8	51.0	11.4	48.1	10.7	45.2	10.0	43.7	9.7	42.3	9.32	39.4	8.65
	15.0	13.7	51.0	10.8	48.1	10.2	45.2	9.5	43.7	9.19	42.3	8.86	39.4	8.23

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0			18.0			20.0			21.0			22.0			24.0	
			TC	PI		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI
	°CDB	°CWB	kW	kW		kW	kW		kW	kW		kW	kW		kW	kW		kW	kW
70 (315)	-19.8	-20.0	30.4	12.8		30.3	13.2		30.3	13.6		30.2	13.8		30.2	14.0		30.1	14.4
	-18.8	-19.0	31.0	12.9		30.9	13.3		30.8	13.7		30.8	13.9		30.8	14.1		30.7	14.5
	-16.7	-17.0	32.2	13.2		32.1	13.6		32.0	14.0		32.0	14.2		32.0	14.4		31.9	14.8
	-14.7	-15.0	33.5	13.5		33.5	13.9		33.4	14.3		33.4	14.4		33.3	14.6		33.3	15.0
	-12.6	-13.0	35.0	13.8		35.0	14.2		34.9	14.5		34.9	14.7		34.8	14.9		34.5	15.0
	-10.5	-11.0	36.7	14.1		36.6	14.4		36.5	14.8		36.5	15.0		36.5	15.1		34.5	14.2
	-9.5	-10.0	37.6	14.3		37.5	14.6		37.4	14.9		37.4	15.1		37.0	15.0		34.5	13.8
	-8.5	-9.1	38.4	14.4		38.3	14.7		38.2	15.0		38.2	15.2		37.0	14.6		34.5	13.5
	-7.0	-7.6	39.8	14.6		39.7	14.9		39.6	15.2		38.3	14.6		37.0	14.0		34.5	12.9
	-5.0	-5.6	41.8	14.9		41.7	15.2		39.6	14.3		38.3	13.8		37.0	13.2		34.5	12.2
	-3.0	-3.7	43.8	15.1		42.1	14.5		39.6	13.5		38.3	13.0		37.0	12.5		34.5	11.5
	0.0	-0.7	44.6	14.2		42.1	13.3		39.6	12.4		38.3	11.9		37.0	11.5		34.5	10.59
	3.0	2.2	44.6	13.0		42.1	12.2		39.6	11.3		38.3	10.9		37.0	10.5		34.5	9.76
	5.0	4.1	44.6	12.3		42.1	11.5		39.6	10.7		38.3	10.4		37.0	9.99		34.5	9.25
	7.0	6.0	44.6	11.6		42.1	10.9		39.6	10.2		38.3	9.82		37.0	9.47		34.5	8.78
	9.0	7.9	44.6	11.0		42.1	10.3		39.6	9.65		38.3	9.32		37.0	8.99		34.5	8.35
	11.0	9.8	44.6	10.4		42.1	9.8		39.6	9.16		38.3	8.85		37.0	8.54		34.5	7.94
	13.0	11.8	44.6	9.9		42.1	9.28		39.6	8.69		38.3	8.39		37.0	8.11		34.5	7.54
	15.0	13.7	44.6	9.4		42.1	8.82		39.6	8.26		38.3	7.99		37.0	7.72		34.5	7.19
60 (270)	-19.8	-20.0	30.2	13.8		30.2	14.2		30.1	14.5		30.1	14.7		30.0	14.9		29.5	14.9
	-18.8	-19.0	30.8	13.9		30.7	14.3		30.7	14.6		30.6	14.8		30.6	15.0		29.5	14.5
	-16.7	-17.0	32.0	14.2		32.0	14.5		31.9	14.8		31.9	15.0		31.7	15.1		29.5	13.9
	-14.7	-15.0	33.4	14.4		33.3	14.8		33.3	15.1		32.8	14.9		31.7	14.4		29.5	13.2
	-12.6	-13.0	34.9	14.7		34.8	15.0		33.9	14.7		32.8	14.2		31.7	13.6		29.5	12.5
	-10.5	-11.0	36.5	15.0		36.1	15.0		33.9	13.9		32.8	13.4		31.7	12.9		29.5	11.9
	-9.5	-10.0	37.4	15.1		36.1	14.6		33.9	13.6		32.8	13.1		31.7	12.6		29.5	11.6
	-8.5	-9.1	38.2	15.2		36.1	14.2		33.9	13.2		32.8	12.7		31.7	12.2		29.5	11.3
	-7.0	-7.6	38.3	14.6		36.1	13.6		33.9	12.7		32.8	12.2		31.7	11.7		29.5	10.84
	-5.0	-5.6	38.3	13.7		36.1	12.8		33.9	12.0		32.8	11.5		31.7	11.1		29.5	10.26
	-3.0	-3.7	38.3	13.0		36.1	12.2		33.9	11.3		32.8	10.92		31.7	10.52		29.5	9.74
	0.0	-0.7	38.3	11.9		36.1	11.1		33.9	10.40		32.8	10.03		31.7	9.67		29.5	8.97
	3.0	2.2	38.3	10.9		36.1	10.25		33.9	9.58		32.8	9.25		31.7	8.93		29.5	8.29
	5.0	4.1	38.3	10.4		36.1	9.72		33.9	9.09		32.8	8.78		31.7	8.48		29.5	7.88
	7.0	6.0	38.3	9.82		36.1	9.22		33.9	8.63		32.8	8.34		31.7	8.06		29.5	7.50
	9.0	7.9	38.3	9.31		36.1	8.75		33.9	8.21		32.8	7.93		31.7	7.67		29.5	7.14
	11.0	9.8	38.3	8.85		36.1	8.32		33.9	7.81		32.8	7.55		31.7	7.30		29.5	6.81
	13.0	11.8	38.3	8.39		36.1	7.90		33.9	7.42		32.8	7.18		31.7	6.94		29.5	6.48
	15.0	13.7	38.3	7.99		36.1	7.53		33.9	7.07		32.8	6.85		31.7	6.63		29.5	6.19
50 (225)	-19.8	-20.0	30.1	14.8		30.0	15.1		28.3	14.1		27.3	13.6		26.4	13.0		24.6	12.0
	-18.8	-19.0	30.6	14.9		30.1	14.8		28.3	13.8		27.3	13.3		26.4	12.8		24.6	11.8
	-16.7	-17.0	31.8	15.2		30.1	14.2		28.3	13.2		27.3	12.7		26.4	12.2		24.6	11.3
	-14.7	-15.0	31.9	14.4		30.1	13.5		28.3	12.5		27.3	12.1		26.4	11.6		24.6	10.74
	-12.6	-13.0	31.9	13.7		30.1	12.8		28.3	11.9		27.3	11.5		26.4	11.06		24.6	10.23
	-10.5	-11.0	31.9	13.0		30.1	12.1		28.3	11.3		27.3	10.91		26.4	10.51		24.6	9.72
	-9.5	-10.0	31.9	12.6		30.1	11.8		28.3	11.01		27.3	10.62		26.4	10.23		24.6	9.48
	-8.5	-9.1	31.9	12.3		30.1	11.5		28.3	10.75		27.3	10.37		26.4	9.99		24.6	9.26
	-7.0	-7.6	31.9	11.8		30.1	11.06		28.3	10.32		27.3	9.96		26.4	9.60		24.6	8.90
	-5.0	-5.6	31.9	11.2		30.1	10.46		28.3	9.77		27.3	9.44		26.4	9.10		24.6	8.45
	-3.0	-3.7	31.9	10.58		30.1	9.92		28.3	9.28		27.3	8.96		26.4	8.65		24.6	8.04
	0.0	-0.7	31.9	9.73		30.1	9.13		28.3	8.55		27.3	8.27		26.4	7.99		24.6	7.43
	3.0	2.2	31.9	8.98		30.1	8.44		28.3	7.92		27.3	7.66		26.4	7.40		24.6	6.90
	5.0	4.1	31.9	8.52		30.1	8.02		28.3	7.53		27.3	7.29		26.4	7.05		24.6	6.57
	7.0	6.0	31.9	8.10		30.1	7.63		28.3	7.17		27.3	6.94		26.4	6.72		24.6	6.27
	9.0	7.9	31.9	7.71		30.1	7.26		28.3	6.83		27.3	6.62		26.4	6.41		24.6	5.99
	11.0	9.8	31.9	7.34		30.1	6.92		28.3	6.52		27.3	6.32		26.4	6.12		24.6	5.72
	13.0	11.8	31.9	6.98		30.1	6.59		28.3	6.21		27.3	6.02		26.4	5.83		24.6	5.46
	15.0	13.7	31.9	6.66		30.1	6.29		28.3	5.93		27.3	5.76		26.4	5.58		24.6	5.23

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

14

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (650)	-19.8	-20.0	39.9	9.85	39.8	10.58	39.7	11.30	39.6	11.7	39.5	12.0	39.4	12.8
	-18.8	-19.0	40.9	10.16	40.7	10.87	40.6	11.6	40.5	11.9	40.4	12.3	40.3	13.0
	-16.7	-17.0	42.7	10.75	42.6	11.4	42.5	12.1	42.4	12.4	42.3	12.8	42.2	13.5
	-14.7	-15.0	44.7	11.32	44.6	12.0	44.5	12.6	44.4	12.9	44.3	13.3	44.2	13.9
	-12.6	-13.0	46.8	11.9	46.7	12.5	46.6	13.1	46.5	13.4	46.4	13.7	46.3	14.3
	-10.5	-11.0	49.1	12.4	48.9	13.0	48.8	13.6	48.7	13.9	48.6	14.1	48.5	14.7
	-9.5	-10.0	50.2	12.6	50.1	13.2	49.9	13.8	49.8	14.1	49.8	14.4	49.6	14.9
	-8.5	-9.1	51.3	12.9	51.1	13.4	51.0	14.0	50.9	14.3	50.8	14.5	50.7	15.1
	-7.0	-7.6	53.1	13.2	52.9	13.8	52.8	14.3	52.7	14.6	52.6	14.8	52.5	15.4
	-5.0	-5.6	55.5	13.7	55.4	14.2	55.3	14.7	55.2	15.0	55.1	15.2	55.0	15.7
	-3.0	-3.7	58.0	14.1	57.9	14.6	57.7	15.1	57.6	15.3	57.6	15.6	57.4	16.1
	0.0	-0.7	62.1	14.7	61.9	15.2	61.8	15.6	61.7	15.9	61.7	16.1	61.5	16.5
	3.0	2.2	66.3	15.2	66.1	15.7	66.0	16.1	65.9	16.3	65.8	16.5	65.7	17.0
	5.0	4.1	69.1	15.6	69.0	16.0	68.8	16.4	68.7	16.6	68.7	16.8	68.5	17.2
	7.0	6.0	72.1	15.9	71.9	16.3	71.8	16.7	71.7	16.9	71.6	17.1	70.8	17.2
	9.0	7.9	75.1	16.2	74.9	16.6	74.8	17.0	74.7	17.1	74.7	17.3	70.8	16.4
	11.0	9.8	78.2	16.5	78.1	16.9	77.9	17.2	77.9	17.4	76.0	17.0	70.8	15.5
	13.0	11.8	81.6	16.8	81.5	17.1	81.3	17.4	78.6	16.8	76.0	16.1	70.8	14.8
	15.0	13.7	85.0	17.0	84.8	17.4	81.3	16.6	78.6	15.9	76.0	15.3	70.8	14.1
120 (600)	-19.8	-20.0	39.8	10.83	39.6	11.50	39.5	12.2	39.4	12.5	39.4	12.8	39.2	13.5
	-18.8	-19.0	40.7	11.12	40.5	11.8	40.4	12.4	40.3	12.8	40.3	13.1	40.1	13.7
	-16.7	-17.0	42.6	11.7	42.4	12.3	42.3	12.9	42.2	13.2	42.2	13.5	42.0	14.2
	-14.7	-15.0	44.6	12.2	44.4	12.8	44.3	13.4	44.2	13.7	44.2	14.0	44.0	14.6
	-12.6	-13.0	46.7	12.7	46.5	13.3	46.4	13.8	46.3	14.1	46.3	14.4	46.1	15.0
	-10.5	-11.0	48.9	13.2	48.7	13.7	48.6	14.3	48.5	14.5	48.5	14.8	48.3	15.3
	-9.5	-10.0	50.0	13.4	49.9	13.9	49.7	14.5	49.7	14.7	49.6	15.0	49.5	15.5
	-8.5	-9.1	51.1	13.6	50.9	14.1	50.8	14.7	50.7	14.9	50.7	15.2	50.5	15.7
	-7.0	-7.6	52.9	14.0	52.7	14.5	52.6	14.9	52.5	15.2	52.5	15.4	52.3	15.9
	-5.0	-5.6	55.3	14.4	55.2	14.9	55.1	15.3	55.0	15.6	55.0	15.8	54.8	16.3
	-3.0	-3.7	57.8	14.8	57.7	15.2	57.5	15.7	57.5	15.9	57.4	16.1	57.3	16.6
	0.0	-0.7	61.9	15.3	61.8	15.7	61.6	16.2	61.6	16.4	61.5	16.6	61.4	17.0
	3.0	2.2	66.1	15.8	65.9	16.2	65.8	16.6	65.7	16.8	65.7	17.0	65.4	17.3
	5.0	4.1	68.9	16.1	68.8	16.5	68.7	16.9	68.6	17.1	68.5	17.3	65.4	16.4
	7.0	6.0	71.9	16.4	71.7	16.8	71.6	17.2	71.5	17.3	70.2	17.0	65.4	15.6
	9.0	7.9	74.9	16.7	74.8	17.1	74.6	17.4	72.6	16.9	70.2	16.2	65.4	14.8
	11.0	9.8	78.0	17.0	77.9	17.3	75.0	16.7	72.6	16.0	70.2	15.4	65.4	14.1
	13.0	11.8	81.4	17.2	79.8	17.1	75.0	15.8	72.6	15.2	70.2	14.6	65.4	13.4
	15.0	13.7	84.6	17.4	79.8	16.2	75.0	15.1	72.6	14.5	70.2	13.9	65.4	12.8
110 (550)	-19.8	-20.0	39.6	11.8	39.4	12.4	39.3	13.0	39.3	13.3	39.2	13.7	39.1	14.3
	-18.8	-19.0	40.5	12.1	40.3	12.7	40.2	13.3	40.2	13.6	40.1	13.9	40.0	14.5
	-16.7	-17.0	42.4	12.6	42.2	13.2	42.1	13.7	42.1	14.0	42.0	14.3	41.9	14.9
	-14.7	-15.0	44.4	13.1	44.2	13.6	44.1	14.2	44.1	14.4	44.0	14.7	43.9	15.2
	-12.6	-13.0	46.5	13.5	46.3	14.1	46.2	14.6	46.2	14.8	46.1	15.1	46.0	15.6
	-10.5	-11.0	48.7	14.0	48.5	14.5	48.4	15.0	48.4	15.2	48.3	15.5	48.2	16.0
	-9.5	-10.0	49.8	14.2	49.7	14.7	49.6	15.2	49.5	15.4	49.5	15.6	49.3	16.1
	-8.5	-9.1	50.9	14.4	50.7	14.9	50.6	15.3	50.6	15.6	50.5	15.8	50.4	16.3
	-7.0	-7.6	52.7	14.7	52.5	15.1	52.4	15.6	52.4	15.8	52.3	16.1	52.2	16.5
	-5.0	-5.6	55.2	15.1	55.0	15.5	54.9	15.9	54.9	16.2	54.8	16.4	54.7	16.8
	-3.0	-3.7	57.6	15.4	57.5	15.8	57.4	16.3	57.3	16.5	57.3	16.7	57.1	17.1
	0.0	-0.7	61.7	15.9	61.6	16.3	61.5	16.7	61.4	16.9	61.3	17.1	59.9	16.9
	3.0	2.2	65.9	16.4	65.7	16.8	65.6	17.1	65.6	17.3	64.3	17.0	59.9	15.6
	5.0	4.1	68.7	16.7	68.6	17.0	68.5	17.4	66.5	16.8	64.3	16.1	59.9	14.8
	7.0	6.0	71.7	17.0	71.5	17.3	68.8	16.6	66.5	16.0	64.3	15.3	59.9	14.1
	9.0	7.9	74.7	17.2	73.2	17.0	68.8	15.8	66.5	15.2	64.3	14.6	59.9	13.4
	11.0	9.8	77.6	17.4	73.2	16.2	68.8	15.0	66.5	14.4	64.3	13.9	59.9	12.8
	13.0	11.8	77.6	16.5	73.2	15.3	68.8	14.2	66.5	13.7	64.3	13.2	59.9	12.1
	15.0	13.7	77.6	15.7	73.2	14.6	68.8	13.6	66.5	13.1	64.3	12.6	59.9	11.6

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (500)	-19.8	-20.0	39.4	12.8	39.3	13.4	39.1	13.9	39.1	14.2	39.0	14.5	38.9	15.0
	-18.8	-19.0	40.3	13.0	40.2	13.6	40.1	14.1	40.0	14.4	39.9	14.7	39.8	15.2
	-16.7	-17.0	42.2	13.5	42.1	14.0	41.9	14.5	41.9	14.8	41.8	15.1	41.7	15.6
	-14.7	-15.0	44.2	13.9	44.1	14.4	43.9	14.9	43.9	15.2	43.8	15.4	43.7	15.9
	-12.6	-13.0	46.3	14.4	46.2	14.8	46.0	15.3	46.0	15.5	45.9	15.8	45.8	16.3
	-10.5	-11.0	48.5	14.8	48.4	15.2	48.3	15.7	48.2	15.9	48.1	16.1	48.0	16.6
	-9.5	-10.0	49.6	15.0	49.5	15.4	49.4	15.8	49.3	16.1	49.3	16.3	49.2	16.7
	-8.5	-9.1	50.7	15.1	50.6	15.6	50.5	16.0	50.4	16.2	50.3	16.4	50.2	16.9
	-7.0	-7.6	52.5	15.4	52.4	15.8	52.3	16.2	52.2	16.5	52.1	16.7	52.0	17.1
	-5.0	-5.6	55.0	15.8	54.9	16.2	54.7	16.6	54.7	16.8	54.6	17.0	54.5	17.3
	-3.0	-3.7	57.4	16.1	57.3	16.5	57.2	16.8	57.2	17.0	57.1	17.2	54.5	16.4
	0.0	-0.7	61.5	16.6	61.4	16.9	61.3	17.3	60.5	17.1	58.5	16.4	54.5	15.1
	3.0	2.2	65.7	17.0	65.6	17.3	62.5	16.4	60.5	15.8	58.5	15.1	54.5	13.9
	5.0	4.1	68.5	17.3	66.5	16.8	62.5	15.6	60.5	15.0	58.5	14.4	54.5	13.2
	7.0	6.0	70.5	17.1	66.5	16.0	62.5	14.8	60.5	14.2	58.5	13.7	54.5	12.6
	9.0	7.9	70.5	16.3	66.5	15.2	62.5	14.1	60.5	13.5	58.5	13.0	54.5	12.0
	11.0	9.8	70.5	15.5	66.5	14.4	62.5	13.4	60.5	12.9	58.5	12.4	54.5	11.4
	13.0	11.8	70.5	14.7	66.5	13.7	62.5	12.7	60.5	12.3	58.5	11.8	54.5	10.9
	15.0	13.7	70.5	14.0	66.5	13.1	62.5	12.2	60.5	11.7	58.5	11.3	54.5	10.4
90 (450)	-19.8	-20.0	39.2	13.8	39.1	14.3	39.0	14.8	38.9	15.0	38.9	15.3	38.8	15.8
	-18.8	-19.0	40.1	14.0	40.0	14.5	39.9	15.0	39.8	15.2	39.8	15.5	39.7	16.0
	-16.7	-17.0	42.0	14.4	41.9	14.9	41.8	15.3	41.7	15.6	41.7	15.8	41.6	16.3
	-14.7	-15.0	44.0	14.8	43.9	15.3	43.8	15.7	43.7	15.9	43.7	16.1	43.6	16.6
	-12.6	-13.0	46.1	15.2	46.0	15.6	45.9	16.0	45.8	16.3	45.8	16.5	45.7	16.9
	-10.5	-11.0	48.3	15.6	48.2	16.0	48.1	16.4	48.0	16.6	48.0	16.8	47.9	17.2
	-9.5	-10.0	49.4	15.7	49.3	16.1	49.2	16.5	49.2	16.7	49.1	16.9	49.0	17.3
	-8.5	-9.1	50.5	15.9	50.4	16.3	50.3	16.7	50.2	16.9	50.2	17.1	49.0	16.9
	-7.0	-7.6	52.3	16.1	52.2	16.5	52.1	16.9	52.0	17.1	52.0	17.3	49.0	16.1
	-5.0	-5.6	54.8	16.5	54.7	16.8	54.6	17.2	54.4	17.3	52.6	16.6	49.0	15.2
	-3.0	-3.7	57.2	16.8	57.1	17.1	56.3	17.1	54.4	16.4	52.6	15.7	49.0	14.4
	0.0	-0.7	61.3	17.2	59.9	16.9	56.3	15.7	54.4	15.1	52.6	14.5	49.0	13.3
	3.0	2.2	63.5	16.7	59.9	15.6	56.3	14.5	54.4	13.9	52.6	13.4	49.0	12.3
	5.0	4.1	63.5	15.9	59.9	14.8	56.3	13.7	54.4	13.2	52.6	12.7	49.0	11.7
	7.0	6.0	63.5	15.1	59.9	14.1	56.3	13.1	54.4	12.6	52.6	12.1	49.0	11.2
	9.0	7.9	63.5	14.3	59.9	13.4	56.3	12.4	54.4	12.0	52.6	11.5	49.0	10.7
	11.0	9.8	63.5	13.6	59.9	12.7	56.3	11.9	54.4	11.4	52.6	11.0	49.0	10.2
	13.0	11.8	63.5	13.0	59.9	12.1	56.3	11.3	54.4	10.9	52.6	10.5	49.0	9.7
	15.0	13.7	63.5	12.4	59.9	11.6	56.3	10.8	54.4	10.4	52.6	10.0	49.0	9.3
80 (400)	-19.8	-20.0	39.0	14.8	38.9	15.2	38.8	15.6	38.8	15.9	38.7	16.1	38.6	16.5
	-18.8	-19.0	39.9	14.9	39.8	15.4	39.7	15.8	39.7	16.0	39.6	16.3	39.5	16.7
	-16.7	-17.0	41.8	15.3	41.7	15.7	41.6	16.2	41.6	16.4	41.5	16.6	41.4	17.0
	-14.7	-15.0	43.8	15.7	43.7	16.1	43.6	16.5	43.6	16.7	43.5	16.9	43.4	17.3
	-12.6	-13.0	45.9	16.0	45.8	16.4	45.7	16.8	45.7	17.0	45.6	17.2	43.6	16.4
	-10.5	-11.0	48.1	16.3	48.0	16.7	47.9	17.1	47.9	17.3	46.8	16.8	43.6	15.4
	-9.5	-10.0	49.2	16.5	49.1	16.9	49.1	17.2	48.4	17.0	46.8	16.3	43.6	15.0
	-8.5	-9.1	50.3	16.6	50.2	17.0	50.0	17.3	48.4	16.6	46.8	15.9	43.6	14.6
	-7.0	-7.6	52.1	16.9	52.0	17.2	50.0	16.5	48.4	15.9	46.8	15.3	43.6	14.0
	-5.0	-5.6	54.6	17.2	53.2	16.8	50.0	15.6	48.4	15.0	46.8	14.4	43.6	13.3
	-3.0	-3.7	56.4	17.1	53.2	15.9	50.0	14.8	48.4	14.2	46.8	13.7	43.6	12.6
	0.0	-0.7	56.4	15.7	53.2	14.7	50.0	13.6	48.4	13.1	46.8	12.6	43.6	11.6
	3.0	2.2	56.4	14.5	53.2	13.5	50.0	12.6	48.4	12.1	46.8	11.7	43.6	10.8
	5.0	4.1	56.4	13.8	53.2	12.9	50.0	12.0	48.4	11.5	46.8	11.1	43.6	10.3
	7.0	6.0	56.4	13.1	53.2	12.3	50.0	11.4	48.4	11.0	46.8	10.6	43.6	9.8
	9.0	7.9	56.4	12.5	53.2	11.7	50.0	10.9	48.4	10.5	46.8	10.1	43.6	9.37
	11.0	9.8	56.4	11.9	53.2	11.1	50.0	10.4	48.4	10.0	46.8	9.7	43.6	8.96
	13.0	11.8	56.4	11.3	53.2	10.6	50.0	9.9	48.4	9.6	46.8	9.23	43.6	8.56
	15.0	13.7	56.4	10.8	53.2	10.2	50.0	9.5	48.4	9.16	46.8	8.84	43.6	8.20

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 TC kW	16.0 PI kW	18.0 TC kW	18.0 PI kW	20.0 TC kW	20.0 PI kW	21.0 TC kW	21.0 PI kW	22.0 TC kW	22.0 PI kW	24.0 TC kW	24.0 PI kW
70 (350)	-19.8	-20.0	38.8	15.7	38.7	16.1	38.6	16.5	38.6	16.7	38.6	16.9	38.1	17.1
	-18.8	-19.0	39.7	15.9	39.6	16.3	39.5	16.7	39.5	16.9	39.5	17.1	38.1	16.6
	-16.7	-17.0	41.6	16.2	41.5	16.6	41.4	17.0	41.4	17.1	40.9	17.0	38.1	15.6
	-14.7	-15.0	43.6	16.5	43.5	16.9	43.4	17.2	42.3	16.8	40.9	16.1	38.1	14.8
	-12.6	-13.0	45.7	16.9	45.6	17.2	43.8	16.4	42.3	15.8	40.9	15.2	38.1	13.9
	-10.5	-11.0	47.9	17.1	46.6	16.7	43.8	15.5	42.3	14.9	40.9	14.3	38.1	13.2
	-9.5	-10.0	49.0	17.3	46.6	16.3	43.8	15.1	42.3	14.5	40.9	13.9	38.1	12.8
	-8.5	-9.1	49.4	17.0	46.6	15.8	43.8	14.7	42.3	14.1	40.9	13.6	38.1	12.5
	-7.0	-7.6	49.4	16.3	46.6	15.2	43.8	14.1	42.3	13.5	40.9	13.0	38.1	12.0
	-5.0	-5.6	49.4	15.4	46.6	14.3	43.8	13.3	42.3	12.8	40.9	12.3	38.1	11.4
	-3.0	-3.7	49.4	14.6	46.6	13.6	43.8	12.6	42.3	12.2	40.9	11.7	38.1	10.8
	0.0	-0.7	49.4	13.4	46.6	12.5	43.8	11.7	42.3	11.2	40.9	10.8	38.1	10.0
	3.0	2.2	49.4	12.4	46.6	11.6	43.8	10.8	42.3	10.4	40.9	10.1	38.1	9.31
	5.0	4.1	49.4	11.8	46.6	11.1	43.8	10.3	42.3	10.0	40.9	9.59	38.1	8.89
	7.0	6.0	49.4	11.3	46.6	10.5	43.8	9.8	42.3	9.50	40.9	9.16	38.1	8.50
	9.0	7.9	49.4	10.7	46.6	10.1	43.8	9.41	42.3	9.08	40.9	8.76	38.1	8.13
	11.0	9.8	49.4	10.3	46.6	9.6	43.8	9.00	42.3	8.69	40.9	8.39	38.1	7.79
	13.0	11.8	49.4	9.8	46.6	9.18	43.8	8.59	42.3	8.30	40.9	8.02	38.1	7.46
	15.0	13.7	49.4	9.4	46.6	8.79	43.8	8.24	42.3	7.96	40.9	7.69	38.1	7.16
60 (300)	-19.8	-20.0	38.6	16.7	38.5	17.1	37.5	16.7	36.3	16.1	35.1	15.4	32.7	14.2
	-18.8	-19.0	39.5	16.9	39.4	17.2	37.5	16.2	36.3	15.6	35.1	15.0	32.7	13.8
	-16.7	-17.0	41.4	17.1	39.9	16.5	37.5	15.3	36.3	14.7	35.1	14.2	32.7	13.0
	-14.7	-15.0	42.3	16.7	39.9	15.6	37.5	14.5	36.3	13.9	35.1	13.4	32.7	12.3
	-12.6	-13.0	42.3	15.8	39.9	14.7	37.5	13.7	36.3	13.2	35.1	12.6	32.7	11.7
	-10.5	-11.0	42.3	14.9	39.9	13.9	37.5	12.9	36.3	12.4	35.1	12.0	32.7	11.0
	-9.5	-10.0	42.3	14.5	39.9	13.5	37.5	12.6	36.3	12.1	35.1	11.6	32.7	10.8
	-8.5	-9.1	42.3	14.1	39.9	13.2	37.5	12.3	36.3	11.8	35.1	11.4	32.7	10.5
	-7.0	-7.6	42.3	13.5	39.9	12.6	37.5	11.8	36.3	11.3	35.1	10.9	32.7	10.09
	-5.0	-5.6	42.3	12.8	39.9	12.0	37.5	11.2	36.3	10.8	35.1	10.4	32.7	9.58
	-3.0	-3.7	42.3	12.2	39.9	11.4	37.5	10.6	36.3	10.2	35.1	9.86	32.7	9.13
	0.0	-0.7	42.3	11.2	39.9	10.5	37.5	9.83	36.3	9.48	35.1	9.14	32.7	8.48
	3.0	2.2	42.3	10.4	39.9	9.78	37.5	9.14	36.3	8.83	35.1	8.52	32.7	7.91
	5.0	4.1	42.3	9.9	39.9	9.33	37.5	8.73	36.3	8.44	35.1	8.15	32.7	7.57
	7.0	6.0	42.3	9.50	39.9	8.92	37.5	8.35	36.3	8.07	35.1	7.80	32.7	7.25
	9.0	7.9	42.3	9.08	39.9	8.53	37.5	7.99	36.3	7.73	35.1	7.47	32.7	6.95
	11.0	9.8	42.3	8.68	39.9	8.17	37.5	7.66	36.3	7.41	35.1	7.16	32.7	6.67
	13.0	11.8	42.3	8.30	39.9	7.81	37.5	7.33	36.3	7.09	35.1	6.86	32.7	6.40
	15.0	13.7	42.3	7.96	39.9	7.49	37.5	7.04	36.3	6.82	35.1	6.59	32.7	6.15
50 (250)	-19.8	-20.0	35.3	15.5	33.3	14.4	31.3	13.4	30.2	12.9	29.2	12.4	27.2	11.5
	-18.8	-19.0	35.3	15.1	33.3	14.0	31.3	13.1	30.2	12.6	29.2	12.1	27.2	11.2
	-16.7	-17.0	35.3	14.2	33.3	13.3	31.3	12.4	30.2	11.9	29.2	11.5	27.2	10.6
	-14.7	-15.0	35.3	13.5	33.3	12.6	31.3	11.7	30.2	11.3	29.2	10.9	27.2	10.03
	-12.6	-13.0	35.3	12.7	33.3	11.9	31.3	11.1	30.2	10.7	29.2	10.3	27.2	9.52
	-10.5	-11.0	35.3	12.0	33.3	11.3	31.3	10.5	30.2	10.13	29.2	9.77	27.2	9.04
	-9.5	-10.0	35.3	11.7	33.3	11.0	31.3	10.2	30.2	9.87	29.2	9.52	27.2	8.82
	-8.5	-9.1	35.3	11.4	33.3	10.7	31.3	9.99	30.2	9.64	29.2	9.30	27.2	8.62
	-7.0	-7.6	35.3	11.0	33.3	10.3	31.3	9.61	30.2	9.28	29.2	8.95	27.2	8.30
	-5.0	-5.6	35.3	10.4	33.3	9.77	31.3	9.13	30.2	8.82	29.2	8.51	27.2	7.90
	-3.0	-3.7	35.3	9.92	33.3	9.31	31.3	8.71	30.2	8.41	29.2	8.12	27.2	7.55
	0.0	-0.7	35.3	9.19	33.3	8.64	31.3	8.09	30.2	7.82	29.2	7.56	27.2	7.04
	3.0	2.2	35.3	8.57	33.3	8.06	31.3	7.56	30.2	7.31	29.2	7.07	27.2	6.59
	5.0	4.1	35.3	8.19	33.3	7.71	31.3	7.24	30.2	7.00	29.2	6.77	27.2	6.32
	7.0	6.0	35.3	7.84	33.3	7.38	31.3	6.93	30.2	6.71	29.2	6.50	27.2	6.07
	9.0	7.9	35.3	7.51	33.3	7.08	31.3	6.65	30.2	6.44	29.2	6.24	27.2	5.83
	11.0	9.8	35.3	7.20	33.3	6.79	31.3	6.39	30.2	6.19	29.2	5.99	27.2	5.61
	13.0	11.8	35.3	6.89	33.3	6.51	31.3	6.13	30.2	5.94	29.2	5.76	27.2	5.39
	15.0	13.7	35.3	6.63	33.3	6.26	31.3	5.90	30.2	5.72	29.2	5.54	27.2	5.19

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ▒ shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (715)	-19.8	-20.0	44.1	11.50	43.9	12.34	43.8	13.2	43.7	13.6	43.6	14.0	43.4	14.9
	-18.8	-19.0	44.8	11.78	44.7	12.6	44.5	13.4	44.5	13.8	44.4	14.3	44.2	15.1
	-16.7	-17.0	46.6	12.3	46.4	13.1	46.2	13.9	46.2	14.3	46.1	14.7	45.9	15.5
	-14.7	-15.0	48.5	12.9	48.3	13.7	48.1	14.5	48.1	14.8	48.0	15.2	47.8	16.0
	-12.6	-13.0	50.6	13.5	50.4	14.3	50.3	15.0	50.2	15.4	50.1	15.7	49.9	16.4
	-10.5	-11.0	52.9	14.1	52.7	14.8	52.6	15.5	52.5	15.9	52.4	16.2	52.3	16.9
	-9.5	-10.0	54.1	14.4	54.0	15.1	53.8	15.8	53.7	16.1	53.7	16.5	53.5	17.1
	-8.5	-9.1	55.3	14.7	55.1	15.3	55.0	16.0	54.9	16.3	54.8	16.7	54.6	17.3
	-7.0	-7.6	57.3	15.1	57.1	15.8	57.0	16.4	56.9	16.7	56.8	17.0	56.7	17.7
	-5.0	-5.6	60.2	15.7	60.0	16.3	59.8	16.9	59.8	17.2	59.7	17.5	59.5	18.1
	-3.0	-3.7	63.1	16.2	62.9	16.8	62.7	17.4	62.7	17.6	62.6	17.9	62.4	18.5
	0.0	-0.7	68.0	17.0	67.9	17.5	67.7	18.0	67.6	18.3	67.5	18.6	67.4	19.1
	3.0	2.2	73.2	17.7	73.1	18.2	72.9	18.7	72.9	18.9	72.8	19.2	72.6	19.7
	5.0	4.1	76.9	18.1	76.7	18.6	76.6	19.1	76.5	19.3	76.4	19.5	76.3	20.0
	7.0	6.0	80.7	18.5	80.6	19.0	80.4	19.4	80.4	19.6	80.3	19.9	78.2	19.5
	9.0	7.9	84.8	18.9	84.6	19.3	84.5	19.8	84.4	20.0	83.9	20.1	78.2	18.4
	11.0	9.8	89.0	19.3	88.8	19.7	88.7	20.1	86.8	19.7	83.9	18.9	78.2	17.3
	13.0	11.8	93.6	19.7	93.4	20.0	89.7	19.2	86.8	18.5	83.9	17.7	78.2	16.3
	15.0	13.7	98.2	20.0	95.5	19.5	89.7	18.1	86.8	17.4	83.9	16.7	78.2	15.4
120 (660)	-19.8	-20.0	43.9	12.6	43.7	13.4	43.6	14.2	43.5	14.6	43.4	15.0	43.3	15.8
	-18.8	-19.0	44.6	12.9	44.5	13.7	44.3	14.4	44.3	14.8	44.2	15.2	44.1	16.0
	-16.7	-17.0	46.3	13.4	46.2	14.2	46.0	14.9	46.0	15.3	45.9	15.6	45.8	16.4
	-14.7	-15.0	48.3	14.0	48.1	14.7	48.0	15.4	47.9	15.7	47.8	16.1	47.7	16.8
	-12.6	-13.0	50.4	14.5	50.2	15.2	50.1	15.9	50.0	16.2	49.9	16.5	49.8	17.2
	-10.5	-11.0	52.7	15.1	52.5	15.7	52.4	16.3	52.3	16.7	52.2	17.0	52.1	17.6
	-9.5	-10.0	53.9	15.3	53.8	16.0	53.6	16.6	53.5	16.9	53.5	17.2	53.3	17.8
	-8.5	-9.1	55.1	15.6	54.9	16.2	54.8	16.8	54.7	17.1	54.6	17.4	54.5	18.0
	-7.0	-7.6	57.1	16.0	56.9	16.6	56.8	17.2	56.7	17.5	56.6	17.8	56.5	18.3
	-5.0	-5.6	59.9	16.5	59.8	17.1	59.6	17.6	59.6	17.9	59.5	18.2	59.4	18.7
	-3.0	-3.7	62.8	17.0	62.7	17.5	62.6	18.1	62.5	18.3	62.4	18.6	62.3	19.1
	0.0	-0.7	67.8	17.7	67.7	18.2	67.5	18.7	67.4	18.9	67.4	19.2	67.2	19.7
	3.0	2.2	73.0	18.4	72.9	18.8	72.7	19.3	72.7	19.5	72.6	19.7	72.2	20.1
	5.0	4.1	76.7	18.8	76.5	19.2	76.4	19.6	76.3	19.8	76.3	20.1	72.2	18.8
	7.0	6.0	80.5	19.1	80.4	19.5	80.2	20.0	80.1	20.2	77.5	19.3	72.2	17.7
	9.0	7.9	84.6	19.5	84.4	19.9	82.8	19.7	80.1	18.9	77.5	18.2	72.2	16.7
	11.0	9.8	88.8	19.8	88.1	20.0	82.8	18.6	80.1	17.8	77.5	17.1	72.2	15.7
	13.0	11.8	93.4	20.2	88.1	18.8	82.8	17.4	80.1	16.8	77.5	16.1	72.2	14.8
	15.0	13.7	93.4	19.0	88.1	17.7	82.8	16.4	80.1	15.8	77.5	15.2	72.2	14.0
110 (605)	-19.8	-20.0	43.6	13.8	43.5	14.5	43.4	15.2	43.3	15.6	43.2	15.9	43.1	16.6
	-18.8	-19.0	44.4	14.0	44.3	14.7	44.2	15.4	44.1	15.8	44.0	16.1	43.9	16.8
	-16.7	-17.0	46.1	14.5	46.0	15.2	45.9	15.8	45.8	16.2	45.7	16.5	45.6	17.2
	-14.7	-15.0	48.0	15.0	47.9	15.6	47.8	16.3	47.7	16.6	47.6	16.9	47.5	17.6
	-12.6	-13.0	50.1	15.5	50.0	16.1	49.9	16.7	49.8	17.0	49.7	17.4	49.6	18.0
	-10.5	-11.0	52.5	16.0	52.3	16.6	52.2	17.2	52.1	17.5	52.1	17.8	51.9	18.4
	-9.5	-10.0	53.7	16.3	53.6	16.8	53.4	17.4	53.4	17.7	53.3	18.0	53.2	18.6
	-8.5	-9.1	54.9	16.5	54.7	17.0	54.6	17.6	54.5	17.9	54.5	18.2	54.3	18.7
	-7.0	-7.6	56.9	16.8	56.7	17.4	56.6	17.9	56.5	18.2	56.5	18.5	56.3	19.0
	-5.0	-5.6	59.7	17.3	59.6	17.8	59.5	18.4	59.4	18.6	59.3	18.9	59.2	19.4
	-3.0	-3.7	62.6	17.8	62.5	18.3	62.4	18.7	62.3	19.0	62.2	19.2	62.1	19.7
	0.0	-0.7	67.6	18.4	67.5	18.9	67.3	19.3	67.3	19.6	67.2	19.8	66.1	19.8
	3.0	2.2	72.8	19.0	72.7	19.4	72.6	19.9	72.5	20.1	71.0	19.7	66.1	18.0
	5.0	4.1	76.5	19.4	76.3	19.8	75.9	20.1	73.5	19.3	71.0	18.5	66.1	17.0
	7.0	6.0	80.3	19.7	80.2	20.1	75.9	18.9	73.5	18.1	71.0	17.4	66.1	16.0
	9.0	7.9	84.3	20.1	80.8	19.1	75.9	17.7	73.5	17.1	71.0	16.4	66.1	15.1
	11.0	9.8	85.7	19.3	80.8	18.0	75.9	16.7	73.5	16.1	71.0	15.4	66.1	14.2
	13.0	11.8	85.7	18.2	80.8	16.9	75.9	15.7	73.5	15.1	71.0	14.5	66.1	13.4
	15.0	13.7	85.7	17.1	80.8	16.0	75.9	14.8	73.5	14.3	71.0	13.7	66.1	12.7

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (550)	-19.8	-20.0	43.4	14.9	43.3	15.6	43.2	16.2	43.1	16.5	43.1	16.9	42.9	17.5
	-18.8	-19.0	44.2	15.1	44.1	15.8	44.0	16.4	43.9	16.7	43.8	17.0	43.7	17.7
	-16.7	-17.0	45.9	15.6	45.8	16.2	45.7	16.8	45.6	17.1	45.5	17.4	45.4	18.0
	-14.7	-15.0	47.8	16.0	47.7	16.6	47.6	17.2	47.5	17.5	47.5	17.8	47.3	18.4
	-12.6	-13.0	49.9	16.5	49.8	17.0	49.7	17.6	49.6	17.9	49.6	18.2	49.5	18.7
	-10.5	-11.0	52.3	16.9	52.1	17.5	52.0	18.0	51.9	18.3	51.9	18.5	51.8	19.1
	-9.5	-10.0	53.5	17.2	53.4	17.7	53.2	18.2	53.2	18.5	53.1	18.7	53.0	19.3
	-8.5	-9.1	54.6	17.4	54.5	17.9	54.4	18.4	54.3	18.7	54.3	18.9	54.2	19.4
	-7.0	-7.6	56.7	17.7	56.5	18.2	56.4	18.7	56.3	18.9	56.3	19.2	56.2	19.7
	-5.0	-5.6	59.5	18.1	59.4	18.6	59.3	19.1	59.2	19.3	59.1	19.5	59.0	20.0
	-3.0	-3.7	62.4	18.5	62.3	19.0	62.2	19.4	62.1	19.7	62.1	19.9	60.1	19.4
	0.0	-0.7	67.4	19.1	67.3	19.6	67.1	20.0	66.8	20.0	64.6	19.2	60.1	17.6
	3.0	2.2	72.6	19.7	72.5	20.1	69.0	19.0	66.8	18.2	64.6	17.5	60.1	16.1
	5.0	4.1	76.3	20.0	73.4	19.3	69.0	17.8	66.8	17.2	64.6	16.5	60.1	15.2
	7.0	6.0	77.9	19.5	73.4	18.1	69.0	16.8	66.8	16.2	64.6	15.5	60.1	14.3
	9.0	7.9	77.9	18.3	73.4	17.0	69.0	15.8	66.8	15.2	64.6	14.6	60.1	13.5
	11.0	9.8	77.9	17.2	73.4	16.1	69.0	14.9	66.8	14.4	64.6	13.8	60.1	12.8
	13.0	11.8	77.9	16.2	73.4	15.1	69.0	14.1	66.8	13.5	64.6	13.0	60.1	12.0
	15.0	13.7	77.9	15.3	73.4	14.3	69.0	13.3	66.8	12.8	64.6	12.3	60.1	11.4
90 (495)	-19.8	-20.0	43.2	16.1	43.1	16.6	43.0	17.2	42.9	17.5	42.9	17.8	42.8	18.4
	-18.8	-19.0	44.0	16.3	43.9	16.8	43.8	17.4	43.7	17.7	43.7	18.0	43.6	18.5
	-16.7	-17.0	45.7	16.6	45.6	17.2	45.5	17.7	45.4	18.0	45.4	18.3	45.3	18.9
	-14.7	-15.0	47.6	17.1	47.5	17.6	47.4	18.1	47.3	18.4	47.3	18.6	47.2	19.2
	-12.6	-13.0	49.7	17.5	49.6	18.0	49.5	18.5	49.4	18.7	49.4	19.0	49.3	19.5
	-10.5	-11.0	52.0	17.9	51.9	18.4	51.8	18.8	51.8	19.1	51.7	19.3	51.6	19.8
	-9.5	-10.0	53.3	18.1	53.2	18.6	53.1	19.0	53.0	19.3	52.9	19.5	52.8	20.0
	-8.5	-9.1	54.4	18.3	54.3	18.7	54.2	19.2	54.2	19.4	54.1	19.7	54.0	20.1
	-7.0	-7.6	56.4	18.6	56.3	19.0	56.2	19.5	56.2	19.7	56.1	19.9	54.1	19.3
	-5.0	-5.6	59.3	19.0	59.2	19.4	59.1	19.8	59.0	20.0	58.1	19.8	54.1	18.1
	-3.0	-3.7	62.2	19.3	62.1	19.7	62.0	20.1	60.1	19.4	58.1	18.6	54.1	17.1
	0.0	-0.7	67.2	19.9	66.1	19.8	62.1	18.3	60.1	17.6	58.1	16.9	54.1	15.5
	3.0	2.2	70.1	19.3	66.1	18.0	62.1	16.7	60.1	16.1	58.1	15.4	54.1	14.2
	5.0	4.1	70.1	18.2	66.1	16.9	62.1	15.7	60.1	15.1	58.1	14.6	54.1	13.4
	7.0	6.0	70.1	17.1	66.1	16.0	62.1	14.8	60.1	14.3	58.1	13.7	54.1	12.7
	9.0	7.9	70.1	16.1	66.1	15.0	62.1	14.0	60.1	13.5	58.1	13.0	54.1	12.0
	11.0	9.8	70.1	15.2	66.1	14.2	62.1	13.2	60.1	12.7	58.1	12.3	54.1	11.3
	13.0	11.8	70.1	14.3	66.1	13.4	62.1	12.5	60.1	12.0	58.1	11.6	54.1	10.7
	15.0	13.7	70.1	13.5	66.1	12.7	62.1	11.8	60.1	11.4	58.1	11.0	54.1	10.2
80 (440)	-19.8	-20.0	43.0	17.2	42.9	17.7	42.8	18.2	42.8	18.5	42.7	18.8	42.6	19.3
	-18.8	-19.0	43.8	17.4	43.7	17.9	43.6	18.4	43.5	18.6	43.5	18.9	43.4	19.4
	-16.7	-17.0	45.5	17.7	45.4	18.2	45.3	18.7	45.2	18.9	45.2	19.2	45.1	19.7
	-14.7	-15.0	47.4	18.1	47.3	18.6	47.2	19.0	47.2	19.3	47.1	19.5	47.0	20.0
	-12.6	-13.0	49.5	18.5	49.4	18.9	49.3	19.4	49.3	19.6	49.2	19.8	48.1	19.6
	-10.5	-11.0	51.8	18.8	51.7	19.3	51.6	19.7	51.6	19.9	51.5	20.1	48.1	18.5
	-9.5	-10.0	53.1	19.0	53.0	19.4	52.9	19.8	52.8	20.1	51.7	19.6	48.1	18.0
	-8.5	-9.1	54.2	19.2	54.1	19.6	54.0	20.0	53.4	19.9	51.7	19.1	48.1	17.5
	-7.0	-7.6	56.2	19.4	56.1	19.8	55.2	19.8	53.4	19.0	51.7	18.2	48.1	16.7
	-5.0	-5.6	59.1	19.8	58.7	20.0	55.2	18.6	53.4	17.8	51.7	17.1	48.1	15.7
	-3.0	-3.7	62.0	20.1	58.7	18.9	55.2	17.5	53.4	16.8	51.7	16.1	48.1	14.9
	0.0	-0.7	62.3	18.4	58.7	17.1	55.2	15.9	53.4	15.3	51.7	14.7	48.1	13.6
	3.0	2.2	62.3	16.8	58.7	15.6	55.2	14.5	53.4	14.0	51.7	13.5	48.1	12.4
	5.0	4.1	62.3	15.8	58.7	14.7	55.2	13.7	53.4	13.2	51.7	12.7	48.1	11.8
	7.0	6.0	62.3	14.9	58.7	13.9	55.2	13.0	53.4	12.5	51.7	12.0	48.1	11.1
	9.0	7.9	62.3	14.1	58.7	13.1	55.2	12.3	53.4	11.8	51.7	11.4	48.1	10.5
	11.0	9.8	62.3	13.3	58.7	12.4	55.2	11.6	53.4	11.2	51.7	10.8	48.1	10.0
	13.0	11.8	62.3	12.5	58.7	11.7	55.2	11.0	53.4	10.6	51.7	10.2	48.1	9.5
	15.0	13.7	62.3	11.9	58.7	11.1	55.2	10.4	53.4	10.0	51.7	9.7	48.1	8.99

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (385)	-19.8	-20.0	42.8	18.3	42.7	18.8	42.6	19.2	42.6	19.5	42.5	19.7	42.1	19.9				
	-18.8	-19.0	43.6	18.5	43.5	18.9	43.4	19.4	43.4	19.6	43.3	19.8	42.1	19.4				
	-16.7	-17.0	45.3	18.8	45.2	19.2	45.1	19.7	45.1	19.9	45.0	20.1	42.1	18.5				
	-14.7	-15.0	47.2	19.1	47.1	19.5	47.0	19.9	46.7	20.0	45.2	19.2	42.1	17.6				
	-12.6	-13.0	49.3	19.4	49.2	19.8	48.3	19.7	46.7	18.9	45.2	18.2	42.1	16.7				
	-10.5	-11.0	51.6	19.8	51.4	20.1	48.3	18.6	46.7	17.9	45.2	17.1	42.1	15.8				
	-9.5	-10.0	52.8	19.9	51.4	19.5	48.3	18.0	46.7	17.3	45.2	16.7	42.1	15.3				
	-8.5	-9.1	54.0	20.1	51.4	18.9	48.3	17.6	46.7	16.9	45.2	16.2	42.1	14.9				
	-7.0	-7.6	54.5	19.4	51.4	18.1	48.3	16.8	46.7	16.2	45.2	15.5	42.1	14.3				
	-5.0	-5.6	54.5	18.3	51.4	17.0	48.3	15.8	46.7	15.2	45.2	14.6	42.1	13.5				
	-3.0	-3.7	54.5	17.2	51.4	16.1	48.3	14.9	46.7	14.4	45.2	13.8	42.1	12.7				
	0.0	-0.7	54.5	15.7	51.4	14.6	48.3	13.6	46.7	13.1	45.2	12.6	42.1	11.7				
	3.0	2.2	54.5	14.3	51.4	13.4	48.3	12.5	46.7	12.0	45.2	11.6	42.1	10.7				
	5.0	4.1	54.5	13.5	51.4	12.7	48.3	11.8	46.7	11.4	45.2	11.0	42.1	10.2				
	7.0	6.0	54.5	12.8	51.4	12.0	48.3	11.2	46.7	10.8	45.2	10.4	42.1	9.65				
	9.0	7.9	54.5	12.1	51.4	11.3	48.3	10.6	46.7	10.2	45.2	9.9	42.1	9.15				
	11.0	9.8	54.5	11.4	51.4	10.7	48.3	10.0	46.7	9.7	45.2	9.36	42.1	8.70				
	13.0	11.8	54.5	10.8	51.4	10.1	48.3	9.5	46.7	9.18	45.2	8.87	42.1	8.25				
	15.0	13.7	54.5	10.3	51.4	9.6	48.3	9.03	46.7	8.73	45.2	8.44	42.1	7.86				
60 (330)	-19.8	-20.0	42.6	19.5	42.5	19.9	41.4	19.5	40.1	18.7	38.7	18.0	36.1	16.5				
	-18.8	-19.0	43.4	19.6	43.3	20.0	41.4	19.0	40.1	18.3	38.7	17.6	36.1	16.1				
	-16.7	-17.0	45.1	19.9	44.1	19.6	41.4	18.1	40.1	17.4	38.7	16.8	36.1	15.4				
	-14.7	-15.0	46.7	20.0	44.1	18.6	41.4	17.2	40.1	16.6	38.7	15.9	36.1	14.7				
	-12.6	-13.0	46.7	18.9	44.1	17.6	41.4	16.3	40.1	15.7	38.7	15.1	36.1	13.9				
	-10.5	-11.0	46.7	17.8	44.1	16.6	41.4	15.5	40.1	14.9	38.7	14.3	36.1	13.2				
	-9.5	-10.0	46.7	17.3	44.1	16.2	41.4	15.0	40.1	14.5	38.7	13.9	36.1	12.8				
	-8.5	-9.1	46.7	16.9	44.1	15.7	41.4	14.6	40.1	14.1	38.7	13.6	36.1	12.5				
	-7.0	-7.6	46.7	16.1	44.1	15.1	41.4	14.0	40.1	13.5	38.7	13.0	36.1	12.0				
	-5.0	-5.6	46.7	15.2	44.1	14.2	41.4	13.2	40.1	12.7	38.7	12.3	36.1	11.3				
	-3.0	-3.7	46.7	14.4	44.1	13.4	41.4	12.5	40.1	12.1	38.7	11.6	36.1	10.8				
	0.0	-0.7	46.7	13.1	44.1	12.3	41.4	11.5	40.1	11.1	38.7	10.7	36.1	9.89				
	3.0	2.2	46.7	12.0	44.1	11.3	41.4	10.5	40.1	10.18	38.7	9.83	36.1	9.12				
	5.0	4.1	46.7	11.4	44.1	10.7	41.4	10.00	40.1	9.66	38.7	9.32	36.1	8.66				
	7.0	6.0	46.7	10.8	44.1	10.1	41.4	9.48	40.1	9.16	38.7	8.85	36.1	8.23				
	9.0	7.9	46.7	10.2	44.1	9.60	41.4	9.00	40.1	8.70	38.7	8.41	36.1	7.83				
	11.0	9.8	46.7	9.7	44.1	9.12	41.4	8.55	40.1	8.27	38.7	8.00	36.1	7.46				
	13.0	11.8	46.7	9.18	44.1	8.64	41.4	8.11	40.1	7.85	38.7	7.60	36.1	7.09				
	15.0	13.7	46.7	8.73	44.1	8.22	41.4	7.73	40.1	7.48	38.7	7.24	36.1	6.77				
50 (275)	-19.8	-20.0	38.9	18.1	36.7	16.8	34.5	15.6	33.4	15.1	32.3	14.5	30.1	13.3				
	-18.8	-19.0	38.9	17.7	36.7	16.5	34.5	15.3	33.4	14.7	32.3	14.2	30.1	13.1				
	-16.7	-17.0	38.9	16.9	36.7	15.7	34.5	14.6	33.4	14.1	32.3	13.5	30.1	12.5				
	-14.7	-15.0	38.9	16.0	36.7	15.0	34.5	13.9	33.4	13.4	32.3	12.9	30.1	11.9				
	-12.6	-13.0	38.9	15.2	36.7	14.2	34.5	13.2	33.4	12.7	32.3	12.3	30.1	11.3				
	-10.5	-11.0	38.9	14.4	36.7	13.4	34.5	12.5	33.4	12.1	32.3	11.6	30.1	10.77				
	-9.5	-10.0	38.9	14.0	36.7	13.1	34.5	12.2	33.4	11.8	32.3	11.3	30.1	10.49				
	-8.5	-9.1	38.9	13.6	36.7	12.8	34.5	11.9	33.4	11.5	32.3	11.1	30.1	10.25				
	-7.0	-7.6	38.9	13.1	36.7	12.2	34.5	11.4	33.4	11.0	32.3	10.63	30.1	9.85				
	-5.0	-5.6	38.9	12.3	36.7	11.6	34.5	10.8	33.4	10.43	32.3	10.06	30.1	9.34				
	-3.0	-3.7	38.9	11.7	36.7	11.0	34.5	10.25	33.4	9.90	32.3	9.55	30.1	8.87				
	0.0	-0.7	38.9	10.7	36.7	10.07	34.5	9.43	33.4	9.12	32.3	8.80	30.1	8.19				
	3.0	2.2	38.9	9.88	36.7	9.29	34.5	8.71	33.4	8.43	32.3	8.14	30.1	7.59				
	5.0	4.1	38.9	9.37	36.7	8.82	34.5	8.28	33.4	8.01	32.3	7.75	30.1	7.23				
	7.0	6.0	38.9	8.89	36.7	8.38	34.5	7.87	33.4	7.62	32.3	7.37	30.1	6.89				
	9.0	7.9	38.9	8.45	36.7	7.97	34.5	7.49	33.4	7.26	32.3	7.03	30.1	6.57				
	11.0	9.8	38.9	8.04	36.7	7.58	34.5	7.14	33.4	6.92	32.3	6.70	30.1	6.27				
	13.0	11.8	38.9	7.63	36.7	7.21	34.5	6.79	33.4	6.59	32.3	6.38	30.1	5.98				
	15.0	13.7	38.9	7.28	36.7	6.88	34.5	6.49	33.4	6.29	32.3	6.10	30.1	5.72				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ▒ shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (786)	-19.8	-20.0	46.9	11.73	46.7	12.6	46.5	13.6	46.5	14.0	46.4	14.5	46.2	15.4
	-18.8	-19.0	47.9	12.1	47.7	13.0	47.6	13.9	47.5	14.3	47.4	14.8	47.2	15.7
	-16.7	-17.0	50.1	12.8	49.9	13.7	49.7	14.5	49.6	15.0	49.6	15.4	49.4	16.3
	-14.7	-15.0	52.4	13.5	52.2	14.3	52.0	15.2	51.9	15.6	51.9	16.0	51.7	16.8
	-12.6	-13.0	54.8	14.2	54.6	15.0	54.5	15.8	54.4	16.2	54.3	16.6	54.1	17.3
	-10.5	-11.0	57.4	14.9	57.2	15.6	57.0	16.3	56.9	16.7	56.9	17.1	56.7	17.8
	-9.5	-10.0	58.7	15.2	58.5	15.9	58.4	16.6	58.3	17.0	58.2	17.4	58.0	18.1
	-8.5	-9.1	59.9	15.5	59.8	16.2	59.6	16.9	59.5	17.2	59.4	17.6	59.2	18.3
	-7.0	-7.6	62.0	15.9	61.9	16.6	61.7	17.3	61.6	17.6	61.5	18.0	61.4	18.6
	-5.0	-5.6	65.0	16.5	64.8	17.1	64.6	17.8	64.6	18.1	64.5	18.4	64.3	19.1
	-3.0	-3.7	67.9	17.0	67.7	17.6	67.6	18.2	67.5	18.6	67.4	18.9	67.2	19.5
	0.0	-0.7	72.8	17.8	72.6	18.3	72.4	18.9	72.3	19.2	72.2	19.5	72.1	20.1
	3.0	2.2	77.7	18.5	77.6	19.0	77.4	19.5	77.3	19.8	77.2	20.1	77.1	20.6
	5.0	4.1	81.2	18.9	81.0	19.4	80.8	19.9	80.7	20.2	80.7	20.4	80.5	20.9
	7.0	6.0	84.7	19.3	84.5	19.8	84.4	20.3	84.3	20.5	84.2	20.8	84.0	21.3
	9.0	7.9	88.4	19.7	88.2	20.1	88.0	20.6	88.0	20.8	87.9	21.1	85.0	20.5
	11.0	9.8	92.2	20.0	92.0	20.5	91.8	20.9	91.7	21.2	91.2	21.2	85.0	19.5
	13.0	11.8	96.3	20.4	96.1	20.8	96.0	21.2	94.4	20.9	91.2	20.1	85.0	18.4
	15.0	13.7	100.3	20.7	100.2	21.1	97.5	20.7	94.4	19.9	91.2	19.1	85.0	17.5
120 (726)	-19.8	-20.0	46.7	13.0	46.5	13.8	46.3	14.7	46.3	15.1	46.2	15.5	46.0	16.4
	-18.8	-19.0	47.7	13.3	47.5	14.1	47.4	15.0	47.3	15.4	47.2	15.8	47.1	16.6
	-16.7	-17.0	49.8	14.0	49.7	14.8	49.5	15.6	49.4	16.0	49.4	16.4	49.2	17.2
	-14.7	-15.0	52.1	14.6	52.0	15.4	51.8	16.1	51.7	16.5	51.7	16.9	51.5	17.7
	-12.6	-13.0	54.6	15.3	54.4	16.0	54.3	16.7	54.2	17.1	54.1	17.4	53.9	18.1
	-10.5	-11.0	57.1	15.9	57.0	16.6	56.8	17.2	56.7	17.6	56.7	17.9	56.5	18.6
	-9.5	-10.0	58.5	16.2	58.3	16.8	58.2	17.5	58.1	17.8	58.0	18.2	57.8	18.8
	-8.5	-9.1	59.7	16.4	59.5	17.1	59.4	17.7	59.3	18.1	59.2	18.4	59.1	19.0
	-7.0	-7.6	61.8	16.8	61.7	17.5	61.5	18.1	61.4	18.4	61.3	18.7	61.2	19.4
	-5.0	-5.6	64.8	17.4	64.6	18.0	64.4	18.6	64.4	18.9	64.3	19.2	64.1	19.8
	-3.0	-3.7	67.7	17.8	67.5	18.4	67.4	19.0	67.3	19.3	67.2	19.6	67.0	20.1
	0.0	-0.7	72.5	18.6	72.4	19.1	72.2	19.6	72.1	19.9	72.1	20.2	71.9	20.7
	3.0	2.2	77.5	19.2	77.4	19.7	77.2	20.2	77.1	20.4	77.0	20.7	76.9	21.2
	5.0	4.1	80.9	19.6	80.8	20.1	80.6	20.5	80.5	20.8	80.5	21.0	78.4	20.7
	7.0	6.0	84.5	19.9	84.3	20.4	84.2	20.9	84.1	21.1	84.0	21.3	78.4	19.6
	9.0	7.9	88.2	20.3	88.0	20.7	87.8	21.2	87.1	21.1	84.2	20.3	78.4	18.6
	11.0	9.8	91.9	20.6	91.8	21.0	90.0	20.9	87.1	20.1	84.2	19.3	78.4	17.7
	13.0	11.8	96.1	21.0	95.8	21.3	90.0	19.8	87.1	19.0	84.2	18.2	78.4	16.8
	15.0	13.7	100.1	21.3	95.8	20.2	90.0	18.8	87.1	18.1	84.2	17.4	78.4	16.0
110 (666)	-19.8	-20.0	46.4	14.2	46.3	15.0	46.1	15.8	46.1	16.2	46.0	16.6	45.8	17.3
	-18.8	-19.0	47.5	14.5	47.3	15.3	47.2	16.1	47.1	16.4	47.0	16.8	46.9	17.6
	-16.7	-17.0	49.6	15.1	49.5	15.9	49.3	16.6	49.2	17.0	49.2	17.3	49.0	18.1
	-14.7	-15.0	51.9	15.7	51.8	16.4	51.6	17.1	51.5	17.5	51.5	17.8	51.3	18.5
	-12.6	-13.0	54.3	16.3	54.2	17.0	54.0	17.6	54.0	18.0	53.9	18.3	53.8	19.0
	-10.5	-11.0	56.9	16.9	56.8	17.5	56.6	18.1	56.5	18.4	56.5	18.8	56.3	19.4
	-9.5	-10.0	58.2	17.1	58.1	17.8	58.0	18.4	57.9	18.7	57.8	19.0	57.7	19.6
	-8.5	-9.1	59.5	17.4	59.3	18.0	59.2	18.6	59.1	18.9	59.0	19.2	58.9	19.8
	-7.0	-7.6	61.6	17.8	61.4	18.3	61.3	18.9	61.2	19.2	61.1	19.5	61.0	20.1
	-5.0	-5.6	64.5	18.2	64.4	18.8	64.2	19.3	64.2	19.6	64.1	19.9	63.9	20.5
	-3.0	-3.7	67.4	18.7	67.3	19.2	67.1	19.7	67.1	20.0	67.0	20.3	66.9	20.8
	0.0	-0.7	72.3	19.3	72.1	19.8	72.0	20.3	71.9	20.6	71.9	20.8	71.7	21.3
	3.0	2.2	77.3	19.9	77.1	20.4	77.0	20.8	76.9	21.1	76.8	21.3	71.9	19.7
	5.0	4.1	80.7	20.3	80.6	20.7	80.4	21.2	79.8	21.2	77.2	20.3	71.9	18.6
	7.0	6.0	84.2	20.6	84.1	21.0	82.5	20.9	79.8	20.1	77.2	19.3	71.9	17.7
	9.0	7.9	87.9	20.9	87.8	21.3	82.5	19.8	79.8	19.0	77.2	18.3	71.9	16.8
	11.0	9.8	91.7	21.2	87.8	20.3	82.5	18.8	79.8	18.1	77.2	17.4	71.9	16.0
	13.0	11.8	93.1	20.6	87.8	19.2	82.5	17.8	79.8	17.1	77.2	16.5	71.9	15.2
	15.0	13.7	93.1	19.6	87.8	18.2	82.5	16.9	79.8	16.3	77.2	15.7	71.9	14.5

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (605)	-19.8	-20.0	46.2	15.5	46.1	16.2	45.9	16.9	45.9	17.2	45.8	17.6	45.7	18.3
	-18.8	-19.0	47.2	15.7	47.1	16.4	47.0	17.1	46.9	17.5	46.8	17.8	46.7	18.5
	-16.7	-17.0	49.4	16.3	49.2	17.0	49.1	17.6	49.1	18.0	49.0	18.3	48.9	18.9
	-14.7	-15.0	51.7	16.9	51.5	17.5	51.4	18.1	51.3	18.4	51.3	18.7	51.1	19.4
	-12.6	-13.0	54.1	17.4	54.0	18.0	53.8	18.6	53.8	18.9	53.7	19.2	53.6	19.8
	-10.5	-11.0	56.7	17.9	56.5	18.4	56.4	19.0	56.3	19.3	56.3	19.6	56.1	20.2
	-9.5	-10.0	58.0	18.1	57.9	18.7	57.7	19.2	57.7	19.5	57.6	19.8	57.5	20.4
	-8.5	-9.1	59.2	18.3	59.1	18.9	59.0	19.4	58.9	19.7	58.8	20.0	58.7	20.5
	-7.0	-7.6	61.4	18.7	61.2	19.2	61.1	19.7	61.0	20.0	61.0	20.3	60.8	20.8
	-5.0	-5.6	64.3	19.1	64.2	19.6	64.0	20.1	64.0	20.4	63.9	20.6	63.8	21.1
	-3.0	-3.7	67.2	19.5	67.1	20.0	66.9	20.5	66.9	20.7	66.8	21.0	65.4	20.8
	0.0	-0.7	72.1	20.1	71.9	20.6	71.8	21.0	71.7	21.2	70.2	20.8	65.4	19.0
	3.0	2.2	77.0	20.7	76.9	21.1	75.0	20.7	72.6	19.9	70.2	19.1	65.4	17.6
	5.0	4.1	80.5	21.0	79.8	21.2	75.0	19.6	72.6	18.9	70.2	18.1	65.4	16.7
	7.0	6.0	84.0	21.3	79.8	20.0	75.0	18.6	72.6	17.9	70.2	17.2	65.4	15.8
	9.0	7.9	84.6	20.4	79.8	19.0	75.0	17.7	72.6	17.0	70.2	16.3	65.4	15.0
	11.0	9.8	84.6	19.4	79.8	18.1	75.0	16.8	72.6	16.2	70.2	15.5	65.4	14.3
	13.0	11.8	84.6	18.4	79.8	17.1	75.0	15.9	72.6	15.3	70.2	14.8	65.4	13.6
	15.0	13.7	84.6	17.5	79.8	16.3	75.0	15.2	72.6	14.6	70.2	14.1	65.4	13.0
90 (545)	-19.8	-20.0	46.0	16.7	45.8	17.3	45.7	18.0	45.7	18.3	45.6	18.6	45.5	19.3
	-18.8	-19.0	47.0	17.0	46.9	17.6	46.8	18.2	46.7	18.5	46.6	18.8	46.5	19.5
	-16.7	-17.0	49.1	17.5	49.0	18.1	48.9	18.7	48.9	19.0	48.8	19.3	48.7	19.8
	-14.7	-15.0	51.4	18.0	51.3	18.5	51.2	19.1	51.1	19.4	51.1	19.7	51.0	20.2
	-12.6	-13.0	53.9	18.4	53.8	19.0	53.6	19.5	53.6	19.8	53.5	20.1	53.4	20.6
	-10.5	-11.0	56.4	18.9	56.3	19.4	56.2	19.9	56.1	20.2	56.1	20.4	56.0	20.9
	-9.5	-10.0	57.8	19.1	57.7	19.6	57.5	20.1	57.5	20.4	57.4	20.6	57.3	21.1
	-8.5	-9.1	59.0	19.3	58.9	19.8	58.8	20.3	58.7	20.5	58.7	20.8	58.5	21.3
	-7.0	-7.6	61.1	19.6	61.0	20.1	60.9	20.6	60.8	20.8	60.8	21.0	58.8	20.5
	-5.0	-5.6	64.1	20.0	63.9	20.5	63.8	20.9	63.8	21.1	63.2	21.1	58.8	19.3
	-3.0	-3.7	67.0	20.4	66.9	20.8	66.7	21.2	65.3	20.8	63.2	19.9	58.8	18.3
	0.0	-0.7	71.8	20.9	71.7	21.3	67.5	19.8	65.3	19.0	63.2	18.3	58.8	16.8
	3.0	2.2	76.2	21.1	71.8	19.6	67.5	18.2	65.3	17.5	63.2	16.9	58.8	15.5
	5.0	4.1	76.2	20.0	71.8	18.6	67.5	17.3	65.3	16.6	63.2	16.0	58.8	14.8
	7.0	6.0	76.2	18.9	71.8	17.7	67.5	16.4	65.3	15.8	63.2	15.2	58.8	14.0
	9.0	7.9	76.2	18.0	71.8	16.8	67.5	15.6	65.3	15.0	63.2	14.5	58.8	13.4
	11.0	9.8	76.2	17.1	71.8	16.0	67.5	14.9	65.3	14.3	63.2	13.8	58.8	12.7
	13.0	11.8	76.2	16.2	71.8	15.2	67.5	14.1	65.3	13.6	63.2	13.1	58.8	12.1
	15.0	13.7	76.2	15.4	71.8	14.4	67.5	13.5	65.3	13.0	63.2	12.5	58.8	11.6
80 (484)	-19.8	-20.0	45.7	17.9	45.6	18.5	45.5	19.1	45.5	19.4	45.4	19.6	45.3	20.2
	-18.8	-19.0	46.8	18.2	46.7	18.7	46.5	19.3	46.5	19.6	46.4	19.8	46.3	20.4
	-16.7	-17.0	48.9	18.6	48.8	19.2	48.7	19.7	48.7	19.9	48.6	20.2	48.5	20.7
	-14.7	-15.0	51.2	19.1	51.1	19.6	51.0	20.1	50.9	20.3	50.9	20.6	50.8	21.1
	-12.6	-13.0	53.6	19.5	53.5	20.0	53.4	20.4	53.4	20.7	53.3	20.9	52.3	20.8
	-10.5	-11.0	56.2	19.9	56.1	20.3	56.0	20.8	55.9	21.0	55.9	21.3	52.3	19.6
	-9.5	-10.0	57.5	20.1	57.4	20.5	57.3	21.0	57.3	21.2	56.1	20.8	52.3	19.1
	-8.5	-9.1	58.8	20.3	58.7	20.7	58.6	21.1	58.1	21.1	56.1	20.2	52.3	18.6
	-7.0	-7.6	60.9	20.5	60.8	21.0	60.0	21.0	58.1	20.2	56.1	19.4	52.3	17.8
	-5.0	-5.6	63.8	20.9	63.7	21.3	60.0	19.8	58.1	19.0	56.1	18.3	52.3	16.8
	-3.0	-3.7	66.7	21.2	63.9	20.2	60.0	18.7	58.1	18.0	56.1	17.3	52.3	15.9
	0.0	-0.7	67.7	19.9	63.9	18.5	60.0	17.2	58.1	16.6	56.1	15.9	52.3	14.7
	3.0	2.2	67.7	18.3	63.9	17.1	60.0	15.9	58.1	15.3	56.1	14.7	52.3	13.6
	5.0	4.1	67.7	17.4	63.9	16.2	60.0	15.1	58.1	14.5	56.1	14.0	52.3	12.9
	7.0	6.0	67.7	16.5	63.9	15.4	60.0	14.4	58.1	13.8	56.1	13.3	52.3	12.3
	9.0	7.9	67.7	15.7	63.9	14.7	60.0	13.7	58.1	13.2	56.1	12.7	52.3	11.7
	11.0	9.8	67.7	14.9	63.9	14.0	60.0	13.0	58.1	12.6	56.1	12.1	52.3	11.2
	13.0	11.8	67.7	14.2	63.9	13.3	60.0	12.4	58.1	12.0	56.1	11.5	52.3	10.7
	15.0	13.7	67.7	13.5	63.9	12.7	60.0	11.8	58.1	11.4	56.1	11.0	52.3	10.2

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (424)	-19.8	-20.0	45.5	19.2	45.4	19.7	45.3	20.2	45.3	20.4	45.2	20.7	45.1	21.2				
	-18.8	-19.0	46.5	19.4	46.4	19.9	46.3	20.4	46.3	20.6	46.3	20.8	45.8	21.0				
	-16.7	-17.0	48.7	19.8	48.6	20.3	48.5	20.7	48.5	20.9	48.4	21.2	45.8	19.9				
	-14.7	-15.0	51.0	20.2	50.9	20.6	50.8	21.1	50.7	21.3	49.1	20.5	45.8	18.8				
	-12.6	-13.0	53.4	20.5	53.3	21.0	52.5	20.9	50.8	20.1	49.1	19.3	45.8	17.7				
	-10.5	-11.0	56.0	20.9	55.9	21.3	52.5	19.7	50.8	19.0	49.1	18.2	45.8	16.8				
	-9.5	-10.0	57.3	21.1	55.9	20.7	52.5	19.2	50.8	18.4	49.1	17.7	45.8	16.3				
	-8.5	-9.1	58.5	21.2	55.9	20.1	52.5	18.7	50.8	18.0	49.1	17.3	45.8	15.9				
	-7.0	-7.6	59.2	20.7	55.9	19.3	52.5	17.9	50.8	17.2	49.1	16.5	45.8	15.2				
	-5.0	-5.6	59.2	19.5	55.9	18.2	52.5	16.9	50.8	16.3	49.1	15.6	45.8	14.4				
	-3.0	-3.7	59.2	18.5	55.9	17.2	52.5	16.0	50.8	15.4	49.1	14.8	45.8	13.7				
	0.0	-0.7	59.2	17.0	55.9	15.8	52.5	14.7	50.8	14.2	49.1	13.7	45.8	12.6				
	3.0	2.2	59.2	15.7	55.9	14.6	52.5	13.6	50.8	13.2	49.1	12.7	45.8	11.7				
	5.0	4.1	59.2	14.9	55.9	13.9	52.5	13.0	50.8	12.5	49.1	12.1	45.8	11.2				
	7.0	6.0	59.2	14.1	55.9	13.3	52.5	12.4	50.8	11.9	49.1	11.5	45.8	10.7				
	9.0	7.9	59.2	13.5	55.9	12.6	52.5	11.8	50.8	11.4	49.1	11.0	45.8	10.2				
	11.0	9.8	59.2	12.8	55.9	12.0	52.5	11.3	50.8	10.9	49.1	10.5	45.8	9.8				
	13.0	11.8	59.2	12.2	55.9	11.5	52.5	10.7	50.8	10.4	49.1	10.0	45.8	9.3				
	15.0	13.7	59.2	11.7	55.9	11.0	52.5	10.3	50.8	9.9	49.1	9.6	45.8	8.93				
60 (363)	-19.8	-20.0	45.3	20.4	45.2	20.9	45.0	21.2	43.6	20.4	42.1	19.6	39.2	18.0				
	-18.8	-19.0	46.3	20.6	46.2	21.0	45.0	20.6	43.6	19.8	42.1	19.0	39.2	17.5				
	-16.7	-17.0	48.5	20.9	47.9	21.0	45.0	19.5	43.6	18.7	42.1	18.0	39.2	16.5				
	-14.7	-15.0	50.7	21.3	47.9	19.8	45.0	18.4	43.6	17.7	42.1	17.0	39.2	15.7				
	-12.6	-13.0	50.8	20.1	47.9	18.7	45.0	17.4	43.6	16.7	42.1	16.1	39.2	14.8				
	-10.5	-11.0	50.8	19.0	47.9	17.7	45.0	16.4	43.6	15.8	42.1	15.2	39.2	14.0				
	-9.5	-10.0	50.8	18.4	47.9	17.2	45.0	16.0	43.6	15.4	42.1	14.8	39.2	13.7				
	-8.5	-9.1	50.8	17.9	47.9	16.7	45.0	15.6	43.6	15.0	42.1	14.4	39.2	13.3				
	-7.0	-7.6	50.8	17.2	47.9	16.1	45.0	14.9	43.6	14.4	42.1	13.9	39.2	12.8				
	-5.0	-5.6	50.8	16.2	47.9	15.2	45.0	14.1	43.6	13.6	42.1	13.1	39.2	12.2				
	-3.0	-3.7	50.8	15.4	47.9	14.4	45.0	13.4	43.6	13.0	42.1	12.5	39.2	11.6				
	0.0	-0.7	50.8	14.2	47.9	13.3	45.0	12.4	43.6	12.0	42.1	11.6	39.2	10.7				
	3.0	2.2	50.8	13.2	47.9	12.3	45.0	11.5	43.6	11.1	42.1	10.7	39.2	10.0				
	5.0	4.1	50.8	12.5	47.9	11.8	45.0	11.0	43.6	10.6	42.1	10.3	39.2	9.53				
	7.0	6.0	50.8	11.9	47.9	11.2	45.0	10.5	43.6	10.1	42.1	9.8	39.2	9.11				
	9.0	7.9	50.8	11.4	47.9	10.7	45.0	10.0	43.6	9.7	42.1	9.37	39.2	8.72				
	11.0	9.8	50.8	10.9	47.9	10.2	45.0	9.6	43.6	9.28	42.1	8.97	39.2	8.36				
	13.0	11.8	50.8	10.4	47.9	9.8	45.0	9.17	43.6	8.87	42.1	8.58	39.2	8.00				
	15.0	13.7	50.8	9.9	47.9	9.4	45.0	8.79	43.6	8.51	42.1	8.23	39.2	7.68				
50 (303)	-19.8	-20.0	42.3	19.7	39.9	18.3	37.5	17.03	36.3	16.4	35.1	15.8	32.7	14.5				
	-18.8	-19.0	42.3	19.1	39.9	17.8	37.5	16.6	36.3	16.0	35.1	15.4	32.7	14.2				
	-16.7	-17.0	42.3	18.1	39.9	16.9	37.5	15.7	36.3	15.1	35.1	14.6	32.7	13.4				
	-14.7	-15.0	42.3	17.1	39.9	16.0	37.5	14.9	36.3	14.3	35.1	13.8	32.7	12.8				
	-12.6	-13.0	42.3	16.2	39.9	15.1	37.5	14.1	36.3	13.6	35.1	13.1	32.7	12.1				
	-10.5	-11.0	42.3	15.3	39.9	14.3	37.5	13.4	36.3	12.9	35.1	12.4	32.7	11.5				
	-9.5	-10.0	42.3	14.9	39.9	13.9	37.5	13.0	36.3	12.5	35.1	12.1	32.7	11.2				
	-8.5	-9.1	42.3	14.5	39.9	13.6	37.5	12.7	36.3	12.2	35.1	11.8	32.7	10.9				
	-7.0	-7.6	42.3	13.9	39.9	13.1	37.5	12.2	36.3	11.8	35.1	11.4	32.7	10.5				
	-5.0	-5.6	42.3	13.2	39.9	12.4	37.5	11.6	36.3	11.2	35.1	10.8	32.7	10.0				
	-3.0	-3.7	42.3	12.6	39.9	11.8	37.5	11.0	36.3	10.7	35.1	10.3	32.7	9.56				
	0.0	-0.7	42.3	11.6	39.9	10.9	37.5	10.2	36.3	9.9	35.1	9.55	32.7	8.89				
	3.0	2.2	42.3	10.8	39.9	10.2	37.5	9.53	36.3	9.22	35.1	8.91	32.7	8.30				
	5.0	4.1	42.3	10.3	39.9	9.7	37.5	9.11	36.3	8.82	35.1	8.52	32.7	7.95				
	7.0	6.0	42.3	9.8	39.9	9.28	37.5	8.71	36.3	8.44	35.1	8.16	32.7	7.62				
	9.0	7.9	42.3	9.42	39.9	8.88	37.5	8.35	36.3	8.09	35.1	7.83	32.7	7.31				
	11.0	9.8	42.3	9.02	39.9	8.50	37.5	8.00	36.3	7.76	35.1	7.51	32.7	7.02				
	13.0	11.8	42.3	8.62	39.9	8.14	37.5	7.66	36.3	7.43	35.1	7.20	32.7	6.74				
	15.0	13.7	42.3	8.27	39.9	7.81	37.5	7.36	36.3	7.14	35.1	6.92	32.7	6.49				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

14

RXYQ26PAY1, PAYL, PTL [50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (845)	-19.8	-20.0	47.6	10.71	47.4	11.8	47.3	12.8	47.2	13.3	47.1	13.8	46.9	14.9
	-18.8	-19.0	48.7	11.1	48.5	12.1	48.3	13.2	48.2	13.7	48.1	14.2	47.9	15.2
	-16.7	-17.0	50.8	11.9	50.6	12.9	50.4	13.9	50.3	14.4	50.3	14.9	50.1	15.8
	-14.7	-15.0	53.1	12.7	52.9	13.7	52.7	14.6	52.6	15.0	52.6	15.5	52.4	16.4
	-12.6	-13.0	55.6	13.5	55.4	14.4	55.2	15.3	55.1	15.7	55.0	16.1	54.8	17.0
	-10.5	-11.0	58.1	14.2	58.0	15.1	57.8	15.9	57.7	16.3	57.6	16.8	57.4	17.6
	-9.5	-10.0	59.5	14.6	59.3	15.4	59.1	16.2	59.0	16.6	58.9	17.1	58.7	17.9
	-8.5	-9.1	60.7	14.9	60.6	15.7	60.4	16.5	60.3	16.9	60.2	17.3	60.0	18.1
	-7.0	-7.6	62.9	15.4	62.7	16.2	62.5	17.0	62.4	17.3	62.3	17.7	62.1	18.5
	-5.0	-5.6	65.9	16.1	65.7	16.8	65.5	17.5	65.4	17.9	65.3	18.3	65.1	19.0
	-3.0	-3.7	68.8	16.7	68.6	17.4	68.4	18.1	68.3	18.4	68.3	18.8	68.1	19.5
	0.0	-0.7	73.7	17.5	73.6	18.2	73.4	18.8	73.3	19.2	73.2	19.5	73.0	20.2
	3.0	2.2	78.8	18.3	78.6	18.9	78.5	19.5	78.4	19.8	78.3	20.1	78.1	20.8
	5.0	4.1	82.3	18.8	82.1	19.4	82.0	20.0	81.9	20.3	81.8	20.5	81.6	21.1
	7.0	6.0	85.9	19.2	85.8	19.8	85.6	20.4	85.5	20.6	85.4	20.9	85.2	21.5
	9.0	7.9	89.7	19.7	89.5	20.2	89.3	20.7	89.2	21.0	89.1	21.3	89.0	21.8
	11.0	9.8	93.6	20.1	93.4	20.6	93.2	21.1	93.1	21.4	93.0	21.6	92.3	21.9
	13.0	11.8	97.8	20.5	97.6	21.0	97.4	21.5	97.3	21.7	97.2	22.0	92.3	20.8
	15.0	13.7	102.0	20.9	101.8	21.3	101.6	21.8	101.5	22.0	99.1	21.5	92.3	19.8
120 (780)	-19.8	-20.0	47.4	12.1	47.2	13.1	47.0	14.0	47.0	14.5	46.9	15.0	46.7	16.0
	-18.8	-19.0	48.4	12.5	48.2	13.4	48.1	14.4	48.0	14.8	47.9	15.3	47.7	16.3
	-16.7	-17.0	50.6	13.3	50.4	14.1	50.2	15.0	50.1	15.5	50.0	15.9	49.9	16.8
	-14.7	-15.0	52.9	14.0	52.7	14.8	52.5	15.7	52.4	16.1	52.3	16.5	52.2	17.4
	-12.6	-13.0	55.3	14.7	55.1	15.5	55.0	16.3	54.9	16.7	54.8	17.1	54.6	17.9
	-10.5	-11.0	57.9	15.4	57.7	16.1	57.5	16.9	57.5	17.3	57.4	17.7	57.2	18.5
	-9.5	-10.0	59.2	15.7	59.1	16.5	58.9	17.2	58.8	17.6	58.7	18.0	58.6	18.7
	-8.5	-9.1	60.5	16.0	60.3	16.7	60.1	17.5	60.1	17.8	60.0	18.2	59.8	19.0
	-7.0	-7.6	62.6	16.5	62.5	17.2	62.3	17.9	62.2	18.2	62.1	18.6	61.9	19.3
	-5.0	-5.6	65.6	17.1	65.4	17.7	65.3	18.4	65.2	18.8	65.1	19.1	64.9	19.8
	-3.0	-3.7	68.6	17.6	68.4	18.3	68.2	18.9	68.1	19.2	68.0	19.6	67.9	20.2
	0.0	-0.7	73.5	18.4	73.3	19.0	73.2	19.6	73.1	19.9	73.0	20.2	72.8	20.8
	3.0	2.2	78.6	19.1	78.4	19.7	78.2	20.3	78.1	20.5	78.1	20.8	77.9	21.4
	5.0	4.1	82.1	19.6	81.9	20.1	81.7	20.7	81.6	20.9	81.6	21.2	81.4	21.7
	7.0	6.0	85.7	20.0	85.5	20.5	85.4	21.0	85.3	21.3	85.2	21.6	85.0	22.1
	9.0	7.9	89.4	20.4	89.3	20.9	89.1	21.4	89.0	21.6	88.9	21.9	85.2	21.0
	11.0	9.8	93.3	20.8	93.2	21.3	93.0	21.7	92.9	22.0	91.5	21.7	85.2	19.9
	13.0	11.8	97.6	21.2	97.4	21.6	97.2	22.1	94.7	21.4	91.5	20.6	85.2	18.9
	15.0	13.7	101.7	21.5	101.5	21.9	97.8	21.2	94.7	20.3	91.5	19.5	85.2	18.0
110 (715)	-19.8	-20.0	47.1	13.5	47.0	14.4	46.8	15.3	46.7	15.7	46.7	16.2	46.5	17.0
	-18.8	-19.0	48.2	13.9	48.0	14.7	47.8	15.6	47.8	16.0	47.7	16.5	47.5	17.3
	-16.7	-17.0	50.3	14.6	50.2	15.4	50.0	16.2	49.9	16.6	49.8	17.0	49.7	17.9
	-14.7	-15.0	52.6	15.2	52.5	16.0	52.3	16.8	52.2	17.2	52.1	17.6	52.0	18.4
	-12.6	-13.0	55.1	15.9	54.9	16.6	54.7	17.4	54.7	17.8	54.6	18.1	54.4	18.9
	-10.5	-11.0	57.6	16.5	57.5	17.2	57.3	17.9	57.2	18.3	57.2	18.6	57.0	19.4
	-9.5	-10.0	59.0	16.8	58.8	17.5	58.7	18.2	58.6	18.5	58.5	18.9	58.4	19.6
	-8.5	-9.1	60.2	17.1	60.1	17.8	59.9	18.4	59.8	18.8	59.8	19.1	59.6	19.8
	-7.0	-7.6	62.4	17.5	62.2	18.2	62.1	18.8	62.0	19.1	61.9	19.5	61.7	20.1
	-5.0	-5.6	65.3	18.1	65.2	18.7	65.0	19.3	65.0	19.6	64.9	19.9	64.7	20.6
	-3.0	-3.7	68.3	18.6	68.1	19.2	68.0	19.8	67.9	20.1	67.8	20.3	67.7	20.9
	0.0	-0.7	73.2	19.3	73.1	19.9	72.9	20.4	72.9	20.7	72.8	21.0	72.6	21.5
	3.0	2.2	78.3	20.0	78.2	20.5	78.0	21.0	77.9	21.3	77.9	21.5	77.7	22.0
	5.0	4.1	81.8	20.4	81.7	20.9	81.5	21.4	81.4	21.6	81.3	21.9	78.1	21.1
	7.0	6.0	85.4	20.8	85.3	21.2	85.1	21.7	85.0	21.9	83.9	21.7	78.1	20.0
	9.0	7.9	89.2	21.1	89.0	21.6	88.9	22.0	86.8	21.5	83.9	20.6	78.1	19.0
	11.0	9.8	93.1	21.5	92.9	21.9	89.7	21.2	86.8	20.4	83.9	19.6	78.1	18.0
	13.0	11.8	97.3	21.8	95.4	21.6	89.7	20.1	86.8	19.3	83.9	18.6	78.1	17.1
	15.0	13.7	101.2	22.0	95.4	20.5	89.7	19.1	86.8	18.4	83.9	17.7	78.1	16.3

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (650)	-19.8	-20.0	46.9	14.9	46.7	15.7	46.6	16.5	46.5	16.9	46.4	17.3	46.3	18.1
	-18.8	-19.0	47.9	15.2	47.8	16.0	47.6	16.8	47.5	17.2	47.5	17.6	47.3	18.4
	-16.7	-17.0	50.1	15.9	49.9	16.6	49.8	17.4	49.7	17.7	49.6	18.1	49.5	18.9
	-14.7	-15.0	52.4	16.5	52.2	17.2	52.1	17.9	52.0	18.3	51.9	18.6	51.8	19.3
	-12.6	-13.0	54.8	17.1	54.7	17.8	54.5	18.4	54.4	18.8	54.4	19.1	54.2	19.8
	-10.5	-11.0	57.4	17.6	57.2	18.3	57.1	18.9	57.0	19.3	57.0	19.6	56.8	20.2
	-9.5	-10.0	58.7	17.9	58.6	18.5	58.5	19.2	58.4	19.5	58.3	19.8	58.2	20.4
	-8.5	-9.1	60.0	18.2	59.8	18.8	59.7	19.4	59.6	19.7	59.6	20.0	59.4	20.6
	-7.0	-7.6	62.1	18.6	62.0	19.1	61.8	19.7	61.8	20.0	61.7	20.3	61.5	20.9
	-5.0	-5.6	65.1	19.1	65.0	19.6	64.8	20.2	64.7	20.5	64.7	20.8	64.5	21.3
	-3.0	-3.7	68.1	19.5	67.9	20.1	67.8	20.6	67.7	20.9	67.6	21.1	67.5	21.7
	0.0	-0.7	73.0	20.2	72.9	20.7	72.7	21.2	72.6	21.4	72.6	21.7	71.0	21.5
	3.0	2.2	78.1	20.8	77.9	21.3	77.8	21.7	77.7	22.0	76.3	21.6	71.0	19.8
	5.0	4.1	81.6	21.2	81.4	21.6	81.3	22.1	78.9	21.3	76.3	20.5	71.0	18.8
	7.0	6.0	85.2	21.5	85.0	21.9	81.5	21.0	78.9	20.2	76.3	19.4	71.0	17.9
	9.0	7.9	88.9	21.8	86.7	21.5	81.5	19.9	78.9	19.2	76.3	18.4	71.0	17.0
	11.0	9.8	92.0	21.8	86.7	20.4	81.5	18.9	78.9	18.2	76.3	17.5	71.0	16.2
	13.0	11.8	92.0	20.7	86.7	19.3	81.5	18.0	78.9	17.3	76.3	16.6	71.0	15.4
	15.0	13.7	92.0	19.7	86.7	18.4	81.5	17.1	78.9	16.5	76.3	15.9	71.0	14.6
90 (585)	-19.8	-20.0	46.6	16.3	46.5	17.1	46.4	17.8	46.3	18.1	46.2	18.5	46.1	19.2
	-18.8	-19.0	47.7	16.6	47.5	17.3	47.4	18.0	47.3	18.4	47.3	18.7	47.1	19.4
	-16.7	-17.0	49.8	17.2	49.7	17.9	49.5	18.5	49.5	18.9	49.4	19.2	49.3	19.9
	-14.7	-15.0	52.1	17.7	52.0	18.4	51.8	19.0	51.8	19.3	51.7	19.7	51.6	20.3
	-12.6	-13.0	54.6	18.3	54.4	18.9	54.3	19.5	54.2	19.8	54.2	20.1	54.0	20.7
	-10.5	-11.0	57.1	18.8	57.0	19.4	56.9	19.9	56.8	20.2	56.8	20.5	56.6	21.1
	-9.5	-10.0	58.5	19.0	58.4	19.6	58.2	20.2	58.2	20.5	58.1	20.7	58.0	21.3
	-8.5	-9.1	59.7	19.2	59.6	19.8	59.5	20.4	59.4	20.6	59.3	20.9	59.2	21.5
	-7.0	-7.6	61.9	19.6	61.7	20.1	61.6	20.7	61.5	20.9	61.5	21.2	61.4	21.7
	-5.0	-5.6	64.8	20.1	64.7	20.6	64.6	21.1	64.5	21.3	64.5	21.6	63.9	21.9
	-3.0	-3.7	67.8	20.5	67.7	21.0	67.5	21.4	67.5	21.7	67.4	21.9	63.9	20.7
	0.0	-0.7	72.7	21.1	72.6	21.5	72.5	22.0	71.0	21.5	68.6	20.7	63.9	19.0
	3.0	2.2	77.8	21.6	77.7	22.0	73.4	20.6	71.0	19.8	68.6	19.1	63.9	17.5
	5.0	4.1	81.3	22.0	78.1	21.0	73.4	19.5	71.0	18.8	68.6	18.1	63.9	16.7
	7.0	6.0	82.8	21.4	78.1	20.0	73.4	18.5	71.0	17.9	68.6	17.2	63.9	15.8
	9.0	7.9	82.8	20.3	78.1	18.9	73.4	17.6	71.0	17.0	68.6	16.3	63.9	15.1
	11.0	9.8	82.8	19.3	78.1	18.0	73.4	16.8	71.0	16.2	68.6	15.6	63.9	14.4
	13.0	11.8	82.8	18.3	78.1	17.1	73.4	15.9	71.0	15.3	68.6	14.8	63.9	13.7
	15.0	13.7	82.8	17.4	78.1	16.3	73.4	15.2	71.0	14.6	68.6	14.1	63.9	13.1
80 (520)	-19.8	-20.0	46.4	17.7	46.3	18.4	46.1	19.0	46.1	19.3	46.0	19.7	45.9	20.3
	-18.8	-19.0	47.4	18.0	47.3	18.6	47.2	19.2	47.1	19.6	47.1	19.9	46.9	20.5
	-16.7	-17.0	49.6	18.5	49.4	19.1	49.3	19.7	49.3	20.0	49.2	20.3	49.1	20.9
	-14.7	-15.0	51.9	19.0	51.7	19.6	51.6	20.1	51.6	20.4	51.5	20.7	51.4	21.3
	-12.6	-13.0	54.3	19.5	54.2	20.0	54.1	20.5	54.0	20.8	54.0	21.1	53.8	21.6
	-10.5	-11.0	56.9	19.9	56.8	20.4	56.7	21.0	56.6	21.2	56.5	21.5	56.4	22.0
	-9.5	-10.0	58.2	20.1	58.1	20.6	58.0	21.2	57.9	21.4	57.9	21.7	56.8	21.6
	-8.5	-9.1	59.5	20.3	59.4	20.8	59.2	21.3	59.2	21.6	59.1	21.8	56.8	21.0
	-7.0	-7.6	61.6	20.6	61.5	21.1	61.4	21.6	61.3	21.8	61.0	21.9	56.8	20.1
	-5.0	-5.6	64.6	21.1	64.5	21.5	64.4	22.0	63.1	21.5	61.0	20.7	56.8	19.0
	-3.0	-3.7	67.6	21.4	67.4	21.9	65.2	21.2	63.1	20.4	61.0	19.6	56.8	18.0
	0.0	-0.7	72.5	22.0	69.4	21.0	65.2	19.5	63.1	18.7	61.0	18.0	56.8	16.6
	3.0	2.2	73.6	20.7	69.4	19.3	65.2	17.9	63.1	17.3	61.0	16.6	56.8	15.4
	5.0	4.1	73.6	19.6	69.4	18.3	65.2	17.0	63.1	16.4	61.0	15.8	56.8	14.6
	7.0	6.0	73.6	18.6	69.4	17.4	65.2	16.2	63.1	15.6	61.0	15.0	56.8	13.9
	9.0	7.9	73.6	17.7	69.4	16.5	65.2	15.4	63.1	14.9	61.0	14.3	56.8	13.3
	11.0	9.8	73.6	16.8	69.4	15.7	65.2	14.7	63.1	14.2	61.0	13.7	56.8	12.7
	13.0	11.8	73.6	16.0	69.4	15.0	65.2	14.0	63.1	13.5	61.0	13.0	56.8	12.1
	15.0	13.7	73.6	15.2	69.4	14.3	65.2	13.3	63.1	12.9	61.0	12.4	56.8	11.5

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (455)	-19.8	-20.0	46.1	19.1	46.0	19.7	45.9	20.3	45.9	20.5	45.8	20.8	45.7	21.4				
	-18.8	-19.0	47.1	19.4	47.0	19.9	46.9	20.5	46.9	20.7	46.8	21.0	46.7	21.6				
	-16.7	-17.0	49.3	19.8	49.2	20.3	49.1	20.9	49.1	21.1	49.0	21.4	48.9	21.9				
	-14.7	-15.0	51.6	20.2	51.5	20.7	51.4	21.2	51.4	21.5	51.3	21.7	49.7	21.2				
	-12.6	-13.0	54.0	20.7	53.9	21.1	53.8	21.6	53.8	21.8	53.4	21.9	49.7	20.1				
	-10.5	-11.0	56.6	21.1	56.5	21.5	56.4	22.0	55.2	21.5	53.4	20.6	49.7	19.0				
	-9.5	-10.0	58.0	21.2	57.9	21.7	57.1	21.7	55.2	20.9	53.4	20.0	49.7	18.4				
	-8.5	-9.1	59.2	21.4	59.1	21.9	57.1	21.1	55.2	20.3	53.4	19.5	49.7	18.0				
	-7.0	-7.6	61.4	21.7	60.7	21.8	57.1	20.2	55.2	19.5	53.4	18.7	49.7	17.2				
	-5.0	-5.6	64.3	22.1	60.7	20.6	57.1	19.1	55.2	18.4	53.4	17.7	49.7	16.3				
	-3.0	-3.7	64.4	20.9	60.7	19.5	57.1	18.1	55.2	17.4	53.4	16.8	49.7	15.5				
	0.0	-0.7	64.4	19.2	60.7	17.9	57.1	16.7	55.2	16.1	53.4	15.5	49.7	14.3				
	3.0	2.2	64.4	17.7	60.7	16.5	57.1	15.4	55.2	14.9	53.4	14.3	49.7	13.3				
	5.0	4.1	64.4	16.8	60.7	15.7	57.1	14.7	55.2	14.2	53.4	13.6	49.7	12.6				
	7.0	6.0	64.4	16.0	60.7	15.0	57.1	14.0	55.2	13.5	53.4	13.0	49.7	12.1				
	9.0	7.9	64.4	15.2	60.7	14.2	57.1	13.3	55.2	12.9	53.4	12.4	48.7	11.5				
	11.0	9.8	64.4	14.5	60.7	13.6	57.1	12.7	55.2	12.3	53.4	11.8	48.7	11.0				
	13.0	11.8	64.4	13.8	60.7	12.9	57.1	12.1	55.2	11.7	53.4	11.3	48.7	10.5				
	15.0	13.7	64.4	13.2	60.7	12.4	57.1	11.6	55.2	11.2	53.4	10.8	48.7	10.1				
60 (390)	-19.8	-20.0	45.9	20.6	45.8	21.0	45.7	21.5	45.7	21.8	45.6	22.0	42.6	20.3				
	-18.8	-19.0	46.9	20.7	46.8	21.2	46.7	21.7	46.7	21.9	45.8	21.5	42.6	19.8				
	-16.7	-17.0	49.1	21.1	49.0	21.6	48.9	22.0	47.3	21.2	45.8	20.4	42.6	18.7				
	-14.7	-15.0	51.4	21.5	51.3	21.9	48.9	20.8	47.3	20.0	45.8	19.3	42.6	17.7				
	-12.6	-13.0	53.8	21.8	52.0	21.2	48.9	19.7	47.3	18.9	45.8	18.2	42.6	16.8				
	-10.5	-11.0	55.2	21.5	52.0	20.0	48.9	18.6	47.3	17.9	45.8	17.2	42.6	15.9				
	-9.5	-10.0	55.2	20.9	52.0	19.5	48.9	18.1	47.3	17.4	45.8	16.8	42.6	15.5				
	-8.5	-9.1	55.2	20.3	52.0	19.0	48.9	17.6	47.3	17.0	45.8	16.3	42.6	15.1				
	-7.0	-7.6	55.2	19.5	52.0	18.2	48.9	16.9	47.3	16.3	45.8	15.7	42.6	14.5				
	-5.0	-5.6	55.2	18.4	52.0	17.2	48.9	16.0	47.3	15.4	45.8	14.9	42.6	13.8				
	-3.0	-3.7	55.2	17.4	52.0	16.3	48.9	15.2	47.3	14.7	45.8	14.1	42.6	13.1				
	0.0	-0.7	55.2	16.1	52.0	15.0	48.9	14.0	47.3	13.6	45.8	13.1	42.6	12.1				
	3.0	2.2	55.2	14.9	52.0	13.9	48.9	13.0	47.3	12.6	45.8	12.1	42.6	11.3				
	5.0	4.1	55.2	14.1	52.0	13.3	48.9	12.4	47.3	12.0	45.8	11.6	42.6	10.8				
	7.0	6.0	55.2	13.5	52.0	12.7	48.9	11.8	47.3	11.5	45.8	11.1	42.6	10.3				
	9.0	7.9	55.2	12.9	52.0	12.1	48.9	11.3	47.3	10.9	45.8	10.6	42.6	9.85				
	11.0	9.8	55.2	12.3	52.0	11.5	48.9	10.8	47.3	10.5	45.8	10.1	42.6	9.43				
	13.0	11.8	55.2	11.7	52.0	11.0	48.9	10.3	47.3	10.0	45.8	9.67	42.6	9.02				
	15.0	13.7	55.2	11.2	52.0	10.5	48.9	9.9	47.3	9.6	45.8	9.27	42.6	8.66				
50 (325)	-19.8	-20.0	45.6	22.0	43.4	20.7	40.8	19.3	39.4	18.5	38.1	17.8	35.5	16.4				
	-18.8	-19.0	46.0	21.6	43.4	20.2	40.8	18.7	39.4	18.0	38.1	17.4	35.5	16.0				
	-16.7	-17.0	46.0	20.5	43.4	19.1	40.8	17.8	39.4	17.1	38.1	16.5	35.5	15.2				
	-14.7	-15.0	46.0	19.4	43.4	18.1	40.8	16.8	39.4	16.2	38.1	15.6	35.5	14.4				
	-12.6	-13.0	46.0	18.3	43.4	17.1	40.8	16.0	39.4	15.4	38.1	14.8	35.5	13.7				
	-10.5	-11.0	46.0	17.3	43.4	16.2	40.8	15.1	39.4	14.6	38.1	14.0	35.5	13.0				
	-9.5	-10.0	46.0	16.9	43.4	15.8	40.8	14.7	39.4	14.2	38.1	13.7	35.5	12.7				
	-8.5	-9.1	46.0	16.4	43.4	15.4	40.8	14.4	39.4	13.9	38.1	13.4	35.5	12.4				
	-7.0	-7.6	46.0	15.8	43.4	14.8	40.8	13.8	39.4	13.3	38.1	12.9	35.5	11.9				
	-5.0	-5.6	46.0	14.9	43.4	14.0	40.8	13.1	39.4	12.7	38.1	12.2	35.5	11.3				
	-3.0	-3.7	46.0	14.2	43.4	13.3	40.8	12.5	39.4	12.1	38.1	11.6	35.5	10.8				
	0.0	-0.7	46.0	13.1	43.4	12.3	40.8	11.6	39.4	11.2	38.1	10.8	35.5	10.05				
	3.0	2.2	46.0	12.2	43.4	11.5	40.8	10.8	39.4	10.4	38.1	10.07	35.5	9.38				
	5.0	4.1	46.0	11.6	43.4	11.0	40.8	10.3	39.4	9.96	38.1	9.63	35.5	8.98				
	7.0	6.0	46.0	11.1	43.4	10.5	40.8	9.84	39.4	9.53	38.1	9.22	35.5	8.61				
	9.0	7.9	46.0	10.6	43.4	10.0	40.8	9.42	39.4	9.12	38.1	8.83	35.5	8.25				
	11.0	9.8	46.0	10.2	43.4	9.59	40.8	9.03	39.4	8.75	38.1	8.47	35.5	7.92				
	13.0	11.8	46.0	9.7	43.4	9.18	40.8	8.64	39.4	8.38	38.1	8.12	35.5	7.60				
	15.0	13.7	46.0	9.32	43.4	8.80	40.8	8.30	39.4	8.05	38.1	7.80	35.5	7.31				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (910)	-19.8	-20.0	51.8	12.2	51.6	13.4	51.4	14.5	51.3	15.1	51.2	15.7	51.0	16.9
	-18.8	-19.0	52.7	12.6	52.5	13.8	52.3	14.9	52.2	15.4	52.1	16.0	51.9	17.1
	-16.7	-17.0	54.7	13.4	54.5	14.5	54.3	15.6	54.2	16.1	54.1	16.7	53.9	17.8
	-14.7	-15.0	57.0	14.2	56.8	15.2	56.6	16.3	56.5	16.8	56.4	17.3	56.2	18.4
	-12.6	-13.0	59.4	15.0	59.2	16.0	59.0	17.0	58.9	17.5	58.8	18.0	58.6	19.0
	-10.5	-11.0	62.1	15.8	61.9	16.8	61.7	17.7	61.6	18.2	61.5	18.7	61.3	19.6
	-9.5	-10.0	63.6	16.2	63.4	17.2	63.2	18.1	63.1	18.6	63.0	19.0	62.8	19.9
	-8.5	-9.1	64.9	16.6	64.7	17.5	64.5	18.4	64.4	18.9	64.3	19.3	64.1	20.2
	-7.0	-7.6	67.3	17.2	67.1	18.1	66.9	18.9	66.8	19.4	66.7	19.8	66.5	20.7
	-5.0	-5.6	70.6	18.0	70.4	18.8	70.2	19.6	70.1	20.0	70.0	20.5	69.8	21.3
	-3.0	-3.7	74.0	18.7	73.8	19.5	73.6	20.2	73.5	20.6	73.4	21.0	73.2	21.8
	0.0	-0.7	79.8	19.7	79.6	20.5	79.4	21.2	79.3	21.6	79.2	21.9	79.0	22.7
	3.0	2.2	85.9	20.7	85.7	21.4	85.5	22.0	85.4	22.4	85.3	22.7	85.1	23.4
	5.0	4.1	90.2	21.3	90.0	21.9	89.8	22.6	89.7	22.9	89.6	23.2	89.4	23.9
	7.0	6.0	94.6	21.8	94.4	22.5	94.2	23.1	94.1	23.4	94.0	23.7	93.8	24.3
	9.0	7.9	99.3	22.4	99.1	23.0	98.9	23.5	98.8	23.8	98.7	24.1	98.5	24.7
	11.0	9.8	104.2	22.9	104.0	23.4	103.8	24.0	103.7	24.3	103.6	24.5	99.7	23.7
	13.0	11.8	109.6	23.4	109.4	23.9	109.2	24.4	109.1	24.7	107.0	24.3	99.7	22.3
	15.0	13.7	115	23.8	115	24.3	114	24.8	111	23.8	107	22.9	99.7	21.0
120 (840)	-19.8	-20.0	51.5	13.8	51.4	14.9	51.2	15.9	51.1	16.5	51.0	17.0	50.8	18.1
	-18.8	-19.0	52.5	14.1	52.3	15.2	52.1	16.2	52.0	16.8	51.9	17.3	51.7	18.3
	-16.7	-17.0	54.5	14.9	54.3	15.9	54.1	16.9	54.0	17.4	53.9	17.9	53.7	18.9
	-14.7	-15.0	56.7	15.6	56.5	16.6	56.3	17.5	56.2	18.0	56.1	18.5	56.0	19.5
	-12.6	-13.0	59.2	16.4	59.0	17.3	58.8	18.2	58.7	18.7	58.6	19.1	58.4	20.0
	-10.5	-11.0	61.9	17.1	61.7	18.0	61.5	18.9	61.4	19.3	61.3	19.8	61.1	20.6
	-9.5	-10.0	63.3	17.5	63.1	18.3	62.9	19.2	62.8	19.6	62.8	20.1	62.6	20.9
	-8.5	-9.1	64.7	17.8	64.5	18.7	64.3	19.5	64.2	19.9	64.1	20.3	63.9	21.2
	-7.0	-7.6	67.0	18.4	66.8	19.2	66.6	20.0	66.5	20.4	66.5	20.8	66.3	21.6
	-5.0	-5.6	70.4	19.1	70.2	19.8	70.0	20.6	69.9	21.0	69.8	21.4	69.6	22.2
	-3.0	-3.7	73.7	19.7	73.6	20.5	73.4	21.2	73.3	21.6	73.2	21.9	73.0	22.7
	0.0	-0.7	79.5	20.7	79.3	21.4	79.2	22.1	79.1	22.4	79.0	22.7	78.8	23.4
	3.0	2.2	85.6	21.6	85.4	22.2	85.3	22.9	85.2	23.2	85.1	23.5	84.9	24.1
	5.0	4.1	89.9	22.1	89.7	22.7	89.5	23.3	89.4	23.6	89.3	23.9	89.2	24.5
	7.0	6.0	94.4	22.7	94.2	23.2	94.0	23.8	93.9	24.1	93.8	24.4	92.0	24.3
	9.0	7.9	99.1	23.2	98.9	23.7	98.7	24.2	98.6	24.5	98.5	24.8	92.0	22.9
	11.0	9.8	104.0	23.6	103.8	24.1	103.6	24.6	102.2	24.4	98.8	23.5	92.0	21.5
	13.0	11.8	109.3	24.1	109.2	24.6	105.6	23.9	102.2	22.9	98.8	22.0	92.0	20.3
	15.0	13.7	115	24.5	112	24.3	106	22.5	102	21.7	98.8	20.8	92.0	19.2
110 (770)	-19.8	-20.0	51.3	15.4	51.1	16.3	50.9	17.3	50.8	17.8	50.8	18.3	50.6	19.3
	-18.8	-19.0	52.2	15.7	52.0	16.6	51.8	17.6	51.8	18.1	51.7	18.6	51.5	19.5
	-16.7	-17.0	54.2	16.3	54.0	17.3	53.8	18.2	53.8	18.6	53.7	19.1	53.5	20.0
	-14.7	-15.0	56.4	17.0	56.3	17.9	56.1	18.8	56.0	19.2	55.9	19.7	55.7	20.6
	-12.6	-13.0	58.9	17.7	58.7	18.6	58.6	19.4	58.5	19.8	58.4	20.2	58.2	21.1
	-10.5	-11.0	61.6	18.4	61.4	19.2	61.3	20.0	61.2	20.4	61.1	20.8	60.9	21.6
	-9.5	-10.0	63.0	18.7	62.9	19.5	62.7	20.3	62.6	20.7	62.5	21.1	62.4	21.9
	-8.5	-9.1	64.4	19.0	64.2	19.8	64.0	20.6	64.0	21.0	63.9	21.4	63.7	22.1
	-7.0	-7.6	66.7	19.6	66.6	20.3	66.4	21.0	66.3	21.4	66.2	21.8	66.1	22.5
	-5.0	-5.6	70.1	20.2	69.9	20.9	69.7	21.6	69.7	22.0	69.6	22.3	69.4	23.0
	-3.0	-3.7	73.5	20.8	73.3	21.5	73.1	22.1	73.0	22.5	73.0	22.8	72.8	23.5
	0.0	-0.7	79.3	21.7	79.1	22.3	78.9	22.9	78.8	23.3	78.8	23.6	78.6	24.2
	3.0	2.2	85.4	22.5	85.2	23.1	85.0	23.7	84.9	24.0	84.8	24.2	84.4	24.7
	5.0	4.1	89.6	23.0	89.5	23.6	89.3	24.1	89.2	24.4	89.1	24.7	84.4	23.2
	7.0	6.0	94.1	23.5	93.9	24.0	93.8	24.5	93.7	24.8	90.6	23.8	84.4	21.9
	9.0	7.9	98.8	23.9	98.6	24.4	96.8	24.3	93.7	23.4	90.6	22.4	84.4	20.6
	11.0	9.8	103.7	24.4	103.0	24.7	96.8	22.9	93.7	22.0	90.6	21.2	84.4	19.5
	13.0	11.8	109.1	24.8	103.0	23.2	96.8	21.5	93.7	20.7	90.6	19.9	84.4	18.3
	15.0	13.7	109	23.4	103	21.9	96.8	20.3	93.7	19.6	90.6	18.8	84.4	17.4

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (700)	-19.8	-20.0	51.0	16.9	50.8	17.8	50.7	18.7	50.6	19.1	50.5	19.6	50.4	20.5
	-18.8	-19.0	51.9	17.2	51.8	18.1	51.6	19.0	51.5	19.4	51.4	19.8	51.3	20.7
	-16.7	-17.0	53.9	17.8	53.8	18.6	53.6	19.5	53.5	19.9	53.4	20.3	53.3	21.2
	-14.7	-15.0	56.1	18.4	56.0	19.2	55.8	20.0	55.8	20.4	55.7	20.8	55.5	21.6
	-12.6	-13.0	58.6	19.1	58.5	19.8	58.3	20.6	58.2	21.0	58.2	21.4	58.0	22.1
	-10.5	-11.0	61.3	19.7	61.2	20.4	61.0	21.2	60.9	21.5	60.9	21.9	60.7	22.6
	-9.5	-10.0	62.8	20.0	62.6	20.7	62.5	21.4	62.4	21.8	62.3	22.1	62.2	22.9
	-8.5	-9.1	64.1	20.3	64.0	21.0	63.8	21.7	63.7	22.0	63.7	22.4	63.5	23.1
	-7.0	-7.6	66.5	20.7	66.3	21.4	66.2	22.1	66.1	22.4	66.0	22.8	65.9	23.4
	-5.0	-5.6	69.8	21.3	69.7	22.0	69.5	22.6	69.4	22.9	69.3	23.2	69.2	23.9
	-3.0	-3.7	73.2	21.9	73.0	22.5	72.9	23.1	72.8	23.4	72.7	23.7	72.6	24.3
	0.0	-0.7	79.0	22.7	78.8	23.3	78.7	23.8	78.6	24.1	78.5	24.4	76.7	24.1
	3.0	2.2	85.1	23.4	84.9	24.0	84.8	24.5	84.7	24.7	82.3	24.0	76.7	22.0
	5.0	4.1	89.4	23.9	89.2	24.4	88.0	24.4	85.2	23.5	82.3	22.6	76.7	20.7
	7.0	6.0	93.8	24.3	93.7	24.8	88.0	23.0	85.2	22.1	82.3	21.3	76.7	19.6
	9.0	7.9	98.5	24.7	93.7	23.3	88.0	21.7	85.2	20.9	82.3	20.1	76.7	18.5
	11.0	9.8	99.3	23.6	93.7	22.0	88.0	20.4	85.2	19.7	82.3	18.9	76.7	17.5
	13.0	11.8	99.3	22.2	93.7	20.7	88.0	19.3	85.2	18.5	82.3	17.9	76.7	16.5
	15.0	13.7	99.3	20.9	93.7	19.6	88.0	18.2	85.2	17.5	82.3	16.9	76.7	15.6
90 (630)	-19.8	-20.0	50.7	18.5	50.6	19.3	50.4	20.1	50.4	20.5	50.3	20.9	50.2	21.7
	-18.8	-19.0	51.6	18.7	51.5	19.5	51.4	20.3	51.3	20.7	51.2	21.1	51.1	21.9
	-16.7	-17.0	53.6	19.3	53.5	20.0	53.4	20.8	53.3	21.2	53.2	21.5	53.1	22.3
	-14.7	-15.0	55.9	19.8	55.7	20.6	55.6	21.3	55.5	21.6	55.5	22.0	55.3	22.7
	-12.6	-13.0	58.3	20.4	58.2	21.1	58.1	21.8	58.0	22.1	57.9	22.5	57.8	23.2
	-10.5	-11.0	61.1	21.0	60.9	21.6	60.8	22.3	60.7	22.6	60.6	22.9	60.5	23.6
	-9.5	-10.0	62.5	21.3	62.4	21.9	62.2	22.5	62.2	22.9	62.1	23.2	61.9	23.8
	-8.5	-9.1	63.8	21.5	63.7	22.1	63.6	22.8	63.5	23.1	63.4	23.4	63.3	24.0
	-7.0	-7.6	66.2	21.9	66.1	22.5	65.9	23.1	65.8	23.4	65.8	23.7	65.6	24.3
	-5.0	-5.6	69.5	22.5	69.4	23.0	69.3	23.6	69.2	23.9	69.1	24.2	69.0	24.8
	-3.0	-3.7	72.9	22.9	72.8	23.5	72.7	24.0	72.6	24.3	72.5	24.6	69.0	23.4
	0.0	-0.7	78.7	23.7	78.6	24.2	78.4	24.7	76.7	24.1	74.1	23.1	69.0	21.3
	3.0	2.2	84.8	24.4	84.3	24.6	79.2	22.9	76.7	22.0	74.1	21.1	69.0	19.5
	5.0	4.1	89.1	24.8	84.3	23.2	79.2	21.5	76.7	20.7	74.1	19.9	69.0	18.4
	7.0	6.0	89.4	23.4	84.3	21.9	79.2	20.3	76.7	19.6	74.1	18.8	69.0	17.4
	9.0	7.9	89.4	22.1	84.3	20.6	79.2	19.2	76.7	18.5	74.1	17.8	69.0	16.4
	11.0	9.8	89.4	20.8	84.3	19.5	79.2	18.1	76.7	17.5	74.1	16.8	69.0	15.5
	13.0	11.8	89.4	19.6	84.3	18.3	79.2	17.1	76.7	16.5	74.1	15.9	69.0	14.7
	15.0	13.7	89.4	18.5	84.3	17.3	79.2	16.2	76.7	15.6	74.1	15.0	69.0	13.9
80 (560)	-19.8	-20.0	50.5	20.0	50.3	20.7	50.2	21.5	50.1	21.8	50.1	22.2	50.0	22.9
	-18.8	-19.0	51.4	20.3	51.2	21.0	51.1	21.7	51.1	22.0	51.0	22.4	50.9	23.1
	-16.7	-17.0	53.4	20.8	53.2	21.4	53.1	22.1	53.1	22.4	53.0	22.8	52.9	23.4
	-14.7	-15.0	55.6	21.3	55.5	21.9	55.4	22.5	55.3	22.9	55.2	23.2	55.1	23.8
	-12.6	-13.0	58.1	21.8	58.0	22.4	57.8	23.0	57.8	23.3	57.7	23.6	57.6	24.2
	-10.5	-11.0	60.8	22.3	60.7	22.8	60.5	23.4	60.5	23.7	60.4	24.0	60.3	24.6
	-9.5	-10.0	62.2	22.5	62.1	23.1	62.0	23.7	61.9	23.9	61.9	24.2	61.4	24.6
	-8.5	-9.1	63.6	22.7	63.5	23.3	63.3	23.8	63.3	24.1	63.2	24.4	61.4	23.9
	-7.0	-7.6	65.9	23.1	65.8	23.6	65.7	24.2	65.6	24.4	65.6	24.7	61.4	22.9
	-5.0	-5.6	69.3	23.6	69.1	24.1	69.0	24.6	68.1	24.4	65.9	23.4	61.4	21.5
	-3.0	-3.7	72.7	24.0	72.5	24.5	70.4	23.9	68.1	23.0	65.9	22.1	61.4	20.3
	0.0	-0.7	78.4	24.7	74.9	23.4	70.4	21.8	68.1	21.0	65.9	20.1	61.4	18.6
	3.0	2.2	79.4	22.9	74.9	21.4	70.4	19.9	68.1	19.2	65.9	18.4	61.4	17.0
	5.0	4.1	79.4	21.6	74.9	20.2	70.4	18.8	68.1	18.1	65.9	17.4	61.4	16.1
	7.0	6.0	79.4	20.4	74.9	19.0	70.4	17.7	68.1	17.1	65.9	16.5	61.4	15.2
	9.0	7.9	79.4	19.2	74.9	18.0	70.4	16.8	68.1	16.2	65.9	15.6	61.4	14.4
	11.0	9.8	79.4	18.2	74.9	17.0	70.4	15.9	68.1	15.3	65.9	14.8	61.4	13.7
	13.0	11.8	79.4	17.1	74.9	16.1	70.4	15.0	68.1	14.5	65.9	14.0	61.4	13.0
	15.0	13.7	79.4	16.2	74.9	15.2	70.4	14.2	68.1	13.7	65.9	13.3	61.4	12.3

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (490)	-19.8	-20.0	50.2	21.6	50.1	22.2	50.0	22.8	49.9	23.1	49.9	23.5	49.7	24.1				
	-18.8	-19.0	51.1	21.8	51.0	22.4	50.9	23.0	50.8	23.3	50.8	23.6	50.7	24.2				
	-16.7	-17.0	53.1	22.2	53.0	22.8	52.9	23.4	52.8	23.7	52.8	24.0	52.7	24.6				
	-14.7	-15.0	55.3	22.7	55.2	23.2	55.1	23.8	55.1	24.1	55.0	24.3	53.7	24.1				
	-12.6	-13.0	57.8	23.1	57.7	23.6	57.6	24.2	57.5	24.4	57.5	24.7	53.7	22.8				
	-10.5	-11.0	60.5	23.5	60.4	24.1	60.3	24.6	59.6	24.4	57.6	23.5	53.7	21.5				
	-9.5	-10.0	62.0	23.8	61.8	24.3	61.6	24.7	59.6	23.7	57.6	22.8	53.7	20.9				
	-8.5	-9.1	63.3	24.0	63.2	24.4	61.6	24.0	59.6	23.1	57.6	22.2	53.7	20.4				
	-7.0	-7.6	65.7	24.3	65.5	24.8	61.6	23.0	59.6	22.1	57.6	21.2	53.7	19.5				
	-5.0	-5.6	69.0	24.7	65.6	23.3	61.6	21.6	59.6	20.8	57.6	20.0	53.7	18.4				
	-3.0	-3.7	69.5	23.6	65.6	22.0	61.6	20.4	59.6	19.7	57.6	18.9	53.7	17.4				
	0.0	-0.7	69.5	21.5	65.6	20.0	61.6	18.6	59.6	18.0	57.6	17.3	53.7	16.0				
	3.0	2.2	69.5	19.6	65.6	18.3	61.6	17.1	59.6	16.5	57.6	15.9	53.7	14.7				
	5.0	4.1	69.5	18.5	65.6	17.3	61.6	16.2	59.6	15.6	57.6	15.0	53.7	13.9				
	7.0	6.0	69.5	17.5	65.6	16.4	61.6	15.3	59.6	14.8	57.6	14.2	53.7	13.2				
	9.0	7.9	69.5	16.5	65.6	15.5	61.6	14.5	59.6	14.0	57.6	13.5	53.7	12.5				
	11.0	9.8	69.5	15.7	65.6	14.7	61.6	13.7	59.6	13.3	57.6	12.8	53.7	11.9				
	13.0	11.8	69.5	14.8	65.6	13.9	61.6	13.0	59.6	12.6	57.6	12.1	53.7	11.3				
	15.0	13.7	69.5	14.0	65.6	13.2	61.6	12.4	59.6	12.0	57.6	11.6	53.7	10.8				
60 (420)	-19.8	-20.0	49.9	23.2	49.8	23.7	49.7	24.2	49.7	24.5	49.4	24.6	46.0	22.6				
	-18.8	-19.0	50.8	23.3	50.7	23.9	50.6	24.4	50.6	24.6	49.4	24.0	46.0	22.1				
	-16.7	-17.0	52.8	23.7	52.7	24.2	52.6	24.7	51.1	23.9	49.4	22.9	46.0	21.1				
	-14.7	-15.0	55.1	24.1	55.0	24.6	52.8	23.6	51.1	22.7	49.4	21.8	46.0	20.0				
	-12.6	-13.0	57.5	24.5	56.2	24.1	52.8	22.3	51.1	21.5	49.4	20.7	46.0	19.0				
	-10.5	-11.0	59.6	24.4	56.2	22.7	52.8	21.1	51.1	20.3	49.4	19.6	46.0	18.0				
	-9.5	-10.0	59.6	23.7	56.2	22.1	52.8	20.5	51.1	19.8	49.4	19.0	46.0	17.5				
	-8.5	-9.1	59.6	23.1	56.2	21.5	52.8	20.0	51.1	19.3	49.4	18.5	46.0	17.1				
	-7.0	-7.6	59.6	22.1	56.2	20.6	52.8	19.2	51.1	18.5	49.4	17.8	46.0	16.4				
	-5.0	-5.6	59.6	20.8	56.2	19.4	52.8	18.1	51.1	17.4	49.4	16.8	46.0	15.5				
	-3.0	-3.7	59.6	19.6	56.2	18.4	52.8	17.1	51.1	16.5	49.4	15.9	46.0	14.7				
	0.0	-0.7	59.6	18.0	56.2	16.8	52.8	15.7	51.1	15.1	49.4	14.6	46.0	13.5				
	3.0	2.2	59.6	16.5	56.2	15.4	52.8	14.4	51.1	13.9	49.4	13.4	46.0	12.5				
	5.0	4.1	59.6	15.6	56.2	14.6	52.8	13.7	51.1	13.2	49.4	12.8	46.0	11.9				
	7.0	6.0	59.6	14.8	56.2	13.9	52.8	13.0	51.1	12.5	49.4	12.1	46.0	11.3				
	9.0	7.9	59.6	14.0	56.2	13.1	52.8	12.3	51.1	11.9	49.4	11.5	46.0	10.7				
	11.0	9.8	59.6	13.3	56.2	12.5	52.8	11.7	51.1	11.3	49.4	11.0	46.0	10.2				
	13.0	11.8	59.6	12.6	56.2	11.8	52.8	11.1	51.1	10.8	49.4	10.4	46.0	9.71				
	15.0	13.7	59.6	12.0	56.2	11.3	52.8	10.6	51.1	10.3	49.4	9.9	46.0	9.27				
50 (350)	-19.8	-20.0	49.6	24.7	46.8	23.0	44.0	21.4	42.6	20.6	41.2	19.8	38.3	18.2				
	-18.8	-19.0	49.7	24.2	46.8	22.5	44.0	20.9	42.6	20.2	41.2	19.4	38.3	17.9				
	-16.7	-17.0	49.7	23.0	46.8	21.5	44.0	20.0	42.6	19.2	41.2	18.5	38.3	17.1				
	-14.7	-15.0	49.7	21.9	46.8	20.5	44.0	19.0	42.6	18.3	41.2	17.6	38.3	16.3				
	-12.6	-13.0	49.7	20.8	46.8	19.4	44.0	18.1	42.6	17.4	41.2	16.8	38.3	15.5				
	-10.5	-11.0	49.7	19.7	46.8	18.4	44.0	17.1	42.6	16.5	41.2	15.9	38.3	14.7				
	-9.5	-10.0	49.7	19.1	46.8	17.9	44.0	16.7	42.6	16.1	41.2	15.5	38.3	14.4				
	-8.5	-9.1	49.7	18.7	46.8	17.5	44.0	16.3	42.6	15.7	41.2	15.1	38.3	14.0				
	-7.0	-7.6	49.7	17.9	46.8	16.7	44.0	15.6	42.6	15.1	41.2	14.5	38.3	13.5				
	-5.0	-5.6	49.7	16.9	46.8	15.8	44.0	14.8	42.6	14.3	41.2	13.8	38.3	12.8				
	-3.0	-3.7	49.7	16.0	46.8	15.0	44.0	14.0	42.6	13.5	41.2	13.1	38.3	12.1				
	0.0	-0.7	49.7	14.7	46.8	13.8	44.0	12.9	42.6	12.5	41.2	12.0	38.3	11.2				
	3.0	2.2	49.7	13.5	46.8	12.7	44.0	11.9	42.6	11.5	41.2	11.1	38.3	10.39				
	5.0	4.1	49.7	12.8	46.8	12.1	44.0	11.3	42.6	11.0	41.2	10.6	38.3	9.89				
	7.0	6.0	49.7	12.2	46.8	11.5	44.0	10.8	42.6	10.4	41.2	10.10	38.3	9.43				
	9.0	7.9	49.7	11.6	46.8	10.9	44.0	10.3	42.6	9.94	41.2	9.62	38.3	8.99				
	11.0	9.8	49.7	11.0	46.8	10.4	44.0	9.78	42.6	9.47	41.2	9.18	38.3	8.59				
	13.0	11.8	49.7	10.5	46.8	9.9	44.0	9.30	42.6	9.02	41.2	8.74	38.3	8.19				
	15.0	13.7	49.7	10.0	46.8	9.42	44.0	8.88	42.6	8.62	41.2	8.36	38.3	7.83				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

14

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (981)	-19.8	-20.0	55.2	12.8	54.9	14.0	54.7	15.2	54.6	15.9	54.5	16.5	54.3	17.7
	-18.8	-19.0	56.1	13.2	55.9	14.4	55.7	15.6	55.6	16.2	55.5	16.8	55.3	18.0
	-16.7	-17.0	58.3	14.0	58.1	15.2	57.9	16.4	57.8	16.9	57.7	17.5	57.4	18.7
	-13.7	-15.0	60.7	14.9	60.5	16.0	60.3	17.1	60.2	17.7	60.1	18.2	59.8	19.3
	-11.8	-13.0	63.3	15.8	63.1	16.8	62.9	17.9	62.8	18.4	62.7	18.9	62.5	20.0
	-9.8	-11.0	66.2	16.6	66.0	17.6	65.8	18.6	65.7	19.1	65.6	19.6	65.4	20.7
	-9.5	-10.0	67.8	17.1	67.5	18.0	67.3	19.0	67.2	19.5	67.1	20.0	66.9	21.0
	-8.5	-9.1	69.2	17.4	69.0	18.4	68.8	19.4	68.7	19.8	68.5	20.3	68.3	21.3
	-7.0	-7.6	71.7	18.1	71.5	19.0	71.3	19.9	71.2	20.4	71.0	20.8	70.8	21.8
	-5.0	-5.6	75.2	18.9	75.0	19.7	74.8	20.6	74.7	21.1	74.6	21.5	74.4	22.4
	-3.0	-3.7	78.8	19.6	78.6	20.4	78.4	21.3	78.3	21.7	78.2	22.1	78.0	23.0
	0.0	-0.7	84.9	20.7	84.7	21.5	84.5	22.3	84.4	22.7	84.3	23.1	84.1	23.8
	3.0	2.2	91.4	21.7	91.1	22.5	90.9	23.2	90.8	23.5	90.7	23.9	90.5	24.6
	5.0	4.1	95.8	22.4	95.6	23.0	95.4	23.7	95.3	24.1	95.2	24.4	95.0	25.1
	7.0	6.0	100.6	22.9	100.3	23.6	100.1	24.2	100.0	24.6	99.9	24.9	99.7	25.5
	9.0	7.9	105	23.5	105	24.1	105	24.7	105	25.1	105	25.4	105	26.0
	11.0	9.8	111	24.0	110	24.6	110	25.2	110	25.5	110	25.8	106	25.2
	13.0	11.8	116	24.6	116	25.1	116	25.7	116	26.0	114	25.8	106	23.7
	15.0	13.7	122	25.0	122	25.6	121	26.1	118	25.3	114	24.3	106	22.4
120 (906)	-19.8	-20.0	54.9	14.5	54.7	15.6	54.5	16.7	54.4	17.3	54.3	17.8	54.1	19.0
	-18.8	-19.0	55.9	14.8	55.7	15.9	55.5	17.0	55.4	17.6	55.3	18.2	55.1	19.3
	-16.7	-17.0	58.0	15.6	57.8	16.7	57.6	17.7	57.5	18.3	57.4	18.8	57.2	19.9
	-13.7	-15.0	60.4	16.4	60.2	17.4	60.0	18.4	59.9	18.9	59.8	19.5	59.6	20.5
	-11.8	-13.0	63.1	17.2	62.9	18.2	62.7	19.1	62.6	19.6	62.5	20.1	62.3	21.1
	-9.8	-11.0	65.9	18.0	65.7	18.9	65.5	19.8	65.4	20.3	65.3	20.8	65.1	21.7
	-9.5	-10.0	67.5	18.4	67.3	19.3	67.1	20.2	67.0	20.6	66.9	21.1	66.7	22.0
	-8.5	-9.1	68.9	18.7	68.7	19.6	68.5	20.5	68.4	20.9	68.3	21.4	68.1	22.3
	-7.0	-7.6	71.4	19.3	71.2	20.2	71.0	21.0	70.9	21.4	70.8	21.9	70.6	22.7
	-5.0	-5.6	74.9	20.1	74.7	20.9	74.5	21.7	74.4	22.1	74.3	22.5	74.1	23.3
	-3.0	-3.7	78.5	20.7	78.3	21.5	78.1	22.3	78.0	22.7	77.9	23.1	77.7	23.8
	0.0	-0.7	84.6	21.8	84.4	22.5	84.2	23.2	84.1	23.6	84.0	23.9	83.8	24.6
	3.0	2.2	91.1	22.7	90.9	23.4	90.7	24.0	90.6	24.4	90.5	24.7	90.3	25.4
	5.0	4.1	95.6	23.3	95.4	23.9	95.2	24.5	95.1	24.9	95.0	25.2	94.8	25.8
	7.0	6.0	100.3	23.8	100.1	24.4	99.9	25.0	99.8	25.3	99.7	25.6	98.3	25.7
	9.0	7.9	105	24.3	105	24.9	105	25.5	105	25.8	105	26.1	98.3	24.3
	11.0	9.8	110	24.8	110	25.4	110	25.9	109	25.9	106	24.9	98.3	22.9
	13.0	11.8	116	25.3	116	25.8	113	25.4	109	24.4	106	23.4	98.3	21.6
	15.0	13.7	122	25.8	120	25.8	113	23.9	109	23.0	106	22.1	98.3	20.4
110 (831)	-19.8	-20.0	54.6	16.1	54.4	17.1	54.2	18.2	54.1	18.7	54.0	19.2	53.9	20.2
	-18.8	-19.0	55.6	16.5	55.4	17.5	55.2	18.5	55.1	19.0	55.0	19.5	54.8	20.5
	-16.7	-17.0	57.7	17.2	57.5	18.1	57.4	19.1	57.3	19.6	57.2	20.1	57.0	21.1
	-13.7	-15.0	60.1	17.9	59.9	18.8	59.8	19.8	59.7	20.2	59.6	20.7	59.4	21.6
	-11.8	-13.0	62.8	18.6	62.6	19.5	62.4	20.4	62.3	20.8	62.2	21.3	62.0	22.2
	-9.8	-11.0	65.6	19.3	65.5	20.2	65.3	21.0	65.2	21.5	65.1	21.9	64.9	22.8
	-9.5	-10.0	67.2	19.7	67.0	20.5	66.8	21.4	66.7	21.8	66.6	22.2	66.5	23.0
	-8.5	-9.1	68.6	20.0	68.4	20.8	68.3	21.7	68.2	22.1	68.1	22.5	67.9	23.3
	-7.0	-7.6	71.1	20.6	70.9	21.3	70.7	22.1	70.7	22.5	70.6	22.9	70.4	23.7
	-5.0	-5.6	74.6	21.2	74.5	22.0	74.3	22.7	74.2	23.1	74.1	23.5	73.9	24.2
	-3.0	-3.7	78.2	21.9	78.1	22.6	77.9	23.3	77.8	23.6	77.7	24.0	77.5	24.7
	0.0	-0.7	84.3	22.8	84.2	23.5	84.0	24.1	83.9	24.5	83.8	24.8	83.6	25.4
	3.0	2.2	90.8	23.7	90.6	24.3	90.4	24.9	90.3	25.2	90.2	25.5	90.0	26.1
	5.0	4.1	95.3	24.2	95.1	24.8	94.9	25.4	94.8	25.6	94.7	25.9	90.1	24.6
	7.0	6.0	100.0	24.7	99.8	25.3	99.6	25.8	99.5	26.1	96.8	25.3	90.1	23.2
	9.0	7.9	105	25.2	105	25.7	103	25.8	100	24.8	96.8	23.8	90.1	21.9
	11.0	9.8	110	25.6	110	26.1	103	24.3	100	23.4	96.8	22.5	90.1	20.7
	13.0	11.8	116	26.1	110	24.6	103	22.9	100	22.0	96.8	21.2	90.1	19.5
	15.0	13.7	117	24.9	110	23.2	103	21.6	100	20.8	96.8	20.0	90.1	18.5

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (755)	-19.8	-20.0	54.3	17.8	54.1	18.7	54.0	19.6	53.9	20.1	53.8	20.6	53.6	21.5
	-18.8	-19.0	55.3	18.1	55.1	19.0	54.9	19.9	54.9	20.4	54.8	20.8	54.6	21.8
	-16.7	-17.0	57.4	18.7	57.3	19.6	57.1	20.5	57.0	20.9	56.9	21.4	56.8	22.3
	-13.7	-15.0	59.8	19.4	59.7	20.2	59.5	21.1	59.4	21.5	59.3	21.9	59.2	22.8
	-11.8	-13.0	62.5	20.0	62.3	20.9	62.1	21.7	62.1	22.1	62.0	22.5	61.8	23.3
	-9.8	-11.0	65.4	20.7	65.2	21.5	65.0	22.3	64.9	22.6	64.9	23.0	64.7	23.8
	-9.5	-10.0	66.9	21.0	66.7	21.8	66.6	22.5	66.5	22.9	66.4	23.3	66.2	24.1
	-8.5	-9.1	68.3	21.3	68.2	22.1	68.0	22.8	67.9	23.2	67.8	23.5	67.7	24.3
	-7.0	-7.6	70.8	21.8	70.7	22.5	70.5	23.2	70.4	23.6	70.3	23.9	70.2	24.7
	-5.0	-5.6	74.4	22.4	74.2	23.1	74.0	23.8	73.9	24.1	73.9	24.5	73.7	25.1
	-3.0	-3.7	77.9	23.0	77.8	23.7	77.6	24.3	77.5	24.6	77.5	24.9	77.3	25.6
	0.0	-0.7	84.1	23.9	83.9	24.5	83.7	25.1	83.6	25.4	83.6	25.7	81.9	25.5
	3.0	2.2	90.5	24.6	90.3	25.2	90.2	25.8	90.1	26.0	88.0	25.4	81.9	23.3
	5.0	4.1	95.0	25.1	94.8	25.7	94.0	25.9	91.0	24.9	88.0	23.9	81.9	22.0
	7.0	6.0	99.7	25.6	99.5	26.1	94.0	24.4	91.0	23.5	88.0	22.6	81.9	20.8
	9.0	7.9	105	26.0	100	24.8	94.0	23.0	91.0	22.1	88.0	21.3	81.9	19.6
	11.0	9.8	106	25.1	100	23.4	94.0	21.7	91.0	20.9	88.0	20.1	81.9	18.6
	13.0	11.8	106	23.6	100	22.0	94.0	20.5	91.0	19.7	88.0	19.0	81.9	17.5
	15.0	13.7	106	22.3	100	20.8	94.0	19.4	91.0	18.7	88.0	18.0	81.9	16.6
90 (680)	-19.8	-20.0	54.0	19.4	53.9	20.3	53.7	21.1	53.6	21.5	53.6	21.9	53.4	22.8
	-18.8	-19.0	55.0	19.7	54.8	20.5	54.7	21.4	54.6	21.8	54.5	22.2	54.4	23.0
	-16.7	-17.0	57.1	20.3	57.0	21.1	56.8	21.9	56.8	22.3	56.7	22.7	56.5	23.5
	-13.7	-15.0	59.5	20.9	59.4	21.6	59.2	22.4	59.2	22.8	59.1	23.2	58.9	23.9
	-11.8	-13.0	62.2	21.5	62.0	22.2	61.9	22.9	61.8	23.3	61.7	23.7	61.6	24.4
	-9.8	-11.0	65.1	22.1	64.9	22.8	64.8	23.5	64.7	23.8	64.6	24.2	64.5	24.9
	-9.5	-10.0	66.6	22.4	66.5	23.0	66.3	23.7	66.2	24.1	66.2	24.4	66.0	25.1
	-8.5	-9.1	68.0	22.6	67.9	23.3	67.7	24.0	67.7	24.3	67.6	24.6	67.4	25.3
	-7.0	-7.6	70.5	23.1	70.4	23.7	70.2	24.3	70.2	24.7	70.1	25.0	69.9	25.6
	-5.0	-5.6	74.1	23.6	73.9	24.2	73.8	24.8	73.7	25.1	73.6	25.5	73.5	26.1
	-3.0	-3.7	77.7	24.1	77.5	24.7	77.4	25.3	77.3	25.6	77.2	25.9	73.7	24.7
	0.0	-0.7	83.8	24.9	83.6	25.5	83.5	26.0	81.9	25.5	79.2	24.5	73.7	22.5
	3.0	2.2	90.2	25.6	90.0	26.1	84.6	24.2	81.9	23.3	79.2	22.4	73.7	20.6
	5.0	4.1	94.7	26.0	90.0	24.6	84.6	22.8	81.9	22.0	79.2	21.1	73.7	19.5
	7.0	6.0	95.5	24.9	90.0	23.2	84.6	21.5	81.9	20.7	79.2	20.0	73.7	18.4
	9.0	7.9	95.5	23.4	90.0	21.9	84.6	20.3	81.9	19.6	79.2	18.9	73.7	17.4
	11.0	9.8	95.5	22.1	90.0	20.7	84.6	19.2	81.9	18.5	79.2	17.9	73.7	16.5
	13.0	11.8	95.5	20.8	90.0	19.5	84.6	18.2	81.9	17.5	79.2	16.9	73.7	15.6
	15.0	13.7	95.5	19.7	90.0	18.4	84.6	17.2	81.9	16.6	79.2	16.0	73.7	14.8
80 (604)	-19.8	-20.0	53.7	21.1	53.6	21.8	53.4	22.6	53.4	22.9	53.3	23.3	53.2	24.1
	-18.8	-19.0	54.7	21.3	54.6	22.0	54.4	22.8	54.4	23.2	54.3	23.5	54.2	24.3
	-16.7	-17.0	56.9	21.8	56.7	22.5	56.6	23.2	56.5	23.6	56.5	24.0	56.3	24.7
	-13.7	-15.0	59.3	22.4	59.1	23.0	59.0	23.7	58.9	24.1	58.9	24.4	58.7	25.1
	-11.8	-13.0	61.9	22.9	61.8	23.5	61.6	24.2	61.6	24.5	61.5	24.8	61.4	25.5
	-9.8	-11.0	64.8	23.4	64.6	24.0	64.5	24.7	64.4	25.0	64.4	25.3	64.2	25.9
	-9.5	-10.0	66.3	23.7	66.2	24.3	66.0	24.9	66.0	25.2	65.9	25.5	65.5	26.0
	-8.5	-9.1	67.7	23.9	67.6	24.5	67.5	25.1	67.4	25.4	67.3	25.7	65.5	25.3
	-7.0	-7.6	70.2	24.3	70.1	24.9	70.0	25.4	69.9	25.7	69.8	26.0	65.5	24.2
	-5.0	-5.6	73.8	24.8	73.6	25.4	73.5	25.9	72.8	25.8	70.4	24.8	65.5	22.8
	-3.0	-3.7	77.4	25.3	77.2	25.8	75.2	25.3	72.8	24.3	70.4	23.4	65.5	21.5
	0.0	-0.7	83.5	26.0	80.0	24.8	75.2	23.1	72.8	22.2	70.4	21.3	65.5	19.6
	3.0	2.2	84.9	24.3	80.0	22.7	75.2	21.1	72.8	20.3	70.4	19.5	65.5	18.0
	5.0	4.1	84.9	22.9	80.0	21.4	75.2	19.9	72.8	19.2	70.4	18.5	65.5	17.1
	7.0	6.0	84.9	21.6	80.0	20.2	75.2	18.8	72.8	18.1	70.4	17.5	65.5	16.2
	9.0	7.9	84.9	20.4	80.0	19.1	75.2	17.8	72.8	17.2	70.4	16.5	65.5	15.3
	11.0	9.8	84.9	19.3	80.0	18.1	75.2	16.9	72.8	16.3	70.4	15.7	65.5	14.5
	13.0	11.8	84.9	18.2	80.0	17.1	75.2	15.9	72.8	15.4	70.4	14.8	65.5	13.8
	15.0	13.7	84.9	17.3	80.0	16.2	75.2	15.1	72.8	14.6	70.4	14.1	65.5	13.1

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (529)	-19.8	-20.0	53.4	22.7	53.3	23.4	53.2	24.0	53.1	24.4	53.1	24.7	53.0	25.3				
	-18.8	-19.0	54.4	22.9	54.3	23.6	54.2	24.2	54.1	24.5	54.1	24.9	53.9	25.5				
	-16.7	-17.0	56.6	23.4	56.4	24.0	56.3	24.6	56.3	24.9	56.2	25.2	56.1	25.9				
	-13.7	-15.0	59.0	23.8	58.8	24.4	58.7	25.0	58.7	25.3	58.6	25.6	57.3	25.4				
	-11.8	-13.0	61.6	24.3	61.5	24.9	61.4	25.5	61.3	25.7	61.3	26.0	57.3	24.1				
	-9.8	-11.0	64.5	24.8	64.4	25.3	64.3	25.9	63.7	25.8	61.6	24.8	57.3	22.8				
	-9.5	-10.0	66.0	25.0	65.9	25.5	65.8	26.1	63.7	25.1	61.6	24.1	57.3	22.1				
	-8.5	-9.1	67.5	25.2	67.3	25.7	65.8	25.4	63.7	24.4	61.6	23.5	57.3	21.6				
	-7.0	-7.6	69.9	25.6	69.8	26.1	65.8	24.3	63.7	23.4	61.6	22.4	57.3	20.7				
	-5.0	-5.6	73.5	26.0	70.0	24.6	65.8	22.9	63.7	22.0	61.6	21.2	57.3	19.5				
	-3.0	-3.7	74.3	24.9	70.0	23.2	65.8	21.6	63.7	20.8	61.6	20.0	57.3	18.5				
	0.0	-0.7	74.3	22.7	70.0	21.2	65.8	19.7	63.7	19.0	61.6	18.3	57.3	16.9				
	3.0	2.2	74.3	20.8	70.0	19.4	65.8	18.1	63.7	17.5	61.6	16.8	57.3	15.6				
	5.0	4.1	74.3	19.6	70.0	18.4	65.8	17.1	63.7	16.5	61.6	15.9	57.3	14.8				
	7.0	6.0	74.3	18.6	70.0	17.4	65.8	16.2	63.7	15.7	61.6	15.1	57.3	14.0				
	9.0	7.9	74.3	17.6	70.0	16.5	65.8	15.4	63.7	14.9	61.6	14.3	57.3	13.3				
	11.0	9.8	74.3	16.6	70.0	15.6	65.8	14.6	63.7	14.1	61.6	13.6	57.3	12.6				
	13.0	11.8	74.3	15.7	70.0	14.8	65.8	13.8	63.7	13.4	61.6	12.9	57.3	12.0				
	15.0	13.7	74.3	14.9	70.0	14.0	65.8	13.2	63.7	12.7	61.6	12.3	57.3	11.4				
60 (453)	-19.8	-20.0	53.1	24.4	53.0	24.9	52.9	25.5	52.9	25.8	52.8	26.0	49.2	23.9				
	-18.8	-19.0	54.1	24.5	54.0	25.1	53.9	25.7	53.9	25.9	52.8	25.4	49.2	23.3				
	-16.7	-17.0	56.3	24.9	56.2	25.5	56.1	26.0	54.6	25.2	52.8	24.2	49.2	22.3				
	-13.7	-15.0	58.7	25.3	58.6	25.8	56.4	24.9	54.6	24.0	52.8	23.0	49.2	21.2				
	-11.8	-13.0	61.3	25.7	60.0	25.4	56.4	23.6	54.6	22.7	52.8	21.8	49.2	20.1				
	-9.8	-11.0	63.6	25.8	60.0	24.0	56.4	22.3	54.6	21.5	52.8	20.7	49.2	19.1				
	-9.5	-10.0	63.6	25.1	60.0	23.4	56.4	21.7	54.6	20.9	52.8	20.1	49.2	18.5				
	-8.5	-9.1	63.6	24.4	60.0	22.8	56.4	21.2	54.6	20.4	52.8	19.6	49.2	18.1				
	-7.0	-7.6	63.6	23.3	60.0	21.8	56.4	20.3	54.6	19.5	52.8	18.8	49.2	17.4				
	-5.0	-5.6	63.6	22.0	60.0	20.5	56.4	19.1	54.6	18.4	52.8	17.8	49.2	16.4				
	-3.0	-3.7	63.6	20.8	60.0	19.4	56.4	18.1	54.6	17.5	52.8	16.8	49.2	15.6				
	0.0	-0.7	63.6	19.0	60.0	17.8	56.4	16.6	54.6	16.0	52.8	15.5	49.2	14.3				
	3.0	2.2	63.6	17.5	60.0	16.4	56.4	15.3	54.6	14.8	52.8	14.3	49.2	13.2				
	5.0	4.1	63.6	16.5	60.0	15.5	56.4	14.5	54.6	14.0	52.8	13.5	49.2	12.6				
	7.0	6.0	63.6	15.7	60.0	14.7	56.4	13.8	54.6	13.3	52.8	12.9	49.2	12.0				
	9.0	7.9	63.6	14.8	60.0	14.0	56.4	13.1	54.6	12.6	52.8	12.2	49.2	11.4				
	11.0	9.8	63.6	14.1	60.0	13.3	56.4	12.4	54.6	12.0	52.8	11.6	49.2	10.8				
	13.0	11.8	63.6	13.4	60.0	12.6	56.4	11.8	54.6	11.4	52.8	11.1	49.2	10.3				
	15.0	13.7	63.6	12.7	60.0	12.0	56.4	11.3	54.6	10.9	52.8	10.5	49.2	9.9				
50 (378)	-19.8	-20.0	52.8	26.0	50.0	24.4	47.0	22.6	45.5	21.8	44.0	21.0	41.0	19.3				
	-18.8	-19.0	53.0	25.6	50.0	23.8	47.0	22.1	45.5	21.3	44.0	20.5	41.0	18.9				
	-16.7	-17.0	53.0	24.4	50.0	22.7	47.0	21.1	45.5	20.4	44.0	19.6	41.0	18.1				
	-13.7	-15.0	53.0	23.2	50.0	21.6	47.0	20.1	45.5	19.4	44.0	18.7	41.0	17.2				
	-11.8	-13.0	53.0	22.0	50.0	20.5	47.0	19.1	45.5	18.4	44.0	17.7	41.0	16.4				
	-9.8	-11.0	53.0	20.8	50.0	19.4	47.0	18.1	45.5	17.5	44.0	16.8	41.0	15.6				
	-9.5	-10.0	53.0	20.2	50.0	18.9	47.0	17.6	45.5	17.0	44.0	16.4	41.0	15.2				
	-8.5	-9.1	53.0	19.7	50.0	18.5	47.0	17.2	45.5	16.6	44.0	16.0	41.0	14.8				
	-7.0	-7.6	53.0	18.9	50.0	17.7	47.0	16.5	45.5	15.9	44.0	15.4	41.0	14.2				
	-5.0	-5.6	53.0	17.9	50.0	16.7	47.0	15.6	45.5	15.1	44.0	14.6	41.0	13.5				
	-3.0	-3.7	53.0	16.9	50.0	15.9	47.0	14.8	45.5	14.3	44.0	13.8	41.0	12.8				
	0.0	-0.7	53.0	15.5	50.0	14.6	47.0	13.7	45.5	13.2	44.0	12.8	41.0	11.9				
	3.0	2.2	53.0	14.3	50.0	13.5	47.0	12.6	45.5	12.2	44.0	11.8	41.0	11.0				
	5.0	4.1	53.0	13.6	50.0	12.8	47.0	12.0	45.5	11.6	44.0	11.2	41.0	10.5				
	7.0	6.0	53.0	12.9	50.0	12.2	47.0	11.4	45.5	11.1	44.0	10.7	41.0	10.0				
	9.0	7.9	53.0	12.3	50.0	11.6	47.0	10.9	45.5	10.5	44.0	10.2	41.0	9.54				
	11.0	9.8	53.0	11.7	50.0	11.0	47.0	10.4	45.5	10.1	44.0	9.7	41.0	9.12				
	13.0	11.8	53.0	11.1	50.0	10.5	47.0	9.9	45.5	9.6	44.0	9.29	41.0	8.70				
	15.0	13.7	53.0	10.6	50.0	10.0	47.0	9.4	45.5	9.16	44.0	8.88	41.0	8.33				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

14

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1040)	-19.8	-20.0	61.3	15.6	61.1	16.9	60.9	18.2	60.8	18.8	60.7	19.48	60.4	20.77
	-18.8	-19.0	62.4	16.0	62.2	17.3	62.0	18.6	61.9	19.2	61.8	19.84	61.5	21.10
	-16.7	-17.0	64.8	16.9	64.6	18.1	64.4	19.4	64.3	20.0	64.2	20.57	63.9	21.79
	-13.7	-15.0	67.5	17.8	67.3	19.0	67.1	20.2	67.0	20.7	66.8	21.3	66.6	22.5
	-11.8	-13.0	70.5	18.7	70.2	19.9	70.0	21.0	69.9	21.5	69.8	22.1	69.6	23.2
	-9.8	-11.0	73.7	19.6	73.5	20.7	73.2	21.8	73.1	22.3	73.0	22.8	72.8	23.9
	-9.5	-10.0	75.4	20.1	75.2	21.1	74.9	22.2	74.8	22.7	74.7	23.2	74.5	24.3
	-8.5	-9.1	77.0	20.5	76.8	21.5	76.5	22.5	76.4	23.0	76.3	23.5	76.1	24.6
	-7.0	-7.6	79.8	21.2	79.6	22.1	79.3	23.1	79.2	23.6	79.1	24.1	78.9	25.1
	-5.0	-5.6	83.7	22.0	83.5	22.9	83.3	23.9	83.2	24.3	83.0	24.8	82.8	25.7
	-3.0	-3.7	87.7	22.8	87.5	23.7	87.3	24.6	87.2	25.0	87.0	25.5	86.8	26.3
	0.0	-0.7	94.6	24.0	94.3	24.8	94.1	25.6	94.0	26.0	93.9	26.4	93.6	27.3
	3.0	2.2	101.7	25.0	101.5	25.8	101.3	26.6	101.1	27.0	101.0	27.3	100.8	28.1
	5.0	4.1	106.7	25.7	106.5	26.4	106.3	27.2	106.2	27.5	106.0	27.9	105.8	28.6
	7.0	6.0	112	26.3	112	27.0	112	27.7	111	28.1	111	28.4	111	29.1
	9.0	7.9	117	26.9	117	27.6	117	28.2	117	28.6	117	28.9	113	28.3
	11.0	9.8	123	27.5	123	28.1	123	28.7	123	29.0	122	29.0	113	26.6
	13.0	11.8	130	28.0	129	28.6	129	29.2	126	28.4	122	27.3	113	25.0
	15.0	13.7	136	28.5	136	29.1	130	27.9	126	26.8	122	25.7	113	23.6
120 (960)	-19.8	-20.0	61.0	17.3	60.8	18.5	60.6	19.7	60.5	20.3	60.4	20.9	60.2	22.1
	-18.8	-19.0	62.1	17.7	61.9	18.9	61.7	20.1	61.6	20.7	61.5	21.3	61.3	22.4
	-16.7	-17.0	64.5	18.6	64.3	19.7	64.1	20.8	64.0	21.4	63.9	21.9	63.7	23.1
	-13.7	-15.0	67.2	19.4	67.0	20.5	66.8	21.6	66.7	22.1	66.6	22.6	66.4	23.7
	-11.8	-13.0	70.2	20.2	70.0	21.3	69.7	22.3	69.6	22.8	69.5	23.3	69.3	24.4
	-9.8	-11.0	73.4	21.1	73.2	22.1	73.0	23.0	72.9	23.5	72.7	24.0	72.5	25.0
	-9.5	-10.0	75.1	21.5	74.9	22.5	74.7	23.4	74.6	23.9	74.5	24.4	74.2	25.3
	-8.5	-9.1	76.7	21.9	76.5	22.8	76.3	23.7	76.2	24.2	76.1	24.7	75.8	25.6
	-7.0	-7.6	79.5	22.5	79.3	23.4	79.0	24.3	78.9	24.7	78.8	25.2	78.6	26.1
	-5.0	-5.6	83.4	23.3	83.2	24.1	83.0	25.0	82.9	25.4	82.8	25.9	82.6	26.7
	-3.0	-3.7	87.4	24.0	87.2	24.8	87.0	25.6	86.9	26.0	86.8	26.5	86.6	27.3
	0.0	-0.7	94.2	25.1	94.0	25.8	93.8	26.6	93.7	27.0	93.6	27.4	93.4	28.1
	3.0	2.2	101.4	26.1	101.2	26.8	101.0	27.5	100.9	27.8	100.8	28.2	100.6	28.9
	5.0	4.1	106.4	26.7	106.2	27.4	106.0	28.0	105.9	28.4	105.8	28.7	104.6	28.9
	7.0	6.0	112	27.3	111	27.9	111	28.5	111	28.8	111	29.2	105	27.2
	9.0	7.9	117	27.8	117	28.4	117	29.0	116	29.1	112	27.9	105	25.7
	11.0	9.8	123	28.3	123	28.9	120	28.5	116	27.4	112	26.3	105	24.2
	13.0	11.8	129	28.8	128	28.9	120	26.8	116	25.8	112	24.8	105	22.8
	15.0	13.7	135	29.3	128	27.3	120	25.3	116	24.4	112	23.4	105	21.5
110 (880)	-19.8	-20.0	60.7	19.1	60.5	20.2	60.3	21.3	60.2	21.8	60.1	22.4	59.9	23.5
	-18.8	-19.0	61.8	19.5	61.6	20.5	61.4	21.6	61.3	22.1	61.2	22.7	61.1	23.8
	-16.7	-17.0	64.2	20.2	64.0	21.2	63.8	22.3	63.7	22.8	63.6	23.3	63.5	24.3
	-13.7	-15.0	66.9	21.0	66.7	22.0	66.5	23.0	66.4	23.4	66.3	23.9	66.1	24.9
	-11.8	-13.0	69.9	21.8	69.7	22.7	69.5	23.6	69.4	24.1	69.3	24.6	69.1	25.5
	-9.8	-11.0	73.1	22.5	72.9	23.4	72.7	24.3	72.6	24.8	72.5	25.2	72.3	26.1
	-9.5	-10.0	74.8	22.9	74.6	23.8	74.4	24.7	74.3	25.1	74.2	25.5	74.0	26.4
	-8.5	-9.1	76.4	23.2	76.2	24.1	76.0	25.0	75.9	25.4	75.8	25.8	75.6	26.7
	-7.0	-7.6	79.2	23.8	79.0	24.6	78.8	25.5	78.7	25.9	78.6	26.3	78.4	27.1
	-5.0	-5.6	83.1	24.5	82.9	25.3	82.7	26.1	82.6	26.5	82.5	26.9	82.3	27.7
	-3.0	-3.7	87.1	25.2	86.9	25.9	86.7	26.7	86.6	27.1	86.5	27.4	86.3	28.2
	0.0	-0.7	93.9	26.2	93.7	26.9	93.5	27.6	93.4	27.9	93.4	28.3	93.2	29.0
	3.0	2.2	101.1	27.1	100.9	27.7	100.7	28.4	100.6	28.7	100.5	29.0	95.9	27.6
	5.0	4.1	106.1	27.7	105.9	28.3	105.7	28.9	105.6	29.2	102.9	28.4	95.9	26.0
	7.0	6.0	111	28.2	111	28.8	110	28.9	106	27.8	103	26.7	95.9	24.5
	9.0	7.9	117	28.7	117	29.2	110	27.3	106	26.2	103	25.2	95.9	23.1
	11.0	9.8	123	29.2	117	27.7	110	25.7	106	24.7	103	23.8	95.9	21.9
	13.0	11.8	124	27.9	117	26.0	110	24.2	106	23.3	103	22.4	95.9	20.6
	15.0	13.7	124	26.4	117	24.6	110	22.8	106	22.0	103	21.2	95.9	19.5

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (800)	-19.8	-20.0	60.4	20.8	60.2	21.8	60.1	22.8	60.0	23.3	59.9	23.8	59.7	24.8
	-18.8	-19.0	61.5	21.2	61.3	22.1	61.2	23.1	61.1	23.6	61.0	24.1	60.8	25.1
	-16.7	-17.0	63.9	21.9	63.7	22.8	63.6	23.7	63.5	24.2	63.4	24.7	63.2	25.6
	-13.7	-15.0	66.6	22.6	66.4	23.5	66.2	24.3	66.2	24.8	66.1	25.2	65.9	26.1
	-11.8	-13.0	69.5	23.3	69.4	24.1	69.2	25.0	69.1	25.4	69.0	25.8	68.8	26.7
	-9.8	-11.0	72.8	24.0	72.6	24.8	72.4	25.6	72.3	26.0	72.2	26.4	72.1	27.2
	-9.5	-10.0	74.5	24.3	74.3	25.1	74.1	25.9	74.0	26.3	73.9	26.7	73.8	27.5
	-8.5	-9.1	76.1	24.6	75.9	25.4	75.7	26.2	75.6	26.6	75.5	27.0	75.4	27.7
	-7.0	-7.6	78.9	25.1	78.7	25.9	78.5	26.6	78.4	27.0	78.3	27.4	78.2	28.1
	-5.0	-5.6	82.8	25.8	82.6	26.5	82.5	27.2	82.4	27.6	82.3	27.9	82.1	28.7
	-3.0	-3.7	86.8	26.4	86.6	27.1	86.5	27.8	86.4	28.1	86.3	28.4	86.1	29.1
	0.0	-0.7	93.6	27.3	93.4	27.9	93.3	28.6	93.2	28.9	93.1	29.2	87.1	27.0
	3.0	2.2	100.8	28.1	100.6	28.7	100.0	29.1	96.8	28.0	93.6	26.8	87.1	24.7
	5.0	4.1	105.8	28.6	105.6	29.2	100.0	27.4	96.8	26.3	93.6	25.3	87.1	23.3
	7.0	6.0	111	29.1	106	27.8	100	25.8	96.8	24.8	93.6	23.8	87.1	21.9
	9.0	7.9	113	28.1	106	26.2	100	24.3	96.8	23.4	93.6	22.5	87.1	20.7
	11.0	9.8	113	26.5	106	24.7	100	23.0	96.8	22.1	93.6	21.3	87.1	19.6
	13.0	11.8	113	24.9	106	23.3	100	21.6	96.8	20.8	93.6	20.1	87.1	18.5
	15.0	13.7	113	23.5	106	22.0	100	20.5	96.8	19.7	93.6	19.0	87.1	17.6
90 (720)	-19.8	-20.0	60.1	22.6	59.9	23.5	59.8	24.4	59.7	24.8	59.6	25.3	59.5	26.2
	-18.8	-19.0	61.2	22.9	61.0	23.8	60.9	24.6	60.8	25.1	60.7	25.5	60.6	26.4
	-16.7	-17.0	63.6	23.5	63.5	24.3	63.3	25.2	63.2	25.6	63.1	26.0	63.0	26.9
	-13.7	-15.0	66.3	24.1	66.1	24.9	66.0	25.7	65.9	26.1	65.8	26.6	65.7	27.4
	-11.8	-13.0	69.2	24.8	69.1	25.5	68.9	26.3	68.8	26.7	68.8	27.1	68.6	27.9
	-9.8	-11.0	72.5	25.4	72.3	26.1	72.1	26.9	72.1	27.2	72.0	27.6	71.8	28.3
	-9.5	-10.0	74.2	25.7	74.0	26.4	73.8	27.1	73.8	27.5	73.7	27.9	73.5	28.6
	-8.5	-9.1	75.8	26.0	75.6	26.7	75.4	27.4	75.4	27.7	75.3	28.1	75.1	28.8
	-7.0	-7.6	78.5	26.4	78.4	27.1	78.2	27.8	78.1	28.1	78.1	28.5	77.9	29.2
	-5.0	-5.6	82.5	27.0	82.3	27.7	82.2	28.3	82.1	28.7	82.0	29.0	78.4	27.7
	-3.0	-3.7	86.5	27.6	86.3	28.2	86.2	28.8	86.1	29.1	84.2	28.5	78.4	26.1
	0.0	-0.7	93.3	28.4	93.2	29.0	90.0	28.1	87.1	27.0	84.2	25.9	78.4	23.8
	3.0	2.2	100.5	29.2	95.8	27.6	90.0	25.6	87.1	24.6	84.2	23.7	78.4	21.8
	5.0	4.1	101.6	27.9	95.8	26.0	90.0	24.1	87.1	23.2	84.2	22.3	78.4	20.6
	7.0	6.0	102	26.3	95.8	24.5	90.0	22.8	87.1	21.9	84.2	21.1	78.4	19.5
	9.0	7.9	102	24.8	95.8	23.1	90.0	21.5	87.1	20.7	84.2	19.9	78.4	18.4
	11.0	9.8	102	23.4	95.8	21.8	90.0	20.3	87.1	19.6	84.2	18.9	78.4	17.5
	13.0	11.8	102	22.0	95.8	20.6	90.0	19.2	87.1	18.5	84.2	17.8	78.4	16.5
	15.0	13.7	102	20.8	95.8	19.5	90.0	18.2	87.1	17.6	84.2	16.9	78.4	15.7
80 (640)	-19.8	-20.0	59.8	24.3	59.7	25.1	59.5	25.9	59.4	26.3	59.4	26.7	59.2	27.5
	-18.8	-19.0	60.9	24.6	60.8	25.4	60.6	26.2	60.5	26.5	60.5	26.9	60.3	27.7
	-16.7	-17.0	63.3	25.1	63.2	25.9	63.0	26.6	63.0	27.0	62.9	27.4	62.7	28.1
	-13.7	-15.0	66.0	25.7	65.8	26.4	65.7	27.1	65.6	27.5	65.6	27.9	65.4	28.6
	-11.8	-13.0	68.9	26.3	68.8	27.0	68.6	27.6	68.6	28.0	68.5	28.3	68.4	29.0
	-9.8	-11.0	72.1	26.8	72.0	27.5	71.9	28.1	71.8	28.5	71.7	28.8	69.7	28.3
	-9.5	-10.0	73.9	27.1	73.7	27.8	73.6	28.4	73.5	28.7	73.4	29.0	69.7	27.4
	-8.5	-9.1	75.5	27.4	75.3	28.0	75.2	28.6	75.1	28.9	74.9	29.1	69.7	26.7
	-7.0	-7.6	78.2	27.8	78.1	28.4	78.0	29.0	77.4	29.0	74.9	27.8	69.7	25.6
	-5.0	-5.6	82.2	28.3	82.0	28.9	80.0	28.4	77.4	27.3	74.9	26.2	69.7	24.1
	-3.0	-3.7	86.2	28.8	85.1	28.8	80.0	26.8	77.4	25.7	74.9	24.7	69.7	22.7
	0.0	-0.7	90.3	28.2	85.1	26.2	80.0	24.4	77.4	23.5	74.9	22.6	69.7	20.8
	3.0	2.2	90.3	25.7	85.1	24.0	80.0	22.3	77.4	21.5	74.9	20.7	69.7	19.1
	5.0	4.1	90.3	24.2	85.1	22.6	80.0	21.1	77.4	20.3	74.9	19.5	69.7	18.0
	7.0	6.0	90.3	22.9	85.1	21.4	80.0	19.9	77.4	19.2	74.9	18.5	69.7	17.1
	9.0	7.9	90.3	21.6	85.1	20.2	80.0	18.8	77.4	18.2	74.9	17.5	69.7	16.2
	11.0	9.8	90.3	20.4	85.1	19.1	80.0	17.8	77.4	17.2	74.9	16.6	69.7	15.4
	13.0	11.8	90.3	19.3	85.1	18.1	80.0	16.9	77.4	16.3	74.9	15.7	69.7	14.6
	15.0	13.7	90.3	18.3	85.1	17.1	80.0	16.0	77.4	15.5	74.9	14.9	69.7	13.8

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0			18.0			20.0			21.0			22.0			24.0	
			TC	PI		TC	PI		TC	PI		TC	PI		TC	PI		TC	PI
	°CDB	°CWB	kW	kW		kW	kW		kW	kW		kW	kW		kW	kW		kW	kW
70 (560)	-19.8	-20.0	59.5	26.1		59.4	26.8		59.2	27.5		59.2	27.8		59.1	28.2		59.0	28.9
	-18.8	-19.0	60.6	26.3		60.5	27.0		60.3	27.7		60.3	28.0		60.2	28.4		60.1	29.0
	-16.7	-17.0	63.0	26.8		62.9	27.4		62.7	28.1		62.7	28.4		62.6	28.8		61.0	28.3
	-13.7	-15.0	65.7	27.3		65.5	27.9		65.4	28.5		65.4	28.9		65.3	29.2		61.0	26.9
	-11.8	-13.0	68.6	27.8		68.5	28.4		68.4	29.0		67.8	28.9		65.5	27.7		61.0	25.5
	-9.8	-11.0	71.8	28.3		71.7	28.8		70.0	28.4		67.8	27.3		65.5	26.2		61.0	24.1
	-9.5	-10.0	73.5	28.5		73.4	29.1		70.0	27.6		67.8	26.5		65.5	25.5		61.0	23.4
	-8.5	-9.1	75.1	28.7		74.5	29.0		70.0	26.9		67.8	25.8		65.5	24.8		61.0	22.8
	-7.0	-7.6	77.9	29.1		74.5	27.7		70.0	25.7		67.8	24.7		65.5	23.7		61.0	21.8
	-5.0	-5.6	79.0	27.9		74.5	26.0		70.0	24.2		67.8	23.3		65.5	22.4		61.0	20.6
	-3.0	-3.7	79.0	26.3		74.5	24.6		70.0	22.8		67.8	22.0		65.5	21.2		61.0	19.5
	0.0	-0.7	79.0	24.0		74.5	22.4		70.0	20.9		67.8	20.1		65.5	19.4		61.0	17.9
	3.0	2.2	79.0	22.0		74.5	20.6		70.0	19.2		67.8	18.5		65.5	17.8		61.0	16.5
	5.0	4.1	79.0	20.8		74.5	19.4		70.0	18.1		67.8	17.5		65.5	16.9		61.0	15.6
	7.0	6.0	79.0	19.6		74.5	18.4		70.0	17.2		67.8	16.6		65.5	16.0		61.0	14.8
	9.0	7.9	79.0	18.6		74.5	17.4		70.0	16.3		67.8	15.7		65.5	15.2		61.0	14.1
	11.0	9.8	79.0	17.6		74.5	16.5		70.0	15.4		67.8	14.9		65.5	14.4		61.0	13.4
	13.0	11.8	79.0	16.6		74.5	15.6		70.0	14.6		67.8	14.1		65.5	13.6		61.0	12.7
	15.0	13.7	79.0	15.8		74.5	14.8		70.0	13.9		67.8	13.4		65.5	13.0		61.0	12.1
60 (480)	-19.8	-20.0	59.2	27.8		59.1	28.4		59.0	29.0		58.1	28.7		56.1	27.5		52.3	25.3
	-18.8	-19.0	60.3	28.0		60.2	28.6		60.0	29.1		58.1	28.0		56.1	26.9		52.3	24.7
	-16.7	-17.0	62.7	28.4		62.6	29.0		60.0	27.7		58.1	26.7		56.1	25.6		52.3	23.5
	-13.7	-15.0	65.4	28.9		63.9	28.4		60.0	26.3		58.1	25.3		56.1	24.3		52.3	22.4
	-11.8	-13.0	67.7	28.9		63.9	26.9		60.0	25.0		58.1	24.0		56.1	23.1		52.3	21.3
	-9.8	-11.0	67.7	27.3		63.9	25.4		60.0	23.6		58.1	22.7		56.1	21.9		52.3	20.2
	-9.5	-10.0	67.7	26.5		63.9	24.7		60.0	23.0		58.1	22.1		56.1	21.3		52.3	19.6
	-8.5	-9.1	67.7	25.8		63.9	24.1		60.0	22.4		58.1	21.5		56.1	20.7		52.3	19.1
	-7.0	-7.6	67.7	24.7		63.9	23.0		60.0	21.4		58.1	20.6		56.1	19.9		52.3	18.4
	-5.0	-5.6	67.7	23.3		63.9	21.7		60.0	20.2		58.1	19.5		56.1	18.8		52.3	17.4
	-3.0	-3.7	67.7	22.0		63.9	20.5		60.0	19.2		58.1	18.5		56.1	17.8		52.3	16.5
	0.0	-0.7	67.7	20.1		63.9	18.8		60.0	17.6		58.1	16.9		56.1	16.3		52.3	15.1
	3.0	2.2	67.7	18.5		63.9	17.3		60.0	16.2		58.1	15.6		56.1	15.1		52.3	14.0
	5.0	4.1	67.7	17.5		63.9	16.4		60.0	15.3		58.1	14.8		56.1	14.3		52.3	13.3
	7.0	6.0	67.7	16.6		63.9	15.5		60.0	14.6		58.1	14.1		56.1	13.6		52.3	12.6
	9.0	7.9	67.7	15.7		63.9	14.8		60.0	13.8		58.1	13.4		56.1	12.9		52.3	12.0
	11.0	9.8	67.7	14.9		63.9	14.0		60.0	13.2		58.1	12.7		56.1	12.3		52.3	11.5
	13.0	11.8	67.7	14.1		63.9	13.3		60.0	12.5		58.1	12.1		56.1	11.7		52.3	10.9
	15.0	13.7	67.7	13.4		63.9	12.7		60.0	11.9		58.1	11.5		56.1	11.2		52.3	10.4
50 (400)	-19.8	-20.0	56.4	27.7		53.2	25.8		50.0	23.9		48.4	23.0		46.8	22.2		43.6	20.4
	-18.8	-19.0	56.4	27.0		53.2	25.2		50.0	23.4		48.4	22.5		46.8	21.7		43.6	20.0
	-16.7	-17.0	56.4	25.8		53.2	24.0		50.0	22.4		48.4	21.5		46.8	20.7		43.6	19.1
	-13.7	-15.0	56.4	24.5		53.2	22.9		50.0	21.3		48.4	20.5		46.8	19.7		43.6	18.2
	-11.8	-13.0	56.4	23.2		53.2	21.7		50.0	20.2		48.4	19.5		46.8	18.8		43.6	17.3
	-9.8	-11.0	56.4	22.0		53.2	20.6		50.0	19.2		48.4	18.5		46.8	17.8		43.6	16.5
	-9.5	-10.0	56.4	21.4		53.2	20.0		50.0	18.7		48.4	18.0		46.8	17.3		43.6	16.0
	-8.5	-9.1	56.4	20.9		53.2	19.5		50.0	18.2		48.4	17.6		46.8	16.9		43.6	15.7
	-7.0	-7.6	56.4	20.0		53.2	18.7		50.0	17.5		48.4	16.9		46.8	16.3		43.6	15.1
	-5.0	-5.6	56.4	18.9		53.2	17.7		50.0	16.5		48.4	16.0		46.8	15.4		43.6	14.3
	-3.0	-3.7	56.4	17.9		53.2	16.8		50.0	15.7		48.4	15.2		46.8	14.6		43.6	13.6
	0.0	-0.7	56.4	16.4		53.2	15.4		50.0	14.5		48.4	14.0		46.8	13.5		43.6	12.6
	3.0	2.2	56.4	15.2		53.2	14.2		50.0	13.4		48.4	12.9		46.8	12.5		43.6	11.6
	5.0	4.1	56.4	14.4		53.2	13.5		50.0	12.7		48.4	12.3		46.8	11.9		43.6	11.1
	7.0	6.0	56.4	13.7		53.2	12.9		50.0	12.1		48.4	11.7		46.8	11.3		43.6	10.6
	9.0	7.9	56.4	13.0		53.2	12.2		50.0	11.5		48.4	11.2		46.8	10.8		43.6	10.1
	11.0	9.8	56.4	12.4		53.2	11.7		50.0	11.0		48.4	10.6		46.8	10.3		43.6	9.6
	13.0	11.8	56.4	11.7		53.2	11.1		50.0	10.5		48.4	10.1		46.8	9.8		43.6	9.20
	15.0	13.7	56.4	11.2		53.2	10.6		50.0	10.0		48.4	9.7		46.8	9.4		43.6	8.80

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

14

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1111)	-19.8	-20.0	62.1	14.5	61.9	15.9	61.6	17.3	61.5	18.0	61.4	18.7	61.1	20.2
	-18.8	-19.0	63.2	15.0	63.0	16.4	62.7	17.7	62.6	18.4	62.5	19.1	62.3	20.5
	-16.7	-17.0	65.7	15.9	65.4	17.3	65.2	18.6	65.0	19.3	64.9	19.9	64.7	21.3
	-13.7	-15.0	68.4	16.9	68.1	18.2	67.9	19.5	67.7	20.1	67.6	20.8	67.4	22.0
	-11.8	-13.0	71.3	17.9	71.1	19.1	70.8	20.4	70.7	21.0	70.6	21.6	70.4	22.8
	-9.8	-11.0	74.6	18.9	74.3	20.1	74.1	21.2	74.0	21.8	73.8	22.4	73.6	23.6
	-9.5	-10.0	76.3	19.4	76.1	20.5	75.8	21.7	75.7	22.2	75.6	22.8	75.3	24.0
	-8.5	-9.1	77.9	19.8	77.7	21.0	77.4	22.1	77.3	22.6	77.2	23.2	76.9	24.3
	-7.0	-7.6	80.7	20.6	80.5	21.6	80.2	22.7	80.1	23.2	80.0	23.8	79.8	24.8
	-5.0	-5.6	84.7	21.5	84.5	22.5	84.2	23.5	84.1	24.0	84.0	24.6	83.7	25.6
	-3.0	-3.7	88.7	22.4	88.5	23.3	88.3	24.3	88.1	24.8	88.0	25.3	87.8	26.2
	0.0	-0.7	96	23.7	95	24.6	95	25.4	95	25.9	95	26.3	95	27.2
	3.0	2.2	103	24.8	103	25.6	102	26.5	102	26.9	102	27.3	102	28.1
	5.0	4.1	108	25.5	108	26.3	107	27.1	107	27.5	107	27.9	107	28.7
	7.0	6.0	113	26.2	113	27.0	113	27.7	113	28.1	112	28.5	112	29.2
	9.0	7.9	119	26.9	119	27.6	118	28.3	118	28.7	118	29.0	118	29.7
	11.0	9.8	125	27.5	124	28.2	124	28.8	124	29.2	124	29.5	121	29.1
	13.0	11.8	131	28.1	131	28.7	130	29.4	130	29.7	130	29.8	121	27.4
	15.0	13.7	137	28.6	137	29.2	137	29.9	134	29.3	130	28.1	121	25.8
120 (1026)	-19.8	-20.0	61.8	16.4	61.6	17.7	61.3	19.0	61.2	19.7	61.1	20.3	60.9	21.6
	-18.8	-19.0	62.9	16.8	62.7	18.1	62.5	19.4	62.3	20.0	62.2	20.7	62.0	22.0
	-16.7	-17.0	65.3	17.7	65.1	19.0	64.9	20.2	64.8	20.8	64.7	21.4	64.4	22.7
	-13.7	-15.0	68.0	18.6	67.8	19.8	67.6	21.0	67.5	21.6	67.4	22.2	67.1	23.4
	-11.8	-13.0	71.0	19.6	70.8	20.7	70.6	21.8	70.4	22.4	70.3	22.9	70.1	24.1
	-9.8	-11.0	74.2	20.5	74.0	21.6	73.8	22.6	73.7	23.2	73.6	23.7	73.3	24.8
	-9.5	-10.0	76.0	20.9	75.7	22.0	75.5	23.0	75.4	23.6	75.3	24.1	75.1	25.1
	-8.5	-9.1	77.6	21.3	77.4	22.4	77.1	23.4	77.0	23.9	76.9	24.4	76.7	25.5
	-7.0	-7.6	80.4	22.0	80.2	23.0	79.9	24.0	79.8	24.5	79.7	25.0	79.5	26.0
	-5.0	-5.6	84.4	22.9	84.2	23.8	83.9	24.8	83.8	25.2	83.7	25.7	83.5	26.6
	-3.0	-3.7	88.4	23.7	88.2	24.6	88.0	25.5	87.9	25.9	87.7	26.4	87.5	27.3
	0.0	-0.7	95	24.9	95	25.7	95	26.5	95	26.9	95	27.3	94.4	28.2
	3.0	2.2	103	25.9	102	26.7	102	27.5	102	27.9	102	28.2	102	29.0
	5.0	4.1	108	26.6	107	27.3	107	28.1	107	28.4	107	28.8	107	29.5
	7.0	6.0	113	27.2	113	27.9	112	28.6	112	29.0	112	29.3	111	29.8
	9.0	7.9	118	27.8	118	28.5	118	29.2	118	29.5	118	29.8	111	28.0
	11.0	9.8	124	28.4	124	29.0	124	29.7	124	30.0	120	28.8	111	26.5
	13.0	11.8	131	29.0	130	29.6	128	29.3	124	28.2	120	27.1	111	24.9
	15.0	13.7	137	29.5	136	29.8	128	27.7	124	26.6	120	25.6	111	23.6
110 (941)	-19.8	-20.0	61.5	18.3	61.3	19.5	61.0	20.7	60.9	21.3	60.8	21.9	60.6	23.1
	-18.8	-19.0	62.6	18.7	62.4	19.9	62.2	21.1	62.1	21.6	62.0	22.2	61.7	23.4
	-16.7	-17.0	65.0	19.5	64.8	20.7	64.6	21.8	64.5	22.4	64.4	22.9	64.2	24.0
	-13.7	-15.0	67.7	20.4	67.5	21.5	67.3	22.5	67.2	23.1	67.1	23.6	66.9	24.7
	-11.8	-13.0	70.7	21.2	70.5	22.3	70.3	23.3	70.2	23.8	70.1	24.3	69.8	25.3
	-9.8	-11.0	73.9	22.1	73.7	23.0	73.5	24.0	73.4	24.5	73.3	25.0	73.1	26.0
	-9.5	-10.0	75.6	22.5	75.4	23.4	75.2	24.4	75.1	24.9	75.0	25.4	74.8	26.3
	-8.5	-9.1	77.3	22.8	77.1	23.8	76.8	24.7	76.7	25.2	76.6	25.7	76.4	26.6
	-7.0	-7.6	80.1	23.5	79.9	24.4	79.7	25.3	79.6	25.7	79.4	26.2	79.2	27.1
	-5.0	-5.6	84.1	24.3	83.8	25.1	83.6	26.0	83.5	26.4	83.4	26.8	83.2	27.7
	-3.0	-3.7	88.1	25.0	87.9	25.8	87.7	26.6	87.6	27.0	87.5	27.4	87.3	28.3
	0.0	-0.7	95	26.1	95	26.8	95	27.6	94	28.0	94.4	28.4	94.1	29.1
	3.0	2.2	102	27.1	102	27.8	102	28.5	102	28.8	102	29.2	101	29.9
	5.0	4.1	107	27.7	107	28.3	107	29.0	107	29.3	107	29.7	102	28.4
	7.0	6.0	113	28.3	112	28.9	112	29.5	112	29.8	110	29.2	102	26.8
	9.0	7.9	118	28.8	118	29.4	117	29.8	113	28.6	110	27.5	102	25.3
	11.0	9.8	124	29.3	124	29.9	117	28.1	113	27.0	110	26.0	102	23.9
	13.0	11.8	130	29.8	125	28.5	117	26.4	113	25.4	110	24.5	102	22.5
	15.0	13.7	132	28.8	125	26.9	117	25.0	113	24.0	110	23.1	102	21.3

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (855)	-19.8	-20.0	61.1	20.2	60.9	21.3	60.8	22.4	60.7	22.9	60.6	23.5	60.4	24.6
	-18.8	-19.0	62.2	20.6	62.1	21.7	61.9	22.7	61.8	23.3	61.7	23.8	61.5	24.9
	-16.7	-17.0	64.7	21.3	64.5	22.4	64.3	23.4	64.2	23.9	64.1	24.4	63.9	25.4
	-13.7	-15.0	67.4	22.1	67.2	23.1	67.0	24.1	66.9	24.5	66.8	25.0	66.6	26.0
	-11.8	-13.0	70.3	22.9	70.2	23.8	70.0	24.7	69.9	25.2	69.8	25.7	69.6	26.6
	-9.8	-11.0	73.6	23.6	73.4	24.5	73.2	25.4	73.1	25.9	73.0	26.3	72.8	27.2
	-9.5	-10.0	75.3	24.0	75.1	24.9	74.9	25.8	74.8	26.2	74.8	26.6	74.6	27.5
	-8.5	-9.1	76.9	24.4	76.7	25.2	76.6	26.1	76.5	26.5	76.4	26.9	76.2	27.8
	-7.0	-7.6	79.7	24.9	79.6	25.7	79.4	26.6	79.3	27.0	79.2	27.4	79.0	28.2
	-5.0	-5.6	83.7	25.6	83.5	26.4	83.3	27.2	83.3	27.6	83.2	28.0	83.0	28.8
	-3.0	-3.7	87.8	26.3	87.6	27.0	87.4	27.8	87.3	28.2	87.2	28.5	87.0	29.3
	0.0	-0.7	95	27.3	94	28.0	94.3	28.7	94.2	29.0	94.1	29.4	92.8	29.5
	3.0	2.2	102	28.2	102	28.8	102	29.5	101	29.8	100	29.3	92.8	26.9
	5.0	4.1	107	28.7	107	29.3	107	29.9	103	28.8	100	27.6	92.8	25.4
	7.0	6.0	112	29.3	112	29.8	107	28.2	103	27.1	100	26.1	92.8	24.0
	9.0	7.9	118	29.8	113	28.6	107	26.6	103	25.6	100	24.6	92.8	22.7
	11.0	9.8	120	29.0	113	27.0	107	25.1	103	24.2	100	23.2	92.8	21.4
	13.0	11.8	120	27.2	113	25.4	107	23.7	103	22.8	100	21.9	92.8	20.2
	15.0	13.7	120	25.7	113	24.0	107	22.4	103	21.6	100	20.8	92.8	19.2
90 (770)	-19.8	-20.0	60.8	22.1	60.6	23.1	60.5	24.1	60.4	24.6	60.3	25.1	60.1	26.0
	-18.8	-19.0	61.9	22.5	61.7	23.4	61.6	24.4	61.5	24.9	61.4	25.3	61.2	26.3
	-16.7	-17.0	64.3	23.1	64.2	24.1	64.0	25.0	63.9	25.4	63.8	25.9	63.7	26.8
	-13.7	-15.0	67.0	23.8	66.9	24.7	66.7	25.6	66.6	26.0	66.5	26.5	66.4	27.4
	-11.8	-13.0	70.0	24.5	69.8	25.4	69.7	26.2	69.6	26.6	69.5	27.0	69.3	27.9
	-9.8	-11.0	73.3	25.2	73.1	26.0	72.9	26.8	72.8	27.2	72.8	27.6	72.6	28.4
	-9.5	-10.0	75.0	25.5	74.8	26.3	74.7	27.1	74.6	27.5	74.5	27.9	74.3	28.7
	-8.5	-9.1	76.6	25.9	76.4	26.6	76.3	27.4	76.2	27.8	76.1	28.2	75.9	28.9
	-7.0	-7.6	79.4	26.4	79.2	27.1	79.1	27.8	79.0	28.2	78.9	28.6	78.7	29.3
	-5.0	-5.6	83.4	27.0	83.2	27.7	83.1	28.4	83.0	28.8	82.9	29.1	82.7	29.8
	-3.0	-3.7	87.4	27.6	87.3	28.3	87.1	28.9	87.0	29.3	86.9	29.6	83.5	28.6
	0.0	-0.7	94.3	28.5	94.1	29.1	94.0	29.7	92.8	29.5	89.7	28.3	83.5	26.0
	3.0	2.2	102	29.3	101	29.9	95.9	28.0	92.8	26.9	89.7	25.9	83.5	23.8
	5.0	4.1	107	29.8	102	28.4	95.9	26.4	92.8	25.4	89.7	24.4	83.5	22.5
	7.0	6.0	108	28.7	102	26.8	95.9	24.9	92.8	24.0	89.7	23.1	83.5	21.3
	9.0	7.9	108	27.1	102	25.3	95.9	23.5	92.8	22.7	89.7	21.8	83.5	20.1
	11.0	9.8	108	25.6	102	23.9	95.9	22.2	92.8	21.4	89.7	20.6	83.5	19.1
	13.0	11.8	108	24.1	102	22.5	95.9	21.0	92.8	20.2	89.7	19.5	83.5	18.0
	15.0	13.7	108	22.8	102	21.3	95.9	19.9	92.8	19.2	89.7	18.5	83.5	17.1
80 (684)	-19.8	-20.0	60.5	24.0	60.3	24.9	60.2	25.8	60.1	26.2	60.0	26.6	59.9	27.5
	-18.8	-19.0	61.6	24.3	61.4	25.2	61.3	26.0	61.2	26.5	61.1	26.9	61.0	27.7
	-16.7	-17.0	64.0	24.9	63.9	25.7	63.7	26.6	63.6	27.0	63.6	27.4	63.4	28.2
	-13.7	-15.0	66.7	25.5	66.6	26.3	66.4	27.1	66.3	27.5	66.3	27.9	66.1	28.7
	-11.8	-13.0	69.7	26.2	69.5	26.9	69.4	27.7	69.3	28.0	69.2	28.4	69.1	29.2
	-9.8	-11.0	72.9	26.8	72.8	27.5	72.6	28.2	72.6	28.6	72.5	28.9	72.3	29.6
	-9.5	-10.0	74.7	27.1	74.5	27.8	74.4	28.5	74.3	28.8	74.2	29.2	74.1	29.9
	-8.5	-9.1	76.3	27.4	76.1	28.0	76.0	28.7	75.9	29.1	75.8	29.4	74.3	29.2
	-7.0	-7.6	79.1	27.8	78.9	28.5	78.8	29.1	78.7	29.4	78.6	29.8	74.3	27.9
	-5.0	-5.6	83.1	28.4	82.9	29.0	82.8	29.6	82.5	29.8	79.7	28.6	74.3	26.3
	-3.0	-3.7	87.1	28.9	87.0	29.5	85.2	29.2	82.5	28.1	79.7	27.0	74.3	24.8
	0.0	-0.7	94.0	29.7	90.7	28.7	85.2	26.6	82.5	25.6	79.7	24.6	74.3	22.7
	3.0	2.2	96.1	28.1	90.7	26.2	85.2	24.4	82.5	23.5	79.7	22.6	74.3	20.8
	5.0	4.1	96.1	26.5	90.7	24.7	85.2	23.0	82.5	22.2	79.7	21.4	74.3	19.7
	7.0	6.0	96.1	25.0	90.7	23.4	85.2	21.8	82.5	21.0	79.7	20.2	74.3	18.7
	9.0	7.9	96.1	23.6	90.7	22.1	85.2	20.6	82.5	19.9	79.7	19.1	74.3	17.7
	11.0	9.8	96.1	22.3	90.7	20.9	85.2	19.5	82.5	18.8	79.7	18.1	74.3	16.8
	13.0	11.8	96.1	21.1	90.7	19.7	85.2	18.4	82.5	17.8	79.7	17.2	74.3	15.9
	15.0	13.7	96.1	20.0	90.7	18.7	85.2	17.5	82.5	16.9	79.7	16.3	74.3	15.1

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (599)	-19.8	-20.0	60.1	25.9	60.0	26.7	59.9	27.5	59.8	27.8	59.8	28.2	59.6	29.0				
	-18.8	-19.0	61.3	26.2	61.1	26.9	61.0	27.7	60.9	28.1	60.9	28.4	60.7	29.2				
	-16.7	-17.0	63.7	26.7	63.6	27.4	63.4	28.2	63.4	28.5	63.3	28.9	63.2	29.6				
	-13.7	-15.0	66.4	27.3	66.3	28.0	66.1	28.6	66.1	29.0	66.0	29.3	65.0	29.4				
	-11.8	-13.0	69.4	27.8	69.2	28.5	69.1	29.1	69.0	29.4	69.0	29.8	65.0	27.8				
	-9.8	-11.0	72.6	28.3	72.5	29.0	72.3	29.6	72.2	29.8	69.8	28.6	65.0	26.3				
	-9.5	-10.0	74.3	28.6	74.2	29.2	74.1	29.8	72.2	29.0	69.8	27.8	65.0	25.6				
	-8.5	-9.1	75.9	28.9	75.8	29.4	74.6	29.4	72.2	28.2	69.8	27.1	65.0	24.9				
	-7.0	-7.6	78.8	29.2	78.6	29.8	74.6	28.1	72.2	27.0	69.8	25.9	65.0	23.9				
	-5.0	-5.6	82.7	29.8	79.3	28.5	74.6	26.4	72.2	25.4	69.8	24.5	65.0	22.5				
	-3.0	-3.7	84.1	28.8	79.3	26.9	74.6	25.0	72.2	24.0	69.8	23.1	65.0	21.3				
	0.0	-0.7	84.1	26.2	79.3	24.5	74.6	22.8	72.2	22.0	69.8	21.2	65.0	19.6				
	3.0	2.2	84.1	24.0	79.3	22.5	74.6	20.9	72.2	20.2	69.8	19.5	65.0	18.0				
	4.0	4.1	84.1	22.7	79.3	21.2	74.6	19.8	72.2	19.1	69.8	18.4	65.0	17.1				
	7.0	6.0	84.1	21.4	79.3	20.1	74.6	18.8	72.2	17.1	69.8	17.5	65.0	16.2				
	9.0	7.9	84.1	20.3	79.3	18.0	74.6	17.8	72.2	17.2	69.8	16.6	65.0	15.4				
	11.0	9.8	84.1	19.2	79.3	18.0	74.6	16.9	72.2	16.3	69.8	15.7	65.0	14.6				
	13.0	11.8	84.1	18.2	79.3	17.1	74.6	16.0	72.2	15.4	69.8	14.9	65.0	13.9				
	15.0	13.7	84.1	17.3	79.3	16.2	74.6	15.2	72.2	14.7	69.8	14.2	65.0	13.2				
60 (513)	-19.8	-20.0	59.8	27.9	59.7	28.5	59.6	29.2	59.5	29.5	59.5	29.8	55.7	27.6				
	-18.8	-19.0	60.9	28.1	60.8	28.7	60.7	29.4	60.6	29.7	59.8	29.4	55.7	27.0				
	-16.7	-17.0	63.4	28.5	63.2	29.1	63.1	29.8	61.8	29.2	59.8	28.0	55.7	25.7				
	-13.7	-15.0	66.1	29.0	65.9	29.6	63.9	28.8	61.8	27.7	59.8	26.6	55.7	24.5				
	-11.8	-13.0	69.0	29.5	68.0	29.4	63.9	27.3	61.8	26.3	59.8	25.2	55.7	23.2				
	-9.8	-11.0	72.1	29.8	68.0	27.8	63.9	25.8	61.8	24.8	59.8	23.9	55.7	22.0				
	-9.5	-10.0	72.1	29.0	68.0	27.0	63.9	25.1	61.8	24.2	59.8	23.2	55.7	21.4				
	-8.5	-9.1	72.1	28.2	68.0	26.3	63.9	24.5	61.8	23.6	59.8	22.7	55.7	20.9				
	-7.0	-7.6	72.1	27.0	68.0	25.2	63.9	23.4	61.8	22.6	59.8	21.7	55.7	20.1				
	-5.0	-5.6	72.1	25.4	68.0	23.7	63.9	22.1	61.8	21.3	59.8	20.5	55.7	19.0				
	-3.0	-3.7	72.1	24.0	68.0	22.5	63.9	20.9	61.8	20.2	59.8	19.4	55.7	18.0				
	0.0	-0.7	72.1	22.0	68.0	20.6	63.9	19.2	61.8	18.5	59.8	17.9	55.7	16.6				
	3.0	2.2	72.1	20.2	68.0	18.9	63.9	17.7	61.8	17.1	59.8	16.5	55.7	15.3				
	5.0	4.1	72.1	19.1	68.0	17.9	63.9	16.8	61.8	16.2	59.8	15.6	55.7	14.5				
	7.0	6.0	72.1	18.1	68.0	17.0	63.9	15.9	61.8	15.4	59.8	14.9	55.7	13.8				
	9.0	7.9	72.1	17.2	68.0	16.1	63.9	15.1	61.8	14.6	59.8	14.1	55.7	13.2				
	11.0	9.8	72.1	16.3	68.0	15.3	63.9	14.4	61.8	13.9	59.8	13.4	55.7	12.5				
	13.0	11.8	72.1	15.4	68.0	14.5	63.9	13.6	61.8	13.2	59.8	12.8	55.7	11.9				
	15.0	13.7	72.1	14.7	68.0	13.8	63.9	13.0	61.8	12.6	59.8	12.2	55.7	11.4				
50 (428)	-19.8	-20.0	59.5	29.8	56.7	28.2	53.3	26.2	51.5	25.2	49.8	24.2	46.4	22.3				
	-18.8	-19.0	60.1	29.6	56.7	27.6	53.3	25.6	51.5	24.6	49.8	23.7	46.4	21.8				
	-16.7	-17.0	60.1	28.2	56.7	26.3	53.3	24.4	51.5	23.5	49.8	22.6	46.4	20.9				
	-13.7	-15.0	60.1	26.8	56.7	25.0	53.3	23.3	51.5	22.4	49.8	21.6	46.4	19.9				
	-11.8	-13.0	60.1	25.4	56.7	23.7	53.3	22.1	51.5	21.3	49.8	20.5	46.4	18.9				
	-9.8	-11.0	60.1	24.0	56.7	22.5	53.3	20.9	51.5	20.2	49.8	19.5	46.4	18.0				
	-9.5	-10.0	60.1	23.4	56.7	21.9	53.3	20.4	51.5	19.7	49.8	18.9	46.4	17.5				
	-8.5	-9.1	60.1	22.8	56.7	21.3	53.3	19.9	51.5	19.2	49.8	18.5	46.4	17.1				
	-7.0	-7.6	60.1	21.8	56.7	20.5	53.3	19.1	51.5	18.4	49.8	17.8	46.4	16.5				
	-5.0	-5.6	60.1	20.6	56.7	19.3	53.3	18.1	51.5	17.4	49.8	16.8	46.4	15.6				
	-3.0	-3.7	60.1	19.6	56.7	18.3	53.3	17.1	51.5	16.6	49.8	16.0	46.4	14.8				
	0.0	-0.7	60.1	18.0	56.7	16.9	53.3	15.8	51.5	15.3	49.8	14.7	46.4	13.7				
	3.0	2.2	60.1	16.6	56.7	15.6	53.3	14.6	51.5	14.1	49.8	13.7	46.4	12.7				
	5.0	4.1	60.1	15.7	56.7	14.8	53.3	13.9	51.5	13.4	49.8	13.0	46.4	12.1				
	7.0	6.0	60.1	14.9	56.7	14.1	53.3	13.2	51.5	12.8	49.8	12.4	46.4	11.6				
	9.0	7.9	60.1	14.2	56.7	13.4	53.3	12.6	51.5	12.2	49.8	11.8	46.4	11.0				
	11.0	9.8	60.1	13.5	56.7	12.7	53.3	12.0	51.5	11.6	49.8	11.3	46.4	10.5				
	13.0	11.8	60.1	12.8	56.7	12.1	53.3	11.4	51.5	11.1	49.8	10.7	46.4	10.1				
	15.0	13.7	60.1	12.2	56.7	11.6	53.3	10.9	51.5	10.6	49.8	10.3	46.4	9.62				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

14

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1170)	-19.8	-20.0	62.9	13.3	62.6	14.9	62.4	16.4	62.2	17.2	62.1	17.9	61.9	19.5
	-18.8	-19.0	64.0	13.8	63.8	15.3	63.5	16.8	63.4	17.6	63.2	18.3	63.0	19.9
	-16.7	-17.0	66.5	14.9	66.2	16.3	65.9	17.8	65.8	18.5	65.7	19.2	65.4	20.7
	-13.7	-15.0	69.2	16.0	68.9	17.3	68.7	18.7	68.5	19.4	68.4	20.1	68.2	21.5
	-11.8	-13.0	72.2	17.0	71.9	18.4	71.7	19.7	71.5	20.3	71.4	21.0	71.2	22.3
	-9.8	-11.0	75.5	18.1	75.2	19.4	74.9	20.6	74.8	21.3	74.7	21.9	74.4	23.2
	-9.5	-10.0	77.2	18.7	76.9	19.9	76.7	21.1	76.6	21.7	76.4	22.3	76.2	23.6
	-8.5	-9.1	78.8	19.1	78.6	20.3	78.3	21.5	78.2	22.1	78.1	22.7	77.8	23.9
	-7.0	-7.6	81.7	19.9	81.4	21.1	81.2	22.2	81.0	22.8	80.9	23.4	80.6	24.6
	-5.0	-5.6	85.7	20.9	85.4	22.0	85.2	23.1	85.0	23.7	84.9	24.2	84.7	25.3
	-3.0	-3.7	89.8	21.9	89.5	22.9	89.2	24.0	89.1	24.5	89.0	25.0	88.7	26.1
	0.0	-0.7	97	23.3	96	24.2	96	25.2	96	25.7	96	26.2	96	27.1
	3.0	2.2	104	24.5	104	25.4	103	26.3	103	26.8	103	27.2	103	28.1
	5.0	4.1	109	25.3	109	26.2	109	27.0	108	27.4	108	27.9	108	28.7
	7.0	6.0	114	26.0	114	26.9	114	27.7	114	28.1	114	28.5	113	29.3
	9.0	7.9	120	26.7	120	27.5	120	28.3	119	28.7	119	29.1	119	29.8
	11.0	9.8	126	27.4	126	28.1	125	28.9	125	29.2	125	29.6	125	30.4
	13.0	11.8	132	28.1	132	28.8	132	29.5	132	29.8	132	30.2	128	29.7
	15.0	13.7	139	28.6	138	29.3	138	30.0	138	30.3	137	30.5	128	28.0
120 (1080)	-19.8	-20.0	62.5	15.4	62.3	16.8	62.1	18.2	62.0	18.9	61.8	19.6	61.6	21.1
	-18.8	-19.0	63.7	15.9	63.4	17.3	63.2	18.6	63.1	19.3	63.0	20.0	62.7	21.4
	-16.7	-17.0	66.1	16.8	65.9	18.2	65.6	19.5	65.5	20.2	65.4	20.8	65.2	22.2
	-13.7	-15.0	68.8	17.8	68.6	19.1	68.4	20.4	68.2	21.0	68.1	21.7	67.9	22.9
	-11.8	-13.0	71.8	18.8	71.6	20.0	71.4	21.3	71.2	21.9	71.1	22.5	70.9	23.7
	-9.8	-11.0	75.1	19.8	74.9	21.0	74.6	22.2	74.5	22.7	74.4	23.3	74.2	24.5
	-9.5	-10.0	76.9	20.3	76.6	21.5	76.4	22.6	76.3	23.2	76.1	23.7	75.9	24.9
	-8.5	-9.1	78.5	20.8	78.2	21.9	78.0	23.0	77.9	23.5	77.8	24.1	77.5	25.2
	-7.0	-7.6	81.3	21.5	81.1	22.6	80.8	23.6	80.7	24.2	80.6	24.7	80.4	25.8
	-5.0	-5.6	85.3	22.4	85.1	23.4	84.9	24.5	84.7	25.0	84.6	25.5	84.4	26.5
	-3.0	-3.7	89.4	23.3	89.2	24.2	88.9	25.2	88.8	25.7	88.7	26.2	88.5	27.2
	0.0	-0.7	96	24.6	96	25.5	96	26.4	96	26.8	96	27.3	95	28.2
	3.0	2.2	104	25.7	103	26.6	103	27.4	103	27.8	103	28.2	103	29.1
	5.0	4.1	109	26.5	109	27.2	108	28.0	108	28.4	108	28.8	108	29.6
	7.0	6.0	114	27.1	114	27.9	114	28.6	113	29.0	113	29.4	113	30.2
	9.0	7.9	120	27.8	119	28.5	119	29.2	119	29.6	119	29.9	118	30.4
	11.0	9.8	126	28.4	125	29.1	125	29.8	125	30.1	125	30.4	118	28.7
	13.0	11.8	132	29.0	132	29.7	131	30.3	131	30.6	127	29.4	118	27.0
	15.0	13.7	138	29.6	138	30.2	136	30.0	131	28.9	127	27.8	118	25.6
110 (990)	-19.8	-20.0	62.2	17.5	62.0	18.8	61.8	20.1	61.7	20.7	61.5	21.4	61.3	22.7
	-18.8	-19.0	63.3	17.9	63.1	19.2	62.9	20.4	62.8	21.1	62.7	21.7	62.4	23.0
	-16.7	-17.0	65.8	18.8	65.5	20.0	65.3	21.2	65.2	21.8	65.1	22.5	64.9	23.7
	-13.7	-15.0	68.5	19.7	68.3	20.9	68.1	22.0	67.9	22.6	67.8	23.2	67.6	24.4
	-11.8	-13.0	71.5	20.6	71.3	21.7	71.1	22.9	70.9	23.4	70.8	24.0	70.6	25.1
	-9.8	-11.0	74.8	21.5	74.5	22.6	74.3	23.7	74.2	24.2	74.1	24.7	73.9	25.8
	-9.5	-10.0	76.5	22.0	76.3	23.0	76.1	24.1	76.0	24.6	75.9	25.1	75.6	26.2
	-8.5	-9.1	78.1	22.4	77.9	23.4	77.7	24.4	77.6	24.9	77.5	25.4	77.3	26.5
	-7.0	-7.6	81.0	23.0	80.8	24.0	80.5	25.0	80.4	25.5	80.3	26.0	80.1	27.0
	-5.0	-5.6	85.0	23.9	84.8	24.8	84.6	25.8	84.4	26.2	84.3	26.7	84.1	27.6
	-3.0	-3.7	89.1	24.7	88.8	25.6	88.6	26.5	88.5	26.9	88.4	27.4	88.2	28.3
	0.0	-0.7	96	25.9	96	26.7	96	27.5	95	27.9	95	28.4	95	29.2
	3.0	2.2	103	27.0	103	27.7	103	28.5	103	28.9	103	29.2	102	30.0
	5.0	4.1	108	27.6	108	28.3	108	29.1	108	29.4	108	29.8	108	30.5
	7.0	6.0	114	28.2	114	28.9	113	29.6	113	30.0	113	30.3	108	29.1
	9.0	7.9	119	28.8	119	29.5	119	30.1	119	30.5	116	29.9	108	27.5
	11.0	9.8	125	29.4	125	30.0	124	30.5	120	29.3	116	28.2	108	25.9
	13.0	11.8	132	30.0	131	30.6	124	28.7	120	27.6	116	26.5	108	24.5
	15.0	13.7	138	30.5	132	29.2	124	27.1	120	26.1	116	25.1	108	23.2

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (900)	-19.8	-20.0	61.8	19.5	61.6	20.7	61.5	21.9	61.4	22.5	61.3	23.1	61.1	24.3
	-18.8	-19.0	63.0	19.9	62.8	21.1	62.6	22.2	62.5	22.8	62.4	23.4	62.2	24.6
	-16.7	-17.0	65.4	20.7	65.2	21.9	65.0	23.0	64.9	23.5	64.8	24.1	64.6	25.2
	-13.7	-15.0	68.1	21.6	67.9	22.6	67.7	23.7	67.6	24.2	67.5	24.8	67.3	25.8
	-11.8	-13.0	71.1	22.4	70.9	23.4	70.7	24.4	70.6	24.9	70.5	25.5	70.3	26.5
	-9.8	-11.0	74.4	23.2	74.2	24.2	74.0	25.2	73.9	25.7	73.8	26.1	73.6	27.1
	-9.5	-10.0	76.2	23.6	76.0	24.6	75.8	25.5	75.7	26.0	75.6	26.5	75.4	27.4
	-8.5	-9.1	77.8	24.0	77.6	24.9	77.4	25.9	77.3	26.3	77.2	26.8	77.0	27.7
	-7.0	-7.6	80.6	24.6	80.4	25.5	80.2	26.4	80.1	26.8	80.0	27.3	79.8	28.2
	-5.0	-5.6	84.6	25.4	84.4	26.2	84.2	27.1	84.1	27.5	84.0	27.9	83.8	28.8
	-3.0	-3.7	88.7	26.1	88.5	26.9	88.3	27.7	88.2	28.1	88.1	28.5	87.9	29.4
	0.0	-0.7	96	27.2	95	27.9	95	28.7	95	29.1	95	29.4	94.9	30.2
	3.0	2.2	103	28.2	103	28.9	103	29.6	102	29.9	102	30.3	98.5	29.2
	5.0	4.1	108	28.8	108	29.4	108	30.1	108	30.4	106	30.0	98.5	27.6
	7.0	6.0	113	29.3	113	30.0	113	30.6	109	29.4	106	28.3	98.5	26.0
	9.0	7.9	119	29.9	119	30.5	113	28.9	109	27.8	106	26.7	98.5	24.6
	11.0	9.8	125	30.4	120	29.3	113	27.2	109	26.2	106	25.2	98.5	23.3
	13.0	11.8	128	29.6	120	27.6	113	25.7	109	24.7	106	23.8	98.5	22.0
	15.0	13.7	128	27.9	120	26.1	113	24.3	109	23.4	106	22.5	98.5	20.8
90 (810)	-19.8	-20.0	61.5	21.6	61.3	22.7	61.1	23.7	61.1	24.3	61.0	24.8	60.8	25.9
	-18.8	-19.0	62.6	22.0	62.4	23.0	62.3	24.0	62.2	24.6	62.1	25.1	61.9	26.1
	-16.7	-17.0	65.1	22.7	64.9	23.7	64.7	24.7	64.6	25.2	64.5	25.7	64.4	26.7
	-13.7	-15.0	67.8	23.4	67.6	24.4	67.4	25.4	67.3	25.8	67.3	26.3	67.1	27.3
	-11.8	-13.0	70.8	24.2	70.6	25.1	70.4	26.0	70.3	26.5	70.3	26.9	70.1	27.9
	-9.8	-11.0	74.1	24.9	73.9	25.8	73.7	26.7	73.6	27.1	73.5	27.6	73.4	28.4
	-9.5	-10.0	75.8	25.3	75.6	26.2	75.5	27.0	75.4	27.4	75.3	27.9	75.1	28.7
	-8.5	-9.1	77.4	25.6	77.3	26.5	77.1	27.3	77.0	27.7	76.9	28.1	76.7	29.0
	-7.0	-7.6	80.3	26.2	80.1	27.0	79.9	27.8	79.8	28.2	79.7	28.6	79.6	29.4
	-5.0	-5.6	84.3	26.9	84.1	27.7	83.9	28.4	83.8	28.8	83.8	29.2	83.6	29.9
	-3.0	-3.7	88.4	27.5	88.2	28.3	88.0	29.0	87.9	29.4	87.8	29.7	87.7	30.4
	0.0	-0.7	95	28.5	95	29.2	95	29.9	94.9	30.2	94.8	30.5	88.6	28.2
	3.0	2.2	103	29.4	102	30.0	102	30.4	98.4	29.2	95.2	28.1	88.6	25.9
	5.0	4.1	108	29.9	108	30.5	102	28.6	98.4	27.6	95.2	26.5	88.6	24.4
	7.0	6.0	113	30.4	108	29.1	102	27.0	98.4	26.0	95.2	25.0	88.6	23.1
	9.0	7.9	115	29.4	108	27.4	102	25.5	98.4	24.6	95.2	23.7	88.6	21.8
	11.0	9.8	115	27.7	108	25.9	102	24.1	98.4	23.3	95.2	22.4	88.6	20.7
	13.0	11.8	115	26.1	108	24.4	102	22.8	98.4	22.0	95.2	21.2	88.6	19.6
	15.0	13.7	115	24.7	108	23.1	102	21.6	98.4	20.8	95.2	20.1	88.6	18.6
80 (720)	-19.8	-20.0	61.2	23.7	61.0	24.6	60.8	25.6	60.8	26.0	60.7	26.5	60.5	27.5
	-18.8	-19.0	62.3	24.0	62.1	24.9	62.0	25.8	61.9	26.3	61.8	26.8	61.6	27.7
	-16.7	-17.0	64.7	24.6	64.6	25.5	64.4	26.4	64.3	26.9	64.2	27.3	64.1	28.2
	-13.7	-15.0	67.4	25.3	67.3	26.2	67.1	27.0	67.0	27.4	67.0	27.9	66.8	28.7
	-11.8	-13.0	70.4	26.0	70.3	26.8	70.1	27.6	70.0	28.0	70.0	28.4	69.8	29.2
	-9.8	-11.0	73.7	26.6	73.6	27.4	73.4	28.2	73.3	28.6	73.2	29.0	73.1	29.8
	-9.5	-10.0	75.5	27.0	75.3	27.7	75.1	28.5	75.1	28.9	75.0	29.2	74.8	30.0
	-8.5	-9.1	77.1	27.3	76.9	28.0	76.8	28.8	76.7	29.1	76.6	29.5	76.5	30.2
	-7.0	-7.6	79.9	27.8	79.8	28.5	79.6	29.2	79.5	29.5	79.4	29.9	78.8	30.3
	-5.0	-5.6	83.9	28.4	83.8	29.1	83.6	29.7	83.5	30.1	83.5	30.4	78.8	28.5
	-3.0	-3.7	88.0	29.0	87.9	29.6	87.7	30.3	87.5	30.5	84.6	29.3	78.8	27.0
	0.0	-0.7	95	29.8	94.8	30.4	90.4	28.9	87.5	27.8	84.6	26.7	78.8	24.6
	3.0	2.2	102	30.5	96.2	28.4	90.4	26.5	87.5	25.5	84.6	24.5	78.8	22.6
	5.0	4.1	102	28.7	96.2	26.8	90.4	25.0	87.5	24.1	84.6	23.2	78.8	21.4
	7.0	6.0	102	27.1	96.2	25.3	90.4	23.6	87.5	22.8	84.6	21.9	78.8	20.3
	9.0	7.9	102	25.6	96.2	24.0	90.4	22.3	87.5	21.5	84.6	20.8	78.8	19.2
	11.0	9.8	102	24.2	96.2	22.7	90.4	21.2	87.5	20.4	84.6	19.7	78.8	18.2
	13.0	11.8	102	22.9	96.2	21.4	90.4	20.0	87.5	19.3	84.6	18.6	78.8	17.3
	15.0	13.7	102	21.7	96.2	20.3	90.4	19.0	87.5	18.3	84.6	17.7	78.8	16.4

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (630)	-19.8	-20.0	60.8	25.7	60.7	26.6	60.5	27.4	60.5	27.8	60.4	28.2	60.2	29.1				
	-18.8	-19.0	61.9	26.0	61.8	26.8	61.6	27.6	61.6	28.1	61.5	28.5	61.4	29.3				
	-16.7	-17.0	64.4	26.6	64.2	27.4	64.1	28.2	64.0	28.5	64.0	28.9	63.8	29.7				
	-13.7	-15.0	67.1	27.2	67.0	27.9	66.8	28.7	66.7	29.0	66.7	29.4	66.5	30.2				
	-11.8	-13.0	70.1	27.8	70.0	28.5	69.8	29.2	69.7	29.5	69.7	29.9	68.9	30.2				
	-9.8	-11.0	73.4	28.3	73.2	29.0	73.1	29.7	73.0	30.0	73.0	30.4	68.9	28.6				
	-9.5	-10.0	75.1	28.6	75.0	29.3	74.8	30.0	74.8	30.3	74.0	30.2	68.9	27.8				
	-8.5	-9.1	76.7	28.9	76.6	29.5	76.5	30.2	76.4	30.5	74.0	29.4	68.9	27.1				
	-7.0	-7.6	79.6	29.3	79.4	29.9	79.1	30.5	76.6	29.3	74.0	28.2	68.9	25.9				
	-5.0	-5.6	83.6	29.9	83.5	30.5	79.1	28.7	76.6	27.6	74.0	26.5	68.9	24.5				
	-3.0	-3.7	87.7	30.4	84.2	29.1	79.1	27.1	76.6	26.1	74.0	25.1	68.9	23.1				
	0.0	-0.7	89.3	28.5	84.2	26.6	79.1	24.8	76.6	23.9	74.0	23.0	68.9	21.2				
	3.0	2.2	89.3	26.1	84.2	24.4	79.1	22.7	76.6	21.9	74.0	21.1	68.9	19.5				
	5.0	4.1	89.3	24.6	84.2	23.0	79.1	21.5	76.6	20.7	74.0	20.0	68.9	18.5				
	7.0	6.0	89.3	23.3	84.2	21.8	79.1	20.4	76.6	19.6	74.0	18.9	68.9	17.6				
	9.0	7.9	89.3	22.0	84.2	20.6	79.1	19.3	76.6	18.6	74.0	18.0	68.9	16.7				
	11.0	9.8	89.3	20.9	84.2	19.6	79.1	18.3	76.6	17.7	74.0	17.1	68.9	15.9				
	13.0	11.8	89.3	19.7	84.2	18.5	79.1	17.3	76.6	16.8	74.0	16.2	68.9	15.1				
	15.0	13.7	89.3	18.7	84.2	17.6	79.1	16.5	76.6	15.9	74.0	15.4	68.9	14.3				
60 (540)	-19.8	-20.0	60.5	27.8	60.3	28.5	60.2	29.2	60.2	29.6	60.1	29.9	59.1	29.9				
	-18.8	-19.0	61.6	28.1	61.5	28.8	61.3	29.4	61.3	29.8	61.2	30.1	59.1	29.3				
	-16.7	-17.0	64.0	28.5	63.9	29.2	63.8	29.9	63.7	30.2	63.4	30.4	59.1	27.9				
	-13.7	-15.0	66.7	29.0	66.6	29.7	66.5	30.3	65.6	30.1	63.4	28.9	59.1	26.6				
	-11.8	-13.0	69.7	29.6	69.6	30.2	67.8	29.6	65.6	28.5	63.4	27.4	59.1	25.2				
	-9.8	-11.0	73.0	30.1	72.2	30.2	67.8	28.0	65.6	27.0	63.4	25.9	59.1	23.9				
	-9.5	-10.0	74.8	30.3	72.2	29.3	67.8	27.2	65.6	26.2	63.4	25.2	59.1	23.3				
	-8.5	-9.1	76.4	30.5	72.2	28.5	67.8	26.5	65.6	25.6	63.4	24.6	59.1	22.7				
	-7.0	-7.6	76.5	29.3	72.2	27.3	67.8	25.4	65.6	24.5	63.4	23.6	59.1	21.8				
	-5.0	-5.6	76.5	27.6	72.2	25.8	67.8	24.0	65.6	23.1	63.4	22.3	59.1	20.6				
	-3.0	-3.7	76.5	26.1	72.2	24.4	67.8	22.7	65.6	21.9	63.4	21.1	59.1	19.5				
	0.0	-0.7	76.5	23.8	72.2	22.3	67.8	20.8	65.6	20.1	63.4	19.4	59.1	18.0				
	3.0	2.2	76.5	21.9	72.2	20.5	67.8	19.2	65.6	18.5	63.4	17.9	59.1	16.6				
	5.0	4.1	76.5	20.7	72.2	19.4	67.8	18.2	65.6	17.6	63.4	17.0	59.1	15.8				
	7.0	6.0	76.5	19.6	72.2	18.4	67.8	17.3	65.6	16.7	63.4	16.1	59.1	15.0				
	9.0	7.9	76.5	18.6	72.2	17.5	67.8	16.4	65.6	15.9	63.4	15.3	59.1	14.3				
	11.0	9.8	76.5	17.7	72.2	16.6	67.8	15.6	65.6	15.1	63.4	14.6	59.1	13.6				
	13.0	11.8	76.5	16.8	72.2	15.8	67.8	14.8	65.6	14.3	63.4	13.9	59.1	12.9				
	15.0	13.7	76.5	15.9	72.2	15.0	67.8	14.1	65.6	13.7	63.4	13.2	59.1	12.4				
50 (450)	-19.8	-20.0	60.1	29.9	60.0	30.5	56.5	28.4	54.7	27.3	52.9	26.3	49.2	24.2				
	-18.8	-19.0	61.2	30.1	60.1	29.9	56.5	27.8	54.7	26.7	52.9	25.7	49.2	23.7				
	-16.7	-17.0	63.7	30.5	60.1	28.5	56.5	26.5	54.7	25.5	52.9	24.6	49.2	22.7				
	-13.7	-15.0	63.8	29.0	60.1	27.1	56.5	25.2	54.7	24.3	52.9	23.4	49.2	21.6				
	-11.8	-13.0	63.8	27.5	60.1	25.7	56.5	24.0	54.7	23.1	52.9	22.2	49.2	20.6				
	-9.8	-11.0	63.8	26.1	60.1	24.4	56.5	22.7	54.7	21.9	52.9	21.1	49.2	19.5				
	-9.5	-10.0	63.8	25.4	60.1	23.7	56.5	22.1	54.7	21.3	52.9	20.6	49.2	19.0				
	-8.5	-9.1	63.8	24.7	60.1	23.1	56.5	21.6	54.7	20.8	52.9	20.1	49.2	18.6				
	-7.0	-7.6	63.8	23.7	60.1	22.2	56.5	20.7	54.7	20.0	52.9	19.3	49.2	17.9				
	-5.0	-5.6	63.8	22.4	60.1	21.0	56.5	19.6	54.7	18.9	52.9	18.3	49.2	16.9				
	-3.0	-3.7	63.8	21.2	60.1	19.9	56.5	18.6	54.7	18.0	52.9	17.3	49.2	16.1				
	0.0	-0.7	63.8	19.5	60.1	18.3	56.5	17.1	54.7	16.6	52.9	16.0	49.2	14.9				
	3.0	2.2	63.8	18.0	60.1	16.9	56.5	15.8	54.7	15.3	52.9	14.8	49.2	13.8				
	5.0	4.1	63.8	17.1	60.1	16.1	56.5	15.1	54.7	14.6	52.9	14.1	49.2	13.2				
	7.0	6.0	63.8	16.2	60.1	15.3	56.5	14.3	54.7	13.9	52.9	13.4	49.2	12.5				
	9.0	7.9	63.8	15.4	60.1	14.5	56.5	13.7	54.7	13.2	52.9	12.8	49.2	12.0				
	11.0	9.8	63.8	14.7	60.1	13.8	56.5	13.0	54.7	12.6	52.9	12.2	49.2	11.4				
	13.0	11.8	63.8	13.9	60.1	13.2	56.5	12.4	54.7	12.0	52.9	11.6	49.2	10.9				
	15.0	13.7	63.8	13.3	60.1	12.6	56.5	11.8	54.7	11.5	52.9	11.1	49.2	10.4				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1235)	-19.8	-20.0	71.4	16.8	71.1	18.3	70.8	19.8	70.7	20.5	70.5	21.3	70.3	22.8
	-18.8	-19.0	72.8	17.3	72.5	18.8	72.3	20.3	72.1	21.0	72.0	21.7	71.7	23.2
	-16.7	-17.0	75.9	18.5	75.6	19.9	75.4	21.3	75.2	22.0	75.1	22.7	74.8	24.1
	-13.7	-15.0	79.3	19.6	79.0	20.9	78.7	22.3	78.6	22.9	78.4	23.6	78.2	24.9
	-11.8	-13.0	82.9	20.7	82.6	21.9	82.3	23.2	82.2	23.9	82.0	24.5	81.8	25.8
	-9.8	-11.0	86.7	21.7	86.4	22.9	86.1	24.2	86.0	24.8	85.9	25.4	85.6	26.6
	-9.5	-10.0	88.7	22.2	88.4	23.4	88.2	24.6	88.0	25.2	87.9	25.8	87.6	27.0
	-8.5	-9.1	90.6	22.7	90.3	23.9	90.0	25.0	89.9	25.6	89.7	26.2	89.5	27.3
	-7.0	-7.6	93.8	23.4	93.5	24.6	93.2	25.7	93.1	26.2	93.0	26.8	92.7	27.9
	-5.0	-5.6	98.3	24.4	98.0	25.5	97.7	26.5	97.6	27.1	97.5	27.6	97.2	28.7
	-3.0	-3.7	103	25.3	103	26.3	102	27.3	102	27.8	102	28.3	102	29.3
	0.0	-0.7	110	26.6	110	27.5	110	28.4	110	28.9	110	29.4	109	30.3
	3.0	2.2	118	27.7	118	28.6	118	29.5	118	29.9	117	30.4	117	31.2
	5.0	4.1	124	28.4	123	29.3	123	30.1	123	30.5	123	30.9	123	31.8
	7.0	6.0	129	29.1	129	29.9	129	30.7	129	31.1	128	31.5	128	32.3
	9.0	7.9	135	29.7	135	30.5	135	31.3	134	31.7	134	32.0	134	32.8
	11.0	9.8	141	30.4	141	31.1	141	31.8	141	32.2	140	32.5	135	31.3
	13.0	11.8	148	31.0	148	31.7	147	32.4	147	32.7	145	32.2	135	29.6
	15.0	13.7	154	31.5	154	32.2	154	32.8	150	31.8	145	30.6	135	28.1
120 (1140)	-19.8	-20.0	71.0	18.8	70.7	20.2	70.5	21.6	70.4	22.3	70.2	22.9	70.0	24.3
	-18.8	-19.0	72.4	19.3	72.2	20.7	71.9	22.0	71.8	22.7	71.7	23.4	71.4	24.7
	-16.7	-17.0	75.5	20.4	75.3	21.7	75.0	23.0	74.9	23.6	74.8	24.2	74.5	25.5
	-13.7	-15.0	78.9	21.4	78.6	22.6	78.4	23.9	78.3	24.5	78.1	25.1	77.9	26.3
	-11.8	-13.0	82.5	22.4	82.2	23.6	82.0	24.8	81.9	25.3	81.7	25.9	81.5	27.1
	-9.8	-11.0	86.3	23.4	86.1	24.5	85.8	25.6	85.7	26.2	85.6	26.7	85.3	27.9
	-9.5	-10.0	88.3	23.8	88.1	24.9	87.8	26.0	87.7	26.6	87.6	27.1	87.3	28.2
	-8.5	-9.1	90.2	24.3	89.9	25.3	89.7	26.4	89.6	27.0	89.4	27.5	89.2	28.6
	-7.0	-7.6	93.4	25.0	93.2	26.0	92.9	27.0	92.8	27.5	92.7	28.1	92.4	29.1
	-5.0	-5.6	97.9	25.8	97.7	26.8	97.4	27.8	97.3	28.3	97.2	28.8	96.9	29.8
	-3.0	-3.7	102	26.6	102	27.6	102	28.5	102	29.0	102	29.5	101	30.4
	0.0	-0.7	110	27.8	110	28.7	109	29.6	109	30.0	109	30.5	109	31.3
	3.0	2.2	118	28.9	118	29.7	117	30.5	117	30.9	117	31.3	117	32.2
	5.0	4.1	123	29.6	123	30.3	123	31.1	123	31.5	123	31.9	122	32.7
	7.0	6.0	129	30.2	129	30.9	128	31.7	128	32.0	128	32.4	124	31.8
	9.0	7.9	135	30.8	135	31.5	134	32.2	134	32.5	134	32.7	124	30.1
	11.0	9.8	141	31.3	141	32.0	140	32.7	138	32.3	134	31.0	124	28.5
	13.0	11.8	148	31.9	147	32.5	143	31.7	138	30.5	134	29.3	124	26.9
	15.0	13.7	154	32.4	152	32.4	143	30.1	138	28.9	134	27.8	124	25.6
110 (1045)	-19.8	-20.0	70.6	20.8	70.4	22.1	70.2	23.4	70.0	24.0	69.9	24.6	69.7	25.9
	-18.8	-19.0	72.1	21.3	71.9	22.5	71.6	23.8	71.5	24.4	71.4	25.0	71.2	26.3
	-16.7	-17.0	75.2	22.3	74.9	23.4	74.7	24.6	74.6	25.2	74.5	25.8	74.3	27.0
	-13.7	-15.0	78.5	23.2	78.3	24.3	78.1	25.5	77.9	26.0	77.8	26.6	77.6	27.7
	-11.8	-13.0	82.1	24.1	81.9	25.2	81.7	26.3	81.5	26.8	81.4	27.4	81.2	28.4
	-9.8	-11.0	86.0	25.0	85.7	26.0	85.5	27.1	85.4	27.6	85.3	28.1	85.0	29.1
	-9.5	-10.0	88.0	25.5	87.7	26.5	87.5	27.5	87.4	28.0	87.3	28.5	87.0	29.5
	-8.5	-9.1	89.8	25.8	89.6	26.8	89.4	27.8	89.3	28.3	89.1	28.8	88.9	29.8
	-7.0	-7.6	93.0	26.5	92.8	27.4	92.6	28.4	92.5	28.8	92.4	29.3	92.1	30.3
	-5.0	-5.6	97.5	27.3	97.3	28.2	97.1	29.1	97.0	29.5	96.9	30.0	96.6	30.9
	-3.0	-3.7	102	28.0	102	28.9	102	29.7	101	30.2	101	30.6	101	31.5
	0.0	-0.7	110	29.1	109	29.9	109	30.7	109	31.1	109	31.5	109	32.3
	3.0	2.2	117	30.1	117	30.8	117	31.6	117	32.0	117	32.3	114	32.0
	5.0	4.1	123	30.7	123	31.4	122	32.1	122	32.5	122	32.8	114	30.2
	7.0	6.0	129	31.3	128	32.0	128	32.6	127	32.5	122	31.2	114	28.6
	9.0	7.9	134	31.8	134	32.5	131	31.9	127	30.7	122	29.5	114	27.1
	11.0	9.8	140	32.3	139	32.6	131	30.2	127	29.1	122	28.0	114	25.7
	13.0	11.8	147	32.8	139	30.8	131	28.6	127	27.5	122	26.4	114	24.4
	15.0	13.7	148	31.3	139	29.2	131	27.1	127	26.1	122	25.1	114	23.2

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (950)	-19.8	-20.0	70.3	22.8	70.0	24.0	69.8	25.2	69.7	25.7	69.6	26.3	69.4	27.5
	-18.8	-19.0	71.7	23.3	71.5	24.4	71.3	25.5	71.2	26.1	71.1	26.7	70.9	27.8
	-16.7	-17.0	74.8	24.2	74.6	25.2	74.4	26.3	74.3	26.8	74.2	27.4	74.0	28.5
	-13.7	-15.0	78.2	25.0	77.9	26.0	77.7	27.1	77.6	27.6	77.5	28.1	77.3	29.1
	-11.8	-13.0	81.7	25.8	81.5	26.8	81.3	27.8	81.2	28.3	81.1	28.8	80.9	29.8
	-9.8	-11.0	85.6	26.7	85.4	27.6	85.2	28.5	85.1	29.0	85.0	29.5	84.7	30.4
	-9.5	-10.0	87.6	27.1	87.4	28.0	87.2	28.9	87.1	29.3	87.0	29.8	86.8	30.7
	-8.5	-9.1	89.5	27.4	89.3	28.3	89.0	29.2	88.9	29.6	88.8	30.1	88.6	31.0
	-7.0	-7.6	92.7	28.0	92.5	28.8	92.3	29.7	92.2	30.1	92.0	30.6	91.8	31.4
	-5.0	-5.6	97.2	28.7	97.0	29.5	96.8	30.4	96.7	30.8	96.6	31.2	96.3	32.0
	-3.0	-3.7	102	29.4	101	30.2	101	31.0	101	31.3	101	31.7	101	32.5
	0.0	-0.7	109	30.4	109	31.1	109	31.8	109	32.2	109	32.6	104	31.1
	3.0	2.2	117	31.3	117	32.0	117	32.6	115	32.4	111	31.1	104	28.5
	5.0	4.1	123	31.8	122	32.5	119	31.8	115	30.6	111	29.4	104	27.0
	7.0	6.0	128	32.4	127	32.4	119	30.1	115	29.0	111	27.8	104	25.6
	9.0	7.9	134	32.9	127	30.7	119	28.5	115	27.4	111	26.4	104	24.3
	11.0	9.8	134	31.2	127	29.1	119	27.0	115	26.0	111	25.0	104	23.1
	13.0	11.8	134	29.5	127	27.5	119	25.6	115	24.6	111	23.7	104	21.9
	15.0	13.7	134	28.0	127	26.1	119	24.3	115	23.4	111	22.5	104	20.8
90 (855)	-19.8	-20.0	69.9	24.9	69.7	25.9	69.5	26.9	69.4	27.5	69.3	28.0	69.1	29.0
	-18.8	-19.0	71.3	25.3	71.2	26.3	71.0	27.3	70.9	27.8	70.8	28.3	70.6	29.3
	-16.7	-17.0	74.4	26.0	74.3	27.0	74.1	28.0	74.0	28.5	73.9	29.0	73.7	29.9
	-13.7	-15.0	77.8	26.8	77.6	27.7	77.4	28.7	77.3	29.1	77.2	29.6	77.0	30.5
	-11.8	-13.0	81.4	27.6	81.2	28.5	81.0	29.3	80.9	29.8	80.8	30.2	80.6	31.1
	-9.8	-11.0	85.2	28.3	85.0	29.1	84.8	30.0	84.7	30.4	84.7	30.8	84.5	31.7
	-9.5	-10.0	87.2	28.7	87.0	29.5	86.9	30.3	86.8	30.7	86.7	31.1	86.5	32.0
	-8.5	-9.1	89.1	29.0	88.9	29.8	88.7	30.6	88.6	31.0	88.5	31.4	88.3	32.2
	-7.0	-7.6	92.3	29.5	92.1	30.3	91.9	31.1	91.8	31.4	91.7	31.8	91.6	32.6
	-5.0	-5.6	96.8	30.2	96.6	30.9	96.4	31.6	96.3	32.0	96.2	32.4	93.3	31.7
	-3.0	-3.7	101	30.8	101	31.5	101	32.2	101	32.5	100	32.6	93.3	29.9
	0.0	-0.7	109	31.7	109	32.3	107	32.3	104	31.1	100	29.8	93.3	27.4
	3.0	2.2	117	32.5	114	31.9	107	29.6	104	28.5	100	27.4	93.3	25.2
	5.0	4.1	121	32.4	114	30.2	107	28.1	104	27.0	100	26.0	93.3	23.9
	7.0	6.0	121	30.7	114	28.6	107	26.6	104	25.6	100	24.6	93.3	22.7
	9.0	7.9	121	29.0	114	27.1	107	25.2	104	24.3	100	23.4	93.3	21.6
	11.0	9.8	121	27.5	114	25.7	107	23.9	104	23.1	100	22.2	93.3	20.5
	13.0	11.8	121	26.0	114	24.3	107	22.7	104	21.9	100	21.1	93.3	19.5
	15.0	13.7	121	24.7	114	23.1	107	21.6	104	20.8	100	20.1	93.3	18.6
80 (760)	-19.8	-20.0	69.5	26.9	69.4	27.8	69.2	28.7	69.1	29.2	69.0	29.7	68.9	30.6
	-18.8	-19.0	71.0	27.2	70.8	28.1	70.6	29.0	70.6	29.5	70.5	29.9	70.3	30.8
	-16.7	-17.0	74.1	27.9	73.9	28.8	73.7	29.7	73.7	30.1	73.6	30.5	73.4	31.4
	-13.7	-15.0	77.4	28.6	77.3	29.4	77.1	30.3	77.0	30.7	76.9	31.1	76.8	31.9
	-11.8	-13.0	81.0	29.3	80.8	30.1	80.7	30.9	80.6	31.3	80.5	31.7	80.3	32.4
	-9.8	-11.0	84.9	30.0	84.7	30.7	84.5	31.4	84.4	31.8	84.3	32.2	83.0	32.2
	-9.5	-10.0	86.9	30.3	86.7	31.0	86.5	31.7	86.4	32.1	86.4	32.5	83.0	31.3
	-8.5	-9.1	88.7	30.6	88.6	31.3	88.4	32.0	88.3	32.3	88.2	32.7	83.0	30.5
	-7.0	-7.6	91.9	31.0	91.8	31.7	91.6	32.4	91.5	32.7	89.1	31.8	83.0	29.2
	-5.0	-5.6	96.4	31.6	96.3	32.3	95.2	32.4	92.1	31.2	89.1	29.9	83.0	27.5
	-3.0	-3.7	101	32.1	101	32.8	95.2	30.6	92.1	29.5	89.1	28.3	83.0	26.1
	0.0	-0.7	107	32.4	101	30.2	95.2	28.1	92.1	27.0	89.1	26.0	83.0	23.9
	3.0	2.2	107	29.8	101	27.8	95.2	25.8	92.1	24.9	89.1	23.9	83.0	22.1
	5.0	4.1	107	28.2	101	26.3	95.2	24.5	92.1	23.6	89.1	22.7	83.0	21.0
	7.0	6.0	107	26.7	101	24.9	95.2	23.2	92.1	22.4	89.1	21.6	83.0	19.9
	9.0	7.9	107	25.3	101	23.7	95.2	22.1	92.1	21.3	89.1	20.5	83.0	19.0
	11.0	9.8	107	24.0	101	22.5	95.2	21.0	92.1	20.2	89.1	19.5	83.0	18.1
	13.0	11.8	107	22.8	101	21.3	95.2	19.9	92.1	19.2	89.1	18.5	83.0	17.2
	15.0	13.7	107	21.7	101	20.3	95.2	19.0	92.1	18.3	89.1	17.7	83.0	16.4

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by .
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0	
	°CDB	°CWB	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW
70 (665)	-19.8	-20.0	69.2	28.9	69.0	29.7	68.9	30.5	68.8	30.9	68.7	31.3	68.6	32.1
	-18.8	-19.0	70.6	29.2	70.5	30.0	70.3	30.8	70.2	31.2	70.2	31.6	70.0	32.4
	-16.7	-17.0	73.7	29.8	73.6	30.6	73.4	31.3	73.3	31.7	73.3	32.1	72.6	32.5
	-13.7	-15.0	77.1	30.4	76.9	31.2	76.8	31.9	76.7	32.2	76.6	32.6	72.6	30.7
	-11.8	-13.0	80.6	31.0	80.5	31.7	80.4	32.4	80.3	32.7	77.9	31.6	72.6	29.1
	-9.8	-11.0	84.5	31.6	84.3	32.3	83.3	32.4	80.6	31.1	77.9	29.9	72.6	27.5
	-9.5	-10.0	86.5	31.9	86.3	32.5	83.3	31.4	80.6	30.2	77.9	29.0	72.6	26.7
	-8.5	-9.1	88.4	32.1	88.2	32.8	83.3	30.6	80.6	29.4	77.9	28.3	72.6	26.0
	-7.0	-7.6	91.6	32.5	88.7	31.6	83.3	29.3	80.6	28.2	77.9	27.1	72.6	25.0
	-5.0	-5.6	94.0	31.9	88.7	29.8	83.3	27.7	80.6	26.6	77.9	25.6	72.6	23.6
	-3.0	-3.7	94.0	30.2	88.7	28.2	83.3	26.2	80.6	25.2	77.9	24.3	72.6	22.4
	0.0	-0.7	94.0	27.6	88.7	25.8	83.3	24.0	80.6	23.2	77.9	22.3	72.6	20.6
	3.0	2.2	94.0	25.4	88.7	23.8	83.3	22.2	80.6	21.4	77.9	20.6	72.6	19.1
	5.0	4.1	94.0	24.1	88.7	22.6	83.3	21.1	80.6	20.3	77.9	19.6	72.6	18.1
	7.0	6.0	94.0	22.9	88.7	21.4	83.3	20.0	80.6	19.3	77.9	18.6	72.6	17.3
	9.0	7.9	94.0	21.8	88.7	20.4	83.3	19.1	80.6	18.4	77.9	17.7	72.6	16.5
	11.0	9.8	94.0	20.7	88.7	19.4	83.3	18.1	80.6	17.5	77.9	16.9	72.6	15.7
	13.0	11.8	94.0	19.6	88.7	18.4	83.3	17.3	80.6	16.7	77.9	16.1	72.6	15.0
	15.0	13.7	94.0	18.7	88.7	17.6	83.3	16.5	80.6	15.9	77.9	15.4	72.6	14.3
60 (570)	-19.8	-20.0	68.8	30.9	68.7	31.6	68.5	32.3	68.5	32.7	66.8	31.8	62.2	29.2
	-18.8	-19.0	70.2	31.2	70.1	31.9	70.0	32.5	69.1	32.3	66.8	31.0	62.2	28.5
	-16.7	-17.0	73.3	31.7	73.2	32.4	71.4	31.8	69.1	30.6	66.8	29.4	62.2	27.0
	-13.7	-15.0	76.7	32.2	76.0	32.5	71.4	30.1	69.1	29.0	66.8	27.8	62.2	25.6
	-11.8	-13.0	80.3	32.7	76.0	30.7	71.4	28.5	69.1	27.4	66.8	26.4	62.2	24.3
	-9.8	-11.0	80.6	31.1	76.0	29.0	71.4	26.9	69.1	25.9	66.8	24.9	62.2	23.0
	-9.5	-10.0	80.6	30.2	76.0	28.2	71.4	26.2	69.1	25.2	66.8	24.3	62.2	22.4
	-8.5	-9.1	80.6	29.4	76.0	27.5	71.4	25.5	69.1	24.6	66.8	23.7	62.2	21.8
	-7.0	-7.6	80.6	28.2	76.0	26.3	71.4	24.5	69.1	23.6	66.8	22.7	62.2	21.0
	-5.0	-5.6	80.6	26.6	76.0	24.9	71.4	23.2	69.1	22.3	66.8	21.5	62.2	19.9
	-3.0	-3.7	80.6	25.2	76.0	23.6	71.4	22.0	69.1	21.2	66.8	20.4	62.2	18.9
	0.0	-0.7	80.6	23.2	76.0	21.7	71.4	20.2	69.1	19.5	66.8	18.8	62.2	17.5
	3.0	2.2	80.6	21.4	76.0	20.0	71.4	18.7	69.1	18.1	66.8	17.5	62.2	16.2
	5.0	4.1	80.6	20.3	76.0	19.1	71.4	17.8	69.1	17.2	66.8	16.6	62.2	15.5
	7.0	6.0	80.6	19.3	76.0	18.1	71.4	17.0	69.1	16.4	66.8	15.9	62.2	14.7
	9.0	7.9	80.6	18.4	76.0	17.3	71.4	16.2	69.1	15.7	66.8	15.1	62.2	14.1
	11.0	9.8	80.6	17.5	76.0	16.5	71.4	15.5	69.1	15.0	66.8	14.5	62.2	13.5
	13.0	11.8	80.6	16.7	76.0	15.7	71.4	14.7	69.1	14.3	66.8	13.8	62.2	12.9
	15.0	13.7	80.6	15.9	76.0	15.0	71.4	14.1	69.1	13.6	66.8	13.2	62.2	12.3
50 (475)	-19.8	-20.0	67.1	32.0	63.3	29.8	59.5	27.7	57.6	26.7	55.7	25.6	51.9	23.6
	-18.8	-19.0	67.1	31.2	63.3	29.1	59.5	27.0	57.6	26.0	55.7	25.0	51.9	23.1
	-16.7	-17.0	67.1	29.6	63.3	27.6	59.5	25.7	57.6	24.7	55.7	23.8	51.9	21.9
	-13.7	-15.0	67.1	28.0	63.3	26.2	59.5	24.3	57.6	23.5	55.7	22.6	51.9	20.9
	-11.8	-13.0	67.1	26.5	63.3	24.8	59.5	23.1	57.6	22.2	55.7	21.4	51.9	19.8
	-9.8	-11.0	67.1	25.1	63.3	23.5	59.5	21.9	57.6	21.1	55.7	20.3	51.9	18.8
	-9.5	-10.0	67.1	24.4	63.3	22.8	59.5	21.3	57.6	20.5	55.7	19.8	51.9	18.3
	-8.5	-9.1	67.1	23.8	63.3	22.3	59.5	20.8	57.6	20.1	55.7	19.3	51.9	17.9
	-7.0	-7.6	67.1	22.8	63.3	21.4	59.5	20.0	57.6	19.3	55.7	18.6	51.9	17.2
	-5.0	-5.6	67.1	21.6	63.3	20.3	59.5	18.9	57.6	18.3	55.7	17.6	51.9	16.4
	-3.0	-3.7	67.1	20.5	63.3	19.3	59.5	18.0	57.6	17.4	55.7	16.8	51.9	15.6
	0.0	-0.7	67.1	18.9	63.3	17.8	59.5	16.7	57.6	16.1	55.7	15.6	51.9	14.5
	2.0	2.2	67.1	17.6	63.3	16.5	59.5	15.5	57.6	15.0	55.7	14.5	51.9	13.5
	5.0	4.1	67.1	16.7	63.3	15.7	59.5	14.8	57.6	14.3	55.7	13.8	51.9	12.9
	7.0	6.0	67.1	15.9	63.3	15.0	59.5	14.1	57.6	13.7	55.7	13.2	51.9	12.3
	9.0	7.9	67.1	15.2	63.3	14.3	59.5	13.5	57.6	13.1	55.7	12.6	51.9	11.8
	11.0	9.8	67.1	14.5	63.3	13.7	59.5	12.9	57.6	12.5	55.7	12.1	51.9	11.3
	13.0	11.8	67.1	13.9	63.3	13.1	59.5	12.3	57.6	11.9	55.7	11.6	51.9	10.8
	15.0	13.7	67.1	13.3	63.3	12.5	59.5	11.8	57.6	11.5	55.7	11.1	51.9	10.4

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1313)	-19.8	-20.0	77.6	19.5	77.3	21.1	77.0	22.7	76.8	23.5	76.7	24.2	76.4	25.8
	-18.8	-19.0	79.1	20.1	78.9	21.7	78.6	23.2	78.4	24.0	78.3	24.7	78.0	26.3
	-16.7	-17.0	82.5	21.3	82.2	22.8	81.9	24.2	81.8	25.0	81.6	25.7	81.4	27.2
	-13.7	-15.0	86.1	22.5	85.8	23.9	85.6	25.3	85.4	26.0	85.3	26.7	85.0	28.1
	-11.8	-13.0	90.0	23.6	89.7	24.9	89.5	26.3	89.3	26.9	89.2	27.6	88.9	28.9
	-9.8	-11.0	94.2	24.7	93.9	26.0	93.6	27.3	93.5	27.9	93.4	28.5	93.1	29.8
	-9.5	-10.0	96.4	25.2	96.1	26.5	95.8	27.7	95.7	28.4	95.5	29.0	95.3	30.2
	-8.5	-9.1	98.4	25.7	98.1	26.9	97.9	28.2	97.7	28.8	97.6	29.4	97.3	30.6
	-7.0	-7.6	101.9	26.5	101.6	27.7	101.4	28.8	101.2	29.4	101.1	30.0	100.8	31.2
	-5.0	-5.6	107	27.5	107	28.6	106	29.7	106	30.3	106	30.9	106	32.0
	-3.0	-3.7	112	28.4	111	29.5	111	30.5	111	31.1	111	31.6	111	32.7
	0.0	-0.7	120	29.8	120	30.8	119	31.7	119	32.2	119	32.7	119	33.7
	3.0	2.2	129	31.0	128	31.9	128	32.8	128	33.3	128	33.8	127	34.7
	5.0	4.1	135	31.7	134	32.6	134	33.5	134	33.9	134	34.4	133	35.3
	7.0	6.0	141	32.4	140	33.3	140	34.1	140	34.5	140	35.0	140	35.8
	9.0	7.9	147	33.1	147	33.9	147	34.7	146	35.1	146	35.5	142	34.6
	11.0	9.8	154	33.8	153	34.5	153	35.3	153	35.7	152	35.7	142	32.8
	13.0	11.8	161	34.4	161	35.1	160	35.9	157	35.1	152	33.7	142	31.0
	15.0	13.7	168	35.0	168	35.7	163	34.6	157	33.3	152	32.0	142	29.4
120 (1212)	-19.8	-20.0	77.2	21.7	76.9	23.1	76.6	24.5	76.5	25.3	76.4	26.0	76.1	27.4
	-18.8	-19.0	78.8	22.2	78.5	23.6	78.2	25.0	78.1	25.7	78.0	26.4	77.7	27.9
	-16.7	-17.0	82.1	23.3	81.8	24.6	81.6	26.0	81.4	26.7	81.3	27.3	81.1	28.7
	-13.7	-15.0	85.7	24.4	85.5	25.6	85.2	26.9	85.1	27.6	84.9	28.2	84.7	29.5
	-11.8	-13.0	89.6	25.4	89.4	26.6	89.1	27.9	89.0	28.5	88.9	29.1	88.6	30.3
	-9.8	-11.0	93.8	26.4	93.6	27.6	93.3	28.8	93.2	29.4	93.0	30.0	92.8	31.1
	-9.5	-10.0	96.0	26.9	95.7	28.1	95.5	29.2	95.4	29.8	95.2	30.4	95.0	31.5
	-8.5	-9.1	98.0	27.4	97.8	28.5	97.5	29.6	97.4	30.2	97.2	30.7	97.0	31.9
	-7.0	-7.6	101.5	28.1	101.3	29.2	101.0	30.3	100.9	30.8	100.8	31.3	100.5	32.4
	-5.0	-5.6	106	29.0	106	30.0	106	31.1	106	31.6	106	32.1	105	33.1
	-3.0	-3.7	111	29.9	111	30.8	111	31.8	111	32.3	111	32.8	110	33.8
	0.0	-0.7	120	31.1	119	32.0	119	32.9	119	33.4	119	33.8	119	34.8
	3.0	2.2	128	32.2	128	33.1	128	33.9	128	34.4	127	34.8	127	35.6
	5.0	4.1	134	32.9	134	33.7	134	34.5	133	35.0	133	35.4	131	35.2
	7.0	6.0	140	33.6	140	34.4	140	35.1	140	35.5	140	35.9	131	33.2
	9.0	7.9	147	34.2	146	34.9	146	35.7	145	35.7	140	34.3	131	31.5
	11.0	9.8	153	34.8	153	35.5	150	35.1	145	33.8	140	32.4	131	29.8
	13.0	11.8	161	35.4	160	35.8	150	33.2	145	31.9	140	30.6	131	28.2
	15.0	13.7	168	35.9	160	33.9	150	31.4	145	30.2	140	29.1	131	26.7
110 (1111)	-19.8	-20.0	76.8	23.8	76.5	25.1	76.3	26.4	76.2	27.1	76.1	27.7	75.8	29.1
	-18.8	-19.0	78.4	24.3	78.1	25.6	77.9	26.9	77.8	27.5	77.6	28.2	77.4	29.5
	-16.7	-17.0	81.7	25.3	81.5	26.5	81.2	27.7	81.1	28.4	81.0	29.0	80.8	30.2
	-13.7	-15.0	85.4	26.2	85.1	27.4	84.9	28.6	84.8	29.2	84.6	29.8	84.4	31.0
	-11.8	-13.0	89.3	27.2	89.0	28.3	88.8	29.5	88.7	30.0	88.5	30.6	88.3	31.7
	-9.8	-11.0	93.4	28.1	93.2	29.2	93.0	30.3	92.8	30.8	92.7	31.4	92.5	32.5
	-9.5	-10.0	95.6	28.6	95.4	29.7	95.1	30.7	95.0	31.2	94.9	31.8	94.7	32.8
	-8.5	-9.1	97.7	29.0	97.4	30.0	97.2	31.1	97.1	31.6	96.9	32.1	96.7	33.1
	-7.0	-7.6	101.2	29.7	100.9	30.7	100.7	31.7	100.6	32.2	100.4	32.7	100.2	33.6
	-5.0	-5.6	106	30.5	106	31.5	106	32.4	105	32.9	105	33.4	105	34.3
	-3.0	-3.7	111	31.3	111	32.2	111	33.1	110	33.5	110	34.0	110	34.9
	0.0	-0.7	119	32.4	119	33.3	119	34.1	119	34.5	119	35.0	118	35.8
	3.0	2.2	128	33.5	128	34.3	127	35.0	127	35.4	127	35.8	120	33.5
	5.0	4.1	134	34.1	134	34.9	133	35.6	133	35.9	129	34.5	120	31.7
	7.0	6.0	140	34.7	140	35.4	138	35.3	133	34.0	129	32.6	120	30.0
	9.0	7.9	146	35.3	146	36.0	138	33.4	133	32.1	129	30.9	120	28.4
	11.0	9.8	153	35.8	146	34.1	138	31.6	133	30.4	129	29.2	120	26.9
	13.0	11.8	155	34.6	146	32.2	138	29.9	133	28.8	129	27.7	120	25.5
	15.0	13.7	155	32.7	146	30.5	138	28.4	133	27.3	129	26.3	120	24.2

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (1010)	-19.8	-20.0	76.4	25.9	76.2	27.1	76.0	28.3	75.9	28.9	75.7	29.5	75.5	30.7
	-18.8	-19.0	78.0	26.3	77.8	27.5	77.5	28.7	77.4	29.3	77.3	29.9	77.1	31.1
	-16.7	-17.0	81.3	27.2	81.1	28.4	80.9	29.5	80.8	30.1	80.7	30.6	80.5	31.8
	-13.7	-15.0	85.0	28.1	84.7	29.2	84.5	30.3	84.4	30.8	84.3	31.4	84.1	32.5
	-11.8	-13.0	88.9	29.0	88.7	30.0	88.4	31.1	88.3	31.6	88.2	32.1	88.0	33.1
	-9.8	-11.0	93.0	29.9	92.8	30.9	92.6	31.8	92.5	32.3	92.4	32.8	92.2	33.8
	-9.5	-10.0	95.2	30.3	95.0	31.2	94.8	32.2	94.7	32.7	94.6	33.2	94.4	34.1
	-8.5	-9.1	97.3	30.7	97.0	31.6	96.8	32.5	96.7	33.0	96.6	33.5	96.4	34.4
	-7.0	-7.6	100.8	31.3	100.6	32.2	100.3	33.1	100.2	33.5	100.1	34.0	99.9	34.9
	-5.0	-5.6	106	32.0	105	32.9	105	33.8	105	34.2	105	34.6	105	35.5
	-3.0	-3.7	111	32.7	110	33.6	110	34.4	110	34.8	110	35.2	109	35.6
	0.0	-0.7	119	33.8	119	34.5	118	35.3	118	35.7	117	35.5	109	32.5
	3.0	2.2	127	34.7	127	35.4	125	35.2	121	33.9	117	32.5	109	29.9
	5.0	4.1	133	35.3	133	35.9	125	33.3	121	32.0	117	30.8	109	28.3
	7.0	6.0	140	35.9	133	34.0	125	31.5	121	30.3	117	29.1	109	26.8
	9.0	7.9	141	34.5	133	32.1	125	29.8	121	28.7	117	27.6	109	25.4
	11.0	9.8	141	32.6	133	30.4	125	28.3	121	27.2	117	26.2	109	24.1
	13.0	11.8	141	30.8	133	28.8	125	26.7	121	25.8	117	24.8	109	22.9
	15.0	13.7	141	29.2	133	27.3	125	25.4	121	24.5	117	23.6	109	21.8
90 (909)	-19.8	-20.0	76.0	28.0	75.8	29.1	75.6	30.2	75.5	30.7	75.4	31.3	75.2	32.3
	-18.8	-19.0	77.6	28.4	77.4	29.5	77.2	30.5	77.1	31.1	77.0	31.6	76.8	32.7
	-16.7	-17.0	81.0	29.2	80.8	30.2	80.6	31.3	80.5	31.8	80.4	32.3	80.2	33.3
	-13.7	-15.0	84.6	30.0	84.4	31.0	84.2	32.0	84.1	32.5	84.0	32.9	83.8	33.9
	-11.8	-13.0	88.5	30.8	88.3	31.8	88.1	32.7	88.0	33.1	87.9	33.6	87.7	34.5
	-9.8	-11.0	92.7	31.6	92.5	32.5	92.3	33.4	92.2	33.8	92.1	34.2	91.9	35.1
	-9.5	-10.0	94.9	32.0	94.7	32.8	94.5	33.7	94.4	34.1	94.3	34.6	94.1	35.4
	-8.5	-9.1	96.9	32.3	96.7	33.1	96.5	34.0	96.4	34.4	96.3	34.8	96.1	35.7
	-7.0	-7.6	100.4	32.8	100.2	33.7	100.0	34.5	99.9	34.9	99.8	35.3	98.0	35.2
	-5.0	-5.6	105	33.5	105	34.3	105	35.1	105	35.5	105	35.9	98.0	33.2
	-3.0	-3.7	110	34.2	110	34.9	110	35.7	109	35.6	105	34.2	98.0	31.3
	0.0	-0.7	118	35.1	118	35.8	113	33.8	109	32.5	105	31.2	98.0	28.7
	3.0	2.2	127	35.9	120	33.4	113	31.0	109	29.9	105	28.7	98.0	26.4
	5.0	4.1	127	33.9	120	31.6	113	29.4	109	28.3	105	27.2	98.0	25.0
	7.0	6.0	127	32.1	120	29.9	113	27.8	109	26.8	105	25.8	98.0	23.8
	9.0	7.9	127	30.4	120	28.3	113	26.4	109	25.4	105	24.5	98.0	22.6
	11.0	9.8	127	28.8	120	26.9	113	25.0	109	24.1	105	23.2	98.0	21.5
	13.0	11.8	127	27.2	120	25.5	113	23.7	109	22.9	105	22.0	98.0	20.4
	15.0	13.7	127	25.9	120	24.2	113	22.6	109	21.8	105	21.0	98.0	19.4
80 (808)	-19.8	-20.0	75.6	30.1	75.5	31.1	75.3	32.0	75.2	32.5	75.1	33.0	74.9	34.0
	-18.8	-19.0	77.2	30.5	77.0	31.4	76.9	32.4	76.8	32.8	76.7	33.3	76.5	34.3
	-16.7	-17.0	80.6	31.2	80.4	32.1	80.2	33.0	80.1	33.5	80.0	33.9	79.9	34.8
	-13.7	-15.0	84.2	31.9	84.0	32.8	83.8	33.7	83.8	34.1	83.7	34.5	83.5	35.4
	-11.8	-13.0	88.1	32.6	87.9	33.5	87.7	34.3	87.7	34.7	87.6	35.1	87.1	35.8
	-9.8	-11.0	92.3	33.3	92.1	34.1	91.9	34.9	91.8	35.3	91.7	35.7	87.1	33.7
	-9.5	-10.0	94.5	33.7	94.3	34.4	94.1	35.2	94.0	35.6	93.6	35.7	87.1	32.8
	-8.5	-9.1	96.5	33.9	96.3	34.7	96.1	35.4	96.1	35.8	93.6	34.8	87.1	31.9
	-7.0	-7.6	100.0	34.4	99.8	35.2	99.6	35.9	96.8	34.7	93.6	33.3	87.1	30.6
	-5.0	-5.6	105	35.1	105	35.7	100	34.0	96.8	32.7	93.6	31.4	87.1	28.8
	-3.0	-3.7	110	35.6	106	34.6	100	32.1	96.8	30.9	93.6	29.7	87.1	27.3
	0.0	-0.7	113	34.0	106	31.6	100	29.4	96.8	28.3	93.6	27.2	87.1	25.1
	3.0	2.2	113	31.2	106	29.1	100	27.0	96.8	26.0	93.6	25.0	87.1	23.1
	5.0	4.1	113	29.5	106	27.5	100	25.6	96.8	24.7	93.6	23.8	87.1	22.0
	7.0	6.0	113	27.9	106	26.1	100	24.3	96.8	23.4	93.6	22.6	87.1	20.9
	9.0	7.9	113	26.5	106	24.8	100	23.1	96.8	22.3	93.6	21.4	87.1	19.9
	11.0	9.8	113	25.1	106	23.5	100	21.9	96.8	21.2	93.6	20.4	87.1	18.9
	13.0	11.8	113	23.8	106	22.3	100	20.8	96.8	20.1	93.6	19.4	87.1	18.0
	15.0	13.7	113	22.6	106	21.2	100	19.8	96.8	19.2	93.6	18.5	87.1	17.2

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (707)	-19.8	-20.0	75.2	32.2	75.1	33.1	74.9	33.9	74.9	34.3	74.8	34.8	74.6	35.6				
	-18.8	-19.0	76.8	32.6	76.7	33.4	76.5	34.2	76.4	34.6	76.4	35.0	76.2	35.9				
	-16.7	-17.0	80.2	33.2	80.0	34.0	79.9	34.8	79.8	35.2	79.7	35.6	79.3	34.0				
	-13.7	-15.0	83.8	33.8	83.7	34.6	83.5	35.3	83.4	35.7	81.9	35.1	76.3	32.2				
	-11.8	-13.0	87.7	34.4	87.6	35.2	87.4	35.9	84.7	34.5	81.9	33.1	76.3	30.4				
	-9.8	-11.0	91.9	35.0	91.7	35.7	87.5	33.9	84.7	32.6	81.9	31.3	76.3	28.8				
	-9.5	-10.0	94.1	35.3	93.1	35.5	87.5	32.9	84.7	31.7	81.9	30.4	76.3	28.0				
	-8.5	-9.1	96.1	35.6	93.1	34.6	87.5	32.1	84.7	30.8	81.9	29.6	76.3	27.3				
	-7.0	-7.6	98.7	35.5	93.1	33.1	87.5	30.7	84.7	29.5	81.9	28.4	76.3	26.1				
	-5.0	-5.6	99	33.5	93.1	31.2	87.5	29.0	84.7	27.9	81.9	26.8	76.3	24.7				
	-3.0	-3.7	99	31.6	93.1	29.5	87.5	27.4	84.7	26.4	81.9	25.4	76.3	23.4				
	0.0	-0.7	99	29.0	93.1	27.0	87.5	25.2	84.7	24.3	81.9	23.4	76.3	21.6				
	3.0	2.2	99	26.6	93.1	24.9	87.5	23.2	84.7	22.4	81.9	21.6	76.3	20.0				
	5.0	4.1	99	25.3	93.1	23.6	87.5	22.0	84.7	21.3	81.9	20.5	76.3	19.0				
	7.0	6.0	99	24.0	93.1	22.4	87.5	21.0	84.7	20.2	81.9	19.5	76.3	18.1				
	9.0	7.9	99	22.8	93.1	21.3	87.5	19.9	84.7	19.3	81.9	18.6	76.3	17.2				
	11.0	9.8	99	21.6	93.1	20.3	87.5	19.0	84.7	18.3	81.9	17.7	76.3	16.4				
	13.0	11.8	99	20.5	93.1	19.3	87.5	18.1	84.7	17.4	81.9	16.9	76.3	15.7				
	15.0	13.7	99	19.6	93.1	18.4	87.5	17.2	84.7	16.7	81.9	16.1	76.3	15.0				
60 (606)	-19.8	-20.0	74.9	34.4	74.7	35.1	74.6	35.8	72.6	34.7	70.2	33.3	65.4	30.6				
	-18.8	-19.0	76.4	34.6	76.3	35.3	75.0	35.2	72.6	33.8	70.2	32.5	65.4	29.8				
	-16.7	-17.0	79.8	35.2	79.7	35.9	75.0	33.3	72.6	32.1	70.2	30.8	65.4	28.3				
	-13.7	-15.0	83.4	35.7	79.8	34.0	75.0	31.6	72.6	30.4	70.2	29.2	65.4	26.8				
	-11.8	-13.0	84.6	34.5	79.8	32.1	75.0	29.8	72.6	28.7	70.2	27.6	65.4	25.4				
	-9.8	-11.0	84.6	32.6	79.8	30.4	75.0	28.2	72.6	27.2	70.2	26.1	65.4	24.1				
	-9.5	-10.0	84.6	31.6	79.8	29.5	75.0	27.4	72.6	26.4	70.2	25.4	65.4	23.5				
	-8.5	-9.1	84.6	30.8	79.8	28.8	75.0	26.8	72.6	25.8	70.2	24.8	65.4	22.9				
	-7.0	-7.6	84.6	29.5	79.8	27.6	75.0	25.6	72.6	24.7	70.2	23.8	65.4	22.0				
	-5.0	-5.6	84.6	27.9	79.8	26.0	75.0	24.3	72.6	23.4	70.2	22.5	65.4	20.8				
	-3.0	-3.7	84.6	26.4	79.8	24.7	75.0	23.0	72.6	22.2	70.2	21.4	65.4	19.8				
	0.0	-0.7	84.6	24.2	79.8	22.7	75.0	21.2	72.6	20.5	70.2	19.7	65.4	18.3				
	3.0	2.2	84.6	22.4	79.8	21.0	75.0	19.6	72.6	18.9	70.2	18.3	65.4	17.0				
	5.0	4.1	84.6	21.3	79.8	19.9	75.0	18.7	72.6	18.0	70.2	17.4	65.4	16.2				
	7.0	6.0	84.6	20.2	79.8	19.0	75.0	17.8	72.6	17.2	70.2	16.6	65.4	15.4				
	9.0	7.9	84.6	19.2	79.8	18.1	75.0	16.9	72.6	16.4	70.2	15.8	65.4	14.7				
	11.0	9.8	84.6	18.3	79.8	17.2	75.0	16.2	72.6	15.6	70.2	15.1	65.4	14.1				
	13.0	11.8	84.6	17.4	79.8	16.4	75.0	15.4	72.6	14.9	70.2	14.4	65.4	13.5				
	15.0	13.7	84.6	16.7	79.8	15.7	75.0	14.7	72.6	14.3	70.2	13.8	65.4	12.9				
50 (505)	-19.8	-20.0	70.5	33.5	66.5	31.2	62.5	29.0	60.5	27.9	58.5	26.8	54.5	24.7				
	-18.8	-19.0	70.5	32.6	66.5	30.4	62.5	28.3	60.5	27.2	58.5	26.2	54.5	24.2				
	-16.7	-17.0	70.5	31.0	66.5	28.9	62.5	26.9	60.5	25.9	58.5	24.9	54.5	23.0				
	-13.7	-15.0	70.5	29.3	66.5	27.4	62.5	25.5	60.5	24.6	58.5	23.7	54.5	21.9				
	-11.8	-13.0	70.5	27.8	66.5	26.0	62.5	24.2	60.5	23.3	58.5	22.4	54.5	20.8				
	-9.8	-11.0	70.5	26.3	66.5	24.6	62.5	22.9	60.5	22.1	58.5	21.3	54.5	19.7				
	-9.5	-10.0	70.5	25.6	66.5	23.9	62.5	22.3	60.5	21.5	58.5	20.7	54.5	19.2				
	-8.5	-9.1	70.5	24.9	66.5	23.3	62.5	21.8	60.5	21.0	58.5	20.3	54.5	18.8				
	-7.0	-7.6	70.5	23.9	66.5	22.4	62.5	20.9	60.5	20.2	58.5	19.5	54.5	18.1				
	-5.0	-5.6	70.5	22.6	66.5	21.2	62.5	19.8	60.5	19.2	58.5	18.5	54.5	17.2				
	-3.0	-3.7	70.5	21.5	66.5	20.2	62.5	18.9	60.5	18.2	58.5	17.6	54.5	16.3				
	0.0	-0.7	70.5	19.8	66.5	18.6	62.5	17.4	60.5	16.9	58.5	16.3	54.5	15.2				
	3.0	2.2	70.5	18.4	66.5	17.3	62.5	16.2	60.5	15.7	58.5	15.2	54.5	14.1				
	5.0	4.1	70.5	17.5	66.5	16.5	62.5	15.5	60.5	15.0	58.5	14.5	54.5	13.5				
	7.0	6.0	70.5	16.7	66.5	15.7	62.5	14.8	60.5	14.3	58.5	13.8	54.5	12.9				
	9.0	7.9	70.5	15.9	66.5	15.0	62.5	14.1	60.5	13.7	58.5	13.2	54.5	12.4				
	11.0	9.8	70.5	15.2	66.5	14.3	62.5	13.5	60.5	13.1	58.5	12.7	54.5	11.8				
	13.0	11.8	70.5	14.5	66.5	13.7	62.5	12.9	60.5	12.5	58.5	12.1	54.5	11.3				
	15.0	13.7	70.5	13.9	66.5	13.1	62.5	12.4	60.5	12.0	58.5	11.6	54.5	10.9				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

14

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1365)	-19.8	-20.0	78.3	18.5	78.0	20.2	77.7	21.9	77.6	22.7	77.4	23.6	77.1	25.25
	-18.8	-19.0	79.9	19.1	79.6	20.8	79.3	22.4	79.1	23.3	79.0	24.1	78.7	25.74
	-16.7	-17.0	83.3	20.4	83.0	22.0	82.7	23.6	82.5	24.3	82.4	25.1	82.1	26.71
	-13.7	-15.0	86.9	21.6	86.6	23.1	86.3	24.7	86.2	25.4	86.0	26.2	85.7	27.7
	-11.8	-13.0	90.8	22.9	90.5	24.3	90.2	25.7	90.1	26.5	89.9	27.2	89.6	28.6
	-9.8	-11.0	95.0	24.0	94.7	25.4	94.4	26.8	94.3	27.5	94.1	28.2	93.8	29.5
	-9.5	-10.0	97.2	24.6	96.9	26.0	96.6	27.3	96.5	28.0	96.3	28.7	96.0	30.0
	-8.5	-9.1	99.3	25.1	99.0	26.5	98.7	27.8	98.5	28.4	98.4	29.1	98.1	30.4
	-7.0	-7.6	103	26.0	103	27.2	102	28.5	102	29.1	102	29.8	102	31.0
	-5.0	-5.6	108	27.1	107	28.3	107	29.5	107	30.1	107	30.7	107	31.9
	-3.0	-3.7	113	28.0	112	29.2	112	30.3	112	30.9	112	31.5	112	32.6
	0.0	-0.7	121	29.5	121	30.6	120	31.6	120	32.2	120	32.7	120	33.8
	3.0	2.2	130	30.8	129	31.8	129	32.8	129	33.3	129	33.8	129	34.8
	5.0	4.1	136	31.6	135	32.6	135	33.5	135	34.0	135	34.5	134	35.4
	7.0	6.0	142	32.4	142	33.3	141	34.2	141	34.7	141	35.1	141	36.0
	9.0	7.9	148	33.1	148	34.0	148	34.9	148	35.3	148	35.7	147	36.6
	11.0	9.8	155	33.8	155	34.6	155	35.5	154	35.9	154	36.3	149	35.3
	13.0	11.8	163	34.5	162	35.3	162	36.1	162	36.5	160	36.3	149	33.3
	15.0	13.7	170	35.1	169	35.9	169	36.6	165	35.8	160	34.4	149	31.6
120 (1260)	-19.8	-20.0	77.9	20.8	77.6	22.3	77.4	23.9	77.2	24.7	77.1	25.5	76.8	27.0
	-18.8	-19.0	79.5	21.4	79.2	22.9	78.9	24.4	78.8	25.2	78.7	25.9	78.4	27.5
	-16.7	-17.0	82.9	22.5	82.6	24.0	82.3	25.4	82.2	26.2	82.0	26.9	81.7	28.4
	-13.7	-15.0	86.5	23.7	86.2	25.1	85.9	26.5	85.8	27.2	85.7	27.9	85.4	29.3
	-11.8	-13.0	90.4	24.8	90.1	26.1	89.9	27.5	89.7	28.1	89.6	28.8	89.3	30.1
	-9.8	-11.0	94.6	25.9	94.3	27.2	94.1	28.4	93.9	29.1	93.8	29.7	93.5	31.0
	-9.5	-10.0	96.8	26.4	96.5	27.7	96.3	28.9	96.1	29.5	96.0	30.2	95.7	31.4
	-8.5	-9.1	98.9	26.9	98.6	28.1	98.3	29.3	98.2	29.9	98.0	30.5	97.8	31.8
	-7.0	-7.6	102	27.7	102	28.9	102	30.0	102	30.6	102	31.2	101	32.4
	-5.0	-5.6	107	28.7	107	29.8	107	30.9	107	31.5	107	32.0	106	33.1
	-3.0	-3.7	112	29.6	112	30.7	112	31.7	112	32.2	111	32.8	111	33.8
	0.0	-0.7	121	30.9	120	31.9	120	32.9	120	33.4	120	33.9	120	34.9
	3.0	2.2	129	32.2	129	33.1	129	34.0	129	34.5	128	34.9	128	35.8
	5.0	4.1	135	32.9	135	33.8	135	34.7	135	35.1	134	35.5	134	36.4
	7.0	6.0	142	33.6	141	34.5	141	35.3	141	35.7	141	36.1	138	35.8
	9.0	7.9	148	34.3	148	35.1	147	35.9	147	36.3	147	36.7	138	33.8
	11.0	9.8	155	34.9	154	35.7	154	36.5	153	36.3	148	34.9	138	32.0
	13.0	11.8	162	35.6	162	36.3	158	35.7	153	34.3	148	32.9	138	30.3
	15.0	13.7	169	36.1	168	36.4	158	33.8	153	32.5	148	31.2	138	28.8
110 (1155)	-19.8	-20.0	77.5	23.1	77.2	24.5	77.0	25.9	76.9	26.6	76.7	27.3	76.5	28.8
	-18.8	-19.0	79.1	23.6	78.8	25.0	78.6	26.4	78.4	27.1	78.3	27.8	78.1	29.2
	-16.7	-17.0	82.4	24.7	82.2	26.0	81.9	27.3	81.8	28.0	81.7	28.7	81.4	30.0
	-13.7	-15.0	86.1	25.7	85.8	27.0	85.6	28.3	85.5	28.9	85.3	29.5	85.1	30.8
	-11.8	-13.0	90.0	26.7	89.8	28.0	89.5	29.2	89.4	29.8	89.3	30.4	89.0	31.6
	-9.8	-11.0	94.2	27.8	94.0	28.9	93.7	30.1	93.6	30.7	93.5	31.2	93.2	32.4
	-9.5	-10.0	96.4	28.3	96.2	29.4	95.9	30.5	95.8	31.1	95.7	31.7	95.4	32.8
	-8.5	-9.1	98.5	28.7	98.2	29.8	98.0	30.9	97.8	31.5	97.7	32.0	97.4	33.1
	-7.0	-7.6	102	29.4	102	30.5	101	31.5	101	32.1	101	32.6	101	33.7
	-5.0	-5.6	107	30.3	107	31.3	106	32.4	106	32.9	106	33.4	106	34.4
	-3.0	-3.7	112	31.1	112	32.1	111	33.1	111	33.6	111	34.1	111	35.0
	0.0	-0.7	120	32.4	120	33.3	120	34.2	120	34.6	119	35.1	119	36.0
	3.0	2.2	129	33.5	129	34.3	128	35.2	128	35.6	128	36.0	126	36.0
	5.0	4.1	135	34.2	135	35.0	134	35.8	134	36.2	134	36.6	126	34.1
	7.0	6.0	141	34.8	141	35.6	141	36.4	140	36.6	135	35.1	126	32.2
	9.0	7.9	148	35.5	147	36.2	145	36.0	140	34.6	135	33.2	126	30.5
	11.0	9.8	154	36.0	154	36.7	145	34.0	140	32.7	135	31.5	126	29.0
	13.0	11.8	162	36.6	154	34.6	145	32.2	140	30.9	135	29.7	126	27.4
	15.0	13.7	163	35.2	154	32.8	145	30.5	140	29.4	135	28.2	126	26.0

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (1050)	-19.8	-20.0	77.1	25.3	76.9	26.6	76.6	27.9	76.5	28.6	76.4	29.2	76.2	30.5
	-18.8	-19.0	78.7	25.8	78.4	27.1	78.2	28.4	78.1	29.0	78.0	29.6	77.8	30.9
	-16.7	-17.0	82.0	26.8	81.8	28.0	81.6	29.2	81.5	29.8	81.3	30.4	81.1	31.7
	-13.7	-15.0	85.7	27.8	85.5	28.9	85.2	30.1	85.1	30.7	85.0	31.2	84.8	32.4
	-11.8	-13.0	89.6	28.7	89.4	29.8	89.1	30.9	89.0	31.5	88.9	32.0	88.7	33.1
	-9.8	-11.0	93.8	29.6	93.6	30.7	93.3	31.7	93.2	32.3	93.1	32.8	92.9	33.8
	-9.5	-10.0	96.0	30.1	95.8	31.1	95.5	32.1	95.4	32.6	95.3	33.2	95.1	34.2
	-8.5	-9.1	98.1	30.5	97.8	31.5	97.6	32.5	97.5	33.0	97.4	33.5	97.1	34.5
	-7.0	-7.6	102	31.1	101	32.1	101	33.1	101	33.5	100.9	34.0	100.7	35.0
	-5.0	-5.6	107	31.9	106	32.9	106	33.8	106	34.3	106	34.7	106	35.6
	-3.0	-3.7	111	32.7	111	33.6	111	34.5	111	34.9	111	35.4	111	36.2
	0.0	-0.7	120	33.8	120	34.7	119	35.5	119	35.9	119	36.3	115	35.0
	3.0	2.2	128	34.8	128	35.6	128	36.4	127	36.5	123	35.0	115	32.2
	5.0	4.1	134	35.5	134	36.2	132	35.8	127	34.5	123	33.1	115	30.4
	7.0	6.0	141	36.1	140	36.5	132	33.9	127	32.6	123	31.3	115	28.8
	9.0	7.9	147	36.6	140	34.6	132	32.1	127	30.9	123	29.7	115	27.4
	11.0	9.8	148	35.1	140	32.7	132	30.4	127	29.3	123	28.2	115	26.0
	13.0	11.8	148	33.1	140	30.9	132	28.8	127	27.7	123	26.7	115	24.6
	15.0	13.7	148	31.4	140	29.4	132	27.3	127	26.3	123	25.3	115	23.4
90 (945)	-19.8	-20.0	76.7	27.6	76.5	28.8	76.3	30.0	76.2	30.5	76.1	31.1	75.9	32.3
	-18.8	-19.0	78.3	28.1	78.1	29.2	77.9	30.3	77.7	30.9	77.6	31.5	77.4	32.6
	-16.7	-17.0	81.6	28.9	81.4	30.0	81.2	31.1	81.1	31.7	81.0	32.2	80.8	33.3
	-13.7	-15.0	85.3	29.8	85.1	30.8	84.9	31.9	84.8	32.4	84.7	32.9	84.4	34.0
	-11.8	-13.0	89.2	30.6	89.0	31.6	88.8	32.6	88.7	33.1	88.6	33.6	88.4	34.6
	-9.8	-11.0	93.4	31.5	93.2	32.4	93.0	33.4	92.9	33.8	92.8	34.3	92.6	35.3
	-9.5	-10.0	95.6	31.9	95.4	32.8	95.2	33.7	95.1	34.2	95.0	34.7	94.8	35.6
	-8.5	-9.1	97.6	32.2	97.4	33.1	97.2	34.1	97.1	34.5	97.0	35.0	96.8	35.9
	-7.0	-7.6	101	32.8	101	33.7	100.8	34.6	100.7	35.0	100.6	35.4	100.3	36.3
	-5.0	-5.6	106	33.6	106	34.4	106	35.2	106	35.7	106	36.1	103	35.7
	-3.0	-3.7	111	34.3	111	35.0	111	35.8	111	36.2	110	36.6	103	33.8
	0.0	-0.7	119	35.3	119	36.0	118	36.4	115	35.0	111	33.6	103	30.9
	3.0	2.2	128	36.2	126	36.0	118	33.4	115	32.1	111	30.9	103	28.4
	5.0	4.1	134	36.5	126	34.0	118	31.6	115	30.4	111	29.3	103	27.0
	7.0	6.0	134	34.5	126	32.2	118	29.9	115	28.8	111	27.7	103	25.6
	9.0	7.9	134	32.7	126	30.5	118	28.4	115	27.3	111	26.3	103	24.3
	11.0	9.8	134	31.0	126	28.9	118	26.9	115	26.0	111	25.0	103	23.1
	13.0	11.8	134	29.3	126	27.4	118	25.5	115	24.6	111	23.7	103	21.9
	15.0	13.7	134	27.8	126	26.0	118	24.3	115	23.4	111	22.6	103	20.9
80 (840)	-19.8	-20.0	76.3	29.9	76.1	30.9	75.9	32.0	75.8	32.5	75.7	33.0	75.5	34.0
	-18.8	-19.0	77.9	30.3	77.7	31.3	77.5	32.3	77.4	32.8	77.3	33.3	77.1	34.4
	-16.7	-17.0	81.2	31.1	81.0	32.0	80.9	33.0	80.8	33.5	80.7	34.0	80.5	35.0
	-13.7	-15.0	84.9	31.8	84.7	32.8	84.5	33.7	84.4	34.2	84.3	34.6	84.1	35.6
	-11.8	-13.0	88.8	32.6	88.6	33.5	88.4	34.4	88.3	34.8	88.2	35.3	88.1	36.1
	-9.8	-11.0	93.0	33.3	92.8	34.2	92.6	35.0	92.5	35.4	92.4	35.9	91.7	36.4
	-9.5	-10.0	95.2	33.7	95.0	34.5	94.8	35.3	94.7	35.8	94.6	36.2	91.7	35.3
	-8.5	-9.1	97.2	34.0	97.1	34.8	96.9	35.6	96.8	36.0	96.7	36.4	91.7	34.4
	-7.0	-7.6	100.8	34.5	100.6	35.3	100.4	36.1	100.3	36.5	98.4	35.8	91.7	32.9
	-5.0	-5.6	106	35.2	106	35.9	105	36.6	102	35.2	98.4	33.8	91.7	31.1
	-3.0	-3.7	111	35.8	110	36.5	105	34.6	102	33.2	98.4	31.9	91.7	29.4
	0.0	-0.7	119	36.6	112	34.1	105	31.6	102	30.5	98.4	29.3	91.7	27.0
	3.0	2.2	119	33.5	112	31.3	105	29.1	102	28.0	98.4	27.0	91.7	24.9
	5.0	4.1	119	31.7	112	29.6	105	27.6	102	26.6	98.4	25.6	91.7	23.6
	7.0	6.0	119	30.0	112	28.1	105	26.2	102	25.2	98.4	24.3	91.7	22.5
	9.0	7.9	119	28.5	112	26.6	105	24.8	102	23.9	98.4	23.1	91.7	21.4
	11.0	9.8	119	27.0	112	25.3	105	23.6	102	22.8	98.4	22.0	91.7	20.3
	13.0	11.8	119	25.6	112	24.0	105	22.4	102	21.6	98.4	20.9	91.7	19.3
	15.0	13.7	119	24.4	112	22.8	105	21.3	102	20.6	98.4	19.9	91.7	18.5

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 TC kW	16.0 PI kW	18.0 TC kW	18.0 PI kW	20.0 TC kW	20.0 PI kW	21.0 TC kW	21.0 PI kW	22.0 TC kW	22.0 PI kW	24.0 TC kW	24.0 PI kW
70 (735)	-19.8	-20.0	75.9	32.2	75.7	33.1	75.6	34.0	75.5	34.4	75.4	34.9	75.2	35.8
	-18.8	-19.0	77.5	32.5	77.3	33.4	77.1	34.3	77.1	34.7	77.0	35.2	76.8	36.1
	-16.7	-17.0	80.8	33.2	80.7	34.0	80.5	34.9	80.4	35.3	80.3	35.8	80.2	36.6
	-13.7	-15.0	84.5	33.9	84.3	34.7	84.1	35.5	84.1	35.9	84.0	36.3	80.2	34.7
	-11.8	-13.0	88.4	34.5	88.2	35.3	88.1	36.1	88.0	36.5	86.1	35.7	80.2	32.8
	-9.8	-11.0	92.6	35.2	92.4	35.9	92.1	36.5	89.1	35.1	86.1	33.7	80.2	31.0
	-9.5	-10.0	94.8	35.5	94.6	36.2	92.1	35.5	89.1	34.1	86.1	32.8	80.2	30.1
	-8.5	-9.1	96.8	35.8	96.7	36.5	92.1	34.6	89.1	33.2	86.1	31.9	80.2	29.4
	-7.0	-7.6	100.4	36.2	98.0	35.6	92.1	33.1	89.1	31.8	86.1	30.6	80.2	28.2
	-5.0	-5.6	104	36.0	98.0	33.6	92.1	31.2	89.1	30.0	86.1	28.9	80.2	26.6
	-3.0	-3.7	104	34.1	98.0	31.8	92.1	29.5	89.1	28.4	86.1	27.4	80.2	25.2
	0.0	-0.7	104	31.2	98.0	29.1	92.1	27.1	89.1	26.1	86.1	25.2	80.2	23.2
	3.0	2.2	104	28.7	98.0	26.8	92.1	25.0	89.1	24.1	86.1	23.2	80.2	21.5
	5.0	4.1	104	27.2	98.0	25.4	92.1	23.7	89.1	22.9	86.1	22.1	80.2	20.4
	7.0	6.0	104	25.8	98.0	24.2	92.1	22.6	89.1	21.8	86.1	21.0	80.2	19.5
	9.0	7.9	104	24.5	98.0	23.0	92.1	21.5	89.1	20.7	86.1	20.0	80.2	18.5
	11.0	9.8	104	23.3	98.0	21.8	92.1	20.4	89.1	19.7	86.1	19.0	80.2	17.7
	13.0	11.8	104	22.1	98.0	20.7	92.1	19.4	89.1	18.8	86.1	18.1	80.2	16.9
	15.0	13.7	104	21.1	98.0	19.8	92.1	18.5	89.1	17.9	86.1	17.3	80.2	16.1
60 (630)	-19.8	-20.0	75.5	34.5	75.3	35.2	75.2	36.0	75.1	36.4	73.8	35.9	68.8	32.9
	-18.8	-19.0	77.1	34.7	76.9	35.5	76.8	36.3	76.4	36.4	73.8	34.9	68.8	32.1
	-16.7	-17.0	80.4	35.3	80.3	36.1	78.9	35.9	76.4	34.5	73.8	33.2	68.8	30.5
	-13.7	-15.0	84.1	35.9	83.9	36.6	78.9	34.0	76.4	32.7	73.8	31.4	68.8	28.9
	-11.8	-13.0	88.0	36.5	84.0	34.6	78.9	32.2	76.4	30.9	73.8	29.7	68.8	27.4
	-9.8	-11.0	89.0	35.1	84.0	32.7	78.9	30.4	76.4	29.3	73.8	28.2	68.8	26.0
	-9.5	-10.0	89.0	34.1	84.0	31.8	78.9	29.6	76.4	28.5	73.8	27.4	68.8	25.3
	-8.5	-9.1	89.0	33.2	84.0	31.0	78.9	28.8	76.4	27.8	73.8	26.7	68.8	24.7
	-7.0	-7.6	89.0	31.8	84.0	29.7	78.9	27.6	76.4	26.6	73.8	25.6	68.8	23.7
	-5.0	-5.6	89.0	30.0	84.0	28.0	78.9	26.1	76.4	25.2	73.8	24.3	68.8	22.4
	-3.0	-3.7	89.0	28.4	84.0	26.6	78.9	24.8	76.4	23.9	73.8	23.0	68.8	21.3
	0.0	-0.7	89.0	26.1	84.0	24.4	78.9	22.8	76.4	22.0	73.8	21.2	68.8	19.7
	3.0	2.2	89.0	24.1	84.0	22.6	78.9	21.1	76.4	20.4	73.8	19.7	68.8	18.3
	5.0	4.1	89.0	22.9	84.0	21.5	78.9	20.1	76.4	19.4	73.8	18.7	68.8	17.4
	7.0	6.0	89.0	21.8	84.0	20.4	78.9	19.1	76.4	18.5	73.8	17.9	68.8	16.6
	9.0	7.9	89.0	20.7	84.0	19.5	78.9	18.2	76.4	17.6	73.8	17.0	68.8	15.9
	11.0	9.8	89.0	19.7	84.0	18.5	78.9	17.4	76.4	16.8	73.8	16.3	68.8	15.2
	13.0	11.8	89.0	18.8	84.0	17.7	78.9	16.6	76.4	16.0	73.8	15.5	68.8	14.5
	15.0	13.7	89.0	17.9	84.0	16.9	78.9	15.8	76.4	15.3	73.8	14.8	68.8	13.9
50 (525)	-19.8	-20.0	74.2	36.1	70.0	33.6	65.8	31.2	63.6	30.1	61.5	28.9	57.3	26.6
	-18.8	-19.0	74.2	35.2	70.0	32.8	65.8	30.5	63.6	29.3	61.5	28.2	57.3	26.0
	-16.7	-17.0	74.2	33.4	70.0	31.1	65.8	28.9	63.6	27.9	61.5	26.8	57.3	24.8
	-13.7	-15.0	74.2	31.6	70.0	29.5	65.8	27.5	63.6	26.5	61.5	25.5	57.3	23.5
	-11.8	-13.0	74.2	29.9	70.0	28.0	65.8	26.0	63.6	25.1	61.5	24.2	57.3	22.4
	-9.8	-11.0	74.2	28.3	70.0	26.5	65.8	24.7	63.6	23.8	61.5	22.9	57.3	21.2
	-9.5	-10.0	74.2	27.5	70.0	25.8	65.8	24.0	63.6	23.2	61.5	22.3	57.3	20.7
	-8.5	-9.1	74.2	26.9	70.0	25.1	65.8	23.5	63.6	22.6	61.5	21.8	57.3	20.2
	-7.0	-7.6	74.2	25.8	70.0	24.1	65.8	22.5	63.6	21.8	61.5	21.0	57.3	19.4
	-5.0	-5.6	74.2	24.4	70.0	22.9	65.8	21.4	63.6	20.6	61.5	19.9	57.3	18.5
	-3.0	-3.7	74.2	23.2	70.0	21.7	65.8	20.3	63.6	19.6	61.5	18.9	57.3	17.6
	0.0	-0.7	74.2	21.4	70.0	20.1	65.8	18.8	63.6	18.2	61.5	17.5	57.3	16.3
	3.0	2.2	74.2	19.8	70.0	18.6	65.8	17.4	63.6	16.9	61.5	16.3	57.3	15.2
	5.0	4.1	74.2	18.8	70.0	17.7	65.8	16.6	63.6	16.1	61.5	15.6	57.3	14.5
	7.0	6.0	74.2	17.9	70.0	16.9	65.8	15.9	63.6	15.4	61.5	14.9	57.3	13.9
	9.0	7.9	74.2	17.1	70.0	16.1	65.8	15.2	63.6	14.7	61.5	14.2	57.3	13.3
	11.0	9.8	74.2	16.3	70.0	15.4	65.8	14.5	63.6	14.1	61.5	13.6	57.3	12.7
	13.0	11.8	74.2	15.6	70.0	14.7	65.8	13.9	63.6	13.4	61.5	13.0	57.3	12.2
	15.0	13.7	74.2	14.9	70.0	14.1	65.8	13.3	63.6	12.9	61.5	12.5	57.3	11.7

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1430)	-19.8	-20.0	79.1	17.4	78.8	19.2	78.4	21.0	78.3	21.9	78.1	22.8	77.8	24.6
	-18.8	-19.0	80.7	18.1	80.3	19.8	80.0	21.6	79.9	22.5	79.7	23.4	79.4	25.2
	-16.7	-17.0	84.0	19.4	83.7	21.1	83.4	22.8	83.2	23.6	83.1	24.5	82.8	26.2
	-13.7	-15.0	87.7	20.7	87.4	22.4	87.1	24.0	86.9	24.8	86.7	25.6	86.4	27.2
	-11.8	-13.0	91.6	22.1	91.3	23.6	91.0	25.1	90.8	25.9	90.7	26.7	90.4	28.2
	-9.8	-11.0	95.9	23.3	95.5	24.8	95.2	26.3	95.1	27.0	94.9	27.7	94.6	29.2
	-9.5	-10.0	98	23.9	98	25.4	97	26.8	97	27.5	97.1	28.3	96.8	29.7
	-8.5	-9.1	100	24.5	100	25.9	99	27.3	99	28.0	99	28.7	99	30.1
	-7.0	-7.6	104	25.4	103	26.8	103	28.1	103	28.8	103	29.5	102	30.8
	-5.0	-5.6	109	26.6	108	27.8	108	29.1	108	29.8	108	30.4	107	31.7
	-3.0	-3.7	114	27.6	113	28.8	113	30.1	113	30.7	113	31.3	112	32.5
	0.0	-0.7	122	29.2	122	30.3	121	31.5	121	32.0	121	32.6	121	33.8
	3.0	2.2	131	30.6	131	31.7	130	32.7	130	33.3	130	33.8	130	34.8
	5.0	4.1	137	31.5	137	32.5	136	33.5	136	34.0	136	34.5	136	35.5
	7.0	6.0	143	32.3	143	33.3	143	34.2	142	34.7	142	35.2	142	36.2
	9.0	7.9	150	33.1	149	34.0	149	34.9	149	35.4	149	35.8	148	36.8
	11.0	9.8	157	33.8	156	34.7	156	35.6	156	36.0	156	36.5	155	37.3
	13.0	11.8	164	34.5	164	35.4	163	36.2	163	36.6	163	37.1	156	35.6
	15.0	13.7	171	35.2	171	36.0	171	36.8	171	37.2	168	36.8	156	33.8
120 (1320)	-19.8	-20.0	78.6	19.8	78.4	21.5	78.1	23.2	77.9	24.0	77.8	24.8	77.5	26.5
	-18.8	-19.0	80.2	20.5	79.9	22.1	79.6	23.7	79.5	24.5	79.4	25.4	79.1	27.0
	-16.7	-17.0	83.6	21.7	83.3	23.3	83.0	24.8	82.9	25.6	82.7	26.4	82.4	28.0
	-13.7	-15.0	87.3	22.9	87.0	24.4	86.7	25.9	86.5	26.7	86.4	27.4	86.1	28.9
	-11.8	-13.0	91.2	24.1	90.9	25.6	90.6	27.0	90.5	27.7	90.3	28.4	90.0	29.8
	-9.8	-11.0	95.4	25.3	95.1	26.7	94.8	28.0	94.7	28.7	94.6	29.4	94.3	30.8
	-9.5	-10.0	98	25.9	97	27.2	97.1	28.5	96.9	29.2	96.8	29.9	96.5	31.2
	-8.5	-9.1	100	26.4	99	27.7	99	29.0	99	29.6	99	30.3	99	31.6
	-7.0	-7.6	103	27.2	103	28.5	103	29.7	103	30.4	102	31.0	102	32.2
	-5.0	-5.6	108	28.3	108	29.5	108	30.7	108	31.3	107	31.9	107	33.1
	-3.0	-3.7	113	29.3	113	30.4	113	31.5	113	32.1	112	32.7	112	33.8
	0.0	-0.7	122	30.7	121	31.8	121	32.8	121	33.4	121	33.9	120	34.9
	3.0	2.2	130	32.0	130	33.0	130	34.0	130	34.5	130	35.0	129	36.0
	5.0	4.1	136	32.8	136	33.8	136	34.7	136	35.2	136	35.6	135	36.6
	7.0	6.0	143	33.6	142	34.5	142	35.4	142	35.8	142	36.3	142	37.2
	9.0	7.9	149	34.3	149	35.2	149	36.0	149	36.4	148	36.9	144	36.2
	11.0	9.8	156	35.0	156	35.8	156	36.6	155	37.0	155	37.3	144	34.3
	13.0	11.8	164	35.7	163	36.5	163	37.2	160	36.7	155	35.3	144	32.4
	15.0	13.7	171	36.3	171	37.0	166	36.2	160	34.8	155	33.4	144	30.8
110 (1210)	-19.8	-20.0	78.2	22.3	78.0	23.8	77.7	25.3	77.6	26.1	77.4	26.9	77.2	28.4
	-18.8	-19.0	79.8	22.9	79.5	24.4	79.3	25.8	79.1	26.6	79.0	27.3	78.7	28.8
	-16.7	-17.0	83.2	24.0	82.9	25.4	82.6	26.9	82.5	27.6	82.4	28.3	82.1	29.7
	-13.7	-15.0	86.8	25.1	86.6	26.5	86.3	27.9	86.2	28.5	86.0	29.2	85.8	30.6
	-11.8	-13.0	90.8	26.2	90.5	27.5	90.2	28.8	90.1	29.5	90.0	30.1	89.7	31.5
	-9.8	-11.0	95.0	27.3	94.7	28.6	94.5	29.8	94.3	30.4	94.2	31.0	93.9	32.3
	-9.5	-10.0	97.2	27.8	97.0	29.0	96.7	30.3	96.6	30.9	96.4	31.5	96.2	32.7
	-8.5	-9.1	99	28.3	99	29.5	99	30.7	99	31.3	98	31.9	98	33.1
	-7.0	-7.6	103	29.1	103	30.2	102	31.4	102	31.9	102	32.5	102	33.7
	-5.0	-5.6	108	30.0	108	31.1	107	32.2	107	32.8	107	33.3	107	34.4
	-3.0	-3.7	113	30.9	113	32.0	112	33.0	112	33.5	112	34.1	112	35.1
	0.0	-0.7	121	32.3	121	33.2	121	34.2	121	34.7	120	35.2	120	36.1
	3.0	2.2	130	33.5	130	34.4	129	35.3	129	35.7	129	36.2	129	37.1
	5.0	4.1	136	34.2	136	35.1	135	35.9	135	36.3	135	36.8	132	36.5
	7.0	6.0	142	34.9	142	35.7	142	36.5	142	36.9	142	37.4	132	34.5
	9.0	7.9	149	35.6	149	36.3	148	37.1	147	37.0	142	35.6	132	32.7
	11.0	9.8	156	36.2	155	36.9	152	36.4	147	35.0	142	33.7	132	31.0
	13.0	11.8	163	36.8	162	37.1	152	34.4	147	33.1	142	31.8	132	29.3
	15.0	13.7	170	37.4	162	35.1	152	32.6	147	31.4	142	30.2	132	27.9

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (1100)	-19.8	-20.0	77.8	24.7	77.6	26.1	77.3	27.5	77.2	28.2	77.1	28.9	76.8	30.3
	-18.8	-19.0	79.4	25.2	79.1	26.6	78.9	28.0	78.8	28.6	78.6	29.3	78.4	30.7
	-16.7	-17.0	82.8	26.3	82.5	27.6	82.3	28.9	82.1	29.5	82.0	30.2	81.8	31.5
	-13.7	-15.0	86.4	27.3	86.2	28.5	85.9	29.8	85.8	30.4	85.7	31.0	85.4	32.3
	-11.8	-13.0	90.4	28.3	90.1	29.5	89.9	30.7	89.7	31.3	89.6	31.9	89.4	33.1
	-9.8	-11.0	94.6	29.3	94.3	30.4	94.1	31.6	94.0	32.1	93.8	32.7	93.6	33.8
	-9.5	-10.0	96.8	29.8	96.5	30.9	96.3	32.0	96.2	32.5	96.1	33.1	95.8	34.2
	-8.5	-9.1	99	30.2	99	31.3	98	32.4	98	32.9	98	33.4	98	34.5
	-7.0	-7.6	102	30.9	102	31.9	102	33.0	102	33.5	102	34.0	101	35.1
	-5.0	-5.6	107	31.8	107	32.8	107	33.8	107	34.3	107	34.8	106	35.8
	-3.0	-3.7	112	32.6	112	33.5	112	34.5	112	35.0	112	35.4	111	36.4
	0.0	-0.7	121	33.8	121	34.7	120	35.6	120	36.0	120	36.5	120	37.3
	3.0	2.2	130	34.9	129	35.7	129	36.5	129	36.9	129	37.4	120	34.5
	5.0	4.1	136	35.6	135	36.4	135	37.1	134	36.9	129	35.5	120	32.6
	7.0	6.0	142	36.2	142	37.0	138	36.3	134	34.9	129	33.6	120	30.9
	9.0	7.9	148	36.8	147	37.0	138	34.4	134	33.1	129	31.8	120	29.3
	11.0	9.8	155	37.4	147	35.0	138	32.5	134	31.3	129	30.1	120	27.8
	13.0	11.8	156	35.5	147	33.1	138	30.8	134	29.7	129	28.5	120	26.3
	15.0	13.7	156	33.6	147	31.4	138	29.2	134	28.2	129	27.1	120	25.1
90 (990)	-19.8	-20.0	77.4	27.2	77.1	28.4	76.9	29.7	76.8	30.3	76.7	30.9	76.5	32.2
	-18.8	-19.0	78.9	27.6	78.7	28.9	78.5	30.1	78.4	30.7	78.3	31.3	78.1	32.5
	-16.7	-17.0	82.3	28.6	82.1	29.7	81.9	30.9	81.8	31.5	81.7	32.1	81.5	33.3
	-13.7	-15.0	86.0	29.5	85.8	30.6	85.5	31.7	85.4	32.3	85.3	32.8	85.1	34.0
	-11.8	-13.0	89.9	30.4	89.7	31.5	89.5	32.5	89.4	33.1	89.3	33.6	89.1	34.7
	-9.8	-11.0	94.1	31.3	93.9	32.3	93.7	33.3	93.6	33.8	93.5	34.3	93.3	35.4
	-9.5	-10.0	96.4	31.7	96.1	32.7	95.9	33.7	95.8	34.2	95.7	34.7	95.5	35.7
	-8.5	-9.1	98	32.1	98	33.1	98	34.0	98	34.5	98	35.0	98	36.0
	-7.0	-7.6	102	32.7	102	33.7	102	34.6	101	35.1	101	35.5	101	36.5
	-5.0	-5.6	107	33.5	107	34.4	107	35.3	106	35.8	106	36.2	106	37.1
	-3.0	-3.7	112	34.3	112	35.1	112	36.0	111	36.4	111	36.8	108	36.2
	0.0	-0.7	120	35.4	120	36.1	120	36.9	120	37.3	116	36.0	108	33.1
	3.0	2.2	129	36.3	129	37.1	124	35.8	120	34.4	116	33.1	108	30.5
	5.0	4.1	135	36.9	132	36.5	124	33.9	120	32.6	116	31.3	108	28.9
	7.0	6.0	140	37.0	132	34.5	124	32.1	120	30.9	116	29.7	108	27.4
	9.0	7.9	140	35.0	132	32.7	124	30.4	120	29.3	116	28.2	108	26.0
	11.0	9.8	140	33.1	132	31.0	124	28.8	120	27.8	116	26.7	108	24.7
	13.0	11.8	140	31.3	132	29.3	124	27.3	120	26.3	116	25.4	108	23.5
	15.0	13.7	140	29.8	132	27.8	124	26.0	120	25.0	116	24.1	108	22.4
80 (880)	-19.8	-20.0	76.9	29.6	76.7	30.7	76.6	31.8	76.5	32.4	76.4	32.9	76.2	34.1
	-18.8	-19.0	78.5	30.0	78.3	31.1	78.1	32.2	78.0	32.7	77.9	33.3	77.7	34.4
	-16.7	-17.0	81.9	30.9	81.7	31.9	81.5	32.9	81.4	33.5	81.3	34.0	81.1	35.0
	-13.7	-15.0	85.6	31.7	85.4	32.7	85.2	33.7	85.1	34.2	85.0	34.7	84.8	35.7
	-11.8	-13.0	89.5	32.5	89.3	33.4	89.1	34.4	89.0	34.9	88.9	35.3	88.7	36.3
	-9.8	-11.0	93.7	33.3	93.5	34.2	93.3	35.1	93.2	35.5	93.1	36.0	92.9	36.9
	-9.5	-10.0	95.9	33.7	95.7	34.5	95.6	35.4	95.5	35.9	95.4	36.3	95.2	37.2
	-8.5	-9.1	98	34.0	98	34.9	98	35.7	98	36.2	97	36.6	96.2	36.9
	-7.0	-7.6	102	34.6	101	35.4	101	36.2	101	36.6	101	37.1	96.2	35.3
	-5.0	-5.6	107	35.3	106	36.1	106	36.9	106	37.3	103	36.2	96.2	33.3
	-3.0	-3.7	112	35.9	111	36.7	110	37.0	107	35.6	103	34.2	96.2	31.5
	0.0	-0.7	120	36.9	117	36.5	110	33.9	107	32.6	103	31.4	96.2	28.9
	3.0	2.2	125	35.9	117	33.5	110	31.2	107	30.0	103	28.9	96.2	26.7
	5.0	4.1	125	34.0	117	31.7	110	29.5	107	28.5	103	27.4	96.2	25.3
	7.0	6.0	125	32.2	117	30.1	110	28.0	107	27.0	103	26.0	96.2	24.0
	9.0	7.9	125	30.5	117	28.5	110	26.6	107	25.6	103	24.7	96.2	22.9
	11.0	9.8	125	28.9	117	27.1	110	25.3	107	24.4	103	23.5	96.2	21.8
	13.0	11.8	125	27.4	117	25.7	110	24.0	107	23.1	103	22.3	96.2	20.7
	15.0	13.7	125	26.1	117	24.4	110	22.8	107	22.0	103	21.3	96.2	19.7

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (770)	-19.8	-20.0	76.5	32.0	76.3	33.0	76.2	34.0	76.1	34.5	76.0	35.0	75.8	35.9				
	-18.8	-19.0	78.1	32.4	77.9	33.4	77.8	34.3	77.7	34.8	77.6	35.3	77.4	36.2				
	-16.7	-17.0	81.5	33.1	81.3	34.1	81.1	35.0	81.0	35.4	81.0	35.9	80.8	36.8				
	-13.7	-15.0	85.1	33.9	85.0	34.7	84.8	35.6	84.7	36.0	84.6	36.5	84.2	37.2				
	-11.8	-13.0	89.1	34.6	88.9	35.4	88.7	36.2	88.6	36.6	88.6	37.1	84.2	35.1				
	-9.8	-11.0	93.3	35.3	93.1	36.1	93.0	36.8	92.9	37.2	90.4	36.1	84.2	33.2				
	-9.5	-10.0	95.5	35.6	95.3	36.4	95.2	37.1	93.5	36.6	90.4	35.1	84.2	32.3				
	-8.5	-9.1	98	35.9	97	36.7	96.6	37.0	93.5	35.6	90.4	34.2	84.2	31.5				
	-7.0	-7.6	101	36.4	101	37.1	96.6	35.4	93.5	34.1	90.4	32.8	84.2	30.2				
	-5.0	-5.6	106	37.0	103	36.0	96.6	33.4	93.5	32.2	90.4	30.9	84.2	28.5				
	-3.0	-3.7	109	36.5	103	34.0	96.6	31.6	93.5	30.5	90.4	29.3	84.2	27.0				
	0.0	-0.7	109	33.4	103	31.2	96.6	29.0	93.5	28.0	90.4	26.9	84.2	24.9				
	3.0	2.2	109	30.7	103	28.7	96.6	26.8	93.5	25.8	90.4	24.9	84.2	23.0				
	5.0	4.1	109	29.1	103	27.2	96.6	25.4	93.5	24.5	90.4	23.6	84.2	21.9				
	7.0	6.0	109	27.6	103	25.9	96.6	24.1	93.5	23.3	90.4	22.5	84.2	20.8				
	9.0	7.9	109	26.2	103	24.6	96.6	23.0	93.5	22.2	90.4	21.4	84.2	19.9				
	11.0	9.8	109	24.9	103	23.4	96.6	21.9	93.5	21.1	90.4	20.4	84.2	18.9				
	13.0	11.8	109	23.6	103	22.2	96.6	20.8	93.5	20.1	90.4	19.4	84.2	18.0				
	15.0	13.7	109	22.5	103	21.2	96.6	19.8	93.5	19.2	90.4	18.5	84.2	17.2				
60 (660)	-19.8	-20.0	76.1	34.5	75.9	35.3	75.8	36.2	75.7	36.6	75.7	37.0	72.2	35.3				
	-18.8	-19.0	77.7	34.8	77.5	35.6	77.4	36.4	77.3	36.8	77.2	37.3	72.2	34.4				
	-16.7	-17.0	81.0	35.4	80.9	36.2	80.8	37.0	80.1	37.0	77.5	35.5	72.2	32.7				
	-13.7	-15.0	84.7	36.0	84.6	36.8	82.8	36.4	80.1	35.0	77.5	33.7	72.2	31.0				
	-11.8	-13.0	88.6	36.7	88.1	37.1	82.8	34.5	80.1	33.2	77.5	31.9	72.2	29.4				
	-9.8	-11.0	92.9	37.3	88.1	35.1	82.8	32.6	80.1	31.4	77.5	30.2	72.2	27.8				
	-9.5	-10.0	93.4	36.5	88.1	34.1	82.8	31.7	80.1	30.5	77.5	29.3	72.2	27.1				
	-8.5	-9.1	93.4	35.6	88.1	33.2	82.8	30.9	80.1	29.7	77.5	28.6	72.2	26.4				
	-7.0	-7.6	93.4	34.1	88.1	31.8	82.8	29.6	80.1	28.5	77.5	27.5	72.2	25.4				
	-5.0	-5.6	93.4	32.2	88.1	30.1	82.8	28.0	80.1	27.0	77.5	26.0	72.2	24.0				
	-3.0	-3.7	93.4	30.5	88.1	28.5	82.8	26.6	80.1	25.6	77.5	24.7	72.2	22.8				
	0.0	-0.7	93.4	28.0	88.1	26.2	82.8	24.5	80.1	23.6	77.5	22.8	72.2	21.1				
	3.0	2.2	93.4	25.8	88.1	24.2	82.8	22.6	80.1	21.8	77.5	21.1	72.2	19.6				
	5.0	4.1	93.4	24.5	88.1	23.0	82.8	21.5	80.1	20.8	77.5	20.1	72.2	18.6				
	7.0	6.0	93.4	23.3	88.1	21.9	82.8	20.5	80.1	19.8	77.5	19.1	72.2	17.8				
	9.0	7.9	93.4	22.2	88.1	20.8	82.8	19.5	80.1	18.9	77.5	18.2	72.2	17.0				
	11.0	9.8	93.4	21.1	88.1	19.9	82.8	18.6	80.1	18.0	77.5	17.4	72.2	16.2				
	13.0	11.8	93.4	20.1	88.1	18.9	82.8	17.7	80.1	17.2	77.5	16.6	72.2	15.5				
	15.0	13.7	93.4	19.2	88.1	18.1	82.8	17.0	80.1	16.4	77.5	15.9	72.2	14.8				
50 (550)	-19.8	-20.0	75.7	36.9	73.4	36.0	69.0	33.4	66.8	32.2	64.6	31.0	60.1	28.5				
	-18.8	-19.0	77.2	37.2	73.4	35.1	69.0	32.6	66.8	31.4	64.6	30.2	60.1	27.9				
	-16.7	-17.0	77.9	35.7	73.4	33.3	69.0	31.0	66.8	29.9	64.6	28.7	60.1	26.5				
	-13.7	-15.0	77.9	33.9	73.4	31.6	69.0	29.4	66.8	28.4	64.6	27.3	60.1	25.2				
	-11.8	-13.0	77.9	32.1	73.4	30.0	69.0	27.9	66.8	26.9	64.6	25.9	60.1	24.0				
	-9.8	-11.0	77.9	30.3	73.4	28.4	69.0	26.5	66.8	25.5	64.6	24.6	60.1	22.8				
	-9.5	-10.0	77.9	29.5	73.4	27.6	69.0	25.8	66.8	24.8	64.6	23.9	60.1	22.2				
	-8.5	-9.1	77.9	28.8	73.4	26.9	69.0	25.1	66.8	24.3	64.6	23.4	60.1	21.7				
	-7.0	-7.6	77.9	27.6	73.4	25.9	69.0	24.2	66.8	23.3	64.6	22.5	60.1	20.8				
	-5.0	-5.6	77.9	26.1	73.4	24.5	69.0	22.9	66.8	22.1	64.6	21.3	60.1	19.8				
	-3.0	-3.7	77.9	24.8	73.4	23.3	69.0	21.8	66.8	21.0	64.6	20.3	60.1	18.9				
	0.0	-0.7	77.9	22.9	73.4	21.5	69.0	20.1	66.8	19.5	64.6	18.8	60.1	17.5				
	3.0	2.2	77.9	21.2	73.4	19.9	69.0	18.7	66.8	18.1	64.6	17.5	60.1	16.3				
	5.0	4.1	77.9	20.2	73.4	19.0	69.0	17.8	66.8	17.2	64.6	16.7	60.1	15.6				
	7.0	6.0	77.9	19.2	73.4	18.1	69.0	17.0	66.8	16.5	64.6	15.9	60.1	14.9				
	9.0	7.9	77.9	18.3	73.4	17.3	69.0	16.2	66.8	15.7	64.6	15.2	60.1	14.2				
	11.0	9.8	77.9	17.5	73.4	16.5	69.0	15.5	66.8	15.1	64.6	14.6	60.1	13.6				
	13.0	11.8	77.9	16.7	73.4	15.8	69.0	14.8	66.8	14.4	64.6	13.9	60.1	13.1				
	15.0	13.7	77.9	16.0	73.4	15.1	69.0	14.2	66.8	13.8	64.6	13.4	60.1	12.5				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1508)	-19.8	-20.0	83.3	18.9	82.9	20.8	82.6	22.8	82.4	23.7	82.3	24.7	81.9	26.6
	-18.8	-19.0	84.7	19.6	84.4	21.4	84.1	23.3	83.9	24.3	83.7	25.2	83.4	27.1
	-16.7	-17.0	88.0	20.9	87.6	22.7	87.3	24.5	87.1	25.4	87.0	26.3	86.6	28.1
	-13.7	-15.0	91.6	22.2	91.2	23.9	90.9	25.7	90.7	26.5	90.6	27.4	90.2	29.1
	-11.8	-13.0	95.5	23.6	95.2	25.2	94.9	26.9	94.7	27.7	94.5	28.5	94.2	30.2
	-9.8	-11.0	100	24.9	100	26.5	99	28.1	99	28.9	99	29.7	99	31.2
	-9.5	-10.0	102	25.6	102	27.1	102	28.7	101	29.4	101	30.2	101	31.8
	-8.5	-9.1	104	26.2	104	27.7	104	29.2	104	30.0	103	30.7	103	32.2
	-7.0	-7.6	108	27.2	108	28.6	107	30.1	107	30.8	107	31.5	107	33.0
	-5.0	-5.6	113	28.4	113	29.8	113	31.2	113	31.9	112	32.6	112	34.0
	-3.0	-3.7	119	29.6	119	30.9	118	32.2	118	32.9	118	33.6	118	34.9
	0.0	-0.7	128	31.4	128	32.6	128	33.8	127	34.4	127	35.0	127	36.2
	3.0	2.2	138	33.0	138	34.1	137	35.2	137	35.8	137	36.4	137	37.5
	5.0	4.1	145	33.9	144	35.0	144	36.1	144	36.6	144	37.2	143	38.2
	7.0	6.0	152	34.9	152	35.9	151	36.9	151	37.4	151	37.9	151	39.0
	9.0	7.9	159	35.8	159	36.7	159	37.7	159	38.2	158	38.7	158	39.6
	11.0	9.8	167	36.6	167	37.5	167	38.4	166	38.9	166	39.4	164	39.5
	13.0	11.8	176	37.4	175	38.3	175	39.2	175	39.6	175	40.1	164	37.1
	15.0	13.7	184	38.2	184	39.0	184	39.8	182	39.7	176	38.1	164	35.1
120 (1392)	-19.8	-20.0	82.8	21.5	82.5	23.3	82.2	25.1	82.1	26.0	81.9	26.8	81.6	28.6
	-18.8	-19.0	84.3	22.1	84.0	23.8	83.7	25.6	83.5	26.5	83.4	27.3	83.1	29.1
	-16.7	-17.0	87.5	23.3	87.2	25.0	86.9	26.7	86.8	27.5	86.6	28.3	86.3	30.0
	-13.7	-15.0	91.1	24.5	90.8	26.2	90.5	27.8	90.4	28.6	90.2	29.4	89.9	31.0
	-11.8	-13.0	95.1	25.8	94.8	27.3	94.5	28.9	94.3	29.6	94.2	30.4	93.9	31.9
	-9.8	-11.0	99	27.0	99	28.5	99	30.0	99	30.7	99	31.4	98	32.9
	-9.5	-10.0	102	27.7	101	29.1	101	30.5	101	31.2	101	31.9	101	33.4
	-8.5	-9.1	104	28.2	104	29.6	103	31.0	103	31.7	103	32.4	103	33.8
	-7.0	-7.6	108	29.1	107	30.5	107	31.8	107	32.5	107	33.2	106	34.5
	-5.0	-5.6	113	30.3	113	31.6	112	32.9	112	33.5	112	34.1	112	35.4
	-3.0	-3.7	118	31.4	118	32.6	118	33.8	118	34.4	118	35.0	117	36.3
	0.0	-0.7	128	33.0	127	34.1	127	35.3	127	35.8	127	36.4	126	37.5
	3.0	2.2	137	34.5	137	35.5	137	36.6	137	37.1	137	37.6	136	38.7
	5.0	4.1	144	35.4	144	36.4	144	37.4	144	37.9	143	38.4	143	39.4
	7.0	6.0	151	36.3	151	37.2	151	38.1	151	38.6	151	39.1	150	40.0
	9.0	7.9	159	37.1	159	38.0	158	38.9	158	39.3	158	39.8	151	38.1
	11.0	9.8	167	37.8	166	38.7	166	39.6	166	40.0	162	39.1	151	35.9
	13.0	11.8	175	38.6	175	39.4	173	39.8	168	38.2	162	36.7	151	33.8
	15.0	13.7	184	39.3	184	40.1	173	37.5	168	36.1	162	34.7	151	31.9
110 (1276)	-19.8	-20.0	82.4	24.1	82.1	25.7	81.8	27.4	81.7	28.2	81.5	29.0	81.3	30.6
	-18.8	-19.0	83.8	24.7	83.6	26.2	83.3	27.8	83.1	28.6	83.0	29.4	82.7	31.0
	-16.7	-17.0	87.1	25.8	86.8	27.3	86.5	28.8	86.4	29.6	86.2	30.4	86.0	31.9
	-13.7	-15.0	90.7	26.9	90.4	28.4	90.1	29.8	90.0	30.6	89.8	31.3	89.6	32.8
	-11.8	-13.0	94.6	28.0	94.4	29.4	94.1	30.8	93.9	31.6	93.8	32.3	93.5	33.7
	-9.8	-11.0	99	29.2	99	30.5	98	31.9	98	32.5	98	33.2	98	34.5
	-9.5	-10.0	101	29.8	101	31.1	101	32.4	101	33.0	100	33.7	100	35.0
	-8.5	-9.1	103	30.3	103	31.5	103	32.8	103	33.5	103	34.1	102	35.4
	-7.0	-7.6	107	31.1	107	32.3	107	33.6	107	34.2	106	34.8	106	36.0
	-5.0	-5.6	113	32.2	112	33.3	112	34.5	112	35.1	112	35.7	111	36.9
	-3.0	-3.7	118	33.2	118	34.3	117	35.4	117	36.0	117	36.5	117	37.6
	0.0	-0.7	127	34.7	127	35.7	127	36.7	127	37.2	126	37.8	126	38.8
	3.0	2.2	137	36.0	137	37.0	136	37.9	136	38.4	136	38.9	136	39.8
	5.0	4.1	144	36.8	144	37.8	143	38.7	143	39.1	143	39.6	139	38.7
	7.0	6.0	151	37.6	151	38.5	150	39.4	150	39.8	149	39.6	139	36.4
	9.0	7.9	158	38.4	158	39.2	158	40.0	154	38.9	149	37.4	139	34.4
	11.0	9.8	166	39.1	166	39.9	159	38.1	154	36.7	149	35.2	139	32.4
	13.0	11.8	175	39.8	169	38.6	159	35.9	154	34.5	149	33.2	139	30.6
	15.0	13.7	179	39.1	169	36.4	159	33.9	154	32.6	149	31.4	139	28.9

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (1160)	-19.8	-20.0	81.9	26.7	81.7	28.2	81.4	29.7	81.3	30.4	81.2	31.1	80.9	32.6
	-18.8	-19.0	83.4	27.2	83.1	28.6	82.9	30.1	82.8	30.8	82.6	31.5	82.4	33.0
	-16.7	-17.0	86.6	28.2	86.4	29.6	86.1	31.0	86.0	31.7	85.9	32.4	85.6	33.8
	-13.7	-15.0	90.2	29.2	90.0	30.6	89.7	31.9	89.6	32.6	89.5	33.2	89.2	34.6
	-11.8	-13.0	94.2	30.3	93.9	31.6	93.7	32.8	93.6	33.5	93.4	34.1	93.2	35.4
	-9.8	-11.0	99	31.3	98	32.5	98	33.8	98	34.4	98	35.0	98	36.2
	-9.5	-10.0	101	31.8	101	33.0	100	34.2	100	34.8	100	35.4	100	36.6
	-8.5	-9.1	103	32.3	103	33.5	103	34.6	102	35.2	102	35.8	102	37.0
	-7.0	-7.6	107	33.1	107	34.2	106	35.3	106	35.9	106	36.4	106	37.5
	-5.0	-5.6	112	34.0	112	35.1	112	36.2	112	36.7	111	37.2	111	38.3
	-3.0	-3.7	118	35.0	117	36.0	117	37.0	117	37.5	117	38.0	117	39.0
	0.0	-0.7	127	36.3	127	37.3	126	38.2	126	38.7	126	39.1	126	40.1
	3.0	2.2	137	37.5	136	38.4	136	39.3	136	39.7	135	39.9	126	36.6
	5.0	4.1	143	38.3	143	39.1	143	40.0	140	39.1	135	37.6	126	34.5
	7.0	6.0	151	39.0	150	39.8	145	38.3	140	36.8	135	35.4	126	32.6
	9.0	7.9	158	39.7	154	38.9	145	36.1	140	34.7	135	33.4	126	30.8
	11.0	9.8	163	39.3	154	36.7	145	34.1	140	32.8	135	31.5	126	29.1
	13.0	11.8	163	37.0	154	34.5	145	32.1	140	30.9	135	29.7	126	27.5
	15.0	13.7	163	34.9	154	32.6	145	30.4	140	29.2	135	28.2	126	26.0
90 (1044)	-19.8	-20.0	81.5	29.3	81.2	30.6	81.0	32.0	80.9	32.6	80.8	33.3	80.6	34.6
	-18.8	-19.0	83.0	29.7	82.7	31.0	82.5	32.4	82.4	33.0	82.3	33.7	82.0	35.0
	-16.7	-17.0	86.2	30.7	85.9	31.9	85.7	33.2	85.6	33.8	85.5	34.4	85.3	35.7
	-13.7	-15.0	89.8	31.6	89.5	32.8	89.3	34.0	89.2	34.6	89.1	35.2	88.9	36.4
	-11.8	-13.0	93.8	32.5	93.5	33.7	93.3	34.8	93.2	35.4	93.1	36.0	92.8	37.1
	-9.8	-11.0	98	33.5	98	34.6	98	35.7	98	36.2	97	36.8	97	37.8
	-9.5	-10.0	100	33.9	100	35.0	100	36.1	100	36.6	100	37.1	99	38.2
	-8.5	-9.1	103	34.3	102	35.4	102	36.4	102	37.0	102	37.5	102	38.5
	-7.0	-7.6	106	35.0	106	36.0	106	37.0	106	37.5	106	38.1	105	39.1
	-5.0	-5.6	112	35.9	111	36.9	111	37.8	111	38.3	111	38.8	111	39.8
	-3.0	-3.7	117	36.7	117	37.6	117	38.6	117	39.0	116	39.5	113	38.8
	0.0	-0.7	126	38.0	126	38.8	126	39.6	126	40.1	122	38.5	113	35.4
	3.0	2.2	136	39.1	136	39.8	130	38.1	126	36.6	122	35.2	113	32.4
	5.0	4.1	143	39.7	138	38.6	130	35.9	126	34.5	122	33.2	113	30.6
	7.0	6.0	147	39.0	138	36.4	130	33.8	126	32.6	122	31.3	113	28.9
	9.0	7.9	147	36.8	138	34.3	130	31.9	126	30.8	122	29.6	113	27.3
	11.0	9.8	147	34.7	138	32.4	130	30.2	126	29.1	122	28.0	113	25.9
	13.0	11.8	147	32.7	138	30.5	130	28.5	126	27.5	122	26.4	113	24.5
	15.0	13.7	147	30.9	138	28.9	130	27.0	126	26.0	122	25.1	113	23.2
80 (928)	-19.8	-20.0	81.0	31.9	80.8	33.1	80.6	34.3	80.5	34.9	80.4	35.4	80.2	36.6
	-18.8	-19.0	82.5	32.3	82.3	33.4	82.1	34.6	82.0	35.2	81.9	35.8	81.7	36.9
	-16.7	-17.0	85.7	33.1	85.5	34.2	85.3	35.3	85.2	35.9	85.1	36.4	84.9	37.6
	-13.7	-15.0	89.3	33.9	89.1	35.0	88.9	36.1	88.8	36.6	88.7	37.1	88.5	38.2
	-11.8	-13.0	93.3	34.8	93.1	35.8	92.9	36.8	92.8	37.3	92.7	37.8	92.5	38.8
	-9.8	-11.0	98	35.6	97	36.6	97	37.6	97	38.0	97	38.5	97	39.5
	-9.5	-10.0	100	36.0	100	37.0	100	37.9	99	38.4	99	38.9	99	39.8
	-8.5	-9.1	102	36.4	102	37.3	102	38.2	102	38.7	102	39.2	101	39.8
	-7.0	-7.6	106	37.0	106	37.9	105	38.8	105	39.2	105	39.7	101	38.0
	-5.0	-5.6	111	37.8	111	38.6	111	39.5	111	39.9	108	39.0	101	35.8
	-3.0	-3.7	117	38.5	116	39.3	116	39.8	112	38.2	108	36.7	101	33.8
	0.0	-0.7	126	39.6	123	39.0	116	36.2	112	34.9	108	33.5	101	30.9
	3.0	2.2	130	38.2	123	35.6	116	33.1	112	31.9	108	30.7	101	28.3
	5.0	4.1	130	36.0	123	33.6	116	31.3	112	30.1	108	29.0	101	26.8
	7.0	6.0	130	33.9	123	31.7	116	29.5	112	28.5	108	27.4	101	25.4
	9.0	7.9	130	32.0	123	30.0	116	27.9	112	27.0	108	26.0	101	24.0
	11.0	9.8	130	30.3	123	28.3	116	26.5	112	25.5	108	24.6	101	22.8
	13.0	11.8	130	28.6	123	26.8	116	25.0	112	24.1	108	23.3	101	21.6
	15.0	13.7	130	27.1	123	25.4	116	23.7	112	22.9	108	22.1	101	20.5

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp. °CDB	Outdoor air temp. °CWB	Indoor air temp. °CDB 16.0 TC kW	16.0 PI kW	18.0 TC kW	18.0 PI kW	20.0 TC kW	20.0 PI kW	21.0 TC kW	21.0 PI kW	22.0 TC kW	22.0 PI kW	24.0 TC kW	24.0 PI kW
70 (812)	-19.8	-20.0	80.6	34.5	80.4	35.5	80.2	36.6	80.1	37.1	80.1	37.6	79.9	38.6
	-18.8	-19.0	82.1	34.8	81.9	35.8	81.7	36.9	81.6	37.4	81.5	37.9	81.3	38.9
	-16.7	-17.0	85.3	35.5	85.1	36.5	84.9	37.5	84.8	38.0	84.8	38.5	84.6	39.4
	-13.7	-15.0	88.9	36.3	88.7	37.2	88.5	38.1	88.4	38.6	88.4	39.1	88.2	40.0
	-11.8	-13.0	92.9	37.0	92.7	37.9	92.5	38.8	92.4	39.2	92.3	39.7	88.2	37.9
	-9.8	-11.0	97	37.7	97	38.6	97	39.4	96.8	39.9	94.7	39.0	88.2	35.8
	-9.5	-10.0	100	38.1	99	38.9	99	39.8	97.9	39.4	94.7	37.9	88.2	34.8
	-8.5	-9.1	102	38.4	101	39.2	101	40.0	97.9	38.4	94.7	36.9	88.2	33.9
	-7.0	-7.6	105	39.0	105	39.7	101	38.2	97.9	36.7	94.7	35.3	88.2	32.5
	-5.0	-5.6	111	39.7	108	38.7	101	36.0	97.9	34.6	94.7	33.3	88.2	30.7
	-3.0	-3.7	114	39.2	108	36.5	101	34.0	97.9	32.7	94.7	31.4	88.2	29.0
	0.0	-0.7	114	35.7	108	33.3	101	31.0	97.9	29.9	94.7	28.8	88.2	26.6
	3.0	2.2	114	32.7	108	30.5	101	28.5	97.9	27.4	94.7	26.4	88.2	24.5
	5.0	4.1	114	30.8	108	28.8	101	26.9	97.9	26.0	94.7	25.0	88.2	23.2
	7.0	6.0	114	29.1	108	27.3	101	25.5	97.9	24.6	94.7	23.7	88.2	22.0
	9.0	7.9	114	27.6	108	25.8	101	24.1	97.9	23.3	94.7	22.5	88.2	20.9
	11.0	9.8	114	26.1	108	24.5	101	22.9	97.9	22.1	94.7	21.4	88.2	19.8
	13.0	11.8	114	24.7	108	23.2	101	21.7	97.9	21.0	94.7	20.2	88.2	18.8
	15.0	13.7	114	23.4	108	22.0	101	20.6	97.9	19.9	94.7	19.3	88.2	17.9
60 (696)	-19.8	-20.0	80.1	37.1	80.0	38.0	79.8	38.9	79.8	39.3	79.7	38.7	75.6	37.5
	-18.8	-19.0	81.6	37.4	81.5	38.3	81.3	39.1	81.2	39.6	81.1	40.0	75.6	38.7
	-16.7	-17.0	84.8	38.0	84.7	38.8	84.5	39.7	83.9	39.7	81.1	38.1	75.6	35.0
	-13.7	-15.0	88.4	38.6	88.3	39.4	86.7	39.2	83.9	37.7	81.1	36.2	75.6	33.3
	-11.8	-13.0	92.4	39.2	92.3	40.0	86.7	37.1	83.9	35.7	81.1	34.4	75.6	31.6
	-9.8	-11.0	96.8	39.9	92.3	37.8	86.7	35.1	83.9	33.8	81.1	32.5	75.6	30.0
	-9.5	-10.0	97.8	39.4	92.3	36.8	86.7	34.2	83.9	32.9	81.1	31.6	75.6	29.2
	-8.5	-9.1	97.8	38.4	92.3	35.8	86.7	33.3	83.9	32.1	81.1	30.8	75.6	28.5
	-7.0	-7.6	97.8	36.7	92.3	34.3	86.7	31.9	83.9	30.7	81.1	29.6	75.6	27.3
	-5.0	-5.6	97.8	34.6	92.3	32.3	86.7	30.1	83.9	29.0	81.1	27.9	75.6	25.8
	-3.0	-3.7	97.8	32.7	92.3	30.5	86.7	28.5	83.9	27.5	81.1	26.4	75.6	24.5
	0.0	-0.7	97.8	29.9	92.3	28.0	86.7	26.1	83.9	25.2	81.1	24.3	75.6	22.5
	3.0	2.2	97.8	27.4	92.3	25.7	86.7	24.0	83.9	23.2	81.1	22.4	75.6	20.8
	5.0	4.1	97.8	25.9	92.3	24.3	86.7	22.8	83.9	22.0	81.1	21.2	75.6	19.7
	7.0	6.0	97.8	24.6	92.3	23.1	86.7	21.6	83.9	20.9	81.1	20.2	75.6	18.8
	9.0	7.9	97.8	23.3	92.3	21.9	86.7	20.5	83.9	19.8	81.1	19.2	75.6	17.9
	11.0	9.8	97.8	22.1	92.3	20.8	86.7	19.5	83.9	18.9	81.1	18.2	75.6	17.0
	13.0	11.8	97.8	20.9	92.3	19.7	86.7	18.5	83.9	17.9	81.1	17.3	75.6	16.2
	15.0	13.7	97.8	19.9	92.3	18.8	86.7	17.6	83.9	17.1	81.1	16.5	75.6	15.4
50 (580)	-19.8	-20.0	79.7	39.7	76.9	38.3	72.3	35.6	69.9	34.3	67.6	32.9	63.0	30.4
	-18.8	-19.0	81.2	39.9	76.9	37.5	72.3	34.8	69.9	33.5	67.6	32.2	63.0	29.7
	-16.7	-17.0	81.5	38.3	76.9	35.8	72.3	33.2	69.9	32.0	67.6	30.8	63.0	28.4
	-13.7	-15.0	81.5	36.4	76.9	34.0	72.3	31.6	69.9	30.5	67.6	29.3	63.0	27.1
	-11.8	-13.0	81.5	34.6	76.9	32.3	72.3	30.1	69.9	29.0	67.6	27.9	63.0	25.8
	-9.8	-11.0	81.5	32.7	76.9	30.6	72.3	28.5	69.9	27.5	67.6	26.5	63.0	24.5
	-9.5	-10.0	81.5	31.8	76.9	29.8	72.3	27.7	69.9	26.8	67.6	25.8	63.0	23.9
	-8.5	-9.1	81.5	31.0	76.9	29.0	72.3	27.1	69.9	26.1	67.6	25.2	63.0	23.3
	-7.0	-7.6	81.5	29.7	76.9	27.8	72.3	26.0	69.9	25.1	67.6	24.2	63.0	22.4
	-5.0	-5.6	81.5	28.1	76.9	26.3	72.3	24.6	69.9	23.7	67.6	22.9	63.0	21.2
	-3.0	-3.7	81.5	26.6	76.9	24.9	72.3	23.3	69.9	22.5	67.6	21.7	63.0	20.2
	0.0	-0.7	81.5	24.4	76.9	22.9	72.3	21.5	69.9	20.8	67.6	20.0	63.0	18.7
	3.0	2.2	81.5	22.5	76.9	21.2	72.3	19.8	69.9	19.2	67.6	18.6	63.0	17.3
	5.0	4.1	81.5	21.4	76.9	20.1	72.3	18.9	69.9	18.3	67.6	17.7	63.0	16.5
	7.0	6.0	81.5	20.3	76.9	19.1	72.3	17.9	69.9	17.4	67.6	16.8	63.0	15.7
	9.0	7.9	81.5	19.3	76.9	18.2	72.3	17.1	69.9	16.6	67.6	16.0	63.0	15.0
	11.0	9.8	81.5	18.3	76.9	17.3	72.3	16.3	69.9	15.8	67.6	15.3	63.0	14.3
	13.0	11.8	81.5	17.4	76.9	16.5	72.3	15.5	69.9	15.0	67.6	14.6	63.0	13.6
	15.0	13.7	81.5	16.6	76.9	15.7	72.3	14.8	69.9	14.4	67.6	13.9	63.0	13.1

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ■.
Note2: The above table shows the average value of conditions which may occur.

RXYQ48PAY1, PAYL, PTL [50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1560)	-19.8	-20.0	86.6	19.5	86.3	21.5	85.9	23.5	85.7	24.5	85.6	25.5	85.2	27.4
	-18.8	-19.0	88.2	20.2	87.8	22.1	87.5	24.1	87.3	25.0	87.1	26.0	86.8	28.0
	-16.7	-17.0	91.5	21.5	91.2	23.4	90.8	25.3	90.7	26.2	90.5	27.1	90.2	29.0
	-13.7	-15.0	95.3	22.9	95.0	24.7	94.6	26.5	94.4	27.4	94.3	28.3	93.9	30.1
	-11.8	-13.0	99.4	24.3	99.1	26.0	98.8	27.7	98.6	28.6	98.4	29.5	98.1	31.2
	-9.8	-11.0	104	25.7	104	27.4	103	29.0	103	29.8	103	30.6	103	32.3
	-9.5	-10.0	106	26.4	106	28.0	106	29.6	106	30.4	105	31.2	105	32.8
	-8.5	-9.1	109	27.0	108	28.6	108	30.2	108	30.9	108	31.7	107	33.3
	-7.0	-7.6	113	28.0	112	29.5	112	31.1	112	31.8	111	32.6	111	34.1
	-5.0	-5.6	118	29.4	118	30.8	117	32.2	117	32.9	117	33.7	117	35.1
	-3.0	-3.7	124	30.6	123	31.9	123	33.3	123	34.0	123	34.7	122	36.0
	0.0	-0.7	133	32.4	133	33.6	133	34.9	132	35.5	132	36.2	132	37.4
	3.0	2.2	143	34.0	143	35.2	143	36.4	142	36.9	142	37.5	142	38.7
	5.0	4.1	150	35.0	150	36.1	150	37.3	150	37.8	149	38.4	149	39.5
	7.0	6.0	158	36.0	157	37.0	157	38.1	157	38.6	157	39.2	156	40.2
	9.0	7.9	165	36.9	165	37.9	165	38.9	165	39.4	164	39.9	164	40.9
	11.0	9.8	174	37.8	173	38.7	173	39.7	173	40.2	173	40.6	171	41.0
	13.0	11.8	182	38.6	182	39.5	182	40.4	182	40.9	181	41.3	171	38.5
	15.0	13.7	191	39.4	191	40.3	191	41.1	189	41.2	183	39.6	171	36.4
120 (1440)	-19.8	-20.0	86.1	22.2	85.8	24.0	85.5	25.9	85.3	26.8	85.2	27.7	84.9	29.5
	-18.8	-19.0	87.7	22.8	87.4	24.6	87.1	26.4	86.9	27.3	86.7	28.2	86.4	30.0
	-16.7	-17.0	91.1	24.0	90.8	25.8	90.4	27.5	90.3	28.4	90.1	29.2	89.8	31.0
	-13.7	-15.0	94.8	25.3	94.5	27.0	94.2	28.7	94.0	29.5	93.9	30.3	93.6	32.0
	-11.8	-13.0	99.0	26.6	98.7	28.2	98.3	29.8	98.2	30.6	98.0	31.4	97.7	33.0
	-9.8	-11.0	103	27.9	103	29.4	103	30.9	103	31.7	103	32.5	102	34.0
	-9.5	-10.0	106	28.6	106	30.0	105	31.5	105	32.3	105	33.0	105	34.5
	-8.5	-9.1	108	29.1	108	30.6	108	32.0	107	32.7	107	33.5	107	34.9
	-7.0	-7.6	112	30.1	112	31.5	111	32.9	111	33.5	111	34.2	111	35.6
	-5.0	-5.6	118	31.3	117	32.6	117	33.9	117	34.6	117	35.3	116	36.6
	-3.0	-3.7	123	32.4	123	33.7	123	34.9	122	35.6	122	36.2	122	37.4
	0.0	-0.7	133	34.1	132	35.3	132	36.4	132	37.0	132	37.6	132	38.7
	3.0	2.2	143	35.6	143	36.7	142	37.8	142	38.3	142	38.8	142	39.9
	5.0	4.1	150	36.5	150	37.6	149	38.6	149	39.1	149	39.6	149	40.6
	7.0	6.0	157	37.4	157	38.4	157	39.4	157	39.9	156	40.4	156	41.3
	9.0	7.9	165	38.3	165	39.2	164	40.1	164	40.6	164	41.0	157	39.5
	11.0	9.8	173	39.1	173	39.9	172	40.8	172	41.3	169	40.5	157	37.2
	13.0	11.8	182	39.8	182	40.7	181	41.3	175	39.7	169	38.1	157	35.1
	15.0	13.7	191	40.6	190	41.4	181	38.9	175	37.5	169	36.0	157	33.2
110 (1320)	-19.8	-20.0	85.7	24.9	85.4	26.6	85.1	28.2	85.0	29.1	84.8	29.9	84.5	31.6
	-18.8	-19.0	87.2	25.4	86.9	27.1	86.6	28.7	86.5	29.6	86.4	30.4	86.1	32.0
	-16.7	-17.0	90.6	26.6	90.3	28.2	90.0	29.8	89.9	30.5	89.7	31.3	89.4	32.9
	-13.7	-15.0	94.4	27.8	94.1	29.3	93.8	30.8	93.6	31.6	93.5	32.3	93.2	33.8
	-11.8	-13.0	98.5	29.0	98.2	30.4	97.9	31.9	97.8	32.6	97.6	33.3	97.3	34.8
	-9.8	-11.0	103	30.1	103	31.5	102	32.9	102	33.6	102	34.3	102	35.7
	-9.5	-10.0	105	30.7	105	32.1	105	33.4	105	34.1	105	34.8	104	36.1
	-8.5	-9.1	108	31.2	107	32.6	107	33.9	107	34.6	107	35.2	107	36.5
	-7.0	-7.6	112	32.1	111	33.4	111	34.7	111	35.3	111	35.9	110	37.2
	-5.0	-5.6	117	33.2	117	34.4	117	35.6	116	36.3	116	36.9	116	38.1
	-3.0	-3.7	123	34.3	122	35.4	122	36.6	122	37.1	122	37.7	122	38.9
	0.0	-0.7	132	35.8	132	36.9	132	37.9	132	38.5	131	39.0	131	40.1
	3.0	2.2	142	37.2	142	38.2	142	39.2	142	39.7	142	40.1	141	41.1
	5.0	4.1	149	38.0	149	39.0	149	39.9	149	40.4	149	40.9	144	40.1
	7.0	6.0	157	38.8	157	39.7	156	40.6	156	41.1	155	41.1	144	37.8
	9.0	7.9	165	39.6	164	40.5	164	41.3	160	40.3	155	38.7	144	35.6
	11.0	9.8	173	40.4	172	41.2	166	39.5	160	38.0	155	36.6	144	33.6
	13.0	11.8	181	41.1	176	40.1	166	37.2	160	35.8	155	34.4	144	31.7
	15.0	13.7	187	40.6	176	37.8	166	35.2	160	33.9	155	32.6	144	30.0

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (1200)	-19.8	-20.0	85.2	27.6	84.9	29.1	84.7	30.6	84.6	31.4	84.4	32.1	84.2	33.7
	-18.8	-19.0	86.8	28.1	86.5	29.6	86.2	31.1	86.1	31.8	86.0	32.6	85.7	34.1
	-16.7	-17.0	90.1	29.1	89.9	30.6	89.6	32.0	89.5	32.7	89.3	33.4	89.1	34.9
	-13.7	-15.0	93.9	30.2	93.6	31.6	93.4	32.9	93.2	33.6	93.1	34.3	92.8	35.7
	-11.8	-13.0	98.0	31.3	97.8	32.6	97.5	33.9	97.4	34.6	97.3	35.2	97.0	36.6
	-9.8	-11.0	103	32.3	102	33.6	102	34.9	102	35.5	102	36.1	102	37.4
	-9.5	-10.0	105	32.9	105	34.1	104	35.3	104	36.0	104	36.6	104	37.8
	-8.5	-9.1	107	33.4	107	34.6	107	35.8	107	36.4	106	37.0	106	38.2
	-7.0	-7.6	111	34.1	111	35.3	111	36.5	110	37.0	110	37.6	110	38.8
	-5.0	-5.6	117	35.2	116	36.3	116	37.4	116	37.9	116	38.5	116	39.6
	-3.0	-3.7	122	36.1	122	37.1	122	38.2	122	38.7	122	39.2	121	40.3
	0.0	-0.7	132	37.5	132	38.5	131	39.4	131	39.9	131	40.4	131	41.4
	3.0	2.2	142	38.8	142	39.7	141	40.6	141	41.0	141	41.3	131	37.9
	5.0	4.1	149	39.5	149	40.4	148	41.3	146	40.5	141	38.9	131	35.8
	7.0	6.0	156	40.3	156	41.1	151	39.7	146	38.2	141	36.7	131	33.8
	9.0	7.9	164	41.0	160	40.3	151	37.4	146	36.0	141	34.6	131	31.9
	11.0	9.8	170	40.8	160	38.0	151	35.3	146	34.0	141	32.7	131	30.2
	13.0	11.8	170	38.3	160	35.8	151	33.3	146	32.1	141	30.9	131	28.5
	15.0	13.7	170	36.2	160	33.8	151	31.5	146	30.4	141	29.2	131	27.0
90 (1080)	-19.8	-20.0	84.7	30.2	84.5	31.6	84.3	33.0	84.2	33.7	84.0	34.4	83.8	35.7
	-18.8	-19.0	86.3	30.7	86.1	32.0	85.8	33.4	85.7	34.1	85.6	34.8	85.3	36.1
	-16.7	-17.0	89.7	31.6	89.4	32.9	89.2	34.2	89.1	34.9	89.0	35.5	88.7	36.8
	-13.7	-15.0	93.4	32.6	93.2	33.9	93.0	35.1	92.8	35.7	92.7	36.3	92.5	37.6
	-11.8	-13.0	97.6	33.6	97.3	34.8	97.1	36.0	97.0	36.6	96.9	37.2	96.6	38.3
	-9.8	-11.0	102	34.6	102	35.7	102	36.8	102	37.4	101	38.0	101	39.1
	-9.5	-10.0	105	35.0	104	36.2	104	37.3	104	37.8	104	38.4	104	39.5
	-8.5	-9.1	107	35.5	107	36.6	106	37.6	106	38.2	106	38.7	106	39.8
	-7.0	-7.6	111	36.2	110	37.2	110	38.3	110	38.8	110	39.3	110	40.3
	-5.0	-5.6	116	37.1	116	38.1	116	39.1	116	39.6	116	40.1	115	41.1
	-3.0	-3.7	122	37.9	122	38.9	121	39.8	121	40.3	121	40.8	118	40.2
	0.0	-0.7	131	39.2	131	40.1	131	40.9	131	41.4	127	39.9	118	36.6
	3.0	2.2	141	40.3	141	41.1	135	39.4	131	37.9	127	36.4	118	33.5
	5.0	4.1	149	41.0	144	40.0	135	37.2	131	35.8	127	34.4	118	31.7
	7.0	6.0	153	40.4	144	37.7	135	35.1	131	33.8	127	32.5	118	30.0
	9.0	7.9	153	38.1	144	35.6	135	33.1	131	31.9	127	30.7	118	28.3
	11.0	9.8	153	36.0	144	33.6	135	31.3	131	30.2	127	29.0	118	26.9
	13.0	11.8	153	33.9	144	31.7	135	29.5	131	28.5	127	27.4	118	25.4
	15.0	13.7	153	32.1	144	30.0	135	28.0	131	27.0	127	26.0	118	24.1
80 (960)	-19.8	-20.0	84.3	32.9	84.1	34.1	83.9	35.4	83.8	36.0	83.6	36.6	83.4	37.8
	-18.8	-19.0	85.8	33.3	85.6	34.5	85.4	35.7	85.3	36.3	85.2	36.9	85.0	38.1
	-16.7	-17.0	89.2	34.2	89.0	35.3	88.8	36.5	88.7	37.1	88.6	37.6	88.4	38.8
	-13.7	-15.0	93.0	35.0	92.8	36.1	92.5	37.2	92.4	37.8	92.3	38.4	92.1	39.5
	-11.8	-13.0	97.1	35.9	96.9	37.0	96.7	38.0	96.6	38.5	96.5	39.1	96.3	40.1
	-9.8	-11.0	102	36.8	101	37.8	101	38.8	101	39.3	101	39.8	101	40.8
	-9.5	-10.0	104	37.2	104	38.2	104	39.2	104	39.7	103	40.2	103	41.1
	-8.5	-9.1	106	37.6	106	38.5	106	39.5	106	40.0	106	40.5	105	41.1
	-7.0	-7.6	110	38.2	110	39.1	110	40.1	110	40.5	110	41.0	105	39.3
	-5.0	-5.6	116	39.0	116	39.9	115	40.8	115	41.2	113	40.3	105	37.0
	-3.0	-3.7	121	39.8	121	40.6	120	41.2	117	39.6	113	38.0	105	35.0
	0.0	-0.7	131	40.9	128	40.4	120	37.5	117	36.1	113	34.7	105	32.0
	3.0	2.2	136	39.6	128	36.9	120	34.3	117	33.1	113	31.8	105	29.3
	5.0	4.1	136	37.3	128	34.8	120	32.4	117	31.2	113	30.1	105	27.8
	7.0	6.0	136	35.2	128	32.9	120	30.6	117	29.5	113	28.4	105	26.3
	9.0	7.9	136	33.2	128	31.1	120	29.0	117	27.9	113	26.9	105	24.9
	11.0	9.8	136	31.4	128	29.4	120	27.4	117	26.5	113	25.5	105	23.7
	13.0	11.8	136	29.6	128	27.8	120	25.9	117	25.0	113	24.2	105	22.4
	15.0	13.7	136	28.1	128	26.3	120	24.6	117	23.8	113	23.0	105	21.3

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ▒ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by ▒.
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB 16.0 TC	16.0 PI	18.0 TC	18.0 PI	20.0 TC	20.0 PI	21.0 TC	21.0 PI	22.0 TC	22.0 PI	24.0 TC	24.0 PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
70 (840)	-19.8	-20.0	83.8	35.6	83.6	36.7	83.4	37.8	83.4	38.3	83.3	38.8	83.1	39.9
	-18.8	-19.0	85.4	36.0	85.2	37.0	85.0	38.1	84.9	38.6	84.8	39.1	84.6	40.2
	-16.7	-17.0	88.7	36.7	88.6	37.7	88.4	38.7	88.3	39.2	88.2	39.7	88.0	40.7
	-13.7	-15.0	92.5	37.5	92.3	38.4	92.1	39.4	92.0	39.9	92.0	40.4	91.8	41.3
	-11.8	-13.0	96.7	38.2	96.5	39.2	96.3	40.1	96.2	40.5	96.1	41.0	91.8	39.2
	-9.8	-11.0	101	39.0	101	39.9	101	40.7	101	41.2	98.6	40.3	91.8	37.1
	-9.5	-10.0	104	39.4	103	40.2	103	41.1	102	40.8	98.6	39.2	91.8	36.0
	-8.5	-9.1	106	39.7	106	40.5	105	41.3	102	39.7	98.6	38.2	91.8	35.1
	-7.0	-7.6	110	40.2	110	41.1	105	39.5	102	38.0	98.6	36.5	91.8	33.6
	-5.0	-5.6	115	41.0	112	40.1	105	37.2	102	35.8	98.6	34.4	91.8	31.7
	-3.0	-3.7	119	40.5	112	37.8	105	35.1	102	33.8	98.6	32.5	91.8	30.0
	0.0	-0.7	119	37.0	112	34.5	105	32.1	102	30.9	98.6	29.8	91.8	27.5
	3.0	2.2	119	33.8	112	31.6	105	29.5	102	28.4	98.6	27.4	91.8	25.3
	5.0	4.1	119	31.9	112	29.9	105	27.9	102	26.9	98.6	25.9	91.8	24.0
	7.0	6.0	119	30.2	112	28.3	105	26.4	102	25.5	98.6	24.6	91.8	22.8
	9.0	7.9	119	28.6	112	26.8	105	25.0	102	24.2	98.6	23.3	91.8	21.6
	11.0	9.8	119	27.1	112	25.4	105	23.8	102	22.9	98.6	22.1	91.8	20.6
	13.0	11.8	119	25.6	112	24.0	105	22.5	102	21.7	98.6	21.0	91.8	19.5
	15.0	13.7	119	24.3	112	22.8	105	21.4	102	20.7	98.6	20.0	91.8	18.6
60 (720)	-19.8	-20.0	83.4	38.3	83.2	39.2	83.0	40.1	83.0	40.6	82.9	41.0	78.7	38.9
	-18.8	-19.0	84.9	38.6	84.7	39.5	84.6	40.4	84.5	40.9	84.4	41.3	78.7	38.0
	-16.7	-17.0	88.3	39.2	88.1	40.1	88.0	41.0	87.4	41.0	84.5	39.4	78.7	36.2
	-13.7	-15.0	92.0	39.9	91.9	40.7	90.3	40.5	87.4	39.0	84.5	37.5	78.7	34.5
	-11.8	-13.0	96.2	40.5	96.0	41.3	90.3	38.4	87.4	37.0	84.5	35.5	78.7	32.7
	-9.8	-11.0	101	41.2	96.1	39.1	90.3	36.3	87.4	35.0	84.5	33.6	78.7	31.0
	-9.5	-10.0	102	40.8	96.1	38.0	90.3	35.3	87.4	34.0	84.5	32.7	78.7	30.2
	-8.5	-9.1	102	39.7	96.1	37.0	90.3	34.4	87.4	33.2	84.5	31.9	78.7	29.4
	-7.0	-7.6	102	38.0	96.1	35.5	90.3	33.0	87.4	31.8	84.5	30.6	78.7	28.2
	-5.0	-5.6	102	35.8	96.1	33.4	90.3	31.1	87.4	30.0	84.5	28.9	78.7	26.7
	-3.0	-3.7	102	33.8	96.1	31.6	90.3	29.5	87.4	28.4	84.5	27.4	78.7	25.3
	0.0	-0.7	102	30.9	96.1	29.0	90.3	27.0	87.4	26.1	84.5	25.1	78.7	23.3
	3.0	2.2	102	28.4	96.1	26.6	90.3	24.9	87.4	24.0	84.5	23.2	78.7	21.5
	5.0	4.1	102	26.9	96.1	25.2	90.3	23.6	87.4	22.8	84.5	22.0	78.7	20.5
	7.0	6.0	102	25.5	96.1	23.9	90.3	22.4	87.4	21.7	84.5	20.9	78.7	19.5
	9.0	7.9	102	24.2	96.1	22.7	90.3	21.3	87.4	20.6	84.5	19.9	78.7	18.5
	11.0	9.8	102	22.9	96.1	21.6	90.3	20.2	87.4	19.6	84.5	18.9	78.7	17.6
	13.0	11.8	102	21.7	96.1	20.5	90.3	19.2	87.4	18.6	84.5	18.0	78.7	16.8
	15.0	13.7	102	20.7	96.1	19.5	90.3	18.3	87.4	17.7	84.5	17.2	78.7	16.0
50 (600)	-19.8	-20.0	82.9	41.0	80.1	39.7	75.3	36.8	72.8	35.5	70.4	34.1	65.6	31.4
	-18.8	-19.0	84.4	41.2	80.1	38.8	75.3	36.0	72.8	34.7	70.4	33.4	65.6	30.8
	-16.7	-17.0	84.9	39.7	80.1	37.0	75.3	34.4	72.8	33.1	70.4	31.9	65.6	29.4
	-13.7	-15.0	84.9	37.7	80.1	35.2	75.3	32.7	72.8	31.5	70.4	30.4	65.6	28.0
	-11.8	-13.0	84.9	35.7	80.1	33.4	75.3	31.1	72.8	30.0	70.4	28.9	65.6	26.7
	-9.8	-11.0	84.9	33.8	80.1	31.6	75.3	29.5	72.8	28.4	70.4	27.4	65.6	25.3
	-9.5	-10.0	84.9	32.9	80.1	30.8	75.3	28.7	72.8	27.7	70.4	26.7	65.6	24.7
	-8.5	-9.1	84.9	32.1	80.1	30.0	75.3	28.0	72.8	27.0	70.4	26.0	65.6	24.1
	-7.0	-7.6	84.9	30.8	80.1	28.8	75.3	26.9	72.8	25.9	70.4	25.0	65.6	23.2
	-5.0	-5.6	84.9	29.1	80.1	27.2	75.3	25.4	72.8	24.6	70.4	23.7	65.6	22.0
	-3.0	-3.7	84.9	27.5	80.1	25.8	75.3	24.1	72.8	23.3	70.4	22.5	65.6	20.9
	0.0	-0.7	84.9	25.3	80.1	23.7	75.3	22.2	72.8	21.5	70.4	20.8	65.6	19.3
	3.0	2.2	84.9	23.3	80.1	21.9	75.3	20.6	72.8	19.9	70.4	19.2	65.6	17.9
	5.0	4.1	84.9	22.1	80.1	20.8	75.3	19.6	72.8	18.9	70.4	18.3	65.6	17.1
	7.0	6.0	84.9	21.0	80.1	19.8	75.3	18.5	72.8	17.9	70.4	17.4	65.6	16.3
	9.0	7.9	84.9	20.0	80.1	18.8	75.3	17.7	72.8	17.2	70.4	16.6	65.6	15.5
	11.0	9.8	84.9	19.0	80.1	17.9	75.3	16.9	72.8	16.4	70.4	15.9	65.6	14.8
	13.0	11.8	84.9	18.1	80.1	17.1	75.3	16.1	72.8	15.6	70.4	15.1	65.6	14.2
	15.0	13.7	84.9	17.2	80.1	16.3	75.3	15.4	72.8	14.9	70.4	14.4	65.6	13.5

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1625)	-19.8	-20.0	91.0	20.7	90.7	22.8	90.3	24.9	90.1	25.9	90.0	27.0	89.6	29.1
	-18.8	-19.0	92.7	21.4	92.3	23.4	91.9	25.5	91.8	26.5	91.6	27.5	91.2	29.6
	-16.7	-17.0	96.2	22.8	95.9	24.8	95.5	26.8	95.3	27.7	95.1	28.7	94.8	30.7
	-13.7	-15.0	100.2	24.3	99.8	26.2	99.5	28.1	99.3	29.0	99.1	30.0	98.7	31.9
	-11.8	-13.0	104.5	25.8	104.2	27.6	103.8	29.4	103.6	30.3	103.4	31.2	103.1	33.0
	-9.8	-11.0	109	27.2	109	29.0	109	30.7	108	31.6	108	32.4	108	34.1
	-9.5	-10.0	112	28.0	111	29.6	111	31.3	111	32.2	111	33.0	110	34.7
	-8.5	-9.1	114	28.6	114	30.3	113	31.9	113	32.7	113	33.6	113	35.2
	-7.0	-7.6	118	29.7	118	31.3	118	32.9	117	33.7	117	34.5	117	36.0
	-5.0	-5.6	124	31.1	124	32.6	123	34.1	123	34.9	123	35.6	123	37.1
	-3.0	-3.7	130	32.4	130	33.8	129	35.2	129	35.9	129	36.7	129	38.1
	0.0	-0.7	140	34.3	140	35.6	139	36.9	139	37.6	139	38.3	139	39.6
	3.0	2.2	151	36.0	150	37.2	150	38.5	150	39.1	150	39.7	149	40.9
	5.0	4.1	158	37.1	158	38.2	157	39.4	157	40.0	157	40.6	157	41.8
	7.0	6.0	166	38.1	165	39.2	165	40.3	165	40.9	165	41.4	164	42.5
	9.0	7.9	174	39.0	174	40.1	173	41.2	173	41.7	173	42.2	173	43.3
	11.0	9.8	182	39.9	182	41.0	182	42.0	182	42.5	181	43.0	179	43.2
	13.0	11.8	192	40.8	191	41.8	191	42.8	191	43.3	191	43.7	179	40.7
	15.0	13.7	201	41.7	201	42.6	200	43.5	199	43.5	192	41.8	179	38.4
120 (1500)	-19.8	-20.0	90.6	23.5	90.2	25.4	89.9	27.4	89.7	28.3	89.6	29.3	89.2	31.3
	-18.8	-19.0	92.2	24.1	91.8	26.0	91.5	27.9	91.3	28.9	91.2	29.8	90.8	31.7
	-16.7	-17.0	95.7	25.5	95.4	27.3	95.1	29.1	94.9	30.0	94.7	31.0	94.4	32.8
	-13.7	-15.0	99.7	26.8	99.4	28.6	99.0	30.3	98.9	31.2	98.7	32.1	98.4	33.8
	-11.8	-13.0	104.0	28.2	103.7	29.9	103.4	31.5	103.2	32.4	103.0	33.2	102.7	34.9
	-9.8	-11.0	109	29.6	108	31.2	108	32.8	108	33.6	108	34.4	107	35.9
	-9.5	-10.0	111	30.2	111	31.8	111	33.4	110	34.1	110	34.9	110	36.5
	-8.5	-9.1	114	30.8	113	32.4	113	33.9	113	34.7	113	35.4	112	36.9
	-7.0	-7.6	118	31.8	117	33.3	117	34.8	117	35.5	117	36.2	116	37.7
	-5.0	-5.6	124	33.1	123	34.5	123	35.9	123	36.6	123	37.3	122	38.7
	-3.0	-3.7	130	34.3	129	35.6	129	37.0	129	37.6	129	38.3	128	39.6
	0.0	-0.7	140	36.1	139	37.3	139	38.5	139	39.1	139	39.8	138	41.0
	3.0	2.2	150	37.7	150	38.8	150	39.9	149	40.5	149	41.1	149	42.2
	5.0	4.1	158	38.6	157	39.7	157	40.8	157	41.4	157	41.9	156	43.0
	7.0	6.0	165	39.6	165	40.6	165	41.6	165	42.2	164	42.7	164	43.7
	9.0	7.9	173	40.5	173	41.5	173	42.4	173	42.9	172	43.4	165	41.7
	11.0	9.8	182	41.3	182	42.2	181	43.2	181	43.6	177	42.8	165	39.3
	13.0	11.8	191	42.1	191	43.0	190	43.6	184	41.9	177	40.2	165	37.0
	15.0	13.7	201	42.9	200	43.7	190	41.1	184	39.5	177	38.0	165	35.0
110 (1375)	-19.8	-20.0	90.1	26.3	89.8	28.1	89.5	29.9	89.3	30.8	89.1	31.7	88.8	33.4
	-18.8	-19.0	91.7	26.9	91.4	28.7	91.1	30.4	90.9	31.3	90.8	32.2	90.5	33.9
	-16.7	-17.0	95.2	28.1	94.9	29.8	94.6	31.5	94.5	32.3	94.3	33.2	94.0	34.8
	-13.7	-15.0	99.2	29.4	98.9	31.0	98.6	32.6	98.4	33.4	98.3	34.2	98.0	35.8
	-11.8	-13.0	103.6	30.6	103.2	32.2	102.9	33.7	102.8	34.5	102.6	35.2	102.3	36.8
	-9.8	-11.0	108	31.9	108	33.4	108	34.8	108	35.6	107	36.3	107	37.7
	-9.5	-10.0	111	32.5	111	33.9	110	35.4	110	36.1	110	36.8	110	38.2
	-8.5	-9.1	113	33.1	113	34.5	113	35.9	112	36.6	112	37.3	112	38.7
	-7.0	-7.6	117	34.0	117	35.3	117	36.7	117	37.3	116	38.0	116	39.4
	-5.0	-5.6	123	35.2	123	36.4	123	37.7	122	38.4	122	39.0	122	40.3
	-3.0	-3.7	129	36.2	129	37.5	128	38.7	128	39.3	128	39.9	128	41.1
	0.0	-0.7	139	37.9	139	39.0	139	40.1	138	40.7	138	41.2	138	42.4
	3.0	2.2	150	39.3	149	40.4	149	41.4	149	41.9	149	42.5	149	43.5
	5.0	4.1	157	40.2	157	41.2	157	42.2	156	42.7	156	43.2	151	42.3
	7.0	6.0	165	41.1	165	42.0	164	43.0	164	43.5	163	43.4	151	39.8
	9.0	7.9	173	41.9	173	42.8	172	43.7	168	42.6	163	40.9	151	37.6
	11.0	9.8	181	42.7	181	43.5	174	41.7	168	40.1	163	38.6	151	35.5
	13.0	11.8	191	43.4	185	42.3	174	39.3	168	37.8	163	36.3	151	33.5
	15.0	13.7	196	42.8	185	39.9	174	37.1	168	35.7	163	34.4	151	31.7

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (1250)	-19.8	-20.0	89.6	29.2	89.3	30.8	89.0	32.4	88.9	33.2	88.7	34.0	88.5	35.6
	-18.8	-19.0	91.2	29.7	90.9	31.3	90.6	32.9	90.5	33.7	90.4	34.5	90.1	36.0
	-16.7	-17.0	94.8	30.8	94.5	32.3	94.2	33.9	94.1	34.6	93.9	35.4	93.6	36.9
	-13.7	-15.0	98.7	32.0	98.4	33.4	98.2	34.9	98.0	35.6	97.9	36.3	97.6	37.8
	-11.8	-13.0	103.1	33.1	102.8	34.5	102.5	35.9	102.4	36.6	102.2	37.3	102.0	38.7
	-9.8	-11.0	108	34.2	108	35.6	107	36.9	107	37.6	107	38.2	107	39.6
	-9.5	-10.0	110	34.8	110	36.1	110	37.4	110	38.0	110	38.7	109	40.0
	-8.5	-9.1	113	35.3	112	36.6	112	37.8	112	38.5	112	39.1	112	40.4
	-7.0	-7.6	117	36.1	117	37.3	116	38.6	116	39.2	116	39.8	116	41.0
	-5.0	-5.6	123	37.2	122	38.4	122	39.5	122	40.1	122	40.7	122	41.9
	-3.0	-3.7	129	38.2	128	39.3	128	40.4	128	41.0	128	41.5	127	42.6
	0.0	-0.7	139	39.7	138	40.7	138	41.7	138	42.2	138	42.7	138	43.8
	3.0	2.2	149	41.0	149	41.9	149	42.9	149	43.4	148	43.6	138	40.0
	5.0	4.1	157	41.8	156	42.7	156	43.6	153	42.8	148	41.1	138	37.8
	7.0	6.0	164	42.6	164	43.5	158	41.9	153	40.3	148	38.7	138	35.6
	9.0	7.9	173	43.3	168	42.5	158	39.5	153	38.0	148	36.6	138	33.7
	11.0	9.8	178	43.0	168	40.1	158	37.3	153	35.9	148	34.5	138	31.9
	13.0	11.8	178	40.5	168	37.8	158	35.1	153	33.9	148	32.6	138	30.1
	15.0	13.7	178	38.2	168	35.7	158	33.3	153	32.0	148	30.9	138	28.5
90 (1125)	-19.8	-20.0	89.1	32.0	88.8	33.5	88.6	34.9	88.5	35.6	88.3	36.4	88.1	37.8
	-18.8	-19.0	90.7	32.5	90.5	33.9	90.2	35.3	90.1	36.1	90.0	36.8	89.7	38.2
	-16.7	-17.0	94.3	33.5	94.0	34.9	93.8	36.2	93.6	36.9	93.5	37.6	93.3	39.0
	-13.7	-15.0	98.2	34.5	98.0	35.8	97.7	37.1	97.6	37.8	97.5	38.4	97.2	39.8
	-11.8	-13.0	102.6	35.5	102.3	36.8	102.1	38.1	102.0	38.7	101.8	39.3	101.6	40.6
	-9.8	-11.0	107	36.6	107	37.8	107	39.0	107	39.6	107	40.2	106	41.4
	-9.5	-10.0	110	37.1	110	38.2	109	39.4	109	40.0	109	40.6	109	41.7
	-8.5	-9.1	112	37.5	112	38.7	112	39.8	112	40.4	111	41.0	111	42.1
	-7.0	-7.6	116	38.3	116	39.4	116	40.5	116	41.0	116	41.6	115	42.7
	-5.0	-5.6	122	39.2	122	40.3	122	41.3	122	41.9	121	42.4	121	43.4
	-3.0	-3.7	128	40.1	128	41.1	128	42.1	127	42.6	127	43.1	124	42.4
	0.0	-0.7	138	41.5	138	42.4	138	43.3	138	43.8	133	42.1	124	38.7
	3.0	2.2	149	42.7	148	43.5	142	41.6	138	40.0	133	38.5	124	35.4
	5.0	4.1	156	43.4	151	42.2	142	39.2	138	37.7	133	36.3	124	33.4
	7.0	6.0	160	42.7	151	39.8	142	37.0	138	35.6	133	34.3	124	31.6
	9.0	7.9	160	40.2	151	37.6	142	34.9	138	33.7	133	32.4	124	29.9
	11.0	9.8	160	38.0	151	35.5	142	33.0	138	31.8	133	30.7	124	28.3
	13.0	11.8	160	35.8	151	33.5	142	31.2	138	30.1	133	29.0	124	26.8
	15.0	13.7	160	33.8	151	31.7	142	29.5	138	28.5	133	27.5	124	25.4
80 (1000)	-19.8	-20.0	88.6	34.8	88.4	36.1	88.2	37.4	88.0	38.1	87.9	38.7	87.7	40.0
	-18.8	-19.0	90.2	35.3	90.0	36.5	89.8	37.8	89.7	38.4	89.6	39.1	89.3	40.3
	-16.7	-17.0	93.8	36.2	93.6	37.4	93.3	38.6	93.2	39.2	93.1	39.8	92.9	41.0
	-13.7	-15.0	97.7	37.1	97.5	38.2	97.3	39.4	97.2	40.0	97.1	40.6	96.8	41.7
	-11.8	-13.0	102.1	38.0	101.9	39.1	101.6	40.2	101.5	40.8	101.4	41.3	101.2	42.4
	-9.8	-11.0	107	38.9	107	40.0	106	41.0	106	41.6	106	42.1	106	43.2
	-9.5	-10.0	109	39.4	109	40.4	109	41.4	109	42.0	109	42.5	108	43.5
	-8.5	-9.1	112	39.8	112	40.8	111	41.8	111	42.3	111	42.8	110	43.4
	-7.0	-7.6	116	40.4	116	41.4	115	42.4	115	42.9	115	43.4	110	41.5
	-5.0	-5.6	122	41.3	121	42.2	121	43.1	121	43.6	118	42.5	110	39.1
	-3.0	-3.7	128	42.1	127	43.0	126	43.4	122	41.8	118	40.1	110	36.9
	0.0	-0.7	138	43.3	135	42.6	126	39.6	122	38.1	118	36.6	110	33.7
	3.0	2.2	143	41.8	135	39.0	126	36.2	122	34.9	118	33.6	110	31.0
	5.0	4.1	143	39.4	135	36.8	126	34.2	122	33.0	118	31.7	110	29.3
	7.0	6.0	143	37.1	135	34.7	126	32.3	122	31.2	118	30.0	110	27.8
	9.0	7.9	143	35.1	135	32.8	126	30.6	122	29.5	118	28.4	110	26.3
	11.0	9.8	143	33.2	135	31.0	126	29.0	122	27.9	118	26.9	110	25.0
	13.0	11.8	143	31.3	135	29.3	126	27.4	122	26.4	118	25.5	110	23.6
	15.0	13.7	143	29.6	135	27.8	126	26.0	122	25.1	118	24.2	110	22.5

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (875)	-19.8	-20.0	88.1	37.7	87.9	38.8	87.7	39.9	87.6	40.5	87.5	41.1	87.3	42.2				
	-18.8	-19.0	89.7	38.1	89.5	39.2	89.4	40.3	89.3	40.8	89.2	41.4	89.0	42.5				
	-16.7	-17.0	93.3	38.8	93.1	39.9	92.9	41.0	92.8	41.5	92.7	42.0	92.5	43.1				
	-13.7	-15.0	97.2	39.6	97.1	40.7	96.9	41.7	96.8	42.2	96.7	42.7	96.4	43.7				
	-11.8	-13.0	101.6	40.4	101.4	41.4	101.2	42.4	101.1	42.9	101.0	43.4	96.4	41.4				
	-9.8	-11.0	106	41.2	106	42.2	106	43.1	106	43.6	103.5	42.6	96.4	39.1				
	-9.5	-10.0	109	41.6	109	42.5	108	43.5	107	43.1	103.5	41.3	96.4	38.0				
	-8.5	-9.1	111	42.0	111	42.9	111	43.6	107	41.9	103.5	40.3	96.4	37.1				
	-7.0	-7.6	115	42.6	115	43.4	111	41.7	107	40.1	103.5	38.5	96.4	35.5				
	-5.0	-5.6	121	43.3	118	42.3	111	39.3	107	37.8	103.5	36.3	96.4	33.5				
	-3.0	-3.7	125	42.8	118	39.9	111	37.1	107	35.7	103.5	34.3	96.4	31.7				
	0.0	-0.7	125	39.0	118	36.4	111	33.9	107	32.7	103.5	31.4	96.4	29.1				
	3.0	2.2	125	35.7	118	33.4	111	31.1	107	30.0	103.5	28.9	96.4	26.7				
	5.0	4.1	125	33.7	118	31.6	111	29.4	107	28.4	103.5	27.4	96.4	25.4				
	7.0	6.0	125	31.9	118	29.8	111	27.9	107	26.9	103.5	25.8	96.4	24.1				
	9.0	7.9	125	30.2	118	28.3	111	26.4	107	25.5	103.5	24.6	96.4	22.8				
	11.0	9.8	125	28.6	118	26.8	111	25.1	107	24.2	103.5	23.4	96.4	21.7				
	13.0	11.8	125	27.0	118	25.4	111	23.7	107	23.0	103.5	22.2	96.4	20.6				
	15.0	13.7	125	25.6	118	24.1	111	22.6	107	21.8	103.5	21.1	96.4	19.6				
60 (750)	-19.8	-20.0	87.6	40.5	87.5	41.5	87.3	42.4	87.2	42.9	87.1	43.4	82.6	41.0				
	-18.8	-19.0	89.3	40.8	89.1	41.8	88.9	42.7	88.8	43.2	88.7	43.7	82.6	40.1				
	-16.7	-17.0	92.8	41.5	92.6	42.4	92.5	43.3	91.8	43.3	88.7	41.6	82.6	38.2				
	-13.7	-15.0	96.8	42.2	96.6	43.1	94.8	42.8	91.8	41.2	88.7	39.5	82.6	36.4				
	-11.8	-13.0	101.1	42.9	100.9	43.7	94.8	40.5	91.8	39.0	88.7	37.5	82.6	34.5				
	-9.8	-11.0	106	43.6	100.9	41.3	94.8	38.4	91.8	36.9	88.7	35.5	82.6	32.7				
	-9.5	-10.0	107	43.0	100.9	40.1	94.8	37.3	91.8	35.9	88.7	34.5	82.6	31.8				
	-8.5	-9.1	107	41.9	100.9	39.1	94.8	36.3	91.8	35.0	88.7	33.7	82.6	31.1				
	-7.0	-7.6	107	40.1	100.9	37.4	94.8	34.8	91.8	33.5	88.7	32.3	82.6	29.8				
	-5.0	-5.6	107	37.8	100.9	35.3	94.8	32.9	91.8	31.7	88.7	30.5	82.6	28.2				
	-3.0	-3.7	107	35.7	100.9	33.4	94.8	31.1	91.8	30.0	88.7	28.9	82.6	26.7				
	0.0	-0.7	107	32.6	100.9	30.6	94.8	28.5	91.8	27.5	88.7	26.5	82.6	24.6				
	3.0	2.2	107	30.0	100.9	28.1	94.8	26.3	91.8	25.4	88.7	24.5	82.6	22.7				
	5.0	4.1	107	28.4	100.9	26.6	94.8	24.9	91.8	24.1	88.7	23.2	82.6	21.6				
	7.0	6.0	107	26.9	100.9	25.2	94.8	23.6	91.8	22.9	88.7	22.1	82.6	20.5				
	9.0	7.9	107	25.5	100.9	24.0	94.8	22.5	91.8	21.7	88.7	21.0	82.6	19.5				
	11.0	9.8	107	24.2	100.9	22.8	94.8	21.4	91.8	20.7	88.7	20.0	82.6	18.6				
	13.0	11.8	107	22.9	100.9	21.6	94.8	20.3	91.8	19.6	88.7	19.0	82.6	17.7				
	15.0	13.7	107	21.8	100.9	20.6	94.8	19.3	91.8	18.7	88.7	18.1	82.6	16.9				
50 (625)	-19.8	-20.0	87.1	43.3	84.1	41.9	79.0	38.9	76.5	37.4	73.9	36.0	68.8	33.2				
	-18.8	-19.0	88.8	43.6	84.1	40.9	79.0	38.0	76.5	36.6	73.9	35.2	68.8	32.5				
	-16.7	-17.0	89.2	41.9	84.1	39.0	79.0	36.3	76.5	35.0	73.9	33.6	68.8	31.0				
	-13.7	-15.0	89.2	39.8	84.1	37.1	79.0	34.5	76.5	33.3	73.9	32.0	68.8	29.6				
	-11.8	-13.0	89.2	37.7	84.1	35.2	79.0	32.8	76.5	31.6	73.9	30.5	68.8	28.2				
	-9.8	-11.0	89.2	35.7	84.1	33.4	79.0	31.1	76.5	30.0	73.9	28.9	68.8	26.7				
	-9.5	-10.0	89.2	34.7	84.1	32.5	79.0	30.3	76.5	29.2	73.9	28.2	68.8	26.1				
	-8.5	-9.1	89.2	33.9	84.1	31.7	79.0	29.6	76.5	28.5	73.9	27.5	68.8	25.5				
	-7.0	-7.6	89.2	32.5	84.1	30.4	79.0	28.4	76.5	27.4	73.9	26.4	68.8	24.5				
	-5.0	-5.6	89.2	30.7	84.1	28.7	79.0	26.9	76.5	25.9	73.9	25.0	68.8	23.2				
	-3.0	-3.7	89.2	29.0	84.1	27.2	79.0	25.5	76.5	24.6	73.9	23.8	68.8	22.1				
	0.0	-0.7	89.2	26.7	84.1	25.1	79.0	23.5	76.5	22.7	73.9	21.9	68.8	20.4				
	3.0	2.2	89.2	24.6	84.1	23.1	79.0	21.7	76.5	21.0	73.9	20.3	68.8	18.9				
	5.0	4.1	89.2	23.4	84.1	22.0	79.0	20.6	76.5	20.0	73.9	19.3	68.8	18.0				
	7.0	6.0	89.2	22.2	84.1	20.9	79.0	19.6	76.5	19.0	73.9	18.4	68.8	17.2				
	9.0	7.9	89.2	21.1	84.1	19.9	79.0	18.7	76.5	18.1	73.9	17.5	68.8	16.4				
	11.0	9.8	89.2	20.1	84.1	18.9	79.0	17.8	76.5	17.3	73.9	16.7	68.8	15.7				
	13.0	11.8	89.2	19.1	84.1	18.0	79.0	17.0	76.5	16.5	73.9	15.9	68.8	14.9				
	15.0	13.7	89.2	18.2	84.1	17.2	79.0	16.2	76.5	15.7	73.9	15.3	68.8	14.3				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1690)	-19.8	-20.0	93.6	21.2	93.2	23.4	92.8	25.5	92.6	26.6	92.4	27.7	92.1	29.9
	-18.8	-19.0	95.2	21.9	94.9	24.0	94.5	26.2	94.3	27.2	94.1	28.3	93.7	30.5
	-16.7	-17.0	98.9	23.4	98.5	25.4	98.1	27.5	98.0	28.5	97.8	29.6	97.4	31.6
	-13.7	-15.0	103.0	24.9	102.6	26.9	102.2	28.9	102.0	29.8	101.8	30.8	101.5	32.8
	-11.8	-13.0	107.4	26.5	107.1	28.3	106.7	30.2	106.5	31.2	106.3	32.1	105.9	34.0
	-9.8	-11.0	112	28.0	112	29.8	112	31.6	111	32.5	111	33.4	111	35.2
	-9.5	-10.0	115	28.7	115	30.5	114	32.2	114	33.1	114	34.0	113	35.8
	-8.5	-9.1	117	29.4	117	31.1	117	32.8	116	33.7	116	34.6	116	36.3
	-7.0	-7.6	122	30.5	121	32.2	121	33.8	121	34.7	120	35.5	120	37.1
	-5.0	-5.6	128	32.0	127	33.5	127	35.1	127	35.9	126	36.7	126	38.3
	-3.0	-3.7	134	33.3	133	34.8	133	36.3	133	37.0	133	37.8	132	39.3
	0.0	-0.7	144	35.3	144	36.7	143	38.1	143	38.8	143	39.4	142	40.8
	3.0	2.2	155	37.1	154	38.4	154	39.7	154	40.3	154	40.9	153	42.2
	5.0	4.1	162	38.2	162	39.4	162	40.6	162	41.2	161	41.9	161	43.1
	7.0	6.0	170	39.2	170	40.4	170	41.6	170	42.1	169	42.7	169	43.9
	9.0	7.9	179	40.2	178	41.3	178	42.5	178	43.0	178	43.6	177	44.7
	11.0	9.8	187	41.2	187	42.2	187	43.3	187	43.8	186	44.3	185	44.9
	13.0	11.8	197	42.1	197	43.1	196	44.1	196	44.6	196	45.1	185	42.2
	15.0	13.7	207	43.0	206	43.9	206	44.9	205	45.2	198	43.4	185	39.9
120 (1560)	-19.8	-20.0	93.1	24.1	92.7	26.1	92.4	28.1	92.2	29.1	92.0	30.2	91.7	32.2
	-18.8	-19.0	94.7	24.8	94.4	26.8	94.0	28.7	93.9	29.7	93.7	30.7	93.4	32.7
	-16.7	-17.0	98.4	26.2	98.0	28.1	97.7	30.0	97.5	30.9	97.4	31.9	97.0	33.7
	-13.7	-15.0	102.4	27.6	102.1	29.4	101.8	31.2	101.6	32.1	101.4	33.0	101.1	34.8
	-11.8	-13.0	106.9	29.0	106.6	30.7	106.2	32.5	106.1	33.3	105.9	34.2	105.5	35.9
	-9.8	-11.0	112	30.4	111	32.1	111	33.7	111	34.6	111	35.4	110	37.0
	-9.5	-10.0	114	31.1	114	32.7	114	34.3	114	35.2	113	36.0	113	37.6
	-8.5	-9.1	117	31.7	116	33.3	116	34.9	116	35.7	116	36.5	115	38.1
	-7.0	-7.6	121	32.8	121	34.3	120	35.8	120	36.6	120	37.3	120	38.9
	-5.0	-5.6	127	34.1	127	35.5	126	37.0	126	37.7	126	38.4	126	39.9
	-3.0	-3.7	133	35.3	133	36.7	132	38.1	132	38.8	132	39.5	132	40.8
	0.0	-0.7	143	37.2	143	38.4	143	39.7	143	40.4	142	41.0	142	42.3
	3.0	2.2	154	38.8	154	40.0	154	41.2	153	41.8	153	42.4	153	43.6
	5.0	4.1	162	39.8	162	41.0	161	42.1	161	42.7	161	43.2	161	44.3
	7.0	6.0	170	40.8	170	41.9	169	43.0	169	43.5	169	44.0	169	45.1
	9.0	7.9	178	41.7	178	42.8	178	43.8	177	44.3	177	44.8	170	43.3
	11.0	9.8	187	42.6	187	43.6	186	44.5	186	45.0	183	44.4	170	40.8
	13.0	11.8	197	43.5	196	44.4	196	45.2	189	43.5	183	41.8	170	38.4
	15.0	13.7	206	44.3	206	45.1	196	42.7	189	41.1	183	39.5	170	36.3
110 (1430)	-19.8	-20.0	92.6	27.1	92.2	28.9	91.9	30.7	91.8	31.7	91.6	32.6	91.3	34.4
	-18.8	-19.0	94.2	27.7	93.9	29.5	93.6	31.3	93.4	32.2	93.3	33.1	93.0	34.9
	-16.7	-17.0	97.9	28.9	97.6	30.7	97.3	32.4	97.1	33.3	96.9	34.2	96.6	35.9
	-13.7	-15.0	101.9	30.2	101.6	31.9	101.3	33.6	101.2	34.4	101.0	35.2	100.7	36.9
	-11.8	-13.0	106.4	31.5	106.1	33.1	105.8	34.7	105.6	35.5	105.5	36.3	105.2	37.9
	-9.8	-11.0	111	32.8	111	34.4	111	35.9	111	36.6	110	37.4	110	38.9
	-9.5	-10.0	114	33.5	114	35.0	113	36.4	113	37.2	113	37.9	113	39.4
	-8.5	-9.1	116	34.1	116	35.5	116	37.0	116	37.7	115	38.4	115	39.9
	-7.0	-7.6	121	35.0	120	36.4	120	37.8	120	38.5	120	39.2	119	40.6
	-5.0	-5.6	127	36.2	126	37.5	126	38.9	126	39.5	126	40.2	125	41.5
	-3.0	-3.7	133	37.3	132	38.6	132	39.9	132	40.5	132	41.1	131	42.4
	0.0	-0.7	143	39.0	143	40.2	142	41.4	142	42.0	142	42.5	142	43.7
	3.0	2.2	154	40.6	154	41.6	153	42.7	153	43.3	153	43.8	153	44.9
	5.0	4.1	161	41.5	161	42.5	161	43.6	161	44.1	161	44.6	156	43.9
	7.0	6.0	169	42.4	169	43.4	169	44.3	169	44.8	168	45.0	156	41.4
	9.0	7.9	178	43.2	177	44.2	177	45.1	174	44.2	168	42.4	156	39.0
	11.0	9.8	186	44.0	186	44.9	179	43.3	174	41.7	168	40.1	156	36.9
	13.0	11.8	196	44.8	191	43.9	179	40.8	174	39.2	168	37.7	156	34.8
	15.0	13.7	202	44.4	191	41.4	179	38.5	174	37.1	168	35.7	156	32.9

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (1300)	-19.8	-20.0	92.1	30.0	91.8	31.7	91.5	33.4	91.3	34.2	91.2	35.0	90.9	36.7
	-18.8	-19.0	93.7	30.6	93.4	32.2	93.2	33.9	93.0	34.7	92.9	35.5	92.6	37.1
	-16.7	-17.0	97.4	31.7	97.1	33.3	96.8	34.9	96.7	35.7	96.5	36.5	96.2	38.0
	-13.7	-15.0	101.4	32.9	101.2	34.4	100.9	35.9	100.7	36.7	100.6	37.4	100.3	38.9
	-11.8	-13.0	105.9	34.1	105.6	35.5	105.3	37.0	105.2	37.7	105.1	38.4	104.8	39.9
	-9.8	-11.0	111	35.3	111	36.6	110	38.0	110	38.7	110	39.4	110	40.8
	-9.5	-10.0	113	35.8	113	37.2	113	38.5	113	39.2	113	39.9	112	41.2
	-8.5	-9.1	116	36.4	116	37.7	115	39.0	115	39.7	115	40.3	115	41.6
	-7.0	-7.6	120	37.2	120	38.5	119	39.8	119	40.4	119	41.0	119	42.3
	-5.0	-5.6	126	38.3	126	39.5	125	40.8	125	41.4	125	42.0	125	43.2
	-3.0	-3.7	132	39.4	132	40.5	132	41.7	131	42.2	131	42.8	131	44.0
	0.0	-0.7	142	40.9	142	42.0	142	43.0	142	43.6	142	44.1	141	45.2
	3.0	2.2	153	42.3	153	43.3	153	44.3	153	44.7	152	45.2	142	41.6
	5.0	4.1	161	43.1	161	44.1	160	45.0	158	44.4	153	42.6	142	39.2
	7.0	6.0	169	43.9	169	44.8	163	43.5	158	41.8	153	40.2	142	37.0
	9.0	7.9	177	44.7	173	44.2	163	41.0	158	39.5	153	37.9	142	35.0
	11.0	9.8	184	44.7	173	41.7	163	38.7	158	37.3	153	35.9	142	33.1
	13.0	11.8	184	42.0	173	39.2	163	36.5	158	35.1	153	33.8	142	31.2
	15.0	13.7	184	39.7	173	37.1	163	34.5	158	33.3	153	32.0	142	29.6
90 (1170)	-19.8	-20.0	91.6	32.9	91.3	34.5	91.0	36.0	90.9	36.7	90.8	37.5	90.5	39.0
	-18.8	-19.0	93.2	33.5	93.0	34.9	92.7	36.4	92.6	37.2	92.4	37.9	92.2	39.4
	-16.7	-17.0	96.9	34.5	96.6	35.9	96.4	37.3	96.2	38.0	96.1	38.8	95.8	40.2
	-13.7	-15.0	100.9	35.5	100.7	36.9	100.4	38.3	100.3	39.0	100.2	39.6	99.9	41.0
	-11.8	-13.0	105.4	36.6	105.2	37.9	104.9	39.2	104.8	39.9	104.6	40.5	104.4	41.8
	-9.8	-11.0	110	37.7	110	38.9	110	40.2	110	40.8	110	41.4	109	42.7
	-9.5	-10.0	113	38.2	113	39.4	112	40.6	112	41.2	112	41.8	112	43.1
	-8.5	-9.1	115	38.7	115	39.9	115	41.1	115	41.6	115	42.2	114	43.4
	-7.0	-7.6	120	39.5	119	40.6	119	41.7	119	42.3	119	42.9	119	44.0
	-5.0	-5.6	126	40.5	125	41.5	125	42.6	125	43.2	125	43.7	125	44.8
	-3.0	-3.7	132	41.4	131	42.4	131	43.5	131	44.0	131	44.5	128	44.0
	0.0	-0.7	142	42.8	142	43.7	141	44.7	141	45.2	137	43.7	128	40.2
	3.0	2.2	153	44.0	153	44.9	147	43.2	142	41.5	137	39.9	128	36.8
	5.0	4.1	160	44.8	156	43.8	147	40.7	142	39.2	137	37.7	128	34.7
	7.0	6.0	166	44.3	156	41.3	147	38.4	142	37.0	137	35.6	128	32.8
	9.0	7.9	166	41.8	156	39.0	147	36.3	142	34.9	137	33.6	128	31.1
	11.0	9.8	166	39.4	156	36.8	147	34.3	142	33.1	137	31.8	128	29.4
	13.0	11.8	166	37.1	156	34.7	147	32.4	142	31.2	137	30.1	128	27.8
	15.0	13.7	166	35.1	156	32.9	147	30.7	142	29.6	137	28.5	128	26.4
80 (1040)	-19.8	-20.0	91.0	35.9	90.8	37.2	90.6	38.6	90.5	39.2	90.4	39.9	90.1	41.3
	-18.8	-19.0	92.7	36.3	92.5	37.7	92.3	39.0	92.1	39.6	92.0	40.3	91.8	41.6
	-16.7	-17.0	96.4	37.3	96.1	38.5	95.9	39.8	95.8	40.4	95.7	41.1	95.5	42.3
	-13.7	-15.0	100.4	38.2	100.2	39.4	100.0	40.6	99.9	41.2	99.7	41.8	99.5	43.0
	-11.8	-13.0	104.9	39.2	104.7	40.3	104.4	41.5	104.3	42.1	104.2	42.6	104.0	43.8
	-9.8	-11.0	110	40.1	110	41.2	109	42.3	109	42.9	109	43.4	109	44.5
	-9.5	-10.0	112	40.6	112	41.7	112	42.7	112	43.3	112	43.8	111	44.9
	-8.5	-9.1	115	41.0	115	42.1	114	43.1	114	43.6	114	44.2	114	45.1
	-7.0	-7.6	119	41.7	119	42.7	119	43.7	118	44.2	118	44.7	114	43.1
	-5.0	-5.6	125	42.6	125	43.5	125	44.5	124	45.0	122	44.2	114	40.6
	-3.0	-3.7	131	43.4	131	44.3	130	45.1	126	43.4	122	41.7	114	38.3
	0.0	-0.7	141	44.6	139	44.3	130	41.1	126	39.5	122	38.0	114	35.0
	3.0	2.2	147	43.4	139	40.4	130	37.6	126	36.2	122	34.8	114	32.2
	5.0	4.1	147	40.9	139	38.2	130	35.5	126	34.2	122	32.9	114	30.4
	7.0	6.0	147	38.6	139	36.0	130	33.6	126	32.4	122	31.2	114	28.8
	9.0	7.9	147	36.4	139	34.1	130	31.8	126	30.6	122	29.5	114	27.3
	11.0	9.8	147	34.4	139	32.2	130	30.1	126	29.0	122	28.0	114	25.9
	13.0	11.8	147	32.5	139	30.4	130	28.4	126	27.4	122	26.5	114	24.6
	15.0	13.7	147	30.8	139	28.9	130	27.0	126	26.1	122	25.1	114	23.4

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0	
	°CDB	°CWB	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW
70 (910)	-19.8	-20.0	90.5	38.8	90.3	40.0	90.1	41.2	90.0	41.8	89.9	42.4	89.7	43.5
	-18.8	-19.0	92.2	39.2	92.0	40.4	91.8	41.5	91.7	42.1	91.6	42.7	91.4	43.8
	-16.7	-17.0	95.9	40.0	95.7	41.1	95.5	42.2	95.4	42.8	95.3	43.4	95.1	44.5
	-13.7	-15.0	99.9	40.9	99.7	41.9	99.5	43.0	99.4	43.5	99.3	44.0	99.1	45.1
	-11.8	-13.0	104.4	41.7	104.2	42.7	104.0	43.7	103.9	44.2	103.8	44.7	99.4	42.9
	-9.8	-11.0	109	42.5	109	43.5	109	44.5	109	44.9	106.8	44.2	99.4	40.6
	-9.5	-10.0	112	42.9	112	43.9	111	44.8	110	44.7	106.8	42.9	99.4	39.5
	-8.5	-9.1	114	43.3	114	44.2	114	45.2	110	43.5	106.8	41.8	99.4	38.5
	-7.0	-7.6	119	43.9	118	44.8	114	43.3	110	41.6	106.8	40.0	99.4	36.8
	-5.0	-5.6	125	44.7	121	43.9	114	40.8	110	39.2	106.8	37.7	99.4	34.8
	-3.0	-3.7	129	44.4	121	41.4	114	38.5	110	37.1	106.8	35.7	99.4	32.9
	0.0	-0.7	129	40.5	121	37.8	114	35.2	110	33.9	106.8	32.6	98.4	30.2
	3.0	2.2	129	37.1	121	34.7	114	32.3	110	31.1	106.8	30.0	98.4	27.8
	5.0	4.1	129	35.0	121	32.8	114	30.6	110	29.5	106.8	28.4	98.4	26.3
	7.0	6.0	129	33.1	121	31.0	114	28.9	110	27.9	106.8	26.9	98.4	25.0
	9.0	7.9	129	31.3	121	29.3	114	27.4	110	26.5	106.8	25.6	98.4	23.7
	11.0	9.8	129	29.7	121	27.8	114	26.0	110	25.1	106.8	24.3	98.4	22.6
	13.0	11.8	129	28.0	121	26.3	114	24.7	110	23.8	106.8	23.0	99.4	21.4
	15.0	13.7	129	26.6	121	25.0	114	23.4	110	22.7	106.8	21.9	99.4	20.4
60 (780)	-19.8	-20.0	90.0	41.8	89.9	42.8	89.7	43.8	89.6	44.3	89.5	44.8	85.2	42.6
	-18.8	-19.0	91.7	42.1	91.5	43.1	91.4	44.1	91.3	44.6	91.2	45.1	85.2	41.6
	-16.7	-17.0	95.4	42.8	95.2	43.8	95.0	44.7	94.7	45.0	91.5	43.2	85.2	39.7
	-13.7	-15.0	99.4	43.5	99.3	44.4	97.8	44.4	94.7	42.7	91.5	41.0	85.2	37.8
	-11.8	-13.0	104.2	44.2	103.7	45.1	97.8	42.1	94.7	40.5	91.5	38.9	85.2	35.9
	-9.8	-11.0	109	45.0	104.1	42.9	97.8	39.8	94.7	38.3	91.5	36.9	85.2	34.0
	-9.5	-10.0	110	44.7	104.1	41.6	97.8	38.7	94.7	37.3	91.5	35.8	85.2	33.1
	-8.5	-9.1	110	43.5	104.1	40.6	97.8	37.7	94.7	36.3	91.5	35.0	85.2	32.3
	-7.0	-7.6	110	41.6	104.1	38.8	97.8	36.1	94.7	34.8	91.5	33.5	85.2	30.9
	-5.0	-5.6	110	39.2	104.1	36.6	97.8	34.1	94.7	32.9	91.5	31.7	85.2	29.3
	-3.0	-3.7	110	37.0	104.1	34.6	97.8	32.3	94.7	31.1	91.5	30.0	85.2	27.8
	0.0	-0.7	110	33.9	104.1	31.7	97.8	29.6	94.7	28.6	91.5	27.6	85.2	25.5
	3.0	2.2	110	31.1	104.1	29.2	97.8	27.3	94.7	26.3	91.5	25.4	85.2	23.6
	5.0	4.1	110	29.5	104.1	27.6	97.8	25.9	94.7	25.0	91.5	24.1	85.2	22.4
	7.0	6.0	110	27.9	104.1	26.2	97.8	24.5	94.7	23.7	91.5	22.9	85.2	21.3
	9.0	7.9	110	26.5	104.1	24.9	97.8	23.3	94.7	22.5	91.5	21.8	85.2	20.3
	11.0	9.8	110	25.1	104.1	23.6	97.8	22.2	94.7	21.5	91.5	20.7	85.2	19.3
	13.0	11.8	110	23.8	104.1	22.4	97.8	21.1	94.7	20.4	91.5	19.7	85.2	18.4
	15.0	13.7	110	22.7	104.1	21.4	97.8	20.1	94.7	19.4	91.5	18.8	85.2	17.6
50 (650)	-19.8	-20.0	89.5	44.7	86.7	43.5	81.5	40.4	78.9	38.9	76.3	37.4	71.0	34.4
	-18.8	-19.0	91.2	45.0	86.7	42.5	81.5	39.5	78.9	38.0	76.3	36.6	71.0	33.7
	-16.7	-17.0	92.0	43.4	86.7	40.5	81.5	37.7	78.9	36.3	76.3	34.9	71.0	32.2
	-13.7	-15.0	92.0	41.3	86.7	38.5	81.5	35.9	78.9	34.6	76.3	33.3	71.0	30.7
	-11.8	-13.0	92.0	39.2	86.7	36.6	81.5	34.1	78.9	32.8	76.3	31.6	71.0	29.2
	-9.8	-11.0	92.0	37.1	86.7	34.7	81.5	32.3	78.9	31.2	76.3	30.0	71.0	27.8
	-9.5	-10.0	92.0	36.1	86.7	33.7	81.5	31.4	78.9	30.3	76.3	29.2	71.0	27.1
	-8.5	-9.1	92.0	35.2	86.7	32.9	81.5	30.7	78.9	29.6	76.3	28.5	71.0	26.4
	-7.0	-7.6	92.0	33.7	86.7	31.6	81.5	29.5	78.9	28.4	76.3	27.4	71.0	25.4
	-5.0	-5.6	92.0	31.8	86.7	29.8	81.5	27.9	78.9	26.9	76.3	26.0	71.0	24.1
	-3.0	-3.7	92.0	30.2	86.7	28.3	81.5	26.5	78.9	25.6	76.3	24.7	71.0	22.9
	0.0	-0.7	92.0	27.7	86.7	26.0	81.5	24.4	78.9	23.6	76.3	22.7	71.0	21.2
	3.0	2.2	92.0	25.5	86.7	24.0	81.5	22.5	78.9	21.8	76.3	21.1	71.0	19.6
	5.0	4.1	92.0	24.2	86.7	22.8	81.5	21.4	78.9	20.7	76.3	20.0	71.0	18.7
	7.0	6.0	92.0	23.0	86.7	21.7	81.5	20.4	78.9	19.7	76.3	19.1	71.0	17.8
	9.0	7.9	92.0	21.9	86.7	20.6	81.5	19.4	78.9	18.8	76.3	18.2	71.0	17.0
	11.0	9.8	92.0	20.8	86.7	19.7	81.5	18.5	78.9	17.9	76.3	17.4	71.0	16.3
	13.0	11.8	92.0	19.8	86.7	18.7	81.5	17.6	78.9	17.1	76.3	16.6	71.0	15.5
	15.0	13.7	92.0	18.9	86.7	17.9	81.5	16.8	78.9	16.3	76.3	15.8	71.0	14.8

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
130 (1755)	-19.8	-20.0	94.3	20.0	94.0	22.3	93.6	24.6	93.4	25.7	93.2	26.9	92.8	29.2
	-18.8	-19.0	96.0	20.8	95.6	23.0	95.3	25.3	95.1	26.4	94.9	27.5	94.5	29.8
	-16.7	-17.0	99.7	22.3	99.3	24.5	98.9	26.7	98.7	27.7	98.5	28.8	98.1	31.0
	-13.7	-15.0	103.8	23.9	103.4	26.0	103.0	28.1	102.8	29.1	102.6	30.2	102.2	32.2
	-11.8	-13.0	108.3	25.6	107.9	27.5	107.5	29.5	107.3	30.5	107.1	31.5	106.7	33.5
	-9.8	-11.0	113	27.2	113	29.1	112	31.0	112	31.9	112	32.9	112	34.8
	-9.5	-10.0	116	28.0	115	29.8	115	31.7	115	32.6	115	33.5	114	35.4
	-8.5	-9.1	118	28.7	118	30.5	117	32.3	117	33.2	117	34.1	117	35.9
	-7.0	-7.6	123	29.9	122	31.6	122	33.3	122	34.2	121	35.1	121	36.8
	-5.0	-5.6	129	31.4	128	33.0	128	34.7	128	35.5	127	36.4	127	38.0
	-3.0	-3.7	135	32.8	134	34.4	134	35.9	134	36.7	133	37.5	133	39.1
	0.0	-0.7	145	34.9	145	36.3	144	37.8	144	38.5	144	39.3	144	40.7
	3.0	2.2	156	36.8	156	38.1	155	39.5	155	40.2	155	40.8	154	42.2
	5.0	4.1	164	37.9	163	39.2	163	40.5	163	41.2	162	41.8	162	43.1
	7.0	6.0	172	39.1	171	40.3	171	41.5	171	42.1	171	42.7	170	43.9
	9.0	7.9	180	40.1	180	41.3	179	42.4	179	43.0	179	43.6	179	44.8
	11.0	9.8	189	41.1	188	42.2	188	43.3	188	43.9	188	44.4	187	45.5
	13.0	11.8	198	42.1	198	43.1	198	44.2	197	44.7	197	45.2	192	44.5
	15.0	13.7	208	43.0	208	44.0	207	45.0	207	45.5	206	45.8	192	42.1
120 (1620)	-19.8	-20.0	93.8	23.1	93.5	25.2	93.1	27.3	92.9	28.4	92.7	29.5	92.4	31.6
	-18.8	-19.0	95.5	23.8	95.1	25.9	94.8	28.0	94.6	29.0	94.4	30.1	94.1	32.1
	-16.7	-17.0	99.2	25.3	98.8	27.3	98.5	29.3	98.3	30.3	98.1	31.3	97.7	33.3
	-13.7	-15.0	103.3	26.7	102.9	28.7	102.5	30.6	102.4	31.5	102.2	32.5	101.8	34.4
	-11.8	-13.0	107.8	28.2	107.4	30.1	107.0	31.9	106.9	32.8	106.7	33.7	106.3	35.6
	-9.8	-11.0	113	29.7	112	31.5	112	33.2	112	34.1	112	35.0	111	36.7
	-9.5	-10.0	115	30.5	115	32.2	115	33.9	114	34.7	114	35.6	114	37.3
	-8.5	-9.1	118	31.1	117	32.8	117	34.5	117	35.3	117	36.1	116	37.8
	-7.0	-7.6	122	32.2	122	33.8	121	35.4	121	36.2	121	37.0	121	38.6
	-5.0	-5.6	128	33.6	128	35.2	127	36.7	127	37.4	127	38.2	127	39.7
	-3.0	-3.7	134	34.9	134	36.4	133	37.8	133	38.6	133	39.3	133	40.7
	0.0	-0.7	145	36.9	144	38.2	144	39.5	144	40.2	143	40.9	143	42.2
	3.0	2.2	155	38.6	155	39.9	155	41.1	155	41.7	154	42.3	154	43.6
	5.0	4.1	163	39.7	163	40.9	162	42.1	162	42.7	162	43.2	162	44.4
	7.0	6.0	171	40.7	171	41.8	170	43.0	170	43.5	170	44.1	170	45.2
	9.0	7.9	180	41.7	179	42.8	179	43.8	179	44.4	178	44.9	177	45.6
	11.0	9.8	188	42.6	188	43.6	188	44.6	187	45.2	187	45.7	177	43.1
	13.0	11.8	198	43.5	198	44.5	197	45.5	197	45.9	190	44.1	177	40.5
	15.0	13.7	207	44.3	207	45.3	203	45.0	197	43.3	190	41.6	177	38.3
110 (1485)	-19.8	-20.0	93.3	26.2	93.0	28.1	92.6	30.1	92.5	31.1	92.3	32.0	92.0	34.0
	-18.8	-19.0	95.0	26.9	94.7	28.8	94.3	30.7	94.2	31.6	94.0	32.6	93.7	34.5
	-16.7	-17.0	98.7	28.2	98.3	30.0	98.0	31.9	97.8	32.8	97.7	33.7	97.3	35.5
	-13.7	-15.0	102.7	29.5	102.4	31.3	102.1	33.1	101.9	33.9	101.8	34.8	101.4	36.6
	-11.8	-13.0	107.2	30.9	106.9	32.6	106.6	34.3	106.4	35.1	106.3	36.0	105.9	37.6
	-9.8	-11.0	112	32.3	112	33.9	111	35.5	111	36.3	111	37.1	111	38.7
	-9.5	-10.0	115	33.0	114	34.5	114	36.1	114	36.9	114	37.7	113	39.2
	-8.5	-9.1	117	33.6	117	35.1	117	36.6	116	37.4	116	38.2	116	39.7
	-7.0	-7.6	121	34.6	121	36.0	121	37.5	121	38.3	120	39.0	120	40.5
	-5.0	-5.6	127	35.9	127	37.3	127	38.7	127	39.4	127	40.1	126	41.5
	-3.0	-3.7	134	37.0	133	38.4	133	39.7	133	40.4	133	41.0	132	42.4
	0.0	-0.7	144	38.8	144	40.1	143	41.3	143	41.9	143	42.5	143	43.8
	3.0	2.2	155	40.4	155	41.6	154	42.7	154	43.3	154	43.9	154	45.0
	5.0	4.1	163	41.4	162	42.5	162	43.6	162	44.1	162	44.7	161	45.8
	7.0	6.0	171	42.4	170	43.4	170	44.4	170	44.9	170	45.5	162	43.6
	9.0	7.9	179	43.3	179	44.2	178	45.2	178	45.7	174	44.8	162	41.2
	11.0	9.8	188	44.1	187	45.0	186	45.7	180	44.0	174	42.3	162	38.9
	13.0	11.8	197	44.9	197	45.8	186	43.0	180	41.4	174	39.8	162	36.7
	15.0	13.7	207	45.7	198	43.7	186	40.6	180	39.1	174	37.6	162	34.7

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB											
			16.0		18.0		20.0		21.0		22.0		24.0	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
100 (1350)	-19.8	-20.0	92.8	29.3	92.5	31.1	92.2	32.8	92.0	33.7	91.9	34.6	91.6	36.4
	-18.8	-19.0	94.5	29.9	94.2	31.6	93.9	33.4	93.7	34.2	93.6	35.1	93.3	36.8
	-16.7	-17.0	98.1	31.1	97.8	32.8	97.5	34.4	97.4	35.3	97.2	36.1	96.9	37.8
	-13.7	-15.0	102.2	32.4	101.9	33.9	101.6	35.5	101.5	36.3	101.3	37.1	101.0	38.7
	-11.8	-13.0	106.7	33.6	106.4	35.1	106.1	36.7	106.0	37.4	105.8	38.2	105.5	39.7
	-9.8	-11.0	112	34.9	111	36.3	111	37.8	111	38.5	111	39.2	110	40.7
	-9.5	-10.0	114	35.5	114	36.9	114	38.3	113	39.0	113	39.7	113	41.2
	-8.5	-9.1	117	36.0	116	37.4	116	38.8	116	39.5	116	40.2	115	41.6
	-7.0	-7.6	121	36.9	121	38.3	120	39.6	120	40.3	120	40.9	120	42.3
	-5.0	-5.6	127	38.1	127	39.4	126	40.6	126	41.3	126	41.9	126	43.2
	-3.0	-3.7	133	39.2	133	40.4	132	41.6	132	42.2	132	42.8	132	44.0
	0.0	-0.7	143	40.8	143	41.9	143	43.0	143	43.6	143	44.2	142	45.3
	3.0	2.2	154	42.3	154	43.3	154	44.3	154	44.9	154	45.4	148	43.9
	5.0	4.1	162	43.2	162	44.1	161	45.1	161	45.6	159	45.0	148	41.4
	7.0	6.0	170	44.0	170	45.0	170	45.9	164	44.1	159	42.4	148	39.0
	9.0	7.9	178	44.8	178	45.7	170	43.3	164	41.6	159	40.0	148	36.9
	11.0	9.8	187	45.6	180	44.0	170	40.9	164	39.3	159	37.8	148	34.9
	13.0	11.8	191	44.3	180	41.4	170	38.5	164	37.1	159	35.7	148	33.0
	15.0	13.7	191	41.9	180	39.1	170	36.4	164	35.1	159	33.8	148	31.2
90 (1215)	-19.8	-20.0	92.2	32.4	92.0	34.0	91.7	35.6	91.6	36.4	91.4	37.2	91.2	38.8
	-18.8	-19.0	93.9	32.9	93.7	34.5	93.4	36.1	93.3	36.8	93.1	37.6	92.9	39.2
	-16.7	-17.0	97.6	34.0	97.3	35.5	97.1	37.0	96.9	37.8	96.8	38.5	96.5	40.0
	-13.7	-15.0	101.7	35.2	101.4	36.6	101.2	38.0	101.0	38.8	100.9	39.5	100.6	40.9
	-11.8	-13.0	106.2	36.3	105.9	37.7	105.7	39.0	105.5	39.7	105.4	40.4	105.1	41.8
	-9.8	-11.0	111	37.4	111	38.7	111	40.0	110	40.7	110	41.3	110	42.7
	-9.5	-10.0	114	38.0	113	39.2	113	40.5	113	41.2	113	41.8	113	43.1
	-8.5	-9.1	116	38.5	116	39.7	116	41.0	115	41.6	115	42.2	115	43.5
	-7.0	-7.6	120	39.3	120	40.5	120	41.7	120	42.3	120	42.9	119	44.1
	-5.0	-5.6	126	40.3	126	41.5	126	42.6	126	43.2	126	43.8	125	44.9
	-3.0	-3.7	133	41.3	132	42.4	132	43.5	132	44.0	132	44.6	131	45.7
	0.0	-0.7	143	42.8	143	43.8	142	44.8	142	45.3	142	45.8	133	42.4
	3.0	2.2	154	44.1	154	45.0	153	45.6	148	43.8	143	42.1	133	38.8
	5.0	4.1	162	44.9	161	45.8	153	43.0	148	41.3	143	39.8	133	36.6
	7.0	6.0	170	45.7	162	43.6	153	40.5	148	39.0	143	37.5	133	34.6
	9.0	7.9	172	44.1	162	41.1	153	38.3	148	36.9	143	35.5	133	32.8
	11.0	9.8	172	41.6	162	38.9	153	36.2	148	34.9	143	33.6	133	31.0
	13.0	11.8	172	39.2	162	36.6	153	34.2	148	32.9	143	31.7	133	29.4
	15.0	13.7	172	37.1	162	34.7	153	32.4	148	31.2	143	30.1	133	27.9
80 (1080)	-19.8	-20.0	91.7	35.5	91.5	36.9	91.2	38.3	91.1	39.1	91.0	39.8	90.8	41.2
	-18.8	-19.0	93.4	36.0	93.2	37.4	92.9	38.8	92.8	39.5	92.7	40.2	92.5	41.5
	-16.7	-17.0	97.1	37.0	96.8	38.3	96.6	39.6	96.5	40.3	96.4	41.0	96.1	42.3
	-13.7	-15.0	101.2	38.0	100.9	39.2	100.7	40.5	100.6	41.2	100.5	41.8	100.2	43.1
	-11.8	-13.0	105.7	39.0	105.4	40.2	105.2	41.4	105.1	42.0	105.0	42.6	104.7	43.9
	-9.8	-11.0	111	40.0	110	41.1	110	42.3	110	42.9	110	43.5	110	44.6
	-9.5	-10.0	113	40.5	113	41.6	113	42.7	113	43.3	112	43.9	112	45.0
	-8.5	-9.1	116	40.9	115	42.0	115	43.1	115	43.7	115	44.2	115	45.4
	-7.0	-7.6	120	41.6	120	42.7	119	43.8	119	44.3	119	44.8	118	45.5
	-5.0	-5.6	126	42.6	126	43.6	125	44.6	125	45.1	125	45.6	118	42.8
	-3.0	-3.7	132	43.4	132	44.4	132	45.4	131	45.8	127	44.0	118	40.4
	0.0	-0.7	142	44.7	142	45.6	136	43.4	131	41.7	127	40.1	118	37.0
	3.0	2.2	153	45.7	144	42.7	136	39.7	131	38.2	127	36.8	118	33.9
	5.0	4.1	153	43.1	144	40.3	136	37.5	131	36.1	127	34.8	118	32.1
	7.0	6.0	153	40.7	144	38.0	136	35.4	131	34.1	127	32.9	118	30.4
	9.0	7.9	153	38.4	144	35.9	136	33.5	131	32.3	127	31.1	118	28.8
	11.0	9.8	153	36.3	144	34.0	136	31.7	131	30.6	127	29.5	118	27.3
	13.0	11.8	153	34.3	144	32.1	136	30.0	131	29.0	127	27.9	118	25.9
	15.0	13.7	153	32.5	144	30.5	136	28.5	131	27.5	127	26.5	118	24.6

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)

Note1: [ ] is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range shown by [ ].
Note2: The above table shows the average value of conditions which may occur.

[50/60Hz]

Heating capacity

Combination (%) (Capacity index)	Outdoor air temp.		Indoor air temp. °CDB															
			16.0		18.0		20.0		21.0		22.0		24.0					
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI				
	°CDB	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW				
70 (945)	-19.8	-20.0	91.2	38.6	91.0	39.9	90.8	41.1	90.7	41.7	90.6	42.3	90.4	43.6				
	-18.8	-19.0	92.9	39.0	92.7	40.3	92.5	41.5	92.4	42.1	92.3	42.7	92.0	43.9				
	-16.7	-17.0	96.6	39.9	96.3	41.1	96.1	42.2	96.0	42.8	95.9	43.4	95.7	44.6				
	-13.7	-15.0	100.6	40.8	100.4	41.9	100.2	43.0	100.1	43.6	100.0	44.1	99.8	45.2				
	-11.8	-13.0	105.1	41.6	104.9	42.7	104.7	43.8	104.6	44.3	104.5	44.9	103.4	45.3				
	-9.8	-11.0	110	42.5	110	43.5	110	44.6	110	45.1	109.4	45.6	103.4	42.8				
	-9.5	-10.0	113	43.0	112	44.0	112	44.9	112	45.4	111.0	45.3	103.4	41.6				
	-8.5	-9.1	115	43.3	115	44.3	115	45.3	115	45.8	111.0	44.1	103.4	40.6				
	-7.0	-7.6	119	44.0	119	44.9	119	45.7	115	43.9	111.0	42.2	103.4	38.9				
	-5.0	-5.6	125	44.8	125	45.7	119	43.0	115	41.4	111.0	39.8	103.4	36.7				
	-3.0	-3.7	132	45.6	126	43.7	119	40.6	115	39.1	111.0	37.6	103.4	34.7				
	0.0	-0.7	134	42.7	126	39.9	119	37.1	115	35.8	111.0	34.4	103.4	31.8				
	3.0	2.2	134	39.1	126	36.6	119	34.1	115	32.9	111.0	31.7	103.4	29.3				
	5.0	4.1	134	36.9	126	34.6	119	32.2	115	31.1	111.0	30.0	103.4	27.8				
	7.0	6.0	134	34.9	126	32.7	119	30.5	115	29.5	111.0	28.4	103.4	26.4				
	9.0	7.9	134	33.0	126	31.0	119	28.9	115	27.9	111.0	27.0	103.4	25.0				
	11.0	9.8	134	31.3	126	29.4	119	27.5	115	26.5	111.0	25.6	103.4	23.8				
	13.0	11.8	134	29.6	126	27.8	119	26.0	115	25.1	111.0	24.3	103.4	22.6				
	15.0	13.7	134	28.1	126	26.4	119	24.7	115	23.9	111.0	23.1	103.4	21.5				
60 (810)	-19.8	-20.0	90.7	41.7	90.5	42.8	90.3	43.9	90.2	44.4	90.1	44.9	88.6	44.9				
	-18.8	-19.0	92.4	42.1	92.2	43.1	92.0	44.2	91.9	44.7	91.8	45.2	88.6	43.9				
	-16.7	-17.0	96.0	42.8	95.9	43.8	95.7	44.8	95.6	45.3	95.2	45.6	88.6	41.9				
	-13.7	-15.0	100.1	43.6	99.9	44.5	99.8	45.5	98.4	45.1	95.2	43.3	88.6	39.9				
	-11.8	-13.0	104.6	44.3	104.4	45.2	101.7	44.4	98.4	42.7	95.2	41.1	88.6	37.8				
	-9.8	-11.0	110	45.1	108.2	45.2	101.7	42.0	98.4	40.4	95.2	38.9	88.6	35.9				
	-9.5	-10.0	112	45.5	108.2	43.9	101.7	40.8	98.4	39.3	95.2	37.8	88.6	34.9				
	-8.5	-9.1	115	45.8	108.2	42.8	101.7	39.8	98.4	38.3	95.2	36.9	88.6	34.0				
	-7.0	-7.6	115	43.9	108.2	41.0	101.7	38.1	98.4	36.7	95.2	35.4	88.6	32.7				
	-5.0	-5.6	115	41.4	108.2	38.7	101.7	36.0	98.4	34.7	95.2	33.4	88.6	30.9				
	-3.0	-3.7	115	39.1	108.2	36.6	101.7	34.1	98.4	32.9	95.2	31.6	88.6	29.3				
	0.0	-0.7	115	35.8	108.2	33.5	101.7	31.2	98.4	30.2	95.2	29.1	88.6	26.9				
	3.0	2.2	115	32.8	108.2	30.8	101.7	28.8	98.4	27.8	95.2	26.8	88.6	24.9				
	5.0	4.1	115	31.1	108.2	29.2	101.7	27.3	98.4	26.4	95.2	25.4	88.6	23.7				
	7.0	6.0	115	29.5	108.2	27.7	101.7	25.9	98.4	25.0	95.2	24.2	88.6	22.5				
	9.0	7.9	115	27.9	108.2	26.3	101.7	24.6	98.4	23.8	95.2	23.0	88.6	21.4				
	11.0	9.8	115	26.5	108.2	24.9	101.7	23.4	98.4	22.6	95.2	21.9	88.6	20.4				
	13.0	11.8	115	25.1	108.2	23.7	101.7	22.2	98.4	21.5	95.2	20.8	88.6	19.4				
	15.0	13.7	115	23.9	108.2	22.5	101.7	21.2	98.4	20.5	95.2	19.8	88.6	18.5				
50 (675)	-19.8	-20.0	90.2	44.8	90.0	45.7	84.8	42.6	82.0	41.0	79.3	39.4	73.9	36.3				
	-18.8	-19.0	91.8	45.1	90.2	44.8	84.8	41.7	82.0	40.1	79.3	38.6	73.9	35.6				
	-16.7	-17.0	95.5	45.7	90.2	42.8	84.8	39.8	82.0	38.3	79.3	36.8	73.9	34.0				
	-13.7	-15.0	95.6	43.6	90.2	40.7	84.8	37.8	82.0	36.5	79.3	35.1	73.9	32.4				
	-11.8	-13.0	95.6	41.3	90.2	38.6	84.8	35.9	82.0	34.6	79.3	33.4	73.9	30.8				
	-9.8	-11.0	95.6	39.1	90.2	36.6	84.8	34.1	82.0	32.9	79.3	31.7	73.9	29.3				
	-9.5	-10.0	95.6	38.0	90.2	35.6	84.8	33.2	82.0	32.0	79.3	30.8	73.9	28.6				
	-8.5	-9.1	95.6	37.1	90.2	34.7	84.8	32.4	82.0	31.2	79.3	30.1	73.9	27.9				
	-7.0	-7.6	95.6	35.6	90.2	33.3	84.8	31.1	82.0	30.0	79.3	28.9	73.9	26.8				
	-5.0	-5.6	95.6	33.6	90.2	31.5	84.8	29.4	82.0	28.4	79.3	27.4	73.9	25.4				
	-3.0	-3.7	95.6	31.8	90.2	29.8	84.8	27.9	82.0	27.0	79.3	26.0	73.9	24.2				
	0.0	-0.7	95.6	29.2	90.2	27.5	84.8	25.7	82.0	24.9	79.3	24.0	73.9	22.3				
	3.0	2.2	95.6	27.0	90.2	25.3	84.8	23.8	82.0	23.0	79.3	22.2	73.9	20.7				
	5.0	4.1	95.6	25.6	90.2	24.1	84.8	22.6	82.0	21.9	79.3	21.2	73.9	19.7				
	7.0	6.0	95.6	24.3	90.2	22.9	84.8	21.5	82.0	20.8	79.3	20.1	73.9	18.8				
	9.0	7.9	95.6	23.1	90.2	21.8	84.8	20.5	82.0	19.8	79.3	19.2	73.9	18.0				
	11.0	9.8	95.6	22.0	90.2	20.7	84.8	19.5	82.0	18.9	79.3	18.3	73.9	17.1				
	13.0	11.8	95.6	20.9	90.2	19.7	84.8	18.6	82.0	18.0	79.3	17.5	73.9	16.4				
	15.0	13.7	95.6	19.9	90.2	18.8	84.8	17.8	82.0	17.2	79.3	16.7	73.9	15.7				

TC Total capacity ; kW
PI Power Input ; kW(Comp.+Outdoor fan motor)


Note1: ■ is shown as reference.
When selecting the unit models, avoid the Outdoor air temperature range ■ shown by ■.
Note2: The above table shows the average value of conditions which may occur.

14


8.3 Capacity Correction Factor (RXYQ-P(A))

RXYQ5PAY1, PAYL, PTL

1. Rate of change in cooling capacity




2. Rate of change in heating capacity




C: 3D053163D

RXYQ8PAY1, PAYL, PTL

1. Rate of change in cooling capacity




2. Rate of change in heating capacity




C: 3D053164E

RXYQ10PAY1, PAYL, PTL

1. Rate of change in cooling capacity




2. Rate of change in heating capacity




C: 3D053165E

RXYQ12PAY1, PAYL, PTL / RXYQ14PAY1, PAYL, PTL / RXYQ24PAY1, PAYL, PTL / RXYQ36PAY1, PAYL, PTL

1. Rate of change in cooling capacity




2. Rate of change in heating capacity




C: 3D053166E

RXYQ16PAY1, PAYL, PTL

1. Rate of change in cooling capacity



2. Rate of change in heating capacity




C: 3D053167F


RXYQ18PAY1, PAYL, PTL / RXYQ26PAY1, PAYL, PTL / RXYQ28PAY1, PAYL, PTL / RXYQ30PAY1, PAYL, PTL
RXYQ38PAY1, PAYL, PTL / RXYQ40PAY1, PAYL, PTL / RXYQ42PAY1, PAYL, PTL / RXYQ44PAY1, PAYL, PTL

14

1. Rate of change in cooling capacity




2. Rate of change in heating capacity




C: 3D053168D

RXYQ22PAY1, PAYL, PTL

1. Rate of change in cooling capacity




2. Rate of change in heating capacity




C: 3D053169D

RXYQ20PAY1, PAYL, PTL / RXYQ32PAY1, PAYL, PTL / RXYQ34PAY1, PAYL, PTL

1. Rate of change in cooling capacity




2. Rate of change in heating capacity




C: 3D053170D

RXYQ46PAY1, PAYL, PTL

1. Rate of change in cooling capacity




2. Rate of change in heating capacity




C: 3D053171D

RXYQ48PAY1, PAYL, PTL

1. Rate of change in cooling capacity




2. Rate of change in heating capacity




C: 3D053172D

RXYQ50PAY1, PAYL, PTL

1. Rate of change in cooling capacity




2. Rate of change in heating capacity




C: 3D053173D

RXYQ52PAY1, PAYL, PTL

1. Rate of change in cooling capacity



2. Rate of change in heating capacity




C: 3D053174D


14

RXYQ54PAY1, PAYL, PTL

1. Rate of change in cooling capacity



2. Rate of change in heating capacity



C: 3D053175D

[Explanation of symbols]

H_P : Level difference (m) between indoor and outdoor units where indoor unit in inferior position

H_M : Level difference (m) between indoor and outdoor units where indoor unit in superior position

L : Equivalent pipe length (m)

α : Rate of change in cooling/heating capacity

[Diameters of the main pipes (Standard size)]

Model	Gas	Liquid
RXYQ5PAY1, PAYL, PTL	ϕ15.9	ϕ9.5
RXYQ8PAY1, PAYL, PTL	ϕ19.1	ϕ9.5
RXYQ10PAY1, PAYL, PTL	ϕ22.2	ϕ9.5
RXYQ12PAY1, PAYL, PTL	ϕ28.6	ϕ12.7
RXYQ14PAY1, PAYL, PTL	ϕ28.6	ϕ12.7
RXYQ16PAY1, PAYL, PTL	ϕ28.6	ϕ12.7

Model	Gas	Liquid
RXYQ18PAY1, PAYL, PTL	ϕ28.6	ϕ15.9
RXYQ20PAY1, PAYL, PTL	ϕ28.6	ϕ15.9
RXYQ22PAY1, PAYL, PTL	ϕ28.6	ϕ15.9
RXYQ24PAY1, PAYL, PTL	ϕ34.9	ϕ15.9
RXYQ26PAY1, PAYL, PTL	ϕ34.9	ϕ19.1
RXYQ28PAY1, PAYL, PTL	ϕ34.9	ϕ19.1

Model	Gas	Liquid
RXYQ30PAY1, PAYL, PTL	ϕ34.9	ϕ19.1
RXYQ32PAY1, PAYL, PTL	ϕ34.9	ϕ19.1
RXYQ34PAY1, PAYL, PTL	ϕ34.9	ϕ19.1
RXYQ36PAY1, PAYL, PTL	ϕ41.3	ϕ19.1
RXYQ38PAY1, PAYL, PTL	ϕ41.3	ϕ19.1
RXYQ40PAY1, PAYL, PTL	ϕ41.3	ϕ19.1

Model	Gas	Liquid
RXYQ42PAY1, PAYL, PTL	ϕ41.3	ϕ19.1
RXYQ44PAY1, PAYL, PTL	ϕ41.3	ϕ19.1
RXYQ46PAY1, PAYL, PTL	ϕ41.3	ϕ19.1
RXYQ48PAY1, PAYL, PTL	ϕ41.3	ϕ19.1
RXYQ50PAY1, PAYL, PTL	ϕ41.3	ϕ19.1
RXYQ52PAY1, PAYL, PTL	ϕ41.3	ϕ19.1
RXYQ54PAY1, PAYL, PTL	ϕ41.3	ϕ19.1

[Notes]

1. These figures illustrate the rate of change in capacity of a standard indoor unit system at maximum load (with the thermostat set to maximum)under standard conditions.
   Moreover, under partial load conditions there is only a minor deviation from the rate of change in capacity shown in the above figures.
2. With this outdoor unit, evaporating pressure constant control when cooling, and condensing pressure constant control when heating is carried out.
3. Method of calculating A/C (cooling/heating) capacity:
   The maximum A/C capacity of the system will be either the total A/C capacity of the indoor units obtained from capacity characteristic table or the maximum A/C capacity of outdoor units as mentioned bellow, whichever smaller.

   Calculating A/C capacity of outdoor units

   • Condition: Indoor unit combination ratio does not exceed 100%.

   Maximum A/C capacity of outdoor units = A/C capacity of outdoor units obtained from capacity characteristic table at the 100% combination
   X Capacity change rate due to piping length to the farthest indoor unit

   • Condition: Indoor unit combination ratio exceeds 100%.

   Maximum A/C capacity of outdoor units = A/C capacity of outdoor units obtained from capacity characteristic table at the combination
   X Capacity change rate due to piping length to the farthest indoor unit
4. When overall equivalent pipe length is 90m or more, the diameter of the main gas and liquid pipes (outdoor unit-branch sections) must be increased.
   When level difference is 50m or more, the diameter of the main liquid pipe (outdoor unit-branch sections) must be increased.

■ Diameter of above case

Model	Gas	Liquid
RXYQ5PAY1, PAYL, PTL	ϕ19.1	Not Increased
RXYQ8PAY1, PAYL, PTL	ϕ22.2	ϕ12.7
RXYQ10PAY1, PAYL, PTL	ϕ25.4*	ϕ12.7
RXYQ12PAY1, PAYL, PTL	Not Increased	ϕ15.9
RXYQ14PAY1, PAYL, PTL	Not Increased	ϕ15.9
RXYQ16PAY1, PAYL, PTL	ϕ31.8*	ϕ15.9

Model	Gas	Liquid
RXYQ18PAY1, PAYL, PTL	ϕ31.8*	ϕ19.1
RXYQ20PAY1, PAYL, PTL	ϕ31.8*	ϕ19.1
RXYQ22PAY1, PAYL, PTL	ϕ31.8*	ϕ19.1
RXYQ24PAY1, PAYL, PTL	Not Increased	ϕ19.1
RXYQ26PAY1, PAYL, PTL	ϕ38.1*	ϕ22.2
RXYQ28PAY1, PAYL, PTL	ϕ38.1*	ϕ22.2

Model	Gas	Liquid
RXYQ30PAY1, PAYL, PTL	ϕ38.1*	ϕ22.2
RXYQ32PAY1, PAYL, PTL	ϕ38.1*	ϕ22.2
RXYQ34PAY1, PAYL, PTL	ϕ38.1*	ϕ22.2
RXYQ36PAY1, PAYL, PTL	Not Increased	ϕ22.2
RXYQ38PAY1, PAYL, PTL	Not Increased	ϕ22.2
RXYQ40PAY1, PAYL, PTL	Not Increased	ϕ22.2

Model	Gas	Liquid
RXYQ42PAY1, PAYL, PTL	Not Increased	ϕ22.2
RXYQ44PAY1, PAYL, PTL	Not Increased	ϕ22.2
RXYQ46PAY1, PAYL, PTL	Not Increased	ϕ22.2
RXYQ48PAY1, PAYL, PTL	Not Increased	ϕ22.2
RXYQ50PAY1, PAYL, PTL	Not Increased	ϕ22.2
RXYQ52PAY1, PAYL, PTL	Not Increased	ϕ22.2
RXYQ54PAY1, PAYL, PTL	Not Increased	ϕ22.2

*If available on the site, use this size. Otherwise it can not be increased.

(Unit: mm)

Temper grade	O Type				1/2 Type							
Outer diameter	ϕ6.4	ϕ9.5	ϕ12.7	ϕ15.9	ϕ19.1	ϕ22.2	ϕ25.4	ϕ28.6	ϕ31.8	ϕ34.9	ϕ38.1	ϕ41.3
Minimum Wall Thickness	0.80	0.80	0.80	0.99	0.80	0.80	0.88	0.99	1.10	1.21	1.32	1.43

5. Read cooling / heating capacity rate of change in the above figures based on the following equivalent length.


Overall equivalent length=
(Equivalent length to main pipe)×Correction factor+(Equivalent length after branching)

Choose a correction factor from the following table.

- When cooling capacity is calculated : gas pipe size
- When heating capacity is calculated : liquid pipe size

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	0.5
Heating (liquid pipe)	1.0	

(Example) RXYQ5PAY1, PAYL, PTL




In the above case
(Cooling) Overall equivalent length=80m×0.5+40m=80m
(Heating) Overall equivalent length=80m×1.0+40m=120m

The rate of change in
cooling capacity when Hp=0m is thus approximately 0.79
heating capacity when Hp=0m is thus approximately 1.00

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	0.5
Heating (liquid pipe)	1.0	0.2

(Example) RXYQ8PAY1, PAYL, PTL




In the above case
(Cooling) Overall equivalent length=80m×0.5+40m=80m
(Heating) Overall equivalent length=80m×0.2+40m=56m

The rete of change in
cooling capacity when Hp=0m is thus approximately 0.86
heating capacity when Hp=0m is thus approximately 1.00

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	0.5
Heating (liquid pipe)	1.0	0.2

(Example) RXYQ10PAY1, PAYL, PTL




In the above case
(Cooling) Overall equivalent length=80m×0.5+40m=80m
(Heating) Overall equivalent length=80m×0.2+40m=56m

The rate of change in
cooling capacity when Hp=0m is thus approximately 0.87
heating capacity when Hp=0m is thus approximately 1.00

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	0.5
Heating (liquid pipe)	1.0	0.3

(Example) RXYQ16PAY1, PAYL, PTL




In the above case
(Cooling) Overall equivalent length=80m×0.5+40m=80m
(Heating) Overall equivalent length=80m×0.3+40m=64m

The rete of change in
cooling capacity when Hp=0m is thus approximately 0.88
heating capacity when Hp=0m is thus approximately 1.00

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	0.5
Heating (liquid pipe)	1.0	0.4

(Example) RXYQ22PAY1, PAYL, PTL




In the above case
(Cooling) Overall equivalent length=80m×0.5+40m=80m
(Heating) Overall equivalent length=80m×0.4+40m=72m

The rete of change in
cooling capacity when Hp=0m is thus approximately 0.86
heating capacity when Hp=0m is thus approximately 1.00

Rate of change (object piping)	Correction factor		
	Standard size	Size increase	
		12・14HP	24・36HP
Cooling (gas pipe)	1.0		
Heating (liquid pipe)	1.0	0.3	0.4

(Example) RXYQ24PAY1, PAYL, PTL (12, 14, 24, 36PAY1, PAYL, PTL)




In the above case
(Cooling) Overall equivalent length=80m×1.0+40m=120m
(Heating) Overall equivalent length=80m×0.4+40m= 72m

The rete of change in
cooling capacity when Hp=0m is thus approximately 0.88
heating capacity when Hp=0m is thus approximately 1.00

14

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	0.5
Heating (liquid pipe)	1.0	0.4

(Example) RXYQ38PAY1, PAYL, PTL (18, 26, 28, 30, 38, 40, 42, 44PAY1, PAYL, PTL)




In the above case
(Cooling) Overall equivalent length=80m×1.0+40m=120m
(Heating) Overall equivalent length=80m×0.4+40m= 72m

The rete of change in
cooling capacity when Hp=0m is thus approximately 0.83
heating capacity when Hp=0m is thus approximately 1.00

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	0.5
Heating (liquid pipe)	1.0	0.4

(Example) RXYQ32PAY1, PAYL, PTL (20, 32, 34PAY1, PAYL, PTL)




In the above case
(Cooling) Overall equivalent length=80m×0.5+40m=80m
(Heating) Overall equivalent length=80m×0.4+40m=72m

The rete of change in
cooling capacity when Hp=0m is thus approximately 0.87
heating capacity when Hp=0m is thus approximately 1.00

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	
Heating (liquid pipe)	1.0	0.4

(Example) RXYQ46PAY1, PAYL, PTL




In the above case
(Cooling) Overall equivalent length=80m×1.0+40m=120m
(Heating) Overall equivalent length=80m×0.4+40m= 72m

The rete of change in
cooling capacity when Hp=0m is thus approximately 0.82
heating capacity when Hp=0m is thus approximately 1.00

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	
Heating (liquid pipe)	1.0	0.4

(Example) RXYQ48PAY1, PAYL, PTL




In the above case
(Cooling) Overall equivalent length=80m×1.0+40m=120m
(Heating) Overall equivalent length=80m×0.4+40m=72m

The rate of change in
cooling capacity when Hp=0m is thus approximately 0.82
heating capacity when Hp=0m is thus approximately 0.99

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	
Heating (liquid pipe)	1.0	0.4

(Example) RXYQ50PAY1, PAYL, PTL




In the above case
(Cooling) Overall equivalent length=80m×1.0+40m=120m
(Heating) Overall equivalent length=80m×0.4+40m= 72m

The rete of change in
cooling capacity when Hp=0m is thus approximately 0.82
heating capacity when Hp=0m is thus approximately 0.95

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	
Heating (liquid pipe)	1.0	0.4

(Example) RXYQ52PAY1, PAYL, PTL




In the above case
(Cooling) Overall equivalent length=80m×1.0+40m=120m
(Heating) Overall equivalent length=80m×0.4+40m= 72m

The rete of change in
cooling capacity when Hp=0m is thus approximately 0.82
heating capacity when Hp=0m is thus approximately 0.90

Rate of change (object piping)	Correction factor	
	Standard size	Size increase
Cooling (gas pipe)	1.0	
Heating (liquid pipe)	1.0	0.4

(Example) RXYQ54PAY1, PAYL, PTL



In the above case
(Cooling) Overall equivalent length=80m×1.0+40m=120m
(Heating) Overall equivalent length=80m×0.4+40m= 72m

The rete of change in
cooling capacity when Hp=0m is thus approximately 0.82
heating capacity when Hp=0m is thus approximately 0.85

6. If heat insulation of piping is insufficient, heat loss will become larger and capacity will decrease.


8.4 Notes for Heating Capacity Characteristics

■ The tables do not take account of the reduction in capacity when frost has accumulated or while the defrosting operation is in progress.
The capacity values which take these factors into account, in other words the integrated heating capacity values, can be calculated as follows:

Formula
Integrated heating capacity = A
Value given in table of capacity characteristics = B
Integrating correction factor for frost accumulation = C
A=B×C

■ Correction factor for finding integrated heating capacity

Inlet Port Temperature of Heat Exchanger (°C / RH 85%)	-7	-5	-3	0	3	5	7
Integrating Correction Factor for Frost Accumulation	0.95	0.93	0.88	0.84	0.85	0.90	1.00




Note:
It will be seen from the figure above that the integrated heating capacity expresses the integrated heating capacity for a single cycle (from defrost operation to defrost operation) in terms of time.

■ Please take note that when there is an accumulation of snow against the outside surface of the outdoor unit heat exchanger there will always be a temporary reduction in capacity although this will, of course, vary in degree in accordance with a number of other factors such as the outdoor temperature (°CDB), relative humidity (RH) and the amount of frosting which occurs.

14

9. Operation Limits



Note:
These figures assume the following operating conditions:
Indoor and outdoor units:
Equivalent pipe length: 7.5m
Level difference: 0m

10. Sound Levels

10.1 50Hz

Overall

dBA

Power Supply Model	Y1: 50Hz/380-415V
RXYQ5PAY1	54
RXYQ8PAY1	57
RXYQ10PAY1	58
RXYQ12PAY1	60
RXYQ14PAY1	60
RXYQ16PAY1	60
RXYQ18PAY1	63
RXYQ20PAY1	62
RXYQ22PAY1	62

dBA

Power Supply Model	Y1: 50Hz/380-415V
RXYQ24PAY1	62
RXYQ26PAY1	64
RXYQ28PAY1	64
RXYQ30PAY1	65
RXYQ32PAY1	63
RXYQ34PAY1	65
RXYQ36PAY1	66
RXYQ38PAY1	65
RXYQ40PAY1	64

dBA


Power Supply Model	Y1: 50Hz/380-415V
RXYQ42PAY1	65
RXYQ44PAY1	67
RXYQ46PAY1	67
RXYQ48PAY1	67
RXYQ50PAY1	67
RXYQ52PAY1	67
RXYQ54PAY1	68

(Note)

Sound level:

Anechoic chamber conversion value, measured at a point 1 m in front of the unit at a height of 1.5m.


During actual operation, these values are normally somewhat higher as a result of ambient conditions.



Octave Band Level


○ - - - - ○ **50Hz**

RXYQ5PAY1




4D052394B

RXYQ8PAY1




4D052395E

RXYQ10PAY1




4D052396E

RXYQ12, 14, 16PAY1



4D052397F

RXYQ18PAY1



4D052398C

14

10.2 60Hz

Overall

dBA

Power Supply / Model	YL: 60Hz/380V TL: 60Hz/220V
RXYQ5PAYL, PTL	54
RXYQ8PAYL, PTL	57
RXYQ10PAYL, PTL	58
RXYQ12PAYL, PTL	60
RXYQ14PAYL, PTL	60
RXYQ16PAYL, PTL	60
RXYQ18PAYL, PTL	63
RXYQ20PAYL, PTL	62
RXYQ22PAYL, PTL	62

dBA

Power Supply / Model	YL: 60Hz/380V TL: 60Hz/220V
RXYQ24PAYL, PTL	62
RXYQ26PAYL, PTL	64
RXYQ28PAYL, PTL	64
RXYQ30PAYL, PTL	65
RXYQ32PAYL, PTL	63
RXYQ34PAYL, PTL	65
RXYQ36PAYL, PTL	66
RXYQ38PAYL, PTL	65
RXYQ40PAYL, PTL	64

dBA


Power Supply / Model	YL: 60Hz/380V TL: 60Hz/220V
RXYQ42PAYL, PTL	65
RXYQ44PAYL, PTL	67
RXYQ46PAYL, PTL	67
RXYQ48PAYL, PTL	67
RXYQ50PAYL, PTL	67
RXYQ52PAYL, PTL	67
RXYQ54PAYL, PTL	68

(Note)

Sound level:

Anechoic chamber conversion value, measured at a point 1 m in front of the unit at a height of 1.5m.


During actual operation, these values are normally somewhat higher as a result of ambient conditions.



Octave Band Level


○ - - - - ○ **60Hz**

RXYQ5PAYL, PTL




4D055870B

RXYQ8PAYL, PTL




4D055871B

RXYQ10PAYL, PTL




4D055872B

RXYQ12, 14, 16PAYL, PTL



4D055873B

RXYQ18PAYL, PTL





4D055874B


11. Accessories

11.1 Standard Accessories


Q5~Q18 type				
Name	Clamp (1)	Clamp (2)	Clamp (3)	Gas side accessory pipe (1)
Quantity	9 pcs.	2 pcs.	1 pc.	1 pc.
Shape	 Small		 Large	

Q5~Q18 type				
Name	Gas side accessory pipe (2)	Liquid side accessory pipe (1)	Liquid side accessory pipe (2)	Others
Quantity	1 pc.	1 pc.	1 pc.	• Operation manual • Installation manual • Declaration of conformity (PED) (RXYQ~PAY1 only) • "REQUEST FOR THE INDICATION" label (Installation records)
Shape	 5-10 HP type 12-18 HP type		 5-10, 14,16 HP type 12,18 HP type	

[RXYQ5 · 8 · 10 type]



[RXYQ12 · 14 · 16 · 18 type]



3P226891-2D

14

11.2 Optional Accessories

RXYQ5 ~ 18PAY1, PAYL, PTL

Optional accessories		RXYQ5PAY1, PAYL, PTL	RXYQ5PAY1E, PAYLE, PTLE	RXYQ8PAY1, PAYL, PTL RXYQ10PAY1, PAYL, PTL	RXYQ8PAY1E, PAYLE, PTLE RXYQ10PAY1E, PAYLE, PTLE	RXYQ12PAY1, PAYL, PTL RXYQ14PAY1, PAYL, PTL RXYQ16PAY1, PAYL, PTL RXYQ18PAY1, PAYL, PTL	RXYQ12PAY1E, PAYLE, PTLE RXYQ14PAY1E, PAYLE, PTLE RXYQ16PAY1E, PAYLE, PTLE RXYQ18PAY1E, PAYLE, PTLE
Cool/Heat Selector		KRC19-26A					
Cool/Heat Selector	Fixing box	KJB111A					
Distributive Piping	Refnet header	KHRP26M22H (Max. 4 branch)		KHRP26M22H, (Max. 4 branch) KHRP26M33H (Max. 8 branch)		KHRP26M22H, KHRP26M33H, (Max. 4 branch) (Max. 8 branch) KHRP26M72H (Max. 8 branch)	
Refnet joint		KHRP26A22T		KHRP26A22T, KHRP26A33T		KHRP26A22T, KHRP26A33T, KHRP26A72T	
Outdoor unit multi connection piping kit		—					
Central drain pan kit		KWC26C160	★KWC26C160E	KWC26C280	★KWC26C280E	KWC26C450	★KWC26C450E
Digital Pressure Gauge Kit		BHGP26A1(E)					

C : 3D053052C

RXYQ20 ~ 36PAY1, PAYL, PTL

Optional accessories		RXYQ20PAY1, PAYL, PTL RXYQ22PAY1, PAYL, PTL	RXYQ20PAY1E, PAYLE, PTLE RXYQ22PAY1E, PAYLE, PTLE	RXYQ24PAY1, PAYL, PTL RXYQ26PAY1, PAYL, PTL RXYQ28PAY1, PAYL, PTL	RXYQ24PAY1E, PAYLE, PTLE RXYQ26PAY1E, PAYLE, PTLE RXYQ28PAY1E, PAYLE, PTLE	RXYQ30PAY1, PAYL, PTL RXYQ32PAY1, PAYL, PTL RXYQ34PAY1, PAYL, PTL RXYQ36PAY1, PAYL, PTL	RXYQ30PAY1E, PAYLE, PTLE RXYQ32PAY1E, PAYLE, PTLE RXYQ34PAY1E, PAYLE, PTLE RXYQ36PAY1E, PAYLE, PTLE
Cool/Heat Selector		KRC19-26A					
Cool/Heat Selector	Fixing box	KJB111A					
Distributive Piping	Refnet header	KHRP26M22H (Max. 4 branch), KHRP26M33H (Max. 8 branch), KHRP26M72H (Max. 8 branch)		KHRP26M22H, KHRP26M33H, KHRP26M72H, KHRP26M73H (Max. 4 branch) (Max. 8 branch) (Max. 8 branch) (Max. 8 branch)			
	Refnet joint	KHRP26A22T, KHRP26A33T, KHRP26A72T		KHRP26A22T, KHRP26A33T, KHRP26A72T, KHRP26A73T			
Outdoor unit multi connection piping kit		BHFP22P100					
Pipe size reducer		—		KHRP26M73TP, KHRP26M73HP			
Central drain pan kit		KWC26C280 KWC26C450	★KWC26C280E ★KWC26C450E	KWC26C280 KWC26C450	★KWC26C280E ★KWC26C450E	KWC26C450×2	★KWC26C450E×2
Digital Pressure Gauge Kit		BHGP26A1(E)					

C : 3D053052C

RXYQ38 ~ 54PAY1, PAYL, PTL

Optional accessories		RXYQ38PAY1, PAYL, PTL RXYQ40PAY1, PAYL, PTL RXYQ42PAY1, PAYL, PTL RXYQ44PAY1, PAYL, PTL RXYQ46PAY1, PAYL, PTL	RXYQ38PAY1E, PAYLE, PTLE RXYQ40PAY1E, PAYLE, PTLE RXYQ42PAY1E, PAYLE, PTLE RXYQ44PAY1E, PAYLE, PTLE RXYQ46PAY1E, PAYLE, PTLE	RXYQ48PAY1, PAYL, PTL RXYQ50PAY1, PAYL, PTL RXYQ52PAY1, PAYL, PTL RXYQ54PAY1, PAYL, PTL	RXYQ48PAY1E, PAYLE, PTLE RXYQ50PAY1E, PAYLE, PTLE RXYQ52PAY1E, PAYLE, PTLE RXYQ54PAY1E, PAYLE, PTLE
Cool/Heat Selector		KRC19-26A			
Cool/Heat Selector	Fixing box	KJB111A			
Distributive Piping	Refnet header	KHRP26M22H, KHRP26M33H, KHRP26M72H, KHRP26M73H (Max. 4 branch) (Max. 8 branch) (Max. 8 branch) (Max. 8 branch)			
	Refnet joint	KHRP26A22T, KHRP26A33T, KHRP26A72T, KHRP26A73T			
Outdoor unit multi connection piping kit		BHFP22P151			
Pipe size reducer		KHRP26M73TP, KHRP26M73HP			
Central drain pan kit		KWC26C280 KWC26C450×2	★KWC26C280E ★KWC26C450E×2	KWC26C450×3	★KWC26C450E×3
Digital Pressure Gauge Kit		BHGP26A1(E)			

C : 3D053052C

Note:
★: Made-to-order products


11.3 Digital Pressure Gauge Kit BHGP26A1(E)

Dimensions

	Model Name
Standard Type	BHGP26A1
Anti-Corrosion Type	BHGP26A1E

Note) 1. Installation Box
[Materials] : SGCC-Z22 (Standard)
SGCC-F08 (Anti-Corrosion • Heavy Anti-Corrosion)
light Camel (Anti-Corrosion)
gray (Heavy Anti-Corrosion)
2. Plastic Cover
[Materials] : Methacrylate Resin
[Finish of Surface] : ▨ flat finish
3. Standard Accessory : Set of Fixing Screw
Clamp Material
Gauge Window Name Plate
Plastic bush
Fixing manual
4. This kit is assembled on site

C : 3D055954



14

DAIKIN Air conditioner Sold separately

Be sure to read and follow all the instructions in the Installation Manual when installing the product. 2P190979-1

Installation Manual of Digital Pressure Gauge Kit BHGP26A1 (E)

Component Parts

■ This Kit contains the following parts.

Parts name	Digital Pressure Gauge Assembly	Resin bush	Clamps		M5×12 screws	M4×12 screws	Gauge window label
			Small	Large			
Parts							
Number	1	1	6	1	2	1	1

Tools required for installation

Phillips screwdriver	Nippers

Cautions


- The Kit includes accessories required for installation. Do not dispose of these accessories until the product is properly installed.
- Before performing installation work, check with a catalog or technical data sheet that the outdoor unit is compatible with the Kit.

Installation procedure

Work procedure

⚠ Warning **⚠ Electric Shock Cautions** Be sure to work with the outdoor unit turned power OFF. An electric shock may be received if your body comes in contact with electric parts with the outdoor unit turned power ON.

1. Turn the outdoor unit power OFF.
2. Remove the front panel. (If the model has two front panels (i.e., one each on the left-hand side and right-hand side), remove the panel on the right-hand side only.)
3. Remove the lid of the electrical box.
4. Refer to the (Installation drawing) and mount the Digital Pressure Gauge Assembly to the panel on the right-hand side. [Parts used: Digital Pressure Gauge Assembly: 1; M5×12 screw: 2]
5. Secure the ground wire to the electrical box with a screw. Refer to section B (detail view) in the (Wiring drawing) for the screwing position. [Parts used: M4×12 screw: 1]
6. Connect the power supply line and communications line of the Digital Pressure Gauge Assembly to the control PCB (A1P) in the electrical box.
   · Power supply line: Connector (white) • X77A
   · Communications line: Connector (blue) • X27A
   At that time, wire the communications line behind the Digital Pressure Gauge Assembly. (Refer to section A (detail view) in the (Wiring drawing).)
7. After connecting the power supply line, communications line, and ground wire, secure the wiring path according to the (Wiring drawing). [Parts used: Clamps: small 6, large 1]
8. Mount the lid of the electrical box.
9. Punch out the knock hole with a diameter of 70 mm on the front panel. (Refer to the mounting dimensions on the upper right-hand side.)
10. Attach the resin bush to the knock hole on the front panel. [Parts used: Resin bush: 1]
11. Mount the front panel.
12. Paste the gauge window label to the front panel. Refer to the (Label pasting drawing) for the pasting position. [Parts used: Gauge window label]





Knock hole on the front panel

Operation Check


⚠ Warning **⚠ Electric Shock Cautions** Close the lid of the electrical box and front panel before turning the product power ON. An electric shock may be received if your body comes in contact with electric parts.

On completion of installation, turn the outdoor unit and indoor unit power ON and make sure that pressures are displayed normally. When figures appear in the discharge pressure display and suction pressure display, the product is working normally. Refer to [Troubleshooting] on the right-hand side and take necessary remedies if no figures are displayed. If the trouble does not fall under any of the items described, contact your Daikin representative.


[Troubleshooting]

	Error display	Cause	Remedy
1	The LED indicator is not lit. 	Power supply is not provided to the outdoor unit.	Provide power supply to the outdoor unit.
		The connector of the power supply line is unplugged.	Insert the connector of the power supply line.
		The power supply line is disconnected or damaged.	Replace the power supply line.
2	All LEDs blink. 	The connector of the communications line is unplugged.	Plug in the connector of the communications line.
		The communications line is disconnected or damaged.	Replace the communications line.
		The outdoor unit is not compatible with the Kit.	Check with a catalog or technical data sheet if the outdoor unit is compatible with the Kit. If the outdoor unit is not compatible, this Kit cannot be used.
3	"□." blinks 	The outdoor unit has a defect.	Refer to the Service Guide and remedy the problem.
		There is a high-voltage line generating noise around the communications line.	Noise may be imposed on the communications line. Separate the high-voltage line.


Wiring drawing



Installation drawing



Label pasting drawing



C : 2P190979